

IPRenewal NPEmails

From: Wentzel, Michael
Sent: Wednesday, September 30, 2015 9:24 AM
To: Louie, Richard
Subject: RE: 2015 Service Water Leaks

Thanks, Rich. I am on travel this week. It would be easiest for me to give you a call on Monday. Will that work?

From: Louie, Richard [mailto:rlouie@entergy.com]
Sent: Tuesday, September 29, 2015 9:45 AM
To: Wentzel, Michael
Subject: [External_Sender] 2015 Service Water Leaks

Mike,

In our letter dated 8/18/2015, we provided information regarding the number of leaks on the SW system for the past 10-years. For year 2015, the number we provided was current as of 6/30/2015.

Since that time, there has been an increase in the number of reported through-wall leakage flaws in ASME ISI Class 3 SW piping. The new number is 6 as of 9/17/2015.

This condition is being tracked in our condition reporting system under CR-IP2-2015-04239.

Please call me at your convenience to discuss this.

Thanks,

Richard Louie
rlouie@entergy.com

Regulatory Assurance
Indian Point Energy Center
(914) 254-6618

Hearing Identifier: IndianPointUnits2and3NonPublic_EX
Email Number: 5312

Mail Envelope Properties (48cbb82065c646e4ad969ac7b1a65403)

Subject: RE: 2015 Service Water Leaks
Sent Date: 9/30/2015 9:23:32 AM
Received Date: 9/30/2015 9:23:32 AM
From: Wentzel, Michael

Created By: Michael.Wentzel@nrc.gov

Recipients:
"Louie, Richard" <rlouie@entergy.com>
Tracking Status: None

Post Office: HQPWMSMRS03.nrc.gov

Files	Size	Date & Time
MESSAGE	1020	9/30/2015 9:23:32 AM

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received: