

Enclosure 6

AREVA Report ANP-3435NP

Non-Proprietary


**AREVA Responses to RAI-8 and RAI-32 from SRXB and SNPB
on MNGP EFW LAR**

Revision 0

August 2015

Note: As discussed with NRC Staff (on September 28, 2015), the results of AREVA Reports ANP-3435P and ANP-3435NP (collectively referred to as ANP 3435P/NP) may be affected by a developing condition report associated with the AREVA core depletion code (MICROBURN-B2) that generated certain inputs for ANP-3435P/NP. Specifically, the decay ratios and peak cladding temperatures for the Two Recirculation Pump Trip cases reported in Section 2.2 will be increased. Figures 32-1 through 32-3 may have to be revised. AREVA has confirmed that this condition has no bearing on the methodology described in ANP-3435P/NP, but it may adversely affect the results. Therefore, to be responsive to the NRC RAIs, Enclosures 5 and 6 are provided to illustrate the methodology and the magnitude of margin to acceptance criteria, with the understanding that a revision to ANP-3435P/NP will be issued when the condition report is resolved and revised analyses are completed.

18 pages follow



ANP-3435NP
Revision 0

AREVA Responses to RAI-8 and RAI-32 from SRXB and SNPB on MNGP EFW LAR

August 2015

Controlled Document

AREVA Inc.

ANP-3435NP
Revision 0

Copyright © 2015

AREVA Inc.
All Rights Reserved

Controlled Document

AREVA Responses to RAI-8 and
RAI-32 from SRXB and SNPB on
MNGP EFW LAR

ANP-3435NP
Revision 0
Page i

Nature of Changes

Item	Page	Description and Justification
1.	All	This is the initial issue

Controlled Document

Contents

1.0	Introduction	1-1
2.0	RAIs and Responses	2-1
2.1	RAI-8: Mitigated ATWSI Calculations	2-1
2.2	RAI-32: 2RPT ATWS.....	2-10

Tables

[]

Figures

Figure 8-1	Core Inlet Subcooling Versus Time For Various Operator Intervention Times	2-3
Figure 8-2	Hot Bundle Inlet Flow Versus Time For Various Operator Intervention Times.....	2-3
Figure 8-3	Hot Bundle Power Versus Time For Various Operator Intervention Times.....	2-4
Figure 8-4	Clad Temperature Versus Time For Various Operator Intervention Times.....	2-4
Figure 8-5	Peak Clad Temperature Versus Operator Intervention Time.....	2-5
Figure 8-6	Gap Conductance Effect on Peak Clad Temperature Versus Operator Intervention Time	2-7
Figure 8-7	Orifice Loss Coefficient Effect on Peak Clad Temperature Versus Operator Intervention Time	2-7
Figure 8-8	[] Effect on Peak Clad Temperature Versus Operator Intervention Time.....	2-8
Figure 32-1	Bundle Power Versus Time For []	2-11
Figure 32-2	Bundle Inlet Flow Versus Time For []	2-12
Figure 32-3	Clad Temperature Versus Time For [].....	2-12

Controlled Document

Nomenclature

Acronym	Definition
2RPT	2 Recirculation Pump Trip
ATWS ATWSi	Anticipated Transient Without Scram ATWS with instability
BOC BWR	Beginning-of-Cycle Boiling Water Reactor
CPR	Critical Power Ratio
DBA	Design Basis Accident
EFW EOC EOIII EPU	Extended Flow Window End-of-Cycle Enhanced Option III (Stability) Extended Power Uprate
MELLLA MELLLA+ MNGP	Maximum Extended Load Line Limit Analysis Maximum Extended Load Line Limit Analysis Plus Monticello Nuclear Generating Plant
TTWBP	Turbine Trip with Bypass

1.0 Introduction

In Reference 1, Northern States Power Company - a Minnesota corporation, doing business as Xcel Energy, submitted a license amendment request (LAR) for the Monticello Nuclear Generating Plant (MNGP). The application was supplemented by Reference 2. The amendment would revise the Technical Specifications and approve certain AREVA analytical methods to support plant operation in the expanded power-flow domain described as the Extended Flow Window (EFW).

The U.S. Nuclear Regulatory Commission (NRC) staff in the Reactor Systems Branch (SRXB) and Nuclear Performance and Code Review Branch (SNPB) has reviewed the application and concluded that additional information is necessary to complete its review. Draft Requests for Additional Information (RAI) were provided as an attachment to Reference 3. AREVA responses to all of these RAI except RAI-8 and RAI-32 were documented in Reference 4. The RAI and the AREVA responses for RAI-8 and RAI-32 are attached.

The revised analysis of Anticipated Transient Without Scram – Instability (ATWSi) described herein should be recognized as the licensee’s analysis of record supporting the proposed amendment to allow operation in the EFW domain. [

]

These responses are provided so Xcel Energy can provide a complete set of responses to the NRC by combining the AREVA responses with the responses being prepared by Xcel Energy.

References

1. License Amendment Request for AREVA Extended Flow Window, October 3, 2014, MNGP L-MT-14-044, ML14283A119.
2. License Amendment Request for AREVA Extended Flow Window Supplement to Response to NRC Staff Questions (TAC No. MF5002), January 9, 2015, MNGP L-MT-14-103, ML15022A165 and ML15022A167.
3. Monticello Nuclear Generating Plant – Request for Additional Information (SRXB/SNPB) re: AREVA Extended Flow Window Licence Amendment Request (TAC No MF5002) - email from Terry Beltz (NRC) to Glenn Adams (Xcel Energy), August 5th, 2015.
4. ANP-3434P Revision 1, *AREVA Responses to RAI from SRXB and SNPB on MNGP EFW LAR*, AREVA, August 2015.

2.0 RAIs and Responses

2.1 RAI-8: Mitigated ATWSI Calculations

ATWSI calculations in the Monticello LAR are for unmitigated (i.e., no operator actions) assumptions.

- a) Provide realistic Anticipated Transient Without Scram with Instability (ATWSI) calculations under the expected conditions crediting operator actions. Provide sensitivity results for later operator action time.
- b) Provide a discussion of uncertainty treatment (e.g., hGap, inlet friction).
- c) Describe the methodology used by AISHA to excite the oscillation when the decay ratio (DR) is close to 1.0.

AREVA Response

- a) Provide realistic Anticipated Transient Without Scram with Instability (ATWSI) calculations under the expected conditions crediting operator actions. Provide sensitivity results for later operator action time.

The case that produced the maximum clad temperature excursion without operator action was repeated while crediting the operator action of lowering the water level. As is demonstrated below, the operator action [

] and the transient is demonstrated to be uneventful. The operator action was delayed by increasing time periods in a series of runs to examine the sensitivity of the action timing. It was found that a delayed action [

]

The sensitivity runs were made with operator action initiated at 90 seconds and at larger values with incremental steps of 10 seconds. [

] The sensitivity to operator action timing is illustrated in the following figures. In some of the figures, only the results of representative runs are shown to avoid crowding of data so the trends are more clearly seen.

Two modifications were made to the original runs in order to properly model the mitigated cases. [

]

Controlled Document

[

]

Figure 8-2 shows the inlet mass flow rate as a function of time for several cases with differing operator action times. [

]

Figure 8-3 shows the limiting bundle power for the cases represented in Figure 8-2.

Figure 8-4 shows the clad temperature excursion for selected cases with differing operator action timing.

[

]

Figure 8-5 depicts the peak clad temperature that is reached in the different simulations with different operator action timing. The figure shows clearly that [

]



Figure 8-1 Core Inlet Subcooling Versus Time For Various Operator Intervention Times



Figure 8-2 Hot Bundle Inlet Flow Versus Time For Various Operator Intervention Times



Figure 8-3 Hot Bundle Power Versus Time For Various Operator Intervention Times



Figure 8-4 Clad Temperature Versus Time For Various Operator Intervention Times

Controlled Document



Figure 8-5 Peak Clad Temperature Versus Operator Intervention Time

Controlled Document

b) Provide a discussion of uncertainty treatment (e.g., hGap, inlet friction).

The mitigated cases as described in item a) above were performed again while varying certain parameters. These parameters have been identified as being of higher importance and also represent a higher level of calculational uncertainty. These parameters include

- The gap conductance was []
- The inlet orifice resistance was []
- []

As shown in Figure 8-6 through Figure 8-8, the effect of these parameter variations on the Peak Clad Temperature (PCT) is []

]

It is important to note that the range of parameter variation imposed on the simulation is larger than the uncertainty for these parameters.

Controlled Document



Figure 8-6 Gap Conductance Effect on Peak Clad Temperature Versus Operator Intervention Time



Figure 8-7 Orifice Loss Coefficient Effect on Peak Clad Temperature Versus Operator Intervention Time



Figure 8-8 [] Effect on Peak Clad Temperature Versus
Operator Intervention Time

Controlled Document

- c) *Describe the methodology used by AISHA to excite the oscillation when the decay ratio (DR) is close to 1.0.*

[

]

References for RAI-8

- 8-1. ANP-3274P Revision 1, "Analytical Methods for Monticello ATWS-I," July 2014.

2.2 **RAI-32: 2RPT ATWS**

The ATWSI analysis of record in the LAR is Turbine Trip with Bypass (TTWBP). When operator actions are credited, the TTWBP does not show significant power oscillations and the limiting ATWSI transient becomes the 2RPT with failure to scram.

Provide the results of 2RPT event with failure to scram. Describe the basis for boundary conditions and operator actions assumed for the analysis.

AREVA Response

The Two Recirculation Pump Trip (2RPT) differs from the Turbine Trip With Bypass (TTWBP) event in that turbines are not isolated and the steam flow to the feedwater heaters is not interrupted. The 2RPT transient results in a much smaller feedwater temperature transient, as the feedwater temperature decreases to a new equilibrium value determined by the final power level. [

[]

Controlled Document

[

]

The results are shown in Figure 32-1 through Figure 32-3. Figure 32-1 shows the limiting bundle power as function of time, and Figure 32-2 shows the corresponding inlet flow rate. Figure 32-3 shows the peak powered rod clad temperature at different axial nodes. The maximum clad temperature of [

]



Figure 32-1 Bundle Power Versus Time For []

Controlled Document



Figure 32-2 Bundle Inlet Flow Versus Time For []



Figure 32-3 Clad Temperature Versus Time For []