



# Exelon Generation®

**Bill Carsky**  
Plant Manager

R.E. Ginna Nuclear Power Plant  
1503 Lake Rd.  
Ontario, NY 14519

315 791 5205 Office  
215 605 9364 Mobile

www.exeloncorp.com  
William.carsky@exeloncorp.com

September 24, 2015

U.S. Nuclear Regulatory Commission  
Washington, DC 20555-0001

ATTENTION: Document Control Desk

SUBJECT: R.E. Ginna Nuclear Power Plant  
Renewed Facility Operating License No. DPR-18  
Docket No. 50-244

### Thirty (30) Day Special Report

In accordance with Section 3.3 and Table 3.3-1, Action 1, of the R.E. Ginna Nuclear Power Plant Offsite Dose Calculation Manual (ODCM), Revision 30, this special report is being submitted due to a radiation monitor being inoperable for greater than 30 days. Section 3.3 of the ODCM requires that the radiation monitor be operable during all modes of operation. However, radiation monitor RM-14A, Plant Vent Accident Range Radiation Monitor, was inoperable for greater than 30 days. This report outlines the action taken, the cause of the inoperability, and period of time the monitor was inoperable.

Radiation monitor RM-14A, was taken out of service on 8/12/15 at 0236 for replacement of upgraded equipment under ECP 13-000030. However, due to challenges to the work schedule presented by unusually high temperatures in the Intermediate Building from unseasonably hot weather, the modification was not completed within 30 days. Installation and testing have been completed and the radiation monitor was returned to operable status on 9/23/15. During the time that RM-14A was Out of Service, compensatory measures were in place.

Return to service of the radiation monitor was delayed based on worker safety issues with heat stress. Corrective Action Program issue report 2555033 was opened to document the radiation monitor being inoperable for greater than 30 days.

There are no regulatory commitments contained in this letter. Should you have any questions regarding this submittal, please contact Thomas Harding at 315-791-5219.

Sincerely,

WC/kc

cc: NRC Regional Administrator, Region I  
NRC Project Manager, Ginna  
NRC Resident Inspector, Ginna

*TE22*  
*NRR*

WPLARC-1003013