

<b>CALCULATION NO.</b> C-CSS-099.20-055	<b>INITIATING DOCUMENT</b> ECP-10-0458	<input type="checkbox"/> <b>VENDOR CALC SUMMARY</b> <b>VENDOR CALCULATION NO.</b>
--	---	--

<input type="checkbox"/> BV1	<input type="checkbox"/> BV2	<input checked="" type="checkbox"/> DB	<input type="checkbox"/> PY
------------------------------	------------------------------	--	-----------------------------

**Title/Subject:**  
 III/ Evaluation for Architectural Flute Shoulder

<b>Category</b>	<input type="checkbox"/> Active	<input type="checkbox"/> Historical	<input checked="" type="checkbox"/> Study
<b>Classification</b>	<input type="checkbox"/> Tier 1 Calculation	<input checked="" type="checkbox"/> Safety-Related/Augmented Quality	<input type="checkbox"/> Nonsafety-Related
<b>Open Assumptions?</b>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	If Yes, Enter Tracking Number	
<b>System Number</b>	N/A		
<b>Functional Location</b>	N/A		
<b>Commitments:</b>	None		
<b>(Perry &amp; Davis-Besse Only)</b>	Calculation Type: N/A	Referenced In Atlas?	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
<b>(Perry Only)</b>	Referenced In USAR Validation Database	<input type="checkbox"/> Yes <input type="checkbox"/> No	

Computer Program(s)				
Program Name	Version / Revision	Category	Status	Description
MathCAD	15.0	C	Active	Analysis and Documentation

Revision Record				
Rev.	Affected Pages	Originator <i>(Print, Sign &amp; Date)</i>	Reviewer/Design Verifier <i>(Print, Sign &amp; Date)</i>	Approver <i>(Print, Sign &amp; Date)</i>
00	All	Yueh-Hua Tsai (Bechtel) <i>Yueh-Hua Tsai 10/31/11</i>	Shen Wang (Bechtel) <i>Shen Wang 10/31/11</i>	Hongchun Liu (Bechtel) <i>Hongchun Liu 10/31/11</i>
Description of Change: Initial Issue				Initiating Document: ECP-10-0458
Describe where the calculation will be evaluated for 10CFR50.59 applicability. <del>See Note 1 on Page 4</del>				NA FOR STUDY CALC <i>10/31/11</i>
Description of Change:				Initiating Document:
Describe where the calculation will be evaluated for 10CFR50.59 applicability.				
Description of Change:				Initiating Document:
Describe where the calculation will be evaluated for 10CFR50.59 applicability.				
Description of Change:				Initiating Document:
Describe where the calculation will be evaluated for 10CFR50.59 applicability.				

CALCULATION NO.  
 C-CSS-099.20-055

 VENDOR CALC SUMMARY  
 VENDOR CALCULATION NO.

## TABLE OF CONTENTS

SUBJECT	PAGE
COVERSHEET:	i
OBJECTIVE OR PURPOSE	iii
SCOPE OF CALCULATION	iii
SUMMARY OF RESULTS/CONCLUSIONS	iii
LIMITATIONS OR RESTRICTION ON CALCULATION APPLICABILITY	iii
IMPACT ON OUTPUT DOCUMENTS	iii
DOCUMENT INDEX	iv
CALCULATION COMPUTATION (BODY OF CALCULATION):	
ANALYSIS METHODOLOGY	3
ASSUMPTIONS	3
ACCEPTANCE CRITERIA	3
COMPUTATION	5
RESULTS	12
CONCLUSIONS	13
ATTACHMENTS:	
ATTACHMENT 1:	Pages
ATTACHMENT 2:	Pages
SUPPORTING DOCUMENTS ( <i>For Records Copy Only</i> )	
DESIGN VERIFICATION RECORD	1 Pages
CALCULATION REVIEW CHECKLIST	3 Pages
10CFR50.59 DOCUMENTATION	0 Pages
DESIGN INTERFACE SUMMARY	0 Pages
DESIGN INTERFACE EVALUATIONS	0 Pages
OTHER : OWNERS ACCEPTANCE REVIEW	2 Pages
EXTERNAL MEDIA? (MICROFICHE, ETC.) (IF YES, PROVIDE LIST IN BODY OF CALCULATION)	<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO
TOTAL NUMBER OF PAGES IN CALCULATION (COVERSHEETS + BODY + ATTACHMENTS)	17 Pages

NOTES:

**CALCULATION NO.**  
**C-CSS-099.20-055** **VENDOR CALC SUMMARY**  
**VENDOR CALCULATION NO.****OBJECTIVE OR PURPOSE:**

The purpose of this calculation is to demonstrate that during a seismic event, with the development of the crack in the architectural flute shoulder, the capacity of rebar(s) can still provide adequate anchorage thus prevent cracked concrete piece from falling, and therefore Seismic II/I condition can be maintained.

**SCOPE OF CALCULATION/REVISION:**

During the seismic event, a crack is assumed to be developed to the point of tendency for the architectural flute. In order to satisfy the Seismic II/I condition, not to allow the concrete to fall off from the Shield Building, under the Safety Shutdown Earthquake (SSE) load condition, the shear-friction / tensile capacity of the rebar(s) would have to provide the capacity to prevent the collapse of the concrete under the worst case scenario so the function and structural integrity of Seismic Category I structure, system, and component in the vicinity will not be affected.

**SUMMARY OF RESULTS/CONCLUSIONS:**

This calculation evaluates the potential crack of the concrete for architectural flute shoulder. In this evaluation, conservative scenarios are considered to include the effect of dead load, vertical seismic load and horizontal seismic load for the load combination (D + E'). It was shown that the shear-friction / tensile capacity of the #8 rebar provides required reinforcement for the concrete so that the collapse of the flute shoulder concrete is prevented and II/I condition of SB will be maintained.

**LIMITATIONS OR RESTRICTIONS ON CALCULATION APPLICABILITY:**

The use of this calculation is limited to Davis-Besse Shield Building for SGRP.

**IMPACT ON OUTPUT DOCUMENTS:**

Not applicable



**TABLE OF CONTENTS**

<u>Description.</u>	<u>Sheet No.</u>
<b>1.0 PURPOSE</b>	<b>3</b>
<b>2.0 METHODOLOGY</b>	<b>3</b>
<b>3.0 ASSUMPTIONS</b>	<b>3</b>
<b>4.0 ACCEPTANCE CRITERIA</b>	<b>3</b>
<b>5.0 DESIGN INPUTS / REFERENCES</b>	<b>4</b>
<b>6.0 CALCULATION</b>	<b>5</b>
<b>6.1 Description of Architectural Flute and Potential Crack</b>	<b>5</b>
<b>6.2 Loading Calculation</b>	<b>6</b>
<b>6.3 Loading Combination under Different Scenarios</b>	<b>10</b>
<b>7.0 CONCLUSION</b>	<b>13</b>

**List of Figures**

<u>Figure No.</u>	<u>Description.</u>	<u>Sheet No.</u>
Figure 6.1	Plan View of Shield Building near Architectural Flute	5
Figure 6.2	Potential Crack Path	6
Figure 6.3	Diameter of Shield Building	7
Figure 6.4	Model for Frequency Estimation	9
Figure 6.5	Horizontal Seismic Normal to the Crack Path	10
Figure 6.6	Horizontal Seismic Parallel to the Crack Path	11

## 1.0 PURPOSE

The purpose of this calculation is to demonstrate that during a seismic event, with the development of the crack in the architectural flute shoulder, the capacity of rebar(s) can still provide adequate anchorage thus prevent cracked concrete piece from falling, and therefore Seismic II/I condition can be maintained.

See the following Seismic II/I definition stated in Ref. 2: "Seismic Category II/I structures, systems and components are defined as those structures, systems and components (or portions thereof) which are not classified as Seismic Category I but whose failure due to a seismic event could affect the function of a Seismic Category I structure, system or component."

## 2.0 METHODOLOGY


During the seismic event, a crack is assumed to be developed to the point of tendency for the architectural flute. In order to satisfy the Seismic II/I condition, not to allow the concrete to fall off from the Shield Building, under the Safety Shutdown Earthquake (SSE) load condition, the shear-friction / tensile capacity of the rebar(s) would have to provide the capacity to prevent the collapse of the concrete under the worst case scenario so the function and structural integrity of Seismic Category I structure, system, and component in the vicinity will not be affected.

## 3.0 ASSUMPTIONS

There are no unverified assumptions used in this calculation. Assumptions and engineering judgment used are identified in the body of the calculation with appropriate justification.

## 4.0 ACCEPTANCE CRITERIA

Due to Seismic Category II/I condition for SB, the calculation is evaluated in accordance with ACI 318-05 (Ref. 5).

	<b>CALCULATION COMPUTATION</b>	Page 4		
NOP-CC-3002-01 Rev. 03		<table border="1" style="width: 100%;"> <tr> <td data-bbox="147 279 1187 348"> CALCULATION NO.:  <b>C-CSS-099.20-055</b> </td> <td data-bbox="1187 279 1466 348"> REVISION:  00 </td> </tr> </table>	CALCULATION NO.: <b>C-CSS-099.20-055</b>	REVISION: 00
CALCULATION NO.: <b>C-CSS-099.20-055</b>	REVISION: 00			

**5.0 DESIGN INPUTS / REFERENCES (Design inputs are annotated with an asterisk \*)**

1. Updated Safety Analysis Report (USAR) for Davis-Besse Nuclear Power Station No. 1, Rev. 28
2. Davis-Besse Nuclear Power Station Unit 1 Design Criteria Manual, Rev. 20
3. NRC Reg. Guide 1.29, Seismic Design Classification, Rev. 3
4. \* Drawings: 7749-C-110, Rev. 6, "Shield Building Roof Plan Wall Section & Details"
5. American Concrete Institute (ACI) 318-05, Building Code Requirements for Structural Concrete and Commentary
6. \* Original Design Calculations: VS01/B01-03, Approval Date 10/4/1976, Rev. 0, "Seismic Analysis of the Containment Structure"
7. \* Original Design Calculations: VS21/B01-01, Approval Date 6/4/1981, Rev. 1, "Shield Building Seismic Analysis"



6.0 CALCULATION

6.1 Description of Architectural Flute and Potential Crack

On the cylindrical wall of the Shield Building, there is architectural flute at every 45° as shown in Figure 6.1. A potential crack (red line shown in Figure 6.2) is considered from the point of tangency to the area near the center of flute as shown in Figure 6.2. One set of "L" shape rebar has two legs crossing the potential crack surface. Since the leg near the point of tendency is too close to the potential crack path, the leg is treated only as stability support. Also, since the spacing of #8 rebar in height is 12", only one rebar per foot is considered for the loading from a piece of flute shoulder. Therefore, shear-friction / tensile capacity provided by the leg is calculated.





Figure 6.1: Plan View of Shield Building near Architectural Flute

**6.2 Loading Calculation**

Conservatively, vertical and horizontal seismic responses (Ref. 6) at the top of the cylindrical wall are applied for the seismic loads. Weight of the concrete outside of the potential crack path is considered as the dead load.



**Figure 6.2: Potential Crack Path**

Angles between shear plane and rebar legs:

$$\alpha := \text{acos} \left[ \frac{(3\text{ft} + 2.5\text{in}) - (2\text{ft} + 10.125\text{in})}{1\text{ft} + 6\text{in}} \right] \cdot \left( \frac{180}{\pi} \right) = 75.93$$

Lines for small triangular area:

$$L1 := \frac{(1\text{ft} + 6\text{in})}{\cos \left[ \frac{(90 - \alpha)}{180} \cdot \pi \right]} = 1.55\text{ft}$$


$$L2 := (1\text{ft} + 6\text{in}) \cdot \tan \left[ \frac{(90 - \alpha)}{180} \cdot \pi \right] = 0.38\text{ft}$$

Small triangular area:

$$A3 := \frac{(1\text{ft} + 6\text{in}) \cdot L2}{2} = 0.28\text{ft}^2$$

Quadrilateral area:

$$A4 := \frac{L1 + (2\text{ft} + 2.5\text{in})}{2} \cdot (2\text{ft} + 10.125\text{in}) = 5.34\text{ft}^2$$



**Figure 6.3: Diameter of Shield Building**

Angle between point of tangency and the centerline of the flute:

$$\theta_1 := \text{atan} \left[ \frac{(17\text{ft} + 11\text{in})}{(72\text{ft})} \right] \cdot \frac{180}{\pi} = 13.97$$

Approximated potential crack length:

$$L := \pi \cdot \frac{\theta_1}{180} \cdot (71\text{ft} + 9\text{in}) - (2\text{ft} + 10.125\text{in}) = 14.66\text{ft}$$

Based on Impulse Response testing, the actual crack length is 10 to 12 feet long.

Entire triangular area based on the angle  $\theta_1$ :

$$A_1 := \frac{72\text{ft} \cdot (17\text{ft} + 11\text{in})}{2} = 645\text{ft}^2$$

Circular area based on the angle  $\theta_1$ :

$$A_2 := \frac{\theta_1}{360} \cdot \pi \cdot (71\text{ft} + 9\text{in})^2 = 627.78\text{ft}^2$$

Total concrete area:

$$A_{\text{conc}} := A_1 - A_2 - A_3 - A_4 = 11.6\text{ft}^2$$

CALCULATION NO.:  
C-CSS-099.20-055

REVISION:  
00

Total volume of the concrete:

$$\text{Vol}_{\text{conc}} := A_{\text{conc}} \cdot 1\text{ft} = 11.6\text{ft}^3$$

Total weight of the concrete:

$$W_{\text{conc}} := \text{Vol}_{\text{conc}} \cdot 0.150 \left( \frac{\text{kip}}{\text{ft}^3} \right) = 1.7402\text{kip}$$

Rebar yield stress:

$$f_y := 60\text{ksi}$$

Rebar area:

$$A_{\text{vf}} := 0.79\text{in}^2$$

Vertical seismic acceleration  
at Elev. 812.77' (g):

$$\text{Acc}_{\text{vert}} := 0.289 \quad [\text{Ref. 6}]$$

Horizontal seismic acceleration  
at Elev. 812.77' (g):

$$\text{Acc}_{\text{horiz}} := 0.605 \quad [\text{Ref. 6}]$$

Vertical seismic force:

$$E_{\text{vert}} := W_{\text{conc}} \cdot \text{Acc}_{\text{vert}} = 0.5\text{kip}$$

Horizontal seismic force:

$$E_{\text{horiz}} := W_{\text{conc}} \cdot \text{Acc}_{\text{horiz}} = 1.05\text{kip}$$

Reduction factor for shear-  
friction:

$$\phi := 0.75$$

Normal weight concrete:

$$\lambda := 1$$

Coefficient of friction:

$$\mu := 0.6 \cdot \lambda \quad [\text{Conservative}]$$

Dead load:

$$D := W_{\text{conc}} = 1.74\text{kip}$$


Modulus of elasticity of  
reinforcement

$$E_s := 29000\text{ksi}$$

Moment of Inertia of rebar:

$$I_{\text{bar}} := \frac{\pi (\text{lin})^4}{64} = 2.37 \times 10^{-6} \text{ft}^4$$

Estimation for seismic amplification factor:



Assumed of crack width:  $h_1 := 0.01\text{in} < h_{\text{crack}} < h_2 := \frac{1}{4}\text{in}$

Lateral stiffness considered from a single rebar:

$$k_1 := \frac{3 \cdot E_s \cdot I_{\text{bar}}}{h_2^3} = 2.73 \times 10^5 \cdot \frac{\text{kip}}{\text{in}} < k < k_2 := \frac{12 \cdot E_s \cdot I_{\text{bar}}}{h_1^3} = 1.71 \times 10^{10} \cdot \frac{\text{kip}}{\text{in}}$$

**Figure 6.4: Model for Frequency Estimation**

Frequency:

$$f_1 := \frac{1}{2 \cdot \pi} \cdot \sqrt{\frac{k_1}{\frac{W_{\text{conc}}}{g}}} = 1239\text{-Hz} < f < f_2 := \frac{1}{2 \cdot \pi} \cdot \sqrt{\frac{k_2}{\frac{W_{\text{conc}}}{g}}} = 309840\text{Hz}$$

Axial stiffness considered from a single rebar:

$$k_3 := \frac{E_s \cdot A_{\text{vf}}}{h_2} = 9.16 \times 10^4 \frac{\text{kip}}{\text{in}} < k < k_4 := \frac{E_s \cdot A_{\text{vf}}}{h_1} = 2.29 \times 10^6 \frac{\text{kip}}{\text{in}}$$

Frequency:

$$f_3 := \frac{1}{2 \cdot \pi} \cdot \sqrt{\frac{k_3}{\frac{W_{\text{conc}}}{g}}} = 718\text{-Hz} < f < f_4 := \frac{1}{2 \cdot \pi} \cdot \sqrt{\frac{k_4}{\frac{W_{\text{conc}}}{g}}} = 3588\text{-Hz}$$

Since the frequency is beyond the cut-off frequency (100Hz from Ref. 7), the amplification due to the SSE load is not required.


Vertical force:  $F_{\text{vert}} := D + E_{\text{vert}} = 2.24\text{-kip}$

Horizontal force:  $F_{\text{horiz}} := E_{\text{horiz}} = 1.05\text{-kip}$

### 6.3 Loading Combination under Different Scenarios

Horizontal seismic force perpendicular or parallel to the potential crack path is evaluated.

- Case 1: Horizontal seismic load normal to the potential crack path of the leg (seismic force out of SB)



**Figure 6.5: Horizontal Seismic Normal to the Crack Path**

Net tension across  
shear plane:

$$N_{u1} := F_{\text{horiz}} = 1.05 \text{ kip}$$

Direct shear transfer  
force along shear plane:

$$V_{\text{vert\_u}} := F_{\text{vert}} = 2.24 \text{ kip}$$

$$V_{\text{horiz\_u}} := 0$$

$$V_{u1} := \sqrt{V_{\text{horiz\_u}}^2 + V_{\text{vert\_u}}^2} = 2.24 \text{ kip}$$

Reinforcement to resist  
net tension:

$$A_{n1} := \frac{N_{u1}}{\phi \cdot f_y \cdot \sin(\alpha)} = 0.046 \text{ in}^2$$


Shear-friction  
reinforcement to resist  
direct shear transfer.

$$A_{vf1} := \frac{V_{u1}}{\phi \cdot f_y \cdot (\mu \cdot \sin(\alpha) + \cos(\alpha))} = 0.043 \text{ in}^2$$

Total area of required  
reinforcement:

$$A_{s1} := A_{vf1} + A_{n1} = 0.089 \text{ in}^2$$

- Case 2: Horizontal seismic load parallel to the potential crack path of the leg



**Figure 6.6: Horizontal Seismic Parallel to the Crack Path**

Net tension across shear plane:

$$N_{u2} := 0$$

Direct shear transfer force along shear plane:

$$V_{\text{vert\_u}} := F_{\text{vert}} = 2.24 \cdot \text{kip}$$

$$V_{\text{horiz\_u}} := F_{\text{horiz}} = 1.05 \cdot \text{kip}$$

$$V_{u2} := \sqrt{V_{\text{horiz\_u}}^2 + V_{\text{vert\_u}}^2} = 2.48 \cdot \text{kip}$$

Reinforcement to resist net tension:

$$A_{n2} := \frac{N_{u2}}{\phi \cdot f_y \cdot \sin(\alpha)} = 0 \cdot \text{in}^2$$

Shear-friction reinforcement to resist direct shear transfer.

$$A_{\text{vf}2} := \frac{V_{u2}}{\phi \cdot f_y \cdot (\mu \cdot \sin(\alpha) + \cos(\alpha))} = 0.047 \cdot \text{in}^2$$

Total area of required reinforcement:

$$A_{s2} := A_{\text{vf}2} + A_{n2} = 0.047 \cdot \text{in}^2$$

CALCULATION NO.:  
C-CSS-099.20-055

REVISION:  
00

Concrete compressive Strength:  $f_c := 4000\text{psi}$

Rebar diameter:  $d_b := 1\text{in}$

For normal weight concrete:  $\psi_e := 1$  [Ref. 5, Sect. 12.5]

Required development length:  $\lambda_e := 1$

$$L_{dh} := \max \left( 8 \cdot d_b, 6\text{in}, \frac{0.02 \cdot \psi_e \cdot \lambda_e \cdot \frac{f_y}{1\text{psi}} \cdot d_b}{\sqrt{\frac{f_c}{1\text{psi}}}} \right) = 1.58\text{ft}$$

Judging from the drawing (Ref. 4), the required development length should be satisfactory. However, a reduction factor of 50% is used for provided reinforcement to cover possible inadequate development length.

Total area of required reinforcement:  $A_{s\_req} := \max(A_{s1}, A_{s2}) = 0.089\text{in}^2$

Provided reinforcement:  $A_{s\_prov} := (50\%) \cdot 0.79\text{in}^2 = 0.4\text{in}^2$

Factor of safety:  $\text{FOS} := \frac{A_{s\_prov}}{A_{s\_req}} = 4.46$

The provided reinforcement is almost 4.5 times of the required reinforcement under conservative assumptions and scenarios.



CALCULATION NO.:  
**C-CSS-099.20-055**REVISION:  
00**7.0 CONCLUSION**

This calculation evaluates the potential crack of the concrete for architectural flute shoulder. In this evaluation, conservative scenarios are considered to include the effect of dead load, vertical seismic load and horizontal seismic load for the load combination (D + E'). It was shown that the shear-friction / tensile capacity of the rebar provides required reinforcement for the concrete so that the collapse of the flute shoulder concrete is prevented and II/I condition of SB will be maintained.

# DESIGN VERIFICATION RECORD

NOP-CC-2001-01 Rev. 00

**SECTION I: TO BE COMPLETED BY DESIGN ORIGINATOR**

DOCUMENT(S)/ACTIVITY TO BE VERIFIED:

II / I Evaluation for Architectural Flute Shoulder, C-CSS-099.20-055 Rev 000

SAFETY RELATED                       AUGMENTED QUALITY                       NONSAFETY RELATED

SUPPORTING/REFERENCE DOCUMENTS

Refer to the body of the calculation.

DESIGN ORIGINATOR: *(Print and Sign Name)*

Yueh-Hua Tsai *Yueh-Hua Tsai*

DATE

10/31/2011

**SECTION II: TO BE COMPLETED BY VERIFIER**

VERIFICATION METHOD *(Check one)*

DESIGN REVIEW *(Complete Design Review Checklist or Calculation Review Checklist)*                       ALTERNATE CALCULATION                       QUALIFICATION TESTING

JUSTIFICATION FOR SUPERVISOR PERFORMING VERIFICATION:

APPROVAL: *(Print and Sign Name)*

DATE

EXTENT OF VERIFICATION:

Verified using Calculation Review Checklist

COMMENTS, ERRORS OR DEFICIENCIES IDENTIFIED?                       YES                       NO

RESOLUTION: *(For Alternate Calculation or Qualification Testing only)*

RESOLVED BY: *(Print and Sign Name)*

DATE

VERIFIER: *(Print and Sign Name)*

Shen Wang *Shen Wang*

DATE

10/31/11

APPROVED BY: *(Print and Sign Name)*

Hongchun Liu *Hongchun Liu*

DATE

10/31/11

# CALCULATION REVIEW CHECKLIST

NOP-CC-2001-04 Rev. 05

**QUESTION**

	QUESTION	NA	Yes	No	COMMENTS	RESOLUTION
<b>GENERAL</b>						
1.	Does the stated objective/purpose clearly describe why the calculation is being performed?		<input checked="" type="checkbox"/>			
2.	Are design input / output documents and references listed and clearly identified in the document index, including edition and addenda, where applicable?		<input checked="" type="checkbox"/>			
3.	Were verbal inputs from third parties properly documented?	<input checked="" type="checkbox"/>				
4.	Are design input parameters, such as physical and geometric characteristic and regulatory or code and standard requirements, accurately taken from the design input documents and correctly incorporated, including tolerances and units?		<input checked="" type="checkbox"/>			
5.	Are the design inputs relevant, current, consistent with design/licensing bases and directly applicable to the purpose of the calculation, including appropriate tolerances and ranges/modes of operation?		<input checked="" type="checkbox"/>			
6.	Are all design inputs retrievable? If not, have they been added as attachments?		<input checked="" type="checkbox"/>			
7.	Are preliminary or conceptual inputs clearly identified for later confirmation as open assumptions?	<input checked="" type="checkbox"/>				
8.	Where applicable, were construction and operating considerations included as input information?		<input checked="" type="checkbox"/>			
9.	Were design input / output documents properly updated to reference this calculation?		<input checked="" type="checkbox"/>			
	<b>ASSUMPTIONS</b>					
10.	Have the assumptions necessary to perform the analysis been clearly identified and adequately described?		<input checked="" type="checkbox"/>			
11.	Are all assumptions for the calculation reasonable and consistent with design/licensing bases?		<input checked="" type="checkbox"/>			
12.	Have all open assumptions needing later confirmation been clearly identified on the Calculation cover sheet, including when the open assumption needs to be closed?	<input checked="" type="checkbox"/>				
13.	Has an SAP Activity Initiation Form been created for open assumptions?	<input checked="" type="checkbox"/>				
14.	Have engineering judgments been clearly identified?	<input checked="" type="checkbox"/>				
15.	Are engineering judgments reasonable and adequately documented?	<input checked="" type="checkbox"/>				
16.	Is suitable justification provided for all assumptions/engineering judgements (except those based upon recognized engineering practice, physical constants or elementary scientific principles)?		<input checked="" type="checkbox"/>			
	<b>METHOD OF ANALYSIS</b>					
17.	Is the method used appropriate considering the purpose and type of calculation?		<input checked="" type="checkbox"/>			
18.	Is the method in accordance with applicable codes, standards, and design/licensing bases?		<input checked="" type="checkbox"/>			
	<b>IDENTIFICATION OF COMPUTER CODES (Ref: NOP-SS-1001)</b>					
19.	Have the versions of the computer codes employed in the design analysis been certified for this application?		<input checked="" type="checkbox"/>			
20.	Are codes properly identified along with source (vendor, organization, etc.)?		<input checked="" type="checkbox"/>			



# CALCULATION REVIEW CHECKLIST

NOP-CC-2001-04 Rev. 05

Page 2 of 3  
 CALCULATION NO. C-CSS-099.20-055  
 REV. 0  
 ADDENDUM NO. N/A  
 UNIT: Davis-Besse 01

QUESTION	NA	Yes	No	COMMENTS	RESOLUTION
21. Is the code applicable for the analysis being performed?		<input checked="" type="checkbox"/>			
22. Is the computer program(s) being used listed on the FENOC Usable Software List for the site?		<input checked="" type="checkbox"/>			
23. Does the computer model, that has been created, adequately reflect actual (or to be modified) plant conditions (e.g., dimensional accuracy, type of model/code options used, time steps, etc.)?		<input checked="" type="checkbox"/>			
24. Did the computer output generate any ERROR or WARNING Messages that could invalidate the results?	<input checked="" type="checkbox"/>				
25. Is the computer output reasonable when compared to inputs and what was expected?		<input checked="" type="checkbox"/>			
<b>COMPUTATIONS</b>					
26. Are the equations used consistent with recognized engineering practice and design/licensing bases?		<input checked="" type="checkbox"/>			
27. Is there a reasonable justification provided for the uses of any equations not in common use?	<input checked="" type="checkbox"/>				
28. Were the mathematical operations performed properly and the results accurate?		<input checked="" type="checkbox"/>			
29. Have adjustment factors, uncertainties, empirical correlations, etc., used in the analysis been correctly applied?		<input checked="" type="checkbox"/>			
30. Is the result presented with proper units and tolerance?		<input checked="" type="checkbox"/>			
31. Has proper consideration been given to results that may be overly sensitive to very small changes in input?		<input checked="" type="checkbox"/>			
<b>CONCLUSIONS</b>					
32. Is the magnitude of the result reasonable and expected when compared to inputs?		<input checked="" type="checkbox"/>			
33. Is there a reasonable justification provided for deviations from the acceptance criteria?	<input checked="" type="checkbox"/>				
34. Are stated conclusions justifiable based on the calculation results?		<input checked="" type="checkbox"/>			
35. Are all pages sequentially numbered and marked with a valid calculation and revision number?		<input checked="" type="checkbox"/>			
36. Is all information legible and reproducible?		<input checked="" type="checkbox"/>			
37. Is the calculation presentation complete and understandable without any need to refer back to the Originator for clarification or explanations?		<input checked="" type="checkbox"/>			
38. Is calculation format presented in a logical and orderly manner, in conformance with the standard calculation content of NOP-CC-3002 (Attachment 1)?		<input checked="" type="checkbox"/>			
39. Have all changes in the documentation been initiated (or signed) and dated by the author of the change and all required reviewers?	<input checked="" type="checkbox"/>				
<b>DESIGN/LICENSING</b>					
40. Have all calculation results stayed within existing design/licensing basis parameters?		<input checked="" type="checkbox"/>			
41. If the response to Question 40 is NO, has Licensing been notified as appropriate? (i.e. UFSAR or Tech Spec Change Request has been initiated).	<input checked="" type="checkbox"/>				
42. Is the direction of trends reasonable?		<input checked="" type="checkbox"/>			

# CALCULATION REVIEW CHECKLIST

QUESTION	NA	Yes	No	COMMENTS	RESOLUTION
43. Has the calculation Preparer used all applicable design information/requirements provided?		<input checked="" type="checkbox"/>			
44. Did the calculation Preparer determine if the calculation was referenced in design basis documents and/or databases?		<input checked="" type="checkbox"/>			
45. Did the Preparer determine if the calculation was used as a reference in the UFSAR?	<input checked="" type="checkbox"/>				
46. If the calculation is used as a reference in the UFSAR, is a change to the UFSAR required or an update to the UFSAR Validation Database, if applicable, required?	<input checked="" type="checkbox"/>				
47. If the answer to Question 46 is YES, have the appropriate documents been initiated?	<input checked="" type="checkbox"/>				
48. Has the applicability of 10CFR50.59 to this calculation been considered and documented?		<input checked="" type="checkbox"/>			
<b>ACCEPTABLE</b>					
49. Does the calculation meet its purpose/objective?		<input checked="" type="checkbox"/>			
50. Is the calculation acceptable for use?		<input checked="" type="checkbox"/>			
51. What checking method was used to review the calculation? Check all that apply.					
• spot check for math					
• complete check for math		<input checked="" type="checkbox"/>			
• comparison with tests					
• check by alternate method					
• comparison with previous calculation					
52. If the calculation was prepared by a vendor, does it comply with the technical and quality requirements described in the Procurement Documents? Reference the Purchase Order number or other procurement document number in the Comments Section of this question.	<input checked="" type="checkbox"/>				
53. Have Professional Engineer (PE) certification requirements been addressed and documented where required by ASME Code (if applicable).	<input checked="" type="checkbox"/>				

**Review Summary:**

<b>Technical Review (Print and Sign Name)</b>	<b>Date</b>	<b>Owner's Acceptance Review (Required for calculations prepared by a vendor)</b>	
		<b>Reviewer (Print and Sign Name)</b>	<b>Date</b>
		N/A	
<b>Design Verification (Print and Sign Name)</b>	<b>Date</b>	<b>Approver (Print and Sign Name)</b>	<b>Date</b>
Shen Wang	10/31/11	N/A	

# OWNER'S ACCEPTANCE REVIEW

DOCUMENT (S) Calculation C-CSS-099.20-055	REV. 0	QUESTION	UNIT 1		VENDOR Bechtel	COMMENTS	RESOLUTION
			NA	Yes No			
1.		Is the purpose or objective of the activity clear, appropriate and well documented?		X			
2.		If there is a split in work scope between the Vendor and Owner, has this been fulfilled to ensure the whole scope is completed?	X				
3.		Were Owner-supplied inputs for the activity used and documented appropriately?		X			
4.		Are the source documents for all inputs documented and are the sources credible as appropriate (including Owner-supplied inputs)?		X			
5.		Are assumptions and use of engineering judgment appropriate?		X			
6.		Are there any open assumptions, which need later confirmation?		X			
7.		If Question 6 is yes, are the open assumptions tracked properly?		X			
8.		If Question 6 is yes, have holds (e.g., on field implementation) been adequately imposed and tracked?		X		Mode 6 Holds on CRs 11-03996 & 11-04402	
9.		Are appropriate design and licensing bases compiled with and documented as such?	X			This analysis is performed to demonstrate operability of the Shield Building	
10.		Are computer codes certified as required? Identify if certified to Owner or Vendor's program.		X			
11.		Are methodologies, design/acceptance criteria and considerations proper, documented and consistently applied to the activity?		X			
12.		Have all pertinent design interfaces been considered and documented?	X				
13.		Have all affected documents/programs been properly identified for follow-up action?	X				
14.		Are testing requirements specified where appropriate?	X				
15.		Have the appropriate procedures been followed for generation of the product?		X			
16.		Has the product been properly checked internally by the Vendor?		X			
17.		Are the results reasonable compared to the inputs?		X			
18.		Has the purpose or objective been met, and is the product acceptable for use?		X			
19.		Is the readability/clarity of the document acceptable?		X			
20.		Does the product comply with the installed plant configuration (i.e., the product will not create a nonconforming condition)?		X		Ref. CR 11-03346	
21.		Has an Owner's Acceptance walkdown been completed as appropriate? If no, provide justification.		X		Owners review of core bores & Impulse Response test information	

# OWNER'S ACCEPTANCE REVIEW

<b>DOCUMENT (S)</b> Calculation C-CSS-099.20-055	<b>REV. 0</b>	<b>VENDOR</b> Bechtel	<b>UNIT 1</b>
<b>QUESTION</b>		<b>COMMENTS</b>	<b>RESOLUTION</b>
22. Does the product comply with the technical and quality requirements described in the procurement documents?  COMPLETED BY: (Print and Sign Name) <span style="font-size: 1.5em; font-family: cursive;">R. BAIR</span>		NA    Yes    No  X	
		IF CHECKLIST IS REVIEWED BY MORE THAN ONE REVIEWER, SIGN BELOW: ADDITIONAL REVIEWER (Print and Sign Name) <span style="font-size: 1.5em; font-family: cursive;">FOR M. ADER PER TELECON R. BAIR</span>	

Jon G. Hook

10/31/11