



**Pacific Gas and
Electric Company®**

Barry S. Allen
Vice President, Nuclear Services

Diablo Canyon Power Plant
Mail Code 104/6
P. O. Box 56
Avila Beach, CA 93424

805.545.4888
Internal: 691.4888
Fax: 805.545.6445

October 7, 2015

PG&E Letter DCL-15-115

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555-0001

10 CFR 50.90

Diablo Canyon Units 1 and 2
Docket No. 50-275, OL-DPR-80
Docket No. 50-323, OL-DPR-82

Withdrawal of License Amendment Request 15-04

Exigent Revision to Technical Specification 3.8.9, "Distribution Systems – Operating"

Reference 1: PG&E Letter DCL-15-091, "License Amendment Request 15-04,
Exigent Revision to Technical Specification 3.8.9, 'Distribution
Systems – Operating,'" dated August 12, 2015

Dear Commissioners and Staff:

On August 12, 2015, Pacific Gas and Electric Company (PG&E) requested approval (Reference 1) of a proposed license amendment request (LAR) to revise Technical Specification (TS) 3.8.9, "Distribution Systems – Operating." The proposed change requested revision of TS 3.8.9, Condition B, Required Action B.1 Completion Time from 2 hours to 24 hours to support replacing electronic style inverter output breakers online.

The LAR requested exigent review by the NRC. Subsequent discussions with the NRC Project Manager for Diablo Canyon Power Plant identified that the justification for an exigent review was not supported, but the review could continue on a routine basis. Because PG&E plans to replace the subject Unit 1 breakers during the upcoming Unit 1 Refueling Outage Nineteen scheduled for October 2015, and the next Unit 2 outage is scheduled sooner than the anticipated review schedule (May 2016), PG&E hereby withdraws License Amendment Request 15-04 submitted in Reference 1.

PG&E makes no regulatory commitments (as defined by NEI 99-04) in this letter. This letter includes no revisions to existing regulatory commitments.

If you have any questions or require additional information, please contact Mr. Hossein Hamzehee at 805-545-4720.



I state under penalty of perjury that the foregoing is true and correct.

Executed on October 7, 2015.

Sincerely,

Barry S. Allen
Vice President – Nuclear Services

mjrm/4557/50709593

cc: Marc L. Dapas, NRC Region IV
Thomas R. Hipschman, NRC Senior Resident Inspector
Siva P. Lingam, NRR Project Manager
Gonzalo L. Perez, Branch Chief, California Dept of Public Health
Diablo Distribution