

ATTACHMENT 19

**ANP-3372NP, Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR
Reference Fuel Cycle Design (Non-Proprietary)**



Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference Fuel Cycle Design

ANP-3372NP
Revision 1

August 2015

AREVA Inc.

(c) 2015 AREVA Inc.

Copyright © 2015

**AREVA Inc.
All Rights Reserved**

Nature of Changes

Item	Page	Description and Justification
1.	2-1	Correction of typographical error, Regulation changed to Regulatory.
2.	Various	Minor changes/removal of proprietary markings/words.

Contents

1.0	Introduction	1-1
2.0	Summary	2-1
3.0	Cycle 19 Fuel Cycle Design	3-1
3.1	General Description	3-1
3.2	Control Rod Patterns and Thermal Limits	3-1
3.3	Hot Excess Reactivity and Cold Shutdown Margin	3-2
4.0	References	4-1
Appendix A	Browns Ferry Unit 3 Cycle 19 Step-Through Depletion Summary, Control Rod Patterns and Core Average Axial Power and Exposure Distributions	A-1
Appendix B	Elevation Views of the Browns Ferry Unit 3 Cycle 19 Fresh Reload Batch Fuel Assemblies	B-1
Appendix C	Browns Ferry Unit 3 Cycle 19 Fresh Fuel Locations	C-1
Appendix D	Browns Ferry Unit 3 Cycle 19 Radial Exposure and Power Distributions	D-1
Appendix E	Browns Ferry Unit 3 Cycle 18 EOC Projection Control Rod Patterns and Core Average Axial Power and Exposure Distributions	E-1

Tables

2.1	Browns Ferry Unit 3 Cycle 19 Energy and Key Results Summary	2-2
2.2	Browns Ferry Unit 3 Cycle 19 Fuel Cycle Design Assembly ID Range by Nuclear Fuel Type.....	2-4
3.1	Cycle 19 Core Composition and Design Parameters.....	3-3
3.2	Browns Ferry Unit 3 Cycle 19 Hot Operating Target k-eff versus Cycle Exposure	3-4
3.3	Browns Ferry Unit 3 Cycle 19 Cold Critical Target k-eff versus Cycle Exposure	3-4
3.4	Browns Ferry Unit 3 Cycle 19 Reactivity Margin Summary (Short EOC18).....	3-5
3.5	Browns Ferry Unit 3 Cycle 19 Reactivity Margin Summary (Nominal EOC18)	3-6
3.6	Browns Ferry Unit 3 Cycle 19 Reactivity Margin Summary (Long EOC18)	3-7

Figures

2.1	Browns Ferry Unit 3 Cycle 19 Design Step-Through k-eff versus Cycle Exposure.....	2-5
2.2	Browns Ferry Unit 3 Cycle 19 Design Margin to Thermal Limits versus Cycle Exposure	2-5
3.1	Browns Ferry Unit 3 Cycle 19 Reference Loading Pattern.....	3-8
3.2	Browns Ferry Unit 3 Cycle 19 Upper Left Quarter Core Layout by Fuel Type	3-10
3.3	Browns Ferry Unit 3 Cycle 19 Upper Right Quarter Core Layout by Fuel Type.....	3-11
3.4	Browns Ferry Unit 3 Cycle 19 Lower Left Quarter Core Layout by Fuel Type	3-12
3.5	Browns Ferry Unit 3 Cycle 19 Lower Right Quarter Core Layout by Fuel Type.....	3-13

Nomenclature

ACE	AREVA's advanced critical power correlation
BLEU	blended low enriched uranium
BOC	beginning of cycle
BOL	beginning of life
BWR	boiling water reactor
CGU	commercial grade uranium
CSDM	cold shutdown margin
EOC	end of cycle
EOFP	end of full power capability
EPU	extended power uprate
FFTR	final feedwater temperature reduction
GWd/MTU	gigawatt days per metric ton of initial uranium
HEXR	hot excess reactivity
LAR	licensing amendment request
LHGR	linear heat generation rate
MCPR	minimum critical power ratio
MICROBURN-B2	AREVA Inc. advanced BWR core simulator methodology with PPR capability
MWd/MTU	megawatt days per metric ton of initial uranium
NRC	Nuclear Regulatory Commission, U. S.
PLFR	part length fuel rod
PPR	Pin Power Reconstruction. The PPR methodology accounts for variation in local rod power distributions due to neighboring assemblies and control state. The local rod power distributions are reconstructed based on the actual flux solution for each statepoint.
R Value	the larger of zero or the shutdown margin at BOC minus the minimum calculated shutdown margin in the cycle
SLC	standby liquid control
SPCB	AREVA NP (formerly Siemens Power Corporation) critical power correlation

1.0 Introduction

AREVA Inc. (AREVA) has performed a fuel cycle design and fuel management calculations for the Browns Ferry Unit 3 Cycle 19 LAR* with ATRIUM™[†] 10XM fuel at EPU (120% OLTP) conditions. These analyses have been performed with the approved AREVA neutronics methodology (Reference 1). The CASMO-4 lattice depletion code was used to generate nuclear data including cross sections and local power peaking factors. The MICROBURN-B2 three dimensional core simulator code, utilizes the pin power reconstruction (PPR) model to determine the thermal margins presented in this report. The ACE critical power correlation (References 2 and 5) was utilized for the ATRIUM 10XM assemblies in the core. The SPCB critical power correlation (Reference 6) was utilized for the ATRIUM-10 assemblies in the core. The following MICROBURN-B2 modeling features are included in this analysis:

- Control blade B-10 depletion
- Explicit neutronic treatment of the spacer grids
- Explicit modeling of the PLFR plenums
- Explicit modeling of the water rod flow

Design results for the Cycle 19 reactor core loading including projected control rod patterns and evaluations of thermal and reactivity margins are presented. The Cycle 19 results are based on projected Cycle 18 core operation as summarized in Table 2.1.

* Browns Ferry Unit 3 Cycle 19 is used as a reference design for the EPU LAR. Use of Cycle 19 throughout this report refers to this reference fuel cycle design.

† ATRIUM is a trademark of AREVA Inc.

2.0 Summary

The Cycle 19 fresh batch size (352 assemblies) and batch average enrichment [

] were determined to meet the energy requirements provided by Tennessee Valley Authority (TVA) (Reference 4). For a complete description of the fresh reload assemblies, see Reference 3. The loading of the Cycle 19 fuel as described in this report results in a projected Cycle 19 full power energy capability of $2,534 \pm 41$ GWd ($18,390 \pm 300$ MWd/MTU). Beyond the full power capability, the cycle has been designed to achieve 172 GWd additional energy via FFTR and coast operation.

In order to obtain optimum operating flexibility, the projected control rod patterns for Cycle 19 were developed to be consistent with a conservative margin to thermal limits. The cycle design calculations also demonstrate adequate hot excess reactivity and cold shutdown margin throughout the cycle. The hot and cold target k-effs used in the design are provided in Table 3.2 and 3.3. Key results from the design analysis are summarized in Table 2.1. Table 2.2 summarizes the assembly identification range by nuclear fuel type batch for the Cycle 19 design. Figures 2.1 and 2.2 provide a summary of the cycle design step-through projection.

The peak rod average power was verified to not exceed 6.3 kW/ft at exposures of > 54 GWd/MTU (Regulatory Guide 1.183, footnote to Table 3).

Table 2.1 Browns Ferry Unit 3 Cycle 19 Energy and Key Results Summary

Cycle Energy, GWd (Cycle Exposure, MWd/MTU)	
Cycle 18	
• Best estimate depletion to Nominal EOC 18	2,390 (17,508)
• Short window EOC 18	2,318 (16,976)
• Long window EOC 18	2,439 (17,862)
Cycle 19	
• EOFP Energy	2,534±41 (18,390±300)
• FFTR and coast Energy	172 (1,246)
• EOC Energy	2,706±41 (19,636±300)
Key Results	
BOC CSDM, %Δk/k (based on short EOC 18)	1.17
Minimum CSDM, %Δk/k (based on short EOC 18)	1.17
Cycle Exposure of Minimum CSDM, MWd/MTU (short basis)	0
Moderator Temperature of Minimum CSDM, °F (short basis)	68
Cycle R Value, %Δk/k (short basis)	0.00
BOC CSDM, %Δk/k (based on nominal EOC 18)	1.46
Minimum CSDM, %Δk/k (based on nominal EOC 18)	1.46
Cycle Exposure of Minimum CSDM, MWd/MTU (nominal basis)	0
Moderator Temperature of Minimum CSDM, °F (nominal basis)	68
Cycle R Value, %Δk/k (nominal basis)	0.00
BOC CSDM, %Δk/k (based on long EOC 18)	1.66
Minimum CSDM, %Δk/k (based on long EOC 18)	1.66
Cycle Exposure of Minimum CSDM, MWd/MTU (long basis)	0
Moderator Temperature of Minimum CSDM, °F (long basis)	68
Cycle R Value, %Δk/k (long basis)	0.00
Minimum SLC SDM, %Δk/k (based on short EOC 18)	2.63
Cycle Exposure of Minimum SLC SDM, MWd/MTU (short basis)	0
Minimum SLC SDM, %Δk/k (based on nominal EOC 18)	2.96
Cycle Exposure of Minimum SLC SDM, MWd/MTU (nominal basis)	0
Minimum SLC SDM, %Δk/k (based on long EOC 18)	3.20
Cycle Exposure of Minimum SLC SDM, MWd/MTU (long basis)	0

Table 2.1 Browns Ferry Unit 3 Cycle 19 Energy and Key Results Summary *(Continued)*

Key Results	
BOC HEXR, % Δ k/k (based on short EOC 18)	1.64
Maximum HEXR, % Δ k/k (based on short EOC 18)	1.70
Cycle Exposure of Maximum HEXR, MWd/MTU (short basis)	13,400
BOC HEXR, % Δ k/k (based on nominal EOC 18)	1.34
Maximum HEXR, % Δ k/k (based on nominal EOC 18)	1.41
Cycle Exposure of Maximum HEXR, MWd/MTU (nominal basis)	13,400
BOC HEXR, % Δ k/k (based on long EOC 18)	1.12
Maximum HEXR, % Δ k/k (based on long EOC 18)	1.20
Cycle Exposure of Maximum HEXR, MWd/MTU (long basis)	13,400
Minimum MAPLHGR Margin, %	17.8
Exposure of Minimum MAPLHGR Margin, MWd/MTU	9,459
Minimum LHGR Margin, %	12.6
Exposure of Minimum LHGR Margin, MWd/MTU	18,051
Minimum CPR Margin, %	8.4
Exposure of Minimum CPR Margin, MWd/MTU	16,836

Table 2.2 Browns Ferry Unit 3 Cycle 19 Fuel Cycle Design Assembly ID Range by Nuclear Fuel Type

Nuclear Fuel Type	Number of Assemblies	Assembly ID Range
14	1	FCE190
16	67	FCF301-FCF460
17	14	FCF493-FCF510
18	26	FCF557-FCF588
19	88	FCG001-FCG088
20	152	FCG201-FCG352
21	64	FCG401-FCG464
22	224	FCH001-FCH224
23	96	FCH301-FCH396
24	32	FCH501-FCH532




Figure 2.1 Browns Ferry Unit 3 Cycle 19 Design Step-Through k-eff versus Cycle Exposure




Figure 2.2 Browns Ferry Unit 3 Cycle 19 Design Margin to Thermal Limits versus Cycle Exposure

3.0 Cycle 19 Fuel Cycle Design

3.1 *General Description*

The assembly design for the Cycle 19 BFE3-19 LAR fresh reload fuel for Browns Ferry Unit 3 is described in detail in Reference 3. Elevation views of the fresh reload fuel design axial enrichment and gadolinia distributions are shown in Appendix B, Figures B.1 through B.3. The loading pattern maintains full core symmetry within a scatter load fuel management scheme. This loading in conjunction with the control rod patterns presented in Appendix A shows acceptable power peaking and associated margins to limits for projected Cycle 19 operation. The analyses supporting this fuel cycle design were based on the core parameters shown in Table 3.1. Figures 3.1 through 3.5, along with Table 3.1 define the reference loading pattern used in the fuel cycle design. The specific core location of the fresh assemblies in Cycle 19 is provided in Appendix C. Key results for the cycle are summarized in Table 2.1. The Cycle 19 BFE3-19 LAR fresh reload fuel assumes the use of BLEU material for one fuel type to account for about 30% of the fresh reload assemblies. This was done to account for the possibility that limited supplies of BLEU material may become available after the current inventory is exhausted.

3.2 *Control Rod Patterns and Thermal Limits*

Projected control rod patterns for Cycle 19 and resultant key operating parameters including thermal margins are shown in Appendix A. The thermal margins presented in this report were determined using the MICROBURN-B2 3D core simulator PPR model and meet the required design margin to thermal limits from Reference 4. A detailed summary of the core parameters resulting from the step-through projection analysis is provided in Tables A.1 and A.2. Limiting results from the step-through are summarized in Table 2.1 and in Figure 2.2. The hot operating target k-eff versus cycle exposure which was determined to be appropriate for Cycle 19 is shown in Table 3.2. The k-eff and margin to limits results from the design cycle depletion are presented graphically in Figures 2.1 and 2.2. The k-eff values presented in Figure 2.1 and in Appendix A are not bias corrected. Selected exposure and radial power distributions from the design step-through are presented in Appendix D. Projected control rod patterns near EOC18 are shown in Appendix E.

3.3 ***Hot Excess Reactivity and Cold Shutdown Margin***

The cycle design calculations demonstrate adequate hot excess reactivity, SLC shutdown margin, and cold shutdown margin throughout the cycle. Key shutdown margin and R-Value results are presented in Table 2.1. The shutdown margin for Cycle 19 is in conformance with the Technical Specification limit of $R + 0.38\% \Delta k/k$ at BOC. The cold target k_{eff} versus exposure determined to be appropriate for calculation of cold shutdown margin in Cycle 19 is shown in Table 3.3. The core hot excess reactivity was calculated at full power with all rods out, 102.5 Mlb/hr core flow, with equilibrium xenon. Tables 3.4 through 3.6 summarize the Cycle 19 reactivity margins versus cycle exposure, including the SLC shutdown margin for the cycle.

Table 3.1 Cycle 19 Core Composition and Design Parameters

Fuel Description	Cycle Loaded	Nuclear Fuel Type	Number of Assemblies
ATRIUM-10 []	16	14	1
ATRIUM-10 []	17	16	67
ATRIUM-10 []	17	17	14
ATRIUM-10 []	17	18	26
ATRIUM 10XM []	18	19	88
ATRIUM 10XM []	18	20	152
ATRIUM 10XM []	18	21	64
ATRIUM 10XM []	19	22	224
ATRIUM 10XM []	19	23	96
ATRIUM 10XM []	19	24	32

Number of Fuel Assemblies in Core	764
Total Number of Fresh Assemblies	352
Total Core Mass, MTU	137.79
Rated Thermal Power Level, MW _t	3,952
Rated Core Flow, Mlb/hr	102.5
Reference Pressure, psia	1,050*
Reference Inlet Subcooling, Btu/lbm	26.94 [†]

* Value is representative of MICROBURN-B2 input for dome pressure at rated conditions and varies depending on core state point.

[†] Value is typically determined by MICROBURN-B2 using a heat balance method based on nominal feedwater temperature and other parameters identified in the cycle specific plant parameters document.

Table 3.2 Browns Ferry Unit 3 Cycle 19 Hot Operating Target k-eff versus Cycle Exposure

Cycle Exposure (MWd/MTU)	Hot Operating k-eff*
0.0	1.0000
7,500.0	0.9985
10,500.0	0.9985
15,000.0	1.0000
25,000.0	1.0000

Table 3.3 Browns Ferry Unit 3 Cycle 19 Cold Critical Target k-eff versus Cycle Exposure

Cycle Exposure (MWd/MTU)	Cold Critical k-eff*
0.0	0.9940
25,000.0	0.9940

* Values are linearly interpolated between cycle exposure points.

**Table 3.4 Browns Ferry Unit 3 Cycle 19 Reactivity Margin Summary
 (Short EOC18)**

Cycle Exposure (MWd/MTU)	Cold Shutdown Margin* (% $\Delta k/k$)	SLC Cold Shutdown Margin [†] (% $\Delta k/k$)	Hot Excess Reactivity (% $\Delta k/k$)
0	1.17	2.63	1.64
175	1.35	2.81	1.58
1,000	1.92	3.27	1.37
2,300	2.37	3.57	1.34
3,300	2.69	3.82	1.30
4,398	2.97	4.11	1.26
5,500	3.16	4.35	1.23
6,500	3.30	4.52	1.24
7,500	3.42	4.64	1.28
8,200	3.48	4.71	1.31
9,464	3.55	4.76	1.41
10,250	3.47	4.75	1.49
11,300	3.33	4.68	1.59
11,800	3.28	4.65	1.63
12,500	3.21	4.62	1.67
13,400	3.12	4.64	1.70
14,528	2.80	4.78	1.66
15,600	2.59	5.09	1.50
16,600	2.48	5.56	1.17
17,375	2.46	6.03	0.75
18,390	2.43	6.50	0.07
19,636	2.62	7.03	--

* Values in **BOLD** are limiting values at elevated moderator temperatures.

[†] Calculated at 366.0 °F ARO conditions.

**Table 3.5 Browns Ferry Unit 3 Cycle 19 Reactivity Margin Summary
 (Nominal EOC18)**

Cycle Exposure (MWd/MTU)	Cold Shutdown Margin* (% $\Delta k/k$)	SLC Cold Shutdown Margin [†] (% $\Delta k/k$)	Hot Excess Reactivity (% $\Delta k/k$)
0	1.46	2.96	1.34
175	1.65	3.16	1.27
1,000	2.25	3.63	1.05
2,300	2.71	3.92	1.03
3,300	3.03	4.15	1.00
4,398	3.24	4.43	0.95
5,500	3.44	4.65	0.94
6,500	3.57	4.79	0.95
7,500	3.67	4.92	0.99
8,200	3.73	4.98	1.03
9,464	3.75	5.02	1.13
10,250	3.64	4.99	1.21
11,300	3.51	4.93	1.30
11,800	3.47	4.90	1.34
12,500	3.43	4.87	1.38
13,400	3.33	4.89	1.41
14,528	3.06	5.02	1.39
15,600	2.79	5.31	1.26
16,600	2.65	5.76	0.96
17,375	2.62	6.21	0.57
18,390	2.58	6.68	-0.11
19,636	2.76	7.19	--

* Values in **BOLD** are limiting values at elevated moderator temperatures.

[†] Calculated at 366.0 °F ARO conditions.

**Table 3.6 Browns Ferry Unit 3 Cycle 19 Reactivity Margin Summary
 (Long EOC18)**

Cycle Exposure (MWd/MTU)	Cold Shutdown Margin* (% $\Delta k/k$)	SLC Cold Shutdown Margin [†] (% $\Delta k/k$)	Hot Excess Reactivity (% $\Delta k/k$)
0	1.66	3.20	1.12
175	1.88	3.40	1.05
1,000	2.49	3.87	0.83
2,300	2.94	4.14	0.81
3,300	3.24	4.37	0.79
4,398	3.44	4.61	0.75
5,500	3.62	4.82	0.74
6,500	3.77	4.98	0.76
7,500	3.87	5.10	0.80
8,200	3.92	5.15	0.84
9,464	3.86	5.18	0.94
10,250	3.74	5.14	1.02
11,300	3.64	5.08	1.10
11,800	3.60	5.04	1.13
12,500	3.56	5.03	1.17
13,400	3.48	5.05	1.20
14,528	3.22	5.17	1.20
15,600	2.94	5.45	1.10
16,600	2.80	5.89	0.83
17,375	2.75	6.34	0.45
18,390	2.69	6.79	-0.22
19,636	2.85	7.30	--

* Values in **BOLD** are limiting values at elevated moderator temperatures.

[†] Calculated at 366.0 °F ARO conditions.

Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design

	1	3	5	7	9	11	13	15	17	19	21	23	25	27	29
60									17 41.1	16 38.1	16 36.9	16 35.9	17 36.0	18 35.3	18 31.9
58	Nuclear Fuel Type BOC Exposure (GWd/MTU)							18 41.2	16 34.1	19 17.9	19 17.2	19 21.4	19 21.4	19 20.3	24 0.0
56						16 41.0	16 37.9	19 21.5	23 0.0	23 0.0	23 0.0	23 0.0	19 17.8	22 0.0	19 20.9
54						16 37.9	19 22.1	23 0.0	20 22.0	23 0.0	20 23.1	23 0.0	23 0.0	23 0.0	22 0.0
52					17 39.5	16 31.8	24 0.0	19 22.0	24 0.0	23 0.0	24 0.0	22 0.0	21 23.7	22 0.0	20 23.2
50			16 40.4	16 37.7	16 32.4	19 19.6	23 0.0	23 0.0	22 0.0	20 24.0	22 0.0	20 24.0	22 0.0	21 23.3	22 0.0
48			16 37.2	19 21.9	24 0.0	23 0.0	19 19.6	22 0.0	20 22.4	22 0.0	21 24.1	22 0.0	20 22.9	22 0.0	21 22.3
46		16 41.6	19 21.4	23 0.0	19 21.9	23 0.0	22 0.0	20 21.9	22 0.0	21 22.7	22 0.0	20 22.8	22 0.0	20 21.9	22 0.0
44	18 41.0	16 34.3	23 0.0	20 21.9	24 0.0	22 0.0	20 21.8	22 0.0	20 22.0	22 0.0	20 23.0	22 0.0	20 22.6	22 0.0	20 22.1
42	16 38.8	19 17.8	23 0.0	23 0.0	23 0.0	20 24.0	22 0.0	21 21.9	22 0.0	21 23.8	22 0.0	20 20.2	22 0.0	20 23.3	22 0.0
40	16 37.4	19 17.2	23 0.0	20 23.1	24 0.0	22 0.0	21 24.0	22 0.0	20 21.0	22 0.0	20 20.9	22 0.0	21 22.8	22 0.0	20 22.7
38	16 36.1	19 21.3	23 0.0	23 0.0	22 0.0	20 24.0	22 0.0	20 22.6	22 0.0	20 20.2	22 0.0	20 22.7	22 0.0	21 23.4	22 0.0
36	16 36.9	19 21.3	19 18.0	23 0.0	21 23.4	22 0.0	20 23.2	22 0.0	20 22.2	22 0.0	21 22.6	22 0.0	20 22.8	22 0.0	20 23.6
34	18 34.9	19 20.4	22 0.0	23 0.0	22 0.0	21 22.3	22 0.0	20 21.9	22 0.0	20 23.1	22 0.0	21 23.4	22 0.0	20 22.9	22 0.0
32	18 32.1	24 0.0	19 20.8	22 0.0	20 23.1	22 0.0	21 22.8	22 0.0	20 23.4	22 0.0	20 22.6	22 0.0	20 23.4	22 0.0	21 23.7

Fuel Type	Description	Cycle Loaded	No. Per Quarter	Per core
14	[	16		0
16	[	17		18
17	[	17		3
18	[	17		6
19	[	18		22
20	[	18		38
21	[	18		16
22	[	19		56
23	[	19		24
24	[	19		8

**Figure 3.2 Browns Ferry Unit 3 Cycle 19 Upper Left Quarter Core
Layout by Fuel Type**

Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference Fuel Cycle Design

	31	33	35	37	39	41	43	45	47	49	51	53	55	57	59
60	18 32.4	18 35.5	17 36.1	16 35.8	16 36.7	16 37.7	16 37.9								
58	24 0.0	19 20.4	19 21.3	19 21.2	19 17.1	19 17.8	16 34.2	18 41.3			Nuclear Fuel Type BOC Exposure (GWd/MTU)				
56	19 20.7	22 0.0	19 17.9	23 0.0	23 0.0	23 0.0	23 0.0	19 21.4	16 37.7	16 40.9					
54	22 0.0	23 0.0	23 0.0	23 0.0	20 23.0	23 0.0	20 21.9	23 0.0	19 22.1	18 40.6					
52	20 23.1	22 0.0	21 23.6	22 0.0	24 0.0	23 0.0	24 0.0	19 21.9	24 0.0	16 32.4	17 41.2				
50	22 0.0	21 23.2	22 0.0	20 23.9	22 0.0	20 23.9	22 0.0	23 0.0	23 0.0	19 19.5	16 31.9	17 39.8	16 41.3		
48	21 22.3	22 0.0	20 22.8	22 0.0	21 24.0	22 0.0	20 22.3	22 0.0	19 19.4	23 0.0	24 0.0	19 21.6	16 38.5		
46	22 0.0	20 21.9	22 0.0	20 22.7	22 0.0	21 22.6	22 0.0	20 21.9	22 0.0	23 0.0	19 21.6	23 0.0	19 21.4	16 41.2	
44	20 22.0	22 0.0	20 22.6	22 0.0	20 20.6	22 0.0	20 21.8	22 0.0	20 21.6	22 0.0	24 0.0	20 21.8	23 0.0	16 34.2	16 37.8
42	22 0.0	20 23.2	22 0.0	20 20.2	22 0.0	21 23.7	22 0.0	21 21.7	22 0.0	20 23.9	23 0.0	23 0.0	23 0.0	19 17.8	16 37.6
40	20 22.6	22 0.0	21 22.6	22 0.0	20 20.9	22 0.0	20 22.8	22 0.0	21 23.8	22 0.0	24 0.0	20 23.0	23 0.0	19 17.0	16 37.4
38	22 0.0	21 23.3	22 0.0	20 22.7	22 0.0	20 19.9	22 0.0	20 22.5	22 0.0	20 23.9	22 0.0	23 0.0	23 0.0	19 21.2	16 36.0
36	20 23.4	22 0.0	20 22.7	22 0.0	21 22.4	22 0.0	20 22.0	22 0.0	20 23.2	22 0.0	21 23.3	23 0.0	19 17.6	19 21.3	17 35.8
34	22 0.0	20 22.9	22 0.0	21 23.4	22 0.0	20 23.0	22 0.0	20 21.9	22 0.0	21 22.1	22 0.0	23 0.0	22 0.0	19 19.9	18 35.5
32	21 23.8	22 0.0	20 23.2	22 0.0	20 22.6	22 0.0	20 23.4	22 0.0	21 22.7	22 0.0	20 23.0	22 0.0	19 20.6	24 0.0	18 32.0
Fuel Type	Description		Cycle Loaded		No. Per Quarter core										
14	[		]		16		0								
16	[		]		17		17								
17	[		]		17		4								
18	[		]		17		6								
19	[		]		18		22								
20	[		]		18		38								
21	[		]		18		16								
22	[		]		19		56								
23	[		]		19		24								
24	[		]		19		8								

Figure 3.3 Browns Ferry Unit 3 Cycle 19 Upper Right Quarter Core Layout by Fuel Type

	1	3	5	7	9	11	13	15	17	19	21	23	25	27	29
30	18 31.9	24 0.0	19 20.6	22 0.0	20 23.1	22 0.0	21 22.8	22 0.0	20 23.4	22 0.0	20 22.6	22 0.0	20 23.2	22 0.0	21 23.8
28	18 35.4	19 19.9	22 0.0	23 0.0	22 0.0	21 22.1	22 0.0	20 21.9	22 0.0	20 23.0	22 0.0	21 23.4	22 0.0	20 22.9	22 0.0
26	16 37.0	19 21.3	19 17.5	23 0.0	21 23.3	22 0.0	20 23.2	22 0.0	20 22.1	22 0.0	21 22.5	22 0.0	20 22.7	22 0.0	20 23.4
24	16 35.8	19 21.2	23 0.0	23 0.0	22 0.0	20 23.9	22 0.0	20 22.5	22 0.0	20 19.8	22 0.0	20 22.7	22 0.0	21 23.3	22 0.0
22	16 37.3	19 17.0	23 0.0	20 23.0	24 0.0	22 0.0	21 23.8	22 0.0	20 22.8	22 0.0	20 20.9	22 0.0	21 22.7	22 0.0	20 22.6
20	16 38.5	19 17.8	23 0.0	23 0.0	23 0.0	20 24.0	22 0.0	21 21.8	22 0.0	21 23.7	22 0.0	20 20.3	22 0.0	20 23.2	22 0.0
18	17 39.8	16 34.0	23 0.0	20 21.9	24 0.0	22 0.0	20 21.6	22 0.0	20 21.8	22 0.0	20 20.6	22 0.0	20 22.6	22 0.0	20 22.0
16		17 41.1	19 21.4	23 0.0	19 21.6	23 0.0	22 0.0	20 21.9	22 0.0	21 22.6	22 0.0	20 22.7	22 0.0	20 21.9	22 0.0
14			16 38.0	19 21.6	24 0.0	23 0.0	19 19.3	22 0.0	20 22.3	22 0.0	21 24.0	22 0.0	20 22.8	22 0.0	21 22.3
12			16 41.1	18 40.4	16 31.8	19 19.5	23 0.0	23 0.0	20 0.0	22 23.9	20 0.0	22 23.9	22 0.0	21 23.2	22 0.0
10					18 41.2	16 32.4	24 0.0	19 21.9	24 0.0	23 0.0	24 0.0	22 0.0	21 23.6	22 0.0	20 23.1
8						18 40.5	19 22.1	23 0.0	20 22.0	23 0.0	20 23.0	23 0.0	23 0.0	23 0.0	22 0.0
6						16 40.8	16 37.6	19 21.3	23 0.0	23 0.0	23 0.0	23 0.0	19 17.9	22 0.0	19 20.7
4	Nuclear Fuel Type BOC Exposure (GWd/MTU)							16 41.3	16 34.3	19 17.7	19 17.0	19 21.2	19 21.3	19 20.4	24 0.0
2									18 41.3	16 37.8	16 36.6	16 35.7	16 37.1	18 35.5	18 32.5

Fuel Type	Description	Cycle Loaded	No. Per Quarter core
14	[	16	0
16	[	17	17
17	[	17	2
18	[	17	8
19	[	18	22
20	[	18	38
21	[	18	16
22	[	19	56
23	[	19	24
24	[	19	8

**Figure 3.4 Browns Ferry Unit 3 Cycle 19 Lower Left Quarter Core
 Layout by Fuel Type**

	31	33	35	37	39	41	43	45	47	49	51	53	55	57	59
30	21 23.7	22 0.0	20 23.3	22 0.0	20 22.6	22 0.0	20 23.4	22 0.0	21 22.8	22 0.0	20 23.1	22 0.0	19 20.8	24 0.0	18 32.4
28	22 0.0	20 22.9	22 0.0	21 23.4	22 0.0	20 23.1	22 0.0	20 21.9	22 0.0	21 22.3	22 0.0	23 0.0	22 0.0	19 20.4	18 35.1
26	20 23.6	22 0.0	20 22.8	22 0.0	21 22.6	22 0.0	20 22.1	22 0.0	20 23.2	22 0.0	21 23.4	23 0.0	19 18.2	19 21.4	17 35.7
24	22 0.0	21 23.3	22 0.0	20 22.7	22 0.0	20 20.2	22 0.0	20 22.6	22 0.0	20 24.0	22 0.0	23 0.0	23 0.0	19 21.3	16 35.9
22	20 22.6	22 0.0	21 22.8	22 0.0	20 21.0	22 0.0	20 21.2	22 0.0	21 24.0	22 0.0	24 0.0	20 23.1	23 0.0	19 17.1	16 37.4
20	22 0.0	20 23.3	22 0.0	20 20.5	22 0.0	21 23.8	22 0.0	21 22.0	22 0.0	20 24.0	23 0.0	23 0.0	23 0.0	19 17.9	16 37.8
18	20 22.0	22 0.0	20 22.6	22 0.0	20 23.0	22 0.0	20 22.0	22 0.0	20 21.7	22 0.0	24 0.0	20 21.9	23 0.0	16 34.2	16 41.0
16	22 0.0	20 21.9	22 0.0	20 22.8	22 0.0	21 22.8	22 0.0	20 21.9	22 0.0	23 0.0	19 21.9	23 0.0	19 21.4	17 41.2	
14	21 22.3	22 0.0	20 22.8	22 0.0	21 24.1	22 0.0	20 22.3	22 0.0	19 19.8	23 0.0	24 0.0	19 21.9	16 38.3		
12	22 0.0	21 23.3	22 0.0	20 24.0	22 0.0	20 24.0	22 0.0	23 0.0	23 0.0	19 19.6	16 32.4	18 40.2	16 40.5		
10	20 23.2	22 0.0	21 23.7	22 0.0	24 0.0	23 0.0	24 0.0	19 22.1	24 0.0	16 32.5	16 38.1				
8	22 0.0	23 0.0	23 0.0	23 0.0	20 23.1	23 0.0	20 22.0	23 0.0	19 22.3	17 39.6					
6	19 20.9	22 0.0	19 18.3	23 0.0	23 0.0	23 0.0	23 0.0	19 21.4	16 38.1	18 41.2					
4	24 0.0	19 20.7	19 21.3	19 21.4	19 17.3	19 17.9	16 34.4	17 40.9				Nuclear Fuel Type BOC Exposure (GWd/MTU)			
2	18 32.7	18 35.5	14 34.9	16 36.0	16 36.9	16 37.9	17 41.2								

Fuel Type	Description	Cycle Loaded	No. Per Quarter core
14	[	16	1
16	[	17	15
17	[	17	5
18	[	17	6
19	[	18	22
20	[	18	38
21	[	18	16
22	[	19	56
23	[	19	24
24	[	19	8

**Figure 3.5 Browns Ferry Unit 3 Cycle 19 Lower Right Quarter Core
 Layout by Fuel Type**

4.0 References

1. EMF-2158(P)(A) Revision 0, *Siemens Power Corporation Methodology for Boiling Water Reactors: Evaluation and Validation of CASMO-4/MICROBURN-B2*, Siemens Power Corporation, October 1999.
2. ANP-10298PA Revision 0, *ACE/ATRIUM 10XM Critical Power Correlation*, AREVA NP, March 2010.
3. ANP-3343P Revision 0, *Nuclear Fuel Design Report Browns Ferry EPU (120% OLTP) Equilibrium Cycle ATRIUM 10XM Fuel*, AREVA Inc., October 2014.
4. BFE-3706 Revision 0, *Browns Ferry Unit 3 EPU Transition Energy Plan*, TVA, October 2014. (38-9226272-001)
5. ANP-3140(P) Revision 0, *Browns Ferry Units 1, 2, and 3 Improved K-factor Model for ACE/ATRIUM 10XM Critical Power Correlation*, AREVA NP, August 2012.
6. EMF-2209(P)(A) Revision 3, *SPCB Critical Power Correlation*, AREVA NP, September 2009.

**Appendix A Browns Ferry Unit 3 Cycle 19 Step-Through Depletion Summary, Control
Rod Patterns and Core Average Axial Power and Exposure Distributions**

Table A.1 Browns Ferry Unit 3 Cycle 19 Design Depletion Summary

Cycle Exposure (Gwd/MT)	Calculated K-eff	Control Rod Density	Total Core Power MWt	Total Core Flow (Mlb/hr)	Ref. Pressure (psia)	Inlet Sub-Cooling (Btu/lb)	Void Fraction	Core Minimum CPR	Core Maximum LHGR (kW/ft)	Core Maximum APLHGR (kW/ft)
0.000	0.99996	5.59	3952.0	103.32	1050.04	26.71	0.480	1.736	12.15	9.05
0.175	0.99997	5.59	3952.0	106.50	1050.04	25.84	0.471	1.748	11.75	8.79
0.176	0.99995	5.41	3952.0	102.50	1050.04	26.94	0.475	1.720	11.66	8.71
0.300	0.99993	5.41	3952.0	106.29	1050.04	25.90	0.466	1.738	11.41	8.58
0.301	0.99998	5.23	3952.0	102.50	1050.04	26.94	0.470	1.704	11.29	8.49
0.575	0.99983	5.23	3952.0	106.50	1050.04	25.84	0.461	1.726	11.15	8.41
0.576	0.99987	5.14	3952.0	104.14	1050.04	26.48	0.463	1.691	11.07	8.36
1.000	0.99977	5.14	3952.0	105.78	1050.04	26.03	0.459	1.700	10.99	8.34
1.500	0.99966	5.14	3952.0	105.78	1050.04	26.03	0.458	1.700	10.87	8.32
1.864	0.99960	5.14	3952.0	105.78	1050.04	26.03	0.457	1.701	10.77	8.29
1.865	0.99962	4.86	3952.0	103.53	1050.04	26.65	0.466	1.702	11.52	8.88
2.300	0.99954	4.86	3952.0	103.73	1050.04	26.59	0.463	1.705	11.37	8.83
2.800	0.99947	4.86	3952.0	104.24	1050.04	26.45	0.461	1.710	11.25	8.81
3.300	0.99933	4.86	3952.0	104.55	1050.04	26.37	0.459	1.711	11.17	8.80
3.800	0.99926	4.86	3952.0	105.06	1050.04	26.23	0.456	1.712	11.11	8.81
4.300	0.99913	4.86	3952.0	105.27	1050.04	26.17	0.455	1.713	11.08	8.85
4.396	0.99913	4.86	3952.0	105.27	1050.04	26.17	0.454	1.713	11.08	8.87
4.398	0.99910	4.91	3952.0	106.50	1050.04	25.84	0.453	1.772	11.02	8.74
4.600	0.99906	4.91	3952.0	106.50	1050.04	25.84	0.453	1.772	11.03	8.77
5.000	0.99898	4.91	3952.0	106.50	1050.04	25.84	0.452	1.772	11.05	8.85
5.500	0.99891	4.91	3952.0	106.29	1050.04	25.90	0.452	1.770	11.08	8.96
6.000	0.99881	4.91	3952.0	105.58	1050.04	26.09	0.452	1.767	11.15	9.09
6.500	0.99872	4.91	3952.0	104.55	1050.04	26.37	0.454	1.761	11.23	9.25
6.928	0.99863	4.91	3952.0	103.32	1050.04	26.71	0.456	1.753	11.31	9.40
6.931	0.99862	4.91	3952.0	106.09	1050.04	25.95	0.448	1.685	10.94	8.96
7.500	0.99850	4.91	3952.0	104.55	1050.04	26.37	0.450	1.682	11.08	9.17
8.000	0.99850	4.91	3952.0	103.11	1050.04	26.76	0.453	1.676	11.21	9.38
8.200	0.99852	4.91	3952.0	102.50	1050.04	26.94	0.454	1.673	11.27	9.46
8.201	0.99852	5.09	3952.0	106.29	1050.04	25.90	0.451	1.714	11.39	9.56
8.700	0.99852	5.09	3952.0	104.55	1050.04	26.37	0.455	1.705	11.55	9.77
9.100	0.99851	5.09	3952.0	102.91	1050.04	26.82	0.459	1.697	11.73	10.00
9.101	0.99851	5.18	3952.0	105.06	1050.04	26.23	0.456	1.719	11.79	10.06
9.459	0.99852	5.18	3952.0	103.53	1050.04	26.65	0.460	1.712	11.97	10.24
9.464	0.99850	5.59	3952.0	106.50	1050.04	25.84	0.456	1.807	11.23	9.78
10.000	0.99852	5.59	3952.0	103.83	1050.04	26.56	0.463	1.797	11.43	9.99
10.250	0.99853	5.59	3952.0	102.60	1050.04	26.91	0.466	1.789	11.47	10.04
10.251	0.99850	5.77	3952.0	106.50	1050.04	25.84	0.462	1.830	11.58	10.14
10.700	0.99858	5.77	3952.0	104.55	1050.04	26.37	0.466	1.818	11.63	10.17
11.000	0.99870	5.77	3952.0	103.53	1050.04	26.65	0.468	1.811	11.67	10.19
11.300	0.99879	5.77	3952.0	102.50	1050.04	26.94	0.469	1.803	11.63	10.13
11.301	0.99879	5.86	3952.0	104.55	1050.04	26.37	0.467	1.822	11.70	10.19
11.800	0.99893	5.86	3952.0	103.01	1050.04	26.79	0.467	1.809	11.44	9.99
11.991	0.99901	5.86	3952.0	102.50	1050.04	26.94	0.467	1.804	11.30	9.88
11.997	0.99902	6.80	3952.0	106.50	1050.04	25.84	0.448	1.764	11.46	10.07
12.500	0.99918	6.80	3952.0	104.86	1050.04	26.28	0.446	1.747	10.85	9.59
13.000	0.99930	6.80	3952.0	103.32	1050.04	26.71	0.442	1.729	10.19	9.05
13.400	0.99948	6.80	3952.0	102.50	1050.04	26.94	0.438	1.715	9.70	8.61
13.401	0.99949	6.89	3952.0	104.45	1050.04	26.39	0.436	1.721	9.76	8.66
13.900	0.99964	6.89	3952.0	103.73	1050.04	26.59	0.429	1.699	9.45	8.41
14.230	0.99973	6.89	3952.0	103.42	1050.04	26.68	0.424	1.679	9.58	8.55
14.523	0.99980	6.89	3952.0	103.53	1050.04	26.65	0.418	1.664	9.72	8.67
14.528	0.99986	5.63	3952.0	102.71	1050.04	26.88	0.438	1.686	9.84	8.43
14.700	0.99989	5.63	3952.0	103.42	1050.04	26.68	0.434	1.683	9.81	8.41
15.100	1.00001	5.63	3952.0	104.55	1050.04	26.37	0.424	1.672	9.57	8.28
15.600	0.99998	5.63	3952.0	106.50	1050.04	25.84	0.412	1.660	9.37	8.41
15.601	0.99998	5.50	3952.0	103.11	1050.04	26.76	0.415	1.632	9.30	8.36
16.025	0.99997	5.50	3952.0	106.50	1050.04	25.84	0.402	1.636	9.46	8.61
16.026	0.99998	5.36	3952.0	103.01	1050.04	26.79	0.406	1.604	9.38	8.54
16.300	0.99997	5.36	3952.0	105.99	1050.04	25.98	0.396	1.615	9.55	8.69
16.301	0.99998	5.23	3952.0	102.50	1050.04	26.94	0.400	1.599	9.76	8.68
16.600	0.99997	5.23	3952.0	106.50	1050.04	25.84	0.389	1.617	9.97	8.87
16.601	0.99996	5.09	3952.0	102.81	1050.04	26.85	0.392	1.579	10.14	9.05

Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
 Fuel Cycle Design

16.835	0.99993	5.09	3952.0	106.50	1050.04	25.84	0.383	1.598	10.27	9.18
16.836	1.00005	4.91	3952.0	102.50	1050.04	26.94	0.387	1.572	10.48	9.45
17.055	0.99997	4.91	3952.0	106.29	1050.04	25.90	0.378	1.593	10.59	9.54
17.059	0.99995	3.11	3952.0	103.53	1050.04	26.65	0.405	1.630	9.75	9.02
17.175	0.99996	3.11	3952.0	106.50	1050.04	25.84	0.399	1.643	9.79	9.06
17.176	0.99997	2.84	3952.0	102.81	1050.04	26.85	0.402	1.633	9.69	8.97
17.375	0.99992	2.84	3952.0	106.60	1050.04	25.82	0.392	1.643	9.77	9.03
17.376	0.99992	2.66	3952.0	102.50	1050.04	26.94	0.395	1.629	9.65	8.93
17.560	0.99991	2.66	3952.0	106.39	1050.04	25.87	0.386	1.639	9.73	8.99
17.561	1.00001	2.48	3952.0	102.50	1050.04	26.94	0.389	1.624	9.62	8.90
17.740	0.99994	2.48	3952.0	106.60	1050.04	25.82	0.380	1.635	9.70	8.95
17.741	1.00004	1.71	3952.0	102.50	1050.04	26.94	0.392	1.634	9.51	8.83
17.900	0.99996	1.71	3952.0	106.60	1050.04	25.82	0.384	1.654	9.59	8.87
17.901	0.99997	1.53	3952.0	102.50	1050.04	26.94	0.388	1.630	9.71	8.83
18.050	0.99999	1.53	3952.0	106.60	1050.04	25.82	0.379	1.655	9.77	8.88
18.051	0.99996	1.35	3952.0	102.91	1050.04	26.82	0.384	1.612	10.64	9.67
18.200	0.99990	1.35	3952.0	107.11	1050.04	25.68	0.375	1.638	10.64	9.66
18.201	1.00006	0.00	3952.0	101.99	1050.04	27.08	0.395	1.629	9.28	8.63
18.390	0.99994	0.00	3952.0	107.62	1050.04	25.55	0.384	1.668	9.38	8.65
18.398	0.99980	0.00	3952.0	102.24	1047.97	29.54	0.384	1.660	9.25	8.53
18.543	0.99990	0.00	3952.0	107.11	1047.97	28.10	0.374	1.690	9.35	8.57
18.550	0.99990	0.00	3952.0	102.50	1046.03	31.84	0.374	1.684	9.24	8.47
18.645	1.00018	0.00	3952.0	106.60	1046.03	30.53	0.366	1.708	9.33	8.52
18.652	0.99997	0.00	3952.0	102.50	1044.65	33.54	0.367	1.701	9.23	8.44
18.826	0.99988	0.00	3952.0	107.62	1044.65	31.83	0.356	1.723	9.34	8.50
18.906	0.99999	0.00	3888.8	107.62	1043.42	31.26	0.352	1.744	9.23	8.39
19.034	1.00012	0.00	3782.1	107.62	1041.36	30.29	0.345	1.781	9.04	8.20
19.501	0.99996	0.00	3414.5	107.62	1034.25	26.98	0.321	1.927	8.49	7.67
19.636	1.00014	0.00	3351.3	107.62	1033.02	26.42	0.317	1.954	8.39	7.57
20.238	1.00042	0.00	2802.0	107.62	1022.40	21.53	0.279	2.261	7.57	6.78

**Table A.2 Browns Ferry Unit 3 Cycle 19 Design Depletion Thermal
Margin Summary**

Cycle Exposure (GWd/MT)	Calculated K-eff	Control Rod Density	Core Limiting CPR	Fraction of Limiting CPR	Core Limiting LHGR (kW/ft)	Fraction of Limiting LHGR	Core Limiting APLHGR (kW/ft)	Fraction of Limiting APLHGR
0.000	0.99996	5.586	1.736	0.824	12.15	0.861	8.96	0.753
0.175	0.99997	5.586	1.748	0.818	11.75	0.833	8.66	0.737
0.176	0.99995	5.405	1.720	0.832	11.66	0.827	8.65	0.730
0.300	0.99993	5.405	1.738	0.823	11.41	0.809	8.46	0.721
0.301	0.99998	5.225	1.704	0.839	11.29	0.801	8.37	0.714
0.575	0.99983	5.225	1.726	0.828	11.15	0.791	8.28	0.709
0.576	0.99987	5.135	1.691	0.846	11.07	0.785	8.23	0.704
1.000	0.99977	5.135	1.700	0.841	10.99	0.779	8.16	0.703
1.500	0.99966	5.135	1.700	0.841	10.87	0.771	8.07	0.701
1.864	0.99960	5.135	1.701	0.841	10.77	0.764	8.00	0.699
1.865	0.99962	4.865	1.702	0.840	11.52	0.817	8.52	0.748
2.300	0.99954	4.865	1.705	0.839	11.37	0.807	8.41	0.744
2.800	0.99947	4.865	1.710	0.836	11.25	0.798	8.31	0.741
3.300	0.99933	4.865	1.711	0.836	11.17	0.792	8.23	0.740
3.800	0.99926	4.865	1.712	0.835	11.11	0.788	8.16	0.740
4.300	0.99913	4.865	1.713	0.835	11.08	0.786	8.10	0.740
4.396	0.99913	4.865	1.713	0.835	11.08	0.786	8.09	0.741
4.398	0.99910	4.910	1.772	0.807	11.02	0.782	8.09	0.724
4.600	0.99906	4.910	1.772	0.807	11.03	0.782	8.08	0.725
5.000	0.99898	4.910	1.772	0.807	11.05	0.784	8.07	0.729
5.500	0.99891	4.910	1.770	0.808	11.08	0.786	7.78	0.735
6.000	0.99881	4.910	1.767	0.809	11.15	0.791	7.80	0.743
6.500	0.99872	4.910	1.761	0.812	11.23	0.796	7.84	0.753
6.928	0.99863	4.910	1.753	0.816	11.31	0.802	7.88	0.762
6.931	0.99862	4.910	1.685	0.848	10.94	0.776	7.81	0.734
7.500	0.99850	4.910	1.682	0.850	11.08	0.786	7.68	0.748
8.000	0.99850	4.910	1.676	0.853	11.21	0.795	7.76	0.762
8.200	0.99852	4.910	1.673	0.855	11.27	0.799	7.79	0.768
8.201	0.99852	5.090	1.714	0.835	11.39	0.808	7.87	0.775
8.700	0.99852	5.090	1.705	0.839	11.55	0.827	7.96	0.791
9.100	0.99851	5.090	1.697	0.843	11.73	0.844	8.04	0.805
9.101	0.99851	5.180	1.719	0.832	11.75	0.849	8.09	0.810
9.459	0.99852	5.180	1.712	0.835	11.97	0.868	8.16	0.822
9.464	0.99850	5.586	1.807	0.791	11.23	0.818	7.63	0.772
10.000	0.99852	5.586	1.797	0.796	11.43	0.838	7.71	0.788
10.250	0.99853	5.586	1.789	0.799	11.47	0.846	7.74	0.795
10.251	0.99850	5.766	1.830	0.781	11.58	0.854	7.83	0.804
10.700	0.99858	5.766	1.818	0.786	11.54	0.859	7.85	0.812
11.000	0.99870	5.766	1.811	0.790	11.52	0.858	7.81	0.812
11.300	0.99879	5.766	1.803	0.793	11.47	0.857	7.77	0.809
11.301	0.99879	5.856	1.822	0.785	11.53	0.862	7.82	0.814
11.800	0.99893	5.856	1.809	0.790	11.44	0.850	7.62	0.801
11.991	0.99901	5.856	1.804	0.793	11.30	0.842	7.53	0.793
11.997	0.99902	6.802	1.764	0.811	11.36	0.863	10.07	0.815
12.500	0.99918	6.802	1.747	0.818	10.85	0.822	9.58	0.782
13.000	0.99930	6.802	1.729	0.833	10.19	0.784	6.99	0.746
13.400	0.99948	6.802	1.715	0.840	9.70	0.753	6.76	0.721
13.401	0.99949	6.892	1.721	0.837	9.76	0.758	6.81	0.726
13.900	0.99964	6.892	1.699	0.848	7.91	0.742	7.10	0.697
14.230	0.99973	6.892	1.679	0.858	8.07	0.756	7.19	0.709
14.523	0.99980	6.892	1.664	0.865	8.18	0.771	7.31	0.720
14.528	0.99986	5.631	1.686	0.854	7.00	0.718	6.62	0.692
14.700	0.99989	5.631	1.683	0.856	7.09	0.719	6.61	0.693
15.100	1.00001	5.631	1.672	0.861	7.38	0.719	6.55	0.691
15.600	0.99998	5.631	1.660	0.868	7.61	0.749	6.93	0.712
15.601	0.99998	5.495	1.632	0.883	7.49	0.745	6.88	0.707
16.025	0.99997	5.495	1.636	0.880	7.69	0.770	7.05	0.729
16.026	0.99998	5.360	1.604	0.898	7.62	0.762	7.00	0.725
16.300	0.99997	5.360	1.615	0.892	7.73	0.777	7.10	0.737
16.301	0.99998	5.225	1.599	0.901	8.17	0.779	7.06	0.734

16.600	0.99997	5.225	1.617	0.891	8.41	0.800	7.16	0.747
16.601	0.99996	5.090	1.579	0.912	8.52	0.814	7.60	0.755
16.835	0.99993	5.090	1.598	0.901	8.59	0.825	7.71	0.768
16.836	1.00005	4.910	1.572	0.916	8.89	0.856	7.93	0.795
17.055	0.99997	4.910	1.593	0.904	9.00	0.870	8.01	0.807
17.059	0.99995	3.108	1.630	0.884	8.02	0.818	7.35	0.774
17.175	0.99996	3.108	1.643	0.876	8.06	0.824	7.38	0.778
17.176	0.99997	2.838	1.633	0.882	7.97	0.816	7.31	0.770
17.375	0.99992	2.838	1.643	0.876	8.04	0.826	7.36	0.778
17.376	0.99992	2.658	1.629	0.884	7.95	0.817	7.28	0.770
17.560	0.99991	2.658	1.639	0.879	8.02	0.827	7.32	0.777
17.561	1.00001	2.477	1.624	0.886	7.93	0.818	7.26	0.770
17.740	0.99994	2.477	1.635	0.881	7.99	0.827	7.29	0.776
17.741	1.00004	1.712	1.634	0.881	7.84	0.811	7.16	0.762
17.900	0.99996	1.712	1.654	0.871	7.89	0.820	7.19	0.767
17.901	0.99997	1.532	1.630	0.884	7.84	0.814	7.17	0.765
18.050	0.99999	1.532	1.655	0.870	7.89	0.822	7.20	0.770
18.051	0.99996	1.351	1.612	0.893	8.78	0.874	9.67	0.799
18.200	0.99990	1.351	1.638	0.879	8.75	0.874	9.66	0.800
18.201	1.00006	0.000	1.629	0.884	7.65	0.800	7.00	0.751
18.390	0.99994	0.000	1.668	0.863	7.71	0.809	7.04	0.757
18.398	0.99980	0.000	1.660	0.868	7.63	0.801	6.96	0.749
18.543	0.99990	0.000	1.690	0.852	7.69	0.810	7.00	0.755
18.550	0.99990	0.000	1.684	0.855	7.62	0.803	6.93	0.748
18.645	1.00018	0.000	1.708	0.843	7.68	0.810	6.97	0.753
18.652	0.99997	0.000	1.701	0.847	7.62	0.804	6.91	0.747
18.826	0.99988	0.000	1.723	0.836	7.69	0.814	6.96	0.754
18.906	0.99999	0.000	1.744	0.826	7.59	0.805	6.86	0.745
19.034	1.00012	0.000	1.781	0.809	7.42	0.789	6.70	0.729
19.501	0.99996	0.000	1.927	0.747	6.81	0.731	6.28	0.670
19.636	1.00014	0.000	1.954	0.737	6.68	0.719	6.19	0.662
20.238	1.00042	0.000	2.261	0.637	6.19	0.642	5.54	0.592

Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design

Revision 1

Page A-6

Cycle:	19	Core Average Exposure: MWd/MTU	13899.8
Exposure: MWd/MTU (GWd)	0.0 (0.00)		
Delta E: MWd/MTU, (GWd)	0.0 (0.00)		
Power: MWt	3952.0 (100.00 %)	Axial Profile	Edit Radial Power
Core Pressure: psia	1050.0	N (PRA)	Power Exposure Zone Avg. Max. IR JR
Inlet Subcooling: Btu/lbm	-26.71	Top 25	0.155 2.763 14 0.482 0.482 35 2
Flow: Mlb/hr	103.32 (100.80 %)	24	0.448 7.994 16 0.425 0.616 9 12
		23	0.583 10.619 17 0.393 0.469 59 36
		22	0.685 12.486 18 0.448 0.506 1 30
		21	0.750 13.539 19 0.874 1.109 13 14
		20	0.793 14.116 20 1.164 1.324 21 22
		19	0.811 14.468 21 1.150 1.282 31 48
		18	0.842 14.821 22 1.167 1.310 21 24
		17	0.872 14.984 23 1.019 1.155 7 28
		16	0.912 15.525 24 0.975 1.110 51 40
		15	0.964 15.982
		14	1.000 15.949
		13	1.145 15.003
		12	1.215 15.292
		11	1.254 15.502
		10	1.283 15.798
		9	1.326 16.230
		8	1.368 16.459
		7	1.421 16.565
		6	1.493 16.986
		5	1.527* 17.042*
		4	1.489 16.515
		3	1.362 15.359
		2	1.031 11.876
		Bottom 1	0.271 3.392
Control Rod Density: %	5.59	% AXIAL TILT	-26.099 -7.358
k-effective:	0.99996	AVG BOT 8ft/12ft	1.1508 1.0457
Void Fraction:	0.480		
Core Delta-P: psia	25.480		
Core Plate Delta-P: psia	20.916		
Coolant Temp: Deg-F	548.6		
In Channel Flow: Mlb/hr	90.76	Active Channel Flow: Mlb/hr	87.46
Total Bypass Flow (%):	12.2	(of total core flow)	
Total Water Rod Flow (%):	3.2	(of total core flow)	
Source Convergence	0.00010		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR					LHGR									
Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K
1.324	20	21	22	1.736	0.824	22	21	38	8.96	0.753	25.7	21	29	14	4	12.15	0.861	0.0	22	29	16	4
1.310	20	19	24	1.738	0.823	22	37	40	8.84	0.748	26.4	21	13	30	4	12.03	0.853	0.0	22	15	32	4
1.310	22	21	24	1.750	0.817	22	29	46	8.92	0.741	24.3	20	29	18	4	11.96	0.848	0.0	22	27	14	4
1.309	22	23	22	1.752	0.816	22	19	36	8.84	0.734	24.2	20	27	16	4	11.85	0.841	0.0	22	13	28	4
1.308	20	37	42	1.754	0.815	22	35	42	8.79	0.728	23.9	20	15	28	4	11.80	0.837	0.0	22	31	50	4
1.306	20	23	24	1.762	0.812	22	15	30	8.56	0.728	26.9	20	21	22	5	11.76	0.834	0.0	22	49	32	4
1.299	20	31	44	1.766	0.810	22	19	40	8.26	0.722	30.1	20	9	30	5	11.72	0.831	0.0	22	23	22	4
1.296	22	31	46	1.767	0.809	22	21	20	8.41	0.721	27.9	20	17	30	5	11.71	0.831	0.0	22	21	24	4
1.290	22	15	30	1.771	0.807	22	23	36	8.23	0.720	30.1	20	29	10	5	11.62	0.824	0.0	22	27	18	4
1.283	22	35	42	1.771	0.807	22	25	38	8.33	0.718	28.3	21	11	28	5	11.62	0.824	0.0	22	21	20	4

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

Figure A.1 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and Axial Distributions at 0.0 MWd/MTU

Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design

Revision 1

Page A-7

Cycle:	19	Core Average Exposure: MWd/MTU	14074.5
Exposure: MWd/MTU (GWd)	175.0 (24.11)		
Delta E: MWd/MTU, (GWd)	175.0 (24.11)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-25.84		
Flow: Mlb/hr	106.50 (103.90 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top	25 0.159 2.793 14 0.483 0.483 35 2
			24 0.461 8.079 16 0.425 0.616 9 12
			23 0.601 10.729 17 0.393 0.470 59 36
			22 0.705 12.616 18 0.448 0.506 1 30
			21 0.771 13.682 19 0.876 1.109 13 14
			20 0.813 14.267 20 1.166 1.327 21 22
			19 0.830 14.622 21 1.152 1.283 31 48
			18 0.861 14.982 22 1.166 1.309 21 24
			17 0.890 15.150 23 1.016 1.152 7 28
			16 0.929 15.696 24 0.973 1.107 51 40
			15 0.980 16.162
			14 1.014 16.136
			13 1.159 15.192
			12 1.227 15.493
			11 1.264 15.709
			10 1.289 16.010
			9 1.327 16.448
			8 1.363 16.684
			7 1.407 16.797
			6 1.470 17.229
			5 1.491* 17.290*
			4 1.440 16.756
			3 1.306 15.579
			2 0.985 12.041
		Bottom	1 0.259 3.438
Control Rod Density: %	5.59		
k-effective:	0.99997		
Void Fraction:	0.471		
Core Delta-P: psia	26.578	% AXIAL TILT	-24.386 -7.505
Core Plate Delta-P: psia	22.013	AVG BOT 8ft/12ft	1.1418 1.0465
Coolant Temp: Deg-F	548.6		
In Channel Flow: Mlb/hr	93.66	Active Channel Flow: Mlb/hr	90.30
Total Bypass Flow (%):	12.1	(of total core flow)	
Total Water Rod Flow (%):	3.2	(of total core flow)	
Source Convergence	0.00009		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR					LHGR									
Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K
1.327	20	21	22	1.748	0.818	22	21	38	8.66	0.737	27.0	21	29	14	5	11.75	0.833	0.4	22	29	16	4
1.313	20	19	24	1.751	0.817	22	37	40	8.58	0.734	27.6	21	13	30	5	11.65	0.826	0.4	22	15	32	5
1.311	20	37	42	1.763	0.811	22	19	36	8.59	0.724	25.9	20	29	18	5	11.58	0.822	0.4	22	33	48	5
1.309	22	21	24	1.766	0.810	22	35	42	8.53	0.718	25.8	20	27	16	5	11.51	0.816	0.4	22	47	34	5
1.308	20	23	24	1.767	0.809	22	29	46	8.40	0.716	27.2	20	21	22	5	11.46	0.813	0.4	22	31	50	5
1.308	22	23	22	1.777	0.805	22	19	40	8.50	0.713	25.5	20	15	28	5	11.43	0.811	0.4	22	23	22	5
1.301	20	31	44	1.779	0.804	22	21	20	8.26	0.710	28.2	20	17	30	5	11.43	0.810	0.4	22	21	24	5
1.294	22	31	46	1.780	0.803	22	15	30	8.09	0.710	30.4	20	9	30	5	11.42	0.810	0.4	22	49	32	5
1.288	22	15	30	1.781	0.803	22	23	36	8.06	0.707	30.4	20	29	10	5	11.33	0.804	0.4	22	21	20	5
1.285	20	33	46	1.782	0.803	22	25	38	8.29	0.705	27.0	20	23	20	5	11.29	0.801	0.4	22	19	22	5

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

Figure A.2 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and Axial Distributions at 175.0 MWd/MTU

Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design

Revision 1

Page A-8

Cycle:	19	Core Average Exposure: MWd/MTU	14075.5
Exposure: MWd/MTU (GWd)	176.0 (24.25)		
Delta E: MWd/MTU, (GWd)	1.0 (0.14)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-26.94		
Flow: Mlb/hr	102.50 (100.00 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top	25 0.162 2.793 14 0.483 0.483 35 2
			24 0.467 8.079 16 0.426 0.616 9 12
			23 0.609 10.730 17 0.394 0.470 59 36
			22 0.717 12.617 18 0.448 0.506 1 30
			21 0.787 13.683 19 0.874 1.108 13 14
			20 0.836 14.268 20 1.167 1.326 39 40
			19 0.862 14.623 21 1.153 1.280 31 48
			18 0.882 14.982 22 1.167 1.307 21 24
			17 0.903 15.151 23 1.014 1.148 7 28
			16 0.935 15.697 24 0.972 1.108 51 40
			15 0.981 16.163
			14 1.011 16.137
			13 1.151 15.193
			12 1.216 15.494
			11 1.250 15.710
			10 1.274 16.011
			9 1.311 16.449
			8 1.347 16.685
			7 1.392 16.798
			6 1.455 17.230
			5 1.479* 17.292*
			4 1.432 16.757
			3 1.302 15.580
			2 0.983 12.042
		Bottom	1 0.258 3.438
Control Rod Density: %	5.41		
k-effective:	0.99995		
Void Fraction:	0.475		
Core Delta-P: psia	25.072	% AXIAL TILT	-23.261 -7.506
Core Plate Delta-P: psia	20.510	AVG BOT 8ft/12ft	1.1339 1.0465
Coolant Temp: Deg-F	548.5		
In Channel Flow: Mlb/hr	90.08	Active Channel Flow: Mlb/hr	86.82
Total Bypass Flow (%):	12.1	(of total core flow)	
Total Water Rod Flow (%):	3.2	(of total core flow)	
Source Convergence	0.00004		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	Value	Margin	Exp.	FT
1.326	20	39	40	1.720	0.832	22	21	8.65	0.730	26.0	21	11.66	0.827	0.4	22
1.313	20	19	24	1.723	0.830	22	37	8.49	0.726	27.6	21	11.55	0.819	0.4	22
1.311	20	37	42	1.736	0.824	22	19	8.61	0.718	24.7	20	11.48	0.814	0.4	22
1.307	22	21	24	1.739	0.822	22	35	8.53	0.711	24.5	20	11.39	0.808	0.4	22
1.306	22	23	22	1.744	0.820	22	19	8.31	0.709	27.2	20	11.34	0.804	0.4	22
1.305	20	23	24	1.745	0.819	22	29	8.41	0.706	25.5	20	11.31	0.802	0.4	22
1.298	20	31	44	1.746	0.819	22	21	8.01	0.703	30.4	20	11.31	0.802	0.4	22
1.292	22	31	46	1.754	0.815	22	23	8.17	0.703	28.2	20	11.31	0.802	0.4	22
1.286	22	15	30	1.754	0.815	22	25	7.99	0.701	30.4	20	11.22	0.796	0.4	22
1.284	20	33	46	1.755	0.815	22	15	8.09	0.698	28.7	21	11.18	0.793	0.4	22

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

Figure A.3 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and Axial Distributions at 176.0 MWd/MTU

Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design

Revision 1

Page A-9

Cycle:	19	Core Average Exposure: MWd/MTU	14199.6
Exposure: MWd/MTU (GWd)	300.0 (41.34)		
Delta E: MWd/MTU, (GWd)	124.0 (17.09)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-25.90		
Flow: Mlb/hr	106.29 (103.70 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top 25	0.165 2.815 14 0.482 0.482 35 2
		24	0.476 8.142 16 0.424 0.614 9 12
		23	0.622 10.811 17 0.393 0.469 59 36
		22	0.730 12.713 18 0.447 0.504 1 30
		21	0.801 13.788 19 0.874 1.109 13 14
		20	0.850 14.380 20 1.168 1.328 39 40
		19	0.875 14.739 21 1.154 1.281 31 48
		18	0.894 15.101 22 1.166 1.307 21 24
		17	0.914 15.272 23 1.014 1.148 7 28
		16	0.946 15.821 24 0.971 1.107 51 40
		15	0.992 16.293
		14	1.020 16.270
		13	1.161 15.327
		12	1.226 15.636
		11	1.259 15.856
		10	1.280 16.160
		9	1.314 16.602
		8	1.346 16.842
		7	1.385 16.960
		6	1.440 17.399
		5	1.453* 17.462*
		4	1.395 16.922
		3	1.259 15.729
		2	0.947 12.155
		Bottom 1	0.249 3.470
Control Rod Density: %	5.41		
k-effective:	0.99993		
Void Fraction:	0.466		
Core Delta-P: psia	26.413	% AXIAL TILT	-22.104 -7.585
Core Plate Delta-P: psia	21.849	AVG BOT 8ft/12ft	1.1278 1.0469
Coolant Temp: Deg-F	548.5		
In Channel Flow: Mlb/hr	93.52	Active Channel Flow: Mlb/hr	90.18
Total Bypass Flow (%):	12.0	(of total core flow)	
Total Water Rod Flow (%):	3.1	(of total core flow)	
Source Convergence	0.00007		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	Value	Margin	Exp.	FT
1.328	20	39	40	1.738	0.823	22	21	8.46	0.721	27.2	21	11.41	0.809	0.8	22
1.314	20	19	24	1.742	0.821	22	37	8.39	0.719	27.8	21	11.35	0.805	0.7	22
1.313	20	37	42	1.753	0.816	22	19	8.39	0.708	26.1	20	11.28	0.800	0.7	22
1.307	22	21	24	1.756	0.814	22	35	8.33	0.703	26.0	20	11.21	0.795	0.7	22
1.306	22	23	22	1.761	0.812	22	19	8.21	0.701	27.4	20	11.17	0.792	0.7	22
1.306	20	23	24	1.763	0.811	22	21	8.30	0.698	25.7	20	11.13	0.789	0.7	22
1.298	20	31	44	1.765	0.810	22	29	8.06	0.695	28.4	20	11.13	0.789	0.7	22
1.292	22	31	46	1.771	0.807	22	23	7.90	0.694	30.7	20	11.13	0.789	0.7	22
1.286	22	15	30	1.771	0.807	22	25	7.87	0.692	30.6	20	11.03	0.782	0.7	22
1.285	20	33	46	1.774	0.806	22	15	7.98	0.690	28.9	21	11.00	0.780	0.7	22

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

Figure A.4 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and Axial Distributions at 300.0 MWd/MTU

Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design

Revision 1

Page A-10

Cycle:	19	Core Average Exposure: MWd/MTU	14200.6
Exposure: MWd/MTU (GWd)	301.0 (41.47)		
Delta E: MWd/MTU, (GWd)	1.0 (0.14)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-26.94		
Flow: Mlb/hr	102.50 (100.00 %)		
		Axial Profile	Edit Radial Power
		N(PRA) Power Exposure	Zone Avg. Max. IR JR
		Top 25	0.166 2.815 14 0.481 0.481 35 2
		24	0.479 8.142 16 0.424 0.614 9 12
		23	0.625 10.812 17 0.393 0.468 59 36
		22	0.736 12.714 18 0.447 0.503 1 30
		21	0.810 13.789 19 0.872 1.107 13 14
		20	0.864 14.381 20 1.169 1.327 39 40
		19	0.897 14.740 21 1.156 1.278 31 48
		18	0.926 15.102 22 1.167 1.304 21 24
		17	0.935 15.273 23 1.011 1.144 53 34
		16	0.959 15.822 24 0.970 1.108 51 40
		15	0.998 16.294
		14	1.021 16.271
		13	1.157 15.329
		12	1.218 15.637
		11	1.248 15.858
		10	1.267 16.161
		9	1.300 16.603
		8	1.331 16.843
		7	1.370 16.961
		6	1.426 17.400
		5	1.440* 17.464*
		4	1.385 16.923
		3	1.252 15.730
		2	0.943 12.155
		Bottom 1	0.248 3.470
Control Rod Density: %	5.23		
k-effective:	0.99998		
Void Fraction:	0.470		
Core Delta-P: psia	24.991	% AXIAL TILT	-21.022 -7.585
Core Plate Delta-P: psia	20.430	AVG BOT 8ft/12ft	1.1212 1.0469
Coolant Temp: Deg-F	548.4		
In Channel Flow: Mlb/hr	90.12	Active Channel Flow: Mlb/hr	86.88
Total Bypass Flow (%):	12.1	(of total core flow)	
Total Water Rod Flow (%):	3.2	(of total core flow)	
Source Convergence	0.00010		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR					LHGR									
Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K
1.327	20	39	40	1.704	0.839	22	21	38	8.37	0.714	27.2	21	29	14	5	11.29	0.801	0.8	22	31	16	5
1.315	20	19	24	1.708	0.837	22	37	40	8.30	0.711	27.8	21	13	30	5	11.23	0.796	0.7	22	15	32	5
1.313	20	37	42	1.722	0.831	22	19	36	8.30	0.701	26.1	20	29	18	5	11.16	0.792	0.7	22	33	48	5
1.304	22	21	24	1.723	0.830	22	19	40	8.25	0.695	26.0	20	27	16	5	11.09	0.787	0.7	22	47	34	5
1.304	22	23	22	1.725	0.829	22	35	42	8.12	0.693	27.4	20	21	22	5	11.05	0.784	0.7	22	31	50	5
1.302	20	23	24	1.726	0.829	22	21	42	8.21	0.691	25.7	20	15	28	5	11.02	0.781	0.7	22	49	32	5
1.295	20	31	44	1.734	0.824	22	29	46	7.82	0.688	30.7	20	9	30	5	11.01	0.781	0.7	22	23	22	5
1.289	22	31	46	1.744	0.820	22	15	30	7.98	0.687	28.4	20	17	30	5	11.01	0.781	0.7	22	21	24	5
1.284	20	33	46	1.747	0.818	22	23	36	7.80	0.685	30.6	20	29	10	5	10.92	0.774	0.7	22	21	20	5
1.283	22	15	30	1.748	0.818	22	25	38	7.90	0.683	28.9	21	11	28	5	10.88	0.772	0.7	22	19	22	5

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

Figure A.5 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and Axial Distributions at 301.0 MWd/MTU

Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design

Revision 1

Page A-11

Cycle:	19	Core Average Exposure: MWd/MTU	14474.5
Exposure: MWd/MTU (GWd)	575.0 (79.23)		
Delta E: MWd/MTU, (GWd)	274.0 (37.75)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-25.84		
Flow: Mlb/hr	106.50 (103.90 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top	25 0.169 2.864 14 0.478 0.478 35 2
			24 0.488 8.284 16 0.422 0.612 9 12
			23 0.636 10.997 17 0.390 0.465 59 36
			22 0.748 12.933 18 0.444 0.501 1 30
			21 0.822 14.029 19 0.871 1.109 13 14
			20 0.876 14.637 20 1.170 1.328 39 40
			19 0.907 15.006 21 1.157 1.279 31 48
			18 0.936 15.376 22 1.168 1.305 21 24
			17 0.944 15.550 23 1.011 1.145 53 34
			16 0.967 16.102 24 0.970 1.109 51 40
			15 1.006 16.586
			14 1.028 16.569
			13 1.165 15.627
			12 1.226 15.951
			11 1.255 16.179
			10 1.274 16.488
			9 1.304 16.938
			8 1.332 17.186
			7 1.365 17.313
			6 1.414 17.766
			5 1.418* 17.832*
			4 1.352 17.275
			3 1.214 16.047
			2 0.911 12.394
		Bottom	1 0.241 3.536
			% AXIAL TILT -20.055 -7.714
			AVG BOT 8ft/12ft 1.1160 1.0475
Control Rod Density: %	5.23		
k-effective:	0.99983		
Void Fraction:	0.461		
Core Delta-P: psia	26.413		
Core Plate Delta-P: psia	21.850		
Coolant Temp: Deg-F	548.5		
In Channel Flow: Mlb/hr	93.74	Active Channel Flow: Mlb/hr	90.42
Total Bypass Flow (%):	12.0	(of total core flow)	
Total Water Rod Flow (%):	3.1	(of total core flow)	
Source Convergence	0.00006		

Top Ten Thermal Limits Summary - Sorted by Margin

Power			MCPR			APLHGR					LHGR				
Value	FT	IR JR	Value	Margin	FT	IR JR	Value	Margin	Exp.	FT	IR JR	K	Value	Margin	Exp.
1.328	20	39 40	1.726	0.828	22	21 38	8.28	0.709	27.7	21	29 14	5	11.15	0.791	1.4 22
1.317	20	19 24	1.731	0.826	22	37 40	8.20	0.706	28.3	21	13 30	5	11.08	0.786	1.4 22
1.315	20	37 42	1.742	0.821	22	19 36	8.20	0.695	26.6	20	29 18	5	11.01	0.781	1.4 22
1.305	22	21 24	1.744	0.820	22	19 40	8.15	0.690	26.5	20	27 16	5	10.94	0.776	1.4 22
1.305	22	37 40	1.747	0.819	22	21 42	8.02	0.688	27.9	20	21 22	5	10.92	0.775	1.4 22
1.303	20	23 24	1.747	0.819	22	35 42	8.11	0.685	26.2	20	15 28	5	10.89	0.772	1.4 22
1.296	20	31 44	1.757	0.814	22	29 46	7.73	0.682	31.1	20	9 30	5	10.86	0.770	1.4 22
1.291	22	31 46	1.767	0.809	22	15 30	7.88	0.682	28.9	20	17 30	5	10.85	0.770	1.4 22
1.285	20	33 46	1.769	0.808	22	23 36	7.70	0.680	31.1	20	29 10	5	10.76	0.763	1.4 22
1.285	22	15 30	1.769	0.808	22	25 38	7.81	0.678	29.3	21	11 28	5	10.72	0.760	1.4 22

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

Figure A.6 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and Axial Distributions at 575.0 MWd/MTU

Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design

Revision 1

Page A-12

Cycle:	19	Core Average Exposure: MWd/MTU	14475.5
Exposure: MWd/MTU (GWd)	576.0 (79.36)		
Delta E: MWd/MTU, (GWd)	1.0 (0.14)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-26.48		
Flow: Mlb/hr	104.14 (101.60 %)		
		Axial Profile	Edit Radial Power
		N(PRA) Power Exposure	Zone Avg. Max. IR JR
		Top 25 0.172 2.864	14 0.477 0.477 35 2
		24 0.494 8.284	16 0.421 0.610 9 12
		23 0.645 10.997	17 0.389 0.464 59 36
		22 0.759 12.934	18 0.443 0.499 1 30
		21 0.837 14.030	19 0.867 1.104 13 14
		20 0.896 14.638	20 1.173 1.331 39 40
		19 0.921 15.007	21 1.159 1.277 31 48
		18 0.945 15.377	22 1.170 1.310 21 24
		17 0.949 15.551	23 1.006 1.140 53 34
		16 0.969 16.103	24 0.965 1.105 51 40
		15 1.005 16.587	
		14 1.025 16.571	
		13 1.160 15.628	
		12 1.218 15.953	
		11 1.246 16.181	
		10 1.264 16.489	
		9 1.295 16.940	
		8 1.322 17.187	
		7 1.356 17.315	
		6 1.405 17.767	
		5 1.411* 17.833*	
		4 1.347 17.277	
		3 1.210 16.048	
		2 0.909 12.395	
		Bottom 1 0.240 3.536	
Control Rod Density: %	5.14		
k-effective:	0.99987		
Void Fraction:	0.463		
Core Delta-P: psia	25.520	% AXIAL TILT	-19.318 -7.715
Core Plate Delta-P: psia	20.958	AVG BOT 8ft/12ft	1.1105 1.0475
Coolant Temp: Deg-F	548.4		
In Channel Flow: Mlb/hr	91.63	Active Channel Flow: Mlb/hr	88.36
Total Bypass Flow (%):	12.0	(of total core flow)	
Total Water Rod Flow (%):	3.1	(of total core flow)	
Source Convergence	0.00007		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR					LHGR									
Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K
1.331	20	39	40	1.691	0.846	22	21	38	8.23	0.704	27.7	21	29	14	5	11.07	0.785	1.4	22	31	16	5
1.319	20	19	24	1.694	0.844	22	37	40	8.15	0.702	28.3	21	13	30	5	11.01	0.781	1.4	22	15	32	5
1.317	20	37	42	1.707	0.838	22	19	36	8.15	0.691	26.6	20	29	18	5	10.94	0.776	1.4	22	33	48	5
1.310	22	21	24	1.710	0.836	22	35	42	8.09	0.685	26.5	20	27	16	5	10.87	0.771	1.4	22	13	28	5
1.310	20	23	24	1.720	0.832	22	19	40	7.97	0.683	27.9	20	21	22	5	10.86	0.770	1.4	22	31	50	5
1.309	22	37	40	1.721	0.831	22	23	36	8.06	0.681	26.2	20	15	28	5	10.82	0.767	1.4	22	49	32	5
1.301	20	31	44	1.721	0.831	22	25	38	7.68	0.678	31.1	20	9	30	5	10.78	0.765	1.4	22	23	22	5
1.291	22	31	46	1.722	0.830	22	21	42	7.83	0.677	28.9	20	17	30	5	10.78	0.765	1.4	22	21	24	5
1.286	20	33	46	1.738	0.823	22	29	46	7.66	0.676	31.1	20	29	10	5	10.69	0.758	1.4	22	21	20	5
1.285	22	15	30	1.742	0.821	22	45	30	7.76	0.674	29.3	21	11	28	5	10.65	0.756	1.4	22	19	22	5

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

Figure A.7 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and Axial Distributions at 576.0 MWd/MTU

Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design

Revision 1

Page A-13

Cycle:	19	Core Average Exposure: MWd/MTU	14899.5
Exposure: MWd/MTU (GWd)	1000.0 (137.79)		
Delta E: MWd/MTU, (GWd)	424.0 (58.42)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-26.03		
Flow: Mlb/hr	105.78 (103.20 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top	25 0.175 2.943 14 0.473 0.473 35 2
			24 0.500 8.510 16 0.418 0.607 9 12
			23 0.652 11.291 17 0.386 0.460 59 36
			22 0.765 13.281 18 0.440 0.496 1 30
			21 0.842 14.413 19 0.864 1.103 13 14
			20 0.900 15.047 20 1.171 1.328 39 40
			19 0.925 15.428 21 1.157 1.274 31 48
			18 0.949 15.809 22 1.174 1.314 21 24
			17 0.952 15.984 23 1.008 1.144 53 34
			16 0.971 16.540 24 0.967 1.110 51 40
			15 1.007 17.039
			14 1.027 17.032
			13 1.161 16.090
			12 1.220 16.438
			11 1.248 16.677
			10 1.267 16.993
			9 1.297 17.456
			8 1.323 17.714
			7 1.355 17.854
			6 1.400 18.326
			5 1.401* 18.393*
			4 1.332 17.810
			3 1.193 16.527
			2 0.896 12.754
		Bottom	1 0.239 3.637
Control Rod Density: %	5.14		
k-effective:	0.99977		
Void Fraction:	0.459		
Core Delta-P: psia	26.106	% AXIAL TILT	-18.907 -7.864
Core Plate Delta-P: psia	21.543	AVG BOT 8ft/12ft	1.1081 1.0482
Coolant Temp: Deg-F	548.4		
In Channel Flow: Mlb/hr	93.12	Active Channel Flow: Mlb/hr	89.82
Total Bypass Flow (%):	12.0	(of total core flow)	
Total Water Rod Flow (%):	3.1	(of total core flow)	
Source Convergence	0.00009		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR					LHGR									
Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K
1.328	20	39	40	1.700	0.841	22	21	38	8.16	0.703	28.5	21	29	14	5	10.99	0.779	2.4	22	29	16	5
1.316	20	19	24	1.704	0.839	22	37	40	8.08	0.700	29.1	21	13	30	5	10.92	0.775	2.4	22	15	32	5
1.315	20	37	42	1.716	0.834	22	19	36	8.07	0.688	27.3	20	29	18	5	10.86	0.770	2.4	22	33	48	5
1.314	22	21	24	1.719	0.832	22	35	42	8.02	0.683	27.2	20	27	16	5	10.80	0.766	2.4	22	31	50	5
1.313	22	37	40	1.728	0.827	22	19	40	7.89	0.681	28.6	20	21	22	5	10.79	0.765	2.4	22	13	28	5
1.306	20	23	24	1.731	0.826	22	21	42	7.99	0.679	26.9	20	15	28	5	10.76	0.763	2.4	22	49	32	5
1.298	20	31	44	1.731	0.826	22	23	36	7.63	0.678	31.8	20	9	30	5	10.69	0.758	2.3	22	23	22	5
1.295	22	31	46	1.731	0.826	22	25	38	7.76	0.675	29.6	20	17	30	5	10.69	0.758	2.3	22	21	24	5
1.289	22	15	30	1.748	0.818	22	29	46	7.60	0.675	31.7	20	29	10	5	10.60	0.751	2.3	22	21	20	5
1.288	22	35	42	1.752	0.816	22	45	30	7.70	0.673	30.0	21	11	28	5	10.58	0.751	2.3	22	9	28	5

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

Figure A.8 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and Axial Distributions at 1,000.0 MWd/MTU

Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design

Revision 1

Page A-14

Cycle:	19	Core Average Exposure: MWd/MTU	15399.6
Exposure: MWd/MTU (GWd)	1500.0 (206.68)		
Delta E: MWd/MTU, (GWd)	500.0 (68.89)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-26.03		
Flow: Mlb/hr	105.78 (103.20 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top	25 0.179 3.038 14 0.469 0.469 35 2
			24 0.507 8.779 16 0.415 0.605 9 12
			23 0.659 11.641 17 0.383 0.456 59 36
			22 0.772 13.694 18 0.437 0.493 1 30
			21 0.848 14.867 19 0.861 1.101 13 14
			20 0.905 15.533 20 1.168 1.322 39 40
			19 0.929 15.926 21 1.154 1.270 31 48
			18 0.952 16.320 22 1.178 1.317 21 24
			17 0.955 16.497 23 1.011 1.148 53 34
			16 0.974 17.056 24 0.971 1.117 51 40
			15 1.009 17.574
			14 1.028 17.577
			13 1.161 16.635
			12 1.220 17.011
			11 1.248 17.263
			10 1.267 17.588
			9 1.297 18.065
			8 1.322 18.336
			7 1.352 18.490
			6 1.395* 18.982
			5 1.393 19.049*
			4 1.321 18.433
			3 1.181 17.084
			2 0.888 13.172
		Bottom	1 0.239 3.756
Control Rod Density: %	5.14		
k-effective:	0.99966		
Void Fraction:	0.458		
Core Delta-P: psia	26.090	% AXIAL TILT	-18.471 -8.015
Core Plate Delta-P: psia	21.528	AVG BOT 8ft/12ft	1.1055 1.0489
Coolant Temp: Deg-F	548.4		
In Channel Flow: Mlb/hr	93.13	Active Channel Flow: Mlb/hr	89.83
Total Bypass Flow (%):	12.0	(of total core flow)	
Total Water Rod Flow (%):	3.1	(of total core flow)	
Source Convergence	0.00007		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR							LHGR							
Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K
1.322	20	39	40	1.700	0.841	22	21	38	8.07	0.701	29.3	21	29	14	5	10.87	0.771	3.6	22	29	16	5
1.317	22	21	24	1.704	0.839	22	37	40	8.00	0.698	29.9	21	13	30	5	10.81	0.767	3.6	22	15	32	5
1.316	22	37	40	1.716	0.833	22	19	36	7.97	0.685	28.1	20	29	18	5	10.74	0.762	3.5	22	33	48	5
1.312	20	19	24	1.720	0.832	22	35	42	7.92	0.680	28.0	20	27	16	5	10.73	0.761	3.5	22	31	50	5
1.310	20	37	42	1.728	0.827	22	19	40	7.79	0.678	29.4	20	21	22	5	10.69	0.758	3.5	22	49	32	5
1.300	20	23	24	1.731	0.826	22	21	42	7.56	0.677	32.6	20	9	30	5	10.67	0.757	3.5	22	13	28	5
1.299	22	31	46	1.733	0.825	22	23	36	7.89	0.676	27.8	20	15	28	5	10.57	0.749	3.5	22	23	22	5
1.293	22	15	30	1.733	0.825	22	25	38	7.53	0.674	32.6	20	29	10	5	10.56	0.749	3.5	22	21	24	5
1.293	20	31	44	1.750	0.817	22	29	46	7.66	0.672	30.4	20	17	30	5	10.50	0.745	3.5	22	9	28	5
1.292	22	35	42	1.751	0.817	22	45	30	7.63	0.672	30.8	21	11	28	5	10.48	0.743	3.4	22	21	20	5

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

Figure A.9 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and Axial Distributions at 1,500.0 MWd/MTU

Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design

Revision 1

Page A-15

Cycle:	19	Core Average Exposure: MWd/MTU	15763.5
Exposure: MWd/MTU (GWd)	1864.0 (256.84)		
Delta E: MWd/MTU, (GWd)	364.0 (50.16)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-26.03		
Flow: Mlb/hr	105.78 (103.20 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top	25 0.182 3.108 14 0.466 0.466 35 2
			24 0.513 8.977 16 0.413 0.603 9 12
			23 0.666 11.899 17 0.381 0.453 59 36
			22 0.778 13.997 18 0.434 0.491 1 30
			21 0.853 15.199 19 0.859 1.100 13 14
			20 0.910 15.888 20 1.165 1.318 39 40
			19 0.933 16.291 21 1.151 1.266 31 48
			18 0.956 16.694 22 1.180 1.318 21 24
			17 0.959 16.872 23 1.014 1.151 53 34
			16 0.977 17.433 24 0.974 1.123 51 40
			15 1.011 17.964
			14 1.029 17.975
			13 1.161 17.032
			12 1.219 17.427
			11 1.247 17.690
			10 1.266 18.021
			9 1.295 18.508
			8 1.320 18.787
			7 1.348 18.951
			6 1.389* 19.458
			5 1.385 19.524*
			4 1.312 18.883
			3 1.172 17.486
			2 0.881 13.474
		Bottom	1 0.239 3.842
Control Rod Density: %	5.14		
k-effective:	0.99960		
Void Fraction:	0.457		
Core Delta-P: psia	26.076	% AXIAL TILT	-18.058 -8.109
Core Plate Delta-P: psia	21.513	AVG BOT 8ft/12ft	1.1030 1.0493
Coolant Temp: Deg-F	548.4		
In Channel Flow: Mlb/hr	93.14	Active Channel Flow: Mlb/hr	89.84
Total Bypass Flow (%):	12.0	(of total core flow)	
Total Water Rod Flow (%):	3.1	(of total core flow)	
Source Convergence	0.00007		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR					LHGR									
Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K
1.318	22	21	24	1.701	0.841	22	21	38	8.00	0.699	29.9	21	29	14	5	10.77	0.764	4.4	22	29	16	5
1.318	20	39	40	1.705	0.839	22	37	40	7.93	0.696	30.5	21	13	30	5	10.71	0.760	4.4	22	15	32	5
1.318	22	37	40	1.716	0.833	22	19	36	7.89	0.681	28.8	20	29	18	5	10.66	0.756	4.3	22	31	50	5
1.308	20	19	24	1.720	0.832	22	35	42	7.85	0.677	28.6	20	27	16	5	10.65	0.755	4.4	22	33	48	5
1.306	20	37	42	1.728	0.827	22	19	40	7.50	0.675	33.2	20	9	30	5	10.62	0.753	4.3	22	49	32	5
1.301	22	31	46	1.731	0.826	22	21	42	7.72	0.675	30.0	20	21	22	5	10.58	0.750	4.3	22	13	28	5
1.295	20	23	24	1.734	0.825	22	23	36	7.82	0.673	28.4	20	15	28	5	10.47	0.742	4.3	22	23	22	5
1.295	22	15	30	1.734	0.825	22	25	38	7.48	0.673	33.1	20	29	10	5	10.46	0.742	4.3	22	21	24	5
1.293	22	35	42	1.749	0.818	22	29	46	7.57	0.670	31.4	21	11	28	5	10.43	0.739	4.3	23	7	26	5
1.293	22	39	42	1.750	0.817	22	45	30	7.59	0.669	31.0	20	17	30	5	10.43	0.739	4.3	22	9	28	5

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

Figure A.10 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and Axial Distributions at 1,864.0 MWd/MTU

Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design

Revision 1

Page A-16

Cycle:	19	Core Average Exposure: MWd/MTU	15764.7
Exposure: MWd/MTU (GWd)	1865.2 (257.00)		
Delta E: MWd/MTU, (GWd)	1.2 (0.16)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-26.65		
Flow: Mlb/hr	103.53 (101.00 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top	25 0.175 3.108 14 0.467 0.467 35 2
			24 0.493 8.977 16 0.424 0.621 9 12
			23 0.640 11.900 17 0.390 0.467 59 36
			22 0.746 13.997 18 0.442 0.505 1 30
			21 0.815 15.200 19 0.877 1.134 47 48
			20 0.865 15.889 20 1.145 1.327 45 34
			19 0.894 16.292 21 1.147 1.311 47 32
			18 0.920 16.695 22 1.164 1.338 47 34
			17 0.940 16.873 23 1.046 1.197 53 34
			16 0.963 17.434 24 1.011 1.213 51 40
			15 1.002 17.966
			14 1.025 17.976
			13 1.160 17.034
			12 1.221 17.429
			11 1.252 17.691
			10 1.274 18.023
			9 1.308 18.509
			8 1.336 18.789
			7 1.369 18.953
			6 1.416 19.460
			5 1.421* 19.525*
			4 1.358 18.885
			3 1.226 17.487
			2 0.929 13.475
		Bottom	1 0.252 3.842
Control Rod Density: %	4.86		
k-effective:	0.99962		
Void Fraction:	0.466		
Core Delta-P: psia	25.338	% AXIAL TILT	-20.484 -8.109
Core Plate Delta-P: psia	20.778	AVG BOT 8ft/12ft	1.1185 1.0493
Coolant Temp: Deg-F	548.4		
In Channel Flow: Mlb/hr	91.06	Active Channel Flow: Mlb/hr	87.80
Total Bypass Flow (%):	12.0	(of total core flow)	
Total Water Rod Flow (%):	3.2	(of total core flow)	
Source Convergence	0.00009		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR					LHGR									
Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K
1.338	22	47	34	1.702	0.840	22	45	30	8.52	0.748	30.5	21	13	30	5	11.52	0.817	4.4	22	15	32	5
1.336	22	45	32	1.704	0.839	22	47	28	8.39	0.740	31.0	20	13	26	5	11.52	0.817	4.2	22	47	34	5
1.331	22	45	36	1.706	0.838	22	45	26	8.32	0.737	31.4	21	11	28	5	11.49	0.815	4.2	22	11	26	5
1.327	20	45	34	1.713	0.835	22	49	30	8.14	0.733	33.3	20	11	24	5	11.46	0.813	2.4	22	13	24	5
1.314	22	47	38	1.730	0.826	22	45	22	8.48	0.730	28.4	20	15	28	5	11.45	0.812	3.8	22	15	26	5
1.312	22	49	32	1.737	0.823	22	47	38	8.18	0.728	32.0	21	13	22	5	11.45	0.812	4.3	22	49	32	5
1.312	20	45	38	1.743	0.820	22	43	28	8.05	0.725	33.2	20	9	30	5	11.37	0.806	3.6	22	49	40	5
1.311	21	47	32	1.746	0.819	22	49	36	8.10	0.721	32.0	21	9	26	5	11.36	0.806	4.1	22	9	24	5
1.308	22	45	40	1.748	0.818	22	43	24	8.31	0.720	29.1	20	15	24	5	11.36	0.806	2.4	22	15	22	5
1.307	20	47	36	1.772	0.807	23	9	20	8.04	0.717	32.2	20	11	20	5	11.33	0.804	4.3	22	9	28	5

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

Figure A.11 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and Axial Distributions at 1,865.2 MWd/MTU

Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design

Revision 1

Page A-17

Cycle:	19	Core Average Exposure: MWd/MTU	16199.5
Exposure: MWd/MTU (GWd)	2300.0 (316.91)		
Delta E: MWd/MTU, (GWd)	434.8 (59.91)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-26.59		
Flow: Mlb/hr	103.73 (101.20 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top	25 0.179 3.191 14 0.463 0.463 35 2
			24 0.502 9.209 16 0.421 0.619 9 12
			23 0.650 12.200 17 0.387 0.463 59 36
			22 0.755 14.348 18 0.439 0.502 1 30
			21 0.823 15.583 19 0.874 1.132 47 48
			20 0.873 16.295 20 1.143 1.322 45 34
			19 0.901 16.712 21 1.144 1.305 47 32
			18 0.926 17.127 22 1.167 1.340 47 34
			17 0.945 17.314 23 1.049 1.200 53 34
			16 0.968 17.879 24 1.014 1.218 51 40
			15 1.006 18.429
			14 1.027 18.450
			13 1.161 17.507
			12 1.220 17.927
			11 1.250 18.202
			10 1.273 18.543
			9 1.305 19.043
			8 1.333 19.334
			7 1.364 19.511
			6 1.408 20.036
			5 1.409* 20.103*
			4 1.344 19.436
			3 1.210 17.985
			2 0.917 13.852
		Bottom	1 0.251 3.951
			% AXIAL TILT -19.840 -8.268
			AVG BOT 8ft/12ft 1.1147 1.0500
Control Rod Density: %	4.86		
k-effective:	0.99954		
Void Fraction:	0.463		
Core Delta-P: psia	25.389		
Core Plate Delta-P: psia	20.829		
Coolant Temp: Deg-F	548.4		
In Channel Flow: Mlb/hr	91.26	Active Channel Flow: Mlb/hr	87.99
Total Bypass Flow (%):	12.0	(of total core flow)	
Total Water Rod Flow (%):	3.1	(of total core flow)	
Source Convergence	0.00007		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR							LHGR							
Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K
1.340	22	47	34	1.705	0.839	22	45	30	8.41	0.744	31.3	21	13	30	5	11.37	0.807	5.3	22	47	34	5
1.338	22	45	32	1.707	0.838	22	47	28	8.28	0.736	31.7	20	13	26	5	11.37	0.806	5.5	22	15	32	5
1.333	22	45	36	1.710	0.836	22	45	26	8.22	0.733	32.2	21	11	28	5	11.35	0.805	5.2	22	11	26	5
1.322	20	45	34	1.715	0.834	22	49	30	8.06	0.731	34.0	20	11	24	5	11.34	0.804	5.4	22	49	32	5
1.316	22	47	38	1.731	0.826	22	45	22	8.36	0.725	29.2	20	15	28	5	11.32	0.803	3.5	22	13	24	5
1.314	22	49	32	1.741	0.822	22	47	38	8.08	0.724	32.7	21	13	22	5	11.30	0.802	4.8	22	15	26	5
1.310	22	45	40	1.746	0.819	22	43	28	7.97	0.722	33.9	20	9	30	5	11.25	0.798	4.6	22	49	40	5
1.306	20	45	38	1.748	0.818	22	49	36	8.02	0.718	32.8	21	9	26	5	11.25	0.798	5.1	22	9	24	5
1.305	21	47	32	1.751	0.817	22	43	24	8.19	0.715	29.9	20	15	24	5	11.23	0.796	3.4	22	15	22	5
1.303	22	49	36	1.776	0.805	22	19	40	7.97	0.715	32.9	20	11	20	5	11.22	0.796	5.3	23	7	26	5

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

Figure A.12 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and Axial Distributions at 2,300.0 MWd/MTU

Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design

Revision 1

Page A-18

Cycle:	19	Core Average Exposure: MWd/MTU	16699.5
Exposure: MWd/MTU (GWd)	2800.0 (385.80)		
Delta E: MWd/MTU, (GWd)	500.0 (68.89)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-26.45		
Flow: Mlb/hr	104.24 (101.70 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top	25 0.184 3.288 14 0.460 0.460 35 2
			24 0.511 9.479 16 0.418 0.616 9 12
			23 0.661 12.550 17 0.384 0.459 59 36
			22 0.765 14.756 18 0.436 0.499 1 30
			21 0.833 16.028 19 0.871 1.131 47 48
			20 0.881 16.767 20 1.140 1.316 45 34
			19 0.908 17.198 21 1.141 1.300 47 32
			18 0.933 17.627 22 1.171 1.343 47 34
			17 0.951 17.824 23 1.052 1.204 53 34
			16 0.972 18.394 24 1.018 1.225 51 40
			15 1.009 18.963
			14 1.028 18.995
			13 1.160 18.052
			12 1.218 18.499
			11 1.247 18.788
			10 1.270 19.140
			9 1.302 19.655
			8 1.329 19.959
			7 1.358 20.150
			6 1.400* 20.696
			5 1.398 20.763*
			4 1.330 20.064
			3 1.196 18.549
			2 0.906 14.280
		Bottom	1 0.249 4.075
			% AXIAL TILT -19.162 -8.420
			AVG BOT 8ft/12ft 1.1105 1.0508
Control Rod Density: %	4.86		
k-effective:	0.99947		
Void Fraction:	0.461		
Core Delta-P: psia	25.552		
Core Plate Delta-P: psia	20.992		
Coolant Temp: Deg-F	548.4		
In Channel Flow: Mlb/hr	91.73	Active Channel Flow: Mlb/hr	88.46
Total Bypass Flow (%):	12.0	(of total core flow)	
Total Water Rod Flow (%):	3.1	(of total core flow)	
Source Convergence	0.00006		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	IR	JR	K	Value
1.343	22	47	34	1.710	0.836	22	45	8.31	0.741	32.2	21	13	30	5	11.25
1.340	22	45	32	1.711	0.836	22	47	8.19	0.734	32.6	20	13	26	5	11.25
1.336	22	45	36	1.715	0.834	22	45	8.14	0.732	33.1	21	11	28	5	11.23
1.321	22	47	38	1.718	0.832	22	49	7.99	0.731	34.9	20	11	24	5	11.23
1.318	22	49	32	1.736	0.824	22	45	8.01	0.723	33.6	21	13	22	5	11.22
1.316	20	45	34	1.746	0.819	22	47	8.26	0.722	30.0	20	15	28	5	11.17
1.313	22	45	40	1.750	0.817	22	49	7.89	0.721	34.8	20	9	30	5	11.16
1.307	22	49	36	1.752	0.816	22	43	7.96	0.719	33.6	21	9	26	5	11.16
1.304	22	43	34	1.756	0.814	22	43	7.92	0.716	33.8	20	11	20	5	11.15
1.302	22	43	24	1.777	0.805	22	19	8.10	0.712	30.8	20	15	24	5	11.13

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

Figure A.13 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and Axial Distributions at 2,800.0 MWd/MTU

Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design

Revision 1

Page A-19

Cycle:	19	Core Average Exposure: MWd/MTU	17199.5
Exposure: MWd/MTU (GWd)	3300.0 (454.69)		
Delta E: MWd/MTU, (GWd)	500.0 (68.89)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-26.37		
Flow: Mlb/hr	104.55 (102.00 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top 25	0.188 3.387 14 0.456 0.456 35 2
		24	0.521 9.755 16 0.416 0.614 9 12
		23	0.672 12.906 17 0.381 0.456 59 36
		22	0.774 15.170 18 0.433 0.496 1 30
		21	0.841 16.478 19 0.868 1.129 47 48
		20	0.889 17.243 20 1.136 1.310 45 34
		19	0.915 17.688 21 1.137 1.295 47 32
		18	0.939 18.131 22 1.174 1.347 47 34
		17	0.955 18.337 23 1.056 1.208 53 34
		16	0.976 18.911 24 1.022 1.233 51 40
		15	1.011 19.499
		14	1.028 19.540
		13	1.158 18.596
		12	1.214 19.070
		11	1.243 19.373
		10	1.266 19.736
		9	1.299 20.266
		8	1.325 20.582
		7	1.353 20.787
		6	1.394* 21.352
		5	1.390 21.417*
		4	1.319 20.686
		3	1.184 19.108
		2	0.897 14.703
		Bottom 1	0.248 4.198
Control Rod Density: %	4.86		
k-effective:	0.99933		
Void Fraction:	0.459		
Core Delta-P: psia	25.643	% AXIAL TILT	-18.556 -8.545
Core Plate Delta-P: psia	21.083	AVG BOT 8ft/12ft	1.1067 1.0514
Coolant Temp: Deg-F	548.4		
In Channel Flow: Mlb/hr	92.02	Active Channel Flow: Mlb/hr	88.75
Total Bypass Flow (%):	12.0	(of total core flow)	
Total Water Rod Flow (%):	3.1	(of total core flow)	
Source Convergence	0.00010		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR							LHGR							
Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K
1.347	22	47	34	1.711	0.836	22	45	30	8.23	0.740	33.1	21	13	30	5	11.17	0.792	7.8	22	49	32	5
1.343	22	45	32	1.714	0.834	22	47	28	8.12	0.733	33.5	20	13	26	5	11.16	0.792	7.8	22	47	34	5
1.339	22	45	36	1.715	0.834	22	45	26	8.08	0.732	33.9	21	11	28	5	11.13	0.789	7.6	22	11	26	5
1.325	22	47	38	1.720	0.831	22	49	30	7.94	0.732	35.7	20	11	24	5	11.13	0.789	5.8	22	13	24	5
1.322	22	49	32	1.739	0.822	22	45	22	7.94	0.723	34.4	21	13	22	5	11.10	0.787	7.8	22	15	32	5
1.317	22	45	40	1.748	0.818	22	47	38	7.83	0.721	35.6	20	9	30	5	11.10	0.787	7.7	23	7	26	5
1.312	22	49	36	1.751	0.817	22	49	36	7.91	0.720	34.4	21	9	26	5	11.10	0.787	7.5	23	9	20	5
1.310	20	45	34	1.757	0.814	22	43	28	8.17	0.720	30.9	20	15	28	5	11.09	0.787	7.5	22	9	24	5
1.306	22	43	34	1.761	0.812	22	43	24	7.88	0.718	34.6	20	11	20	5	11.08	0.786	7.0	22	49	40	5
1.305	22	43	24	1.779	0.804	22	19	40	8.10	0.712	30.6	20	13	18	5	11.06	0.784	7.2	22	15	26	5

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

Figure A.14 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and Axial Distributions at 3,300.0 MWd/MTU

Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design

Revision 1

Page A-20

Cycle:	19	Core Average Exposure: MWd/MTU	17699.5
Exposure: MWd/MTU (GWd)	3800.0 (523.59)		
Delta E: MWd/MTU, (GWd)	500.0 (68.89)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-26.23		
Flow: Mlb/hr	105.06 (102.50 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top	25 0.192 3.489 14 0.452 0.452 35 2
			24 0.530 10.035 16 0.413 0.612 9 12
			23 0.683 13.268 17 0.378 0.452 59 36
			22 0.784 15.588 18 0.431 0.493 1 30
			21 0.850 16.932 19 0.865 1.128 47 48
			20 0.896 17.723 20 1.133 1.305 45 34
			19 0.921 18.182 21 1.133 1.290 47 32
			18 0.944 18.637 22 1.178 1.351 47 34
			17 0.960 18.852 23 1.060 1.213 53 34
			16 0.979 19.430 24 1.027 1.241 51 40
			15 1.012 20.036
			14 1.028 20.086
			13 1.155 19.139
			12 1.210 19.639
			11 1.239 19.955
			10 1.263 20.330
			9 1.295 20.876
			8 1.321 21.204
			7 1.349 21.421
			6 1.388* 22.005
			5 1.382 22.068*
			4 1.310 21.303
			3 1.173 19.661
			2 0.888 15.122
		Bottom	1 0.247 4.321
Control Rod Density: %	4.86		
k-effective:	0.99926		
Void Fraction:	0.456		
Core Delta-P: psia	25.810	% AXIAL TILT	-17.985 -8.645
Core Plate Delta-P: psia	21.250	AVG BOT 8ft/12ft	1.1029 1.0518
Coolant Temp: Deg-F	548.4		
In Channel Flow: Mlb/hr	92.49	Active Channel Flow: Mlb/hr	89.22
Total Bypass Flow (%):	12.0	(of total core flow)	
Total Water Rod Flow (%):	3.1	(of total core flow)	
Source Convergence	0.00010		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	Value	Margin	Exp.	FT
1.351	22	47	34	1.712	0.835	22	45	8.16	0.740	33.9	21	11.11	0.788	9.0	22
1.346	22	45	32	1.716	0.833	22	45	7.90	0.734	36.5	20	11.10	0.788	8.9	22
1.342	22	45	36	1.718	0.832	22	47	8.06	0.733	34.3	20	11.08	0.786	8.7	23
1.329	22	47	38	1.723	0.830	22	49	8.02	0.733	34.8	21	11.06	0.784	8.9	23
1.327	22	49	32	1.744	0.820	22	45	7.88	0.723	35.3	21	11.05	0.784	8.6	22
1.321	22	45	40	1.751	0.817	22	47	7.87	0.722	35.3	21	11.04	0.783	7.0	22
1.318	22	49	36	1.752	0.816	22	49	7.78	0.722	36.4	20	11.03	0.782	8.7	22
1.309	22	43	34	1.761	0.812	22	43	7.84	0.721	35.4	20	11.02	0.781	8.1	22
1.308	22	43	24	1.763	0.811	22	43	8.09	0.719	31.8	20	11.01	0.781	8.4	24
1.305	20	45	34	1.781	0.803	22	19	8.05	0.713	31.5	20	11.00	0.780	9.0	22

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

Figure A.15 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and Axial Distributions at 3,800.0 MWd/MTU

Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design

Revision 1

Page A-21

Cycle:	19	Core Average Exposure: MWd/MTU	18199.4
Exposure: MWd/MTU (GWd)	4300.0 (592.48)		
Delta E: MWd/MTU, (GWd)	500.0 (68.89)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-26.17		
Flow: Mlb/hr	105.27 (102.70 %)		
		Axial Profile	Edit Radial Power
		N(PRA) Power Exposure	Zone Avg. Max. IR JR
		Top 25 0.196 3.593	14 0.449 0.449 35 2
		24 0.539 10.321	16 0.410 0.610 9 12
		23 0.693 13.635	17 0.376 0.448 59 36
		22 0.792 16.012	18 0.428 0.490 1 30
		21 0.857 17.390	19 0.862 1.126 47 48
		20 0.902 18.206	20 1.130 1.299 45 34
		19 0.926 18.679	21 1.130 1.285 47 32
		18 0.948 19.146	22 1.182 1.355 47 34
		17 0.962 19.368	23 1.063 1.218 53 34
		16 0.980 19.949	24 1.031 1.249 51 40
		15 1.013 20.573	
		14 1.026 20.631	
		13 1.152 19.680	
		12 1.205 20.205	
		11 1.234 20.536	
		10 1.258 20.922	
		9 1.291 21.483	
		8 1.318 21.823	
		7 1.346 22.054	
		6 1.385* 22.657	
		5 1.378 22.716*	
		4 1.304 21.917	
		3 1.167 20.211	
		2 0.883 15.538	
		Bottom 1 0.247 4.443	
Control Rod Density: %	4.86		
k-effective:	0.99913		
Void Fraction:	0.455		
Core Delta-P: psia	25.871	% AXIAL TILT	-17.526 -8.726
Core Plate Delta-P: psia	21.311	AVG BOT 8ft/12ft	1.0997 1.0521
Coolant Temp: Deg-F	548.3		
In Channel Flow: Mlb/hr	92.69	Active Channel Flow: Mlb/hr	89.41
Total Bypass Flow (%):	12.0	(of total core flow)	
Total Water Rod Flow (%):	3.1	(of total core flow)	
Source Convergence	0.00008		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR							LHGR							
Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K
1.355	22	47	34	1.713	0.835	22	45	30	8.10	0.740	34.8	21	13	30	5	11.08	0.786	9.9	23	9	20	5
1.349	22	45	32	1.716	0.833	22	45	26	7.87	0.737	37.4	20	11	24	5	11.07	0.785	10.2	22	49	32	5
1.346	22	45	36	1.721	0.831	22	47	28	7.97	0.734	35.6	21	11	28	5	11.06	0.785	10.1	22	47	34	5
1.334	22	47	38	1.726	0.829	22	49	30	8.00	0.734	35.2	20	13	26	5	11.03	0.783	10.1	23	7	26	5
1.331	22	49	32	1.747	0.819	22	45	22	7.84	0.725	36.1	21	9	26	5	11.01	0.781	9.5	22	49	40	5
1.325	22	45	40	1.753	0.816	22	47	38	7.83	0.725	36.1	21	13	22	5	11.01	0.781	9.8	22	49	26	5
1.323	22	49	36	1.754	0.815	22	49	36	7.82	0.725	36.3	20	11	20	5	11.00	0.780	9.6	24	9	22	5
1.312	22	43	34	1.762	0.812	22	43	28	7.74	0.724	37.3	20	9	30	5	11.00	0.780	9.1	22	47	24	5
1.310	22	43	24	1.764	0.811	22	43	24	8.02	0.718	32.6	20	15	28	5	10.99	0.780	9.8	22	9	24	5
1.299	20	45	34	1.782	0.802	22	19	40	8.01	0.715	32.4	20	13	18	5	10.91	0.774	9.6	22	47	42	5

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

Figure A.16 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and Axial Distributions at 4,300.0 MWd/MTU

Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design

Revision 1

Page A-22

Cycle:	19	Core Average Exposure: MWd/MTU	18295.3
Exposure: MWd/MTU (GWd)	4395.8 (605.68)		
Delta E: MWd/MTU, (GWd)	95.8 (13.20)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-26.17		
Flow: Mlb/hr	105.27 (102.70 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top	25 0.197 3.613 14 0.448 0.448 35 2
			24 0.540 10.376 16 0.410 0.609 9 12
			23 0.694 13.706 17 0.375 0.448 59 36
			22 0.794 16.093 18 0.427 0.490 1 30
			21 0.858 17.478 19 0.862 1.125 47 48
			20 0.903 18.299 20 1.129 1.298 45 34
			19 0.927 18.774 21 1.129 1.284 47 32
			18 0.949 19.243 22 1.182 1.356 47 34
			17 0.963 19.468 23 1.064 1.219 53 34
			16 0.980 20.049 24 1.032 1.250 51 40
			15 1.012 20.676
			14 1.026 20.736
			13 1.151 19.784
			12 1.204 20.314
			11 1.232 20.647
			10 1.257 21.035
			9 1.290 21.599
			8 1.317 21.942
			7 1.345 22.175
			6 1.384* 22.781
			5 1.378 22.840*
			4 1.304 22.034
			3 1.166 20.315
			2 0.882 15.617
		Bottom	1 0.247 4.467
Control Rod Density: %	4.86		
k-effective:	0.99913		
Void Fraction:	0.454		
Core Delta-P: psia	25.869	% AXIAL TILT	-17.459 -8.739
Core Plate Delta-P: psia	21.309	AVG BOT 8ft/12ft	1.0992 1.0522
Coolant Temp: Deg-F	548.3		
In Channel Flow: Mlb/hr	92.69	Active Channel Flow: Mlb/hr	89.41
Total Bypass Flow (%):	11.9	(of total core flow)	
Total Water Rod Flow (%):	3.1	(of total core flow)	
Source Convergence	0.00009		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	Value	Margin	Exp.	FT
1.356	22	47	34	1.713	0.835	22	45	8.09	0.741	35.0	21	11.08	0.786	10.1	23
1.349	22	45	32	1.716	0.833	22	45	7.86	0.738	37.5	20	11.06	0.785	10.4	22
1.346	22	45	36	1.722	0.831	22	47	7.97	0.735	35.8	21	11.06	0.784	10.3	22
1.335	22	47	38	1.726	0.828	22	49	8.00	0.735	35.4	20	11.03	0.783	10.3	23
1.332	22	49	32	1.747	0.819	22	45	7.83	0.726	36.3	21	11.02	0.781	9.8	22
1.325	22	45	40	1.753	0.816	22	47	7.82	0.726	36.4	20	11.01	0.781	9.8	24
1.324	22	49	36	1.754	0.815	22	49	7.83	0.725	36.3	21	11.01	0.781	10.0	22
1.312	22	43	34	1.762	0.811	22	43	7.73	0.724	37.4	20	11.00	0.780	9.3	22
1.311	22	43	24	1.764	0.811	22	43	8.01	0.719	32.8	20	11.00	0.780	10.1	22
1.299	22	47	42	1.782	0.802	22	17	8.00	0.716	32.5	20	10.91	0.774	9.8	22

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

Figure A.17 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and Axial Distributions at 4,395.8 MWd/MTU

**Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design**

Revision 1

Page A-23

Cycle:	19	Core Average Exposure: MWd/MTU	18297.6
Exposure: MWd/MTU (GWd)	4398.1 (606.00)		
Delta E: MWd/MTU, (GWd)	2.3 (0.32)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-25.84		
Flow: Mlb/hr	106.50 (103.90 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top	25 0.195 3.614 14 0.454 0.454 35 2
			24 0.536 10.377 16 0.412 0.614 9 12
			23 0.689 13.708 17 0.377 0.443 59 36
			22 0.787 16.095 18 0.429 0.483 1 30
			21 0.849 17.481 19 0.866 1.140 47 48
			20 0.898 18.301 20 1.116 1.273 43 44
			19 0.925 18.776 21 1.152 1.252 45 42
			18 0.951 19.246 22 1.179 1.320 43 42
			17 0.955 19.470 23 1.069 1.209 51 42
			16 0.976 20.051 24 1.038 1.236 51 40
			15 1.011 20.679
			14 1.027 20.738
			13 1.153 19.786
			12 1.207 20.316
			11 1.237 20.649
			10 1.262 21.037
			9 1.296 21.602
			8 1.322 21.945
			7 1.350 22.178
			6 1.389* 22.784
			5 1.381 22.843*
			4 1.306 22.037
			3 1.167 20.318
			2 0.882 15.619
		Bottom	1 0.247 4.467
Control Rod Density: %	4.91		
k-effective:	0.99910		
Void Fraction:	0.453		
Core Delta-P: psia	26.334	% AXIAL TILT	-17.810 -8.740
Core Plate Delta-P: psia	21.773	AVG BOT 8ft/12ft	1.1015 1.0522
Coolant Temp: Deg-F	548.4		
In Channel Flow: Mlb/hr	93.79	Active Channel Flow: Mlb/hr	90.48
Total Bypass Flow (%):	11.9	(of total core flow)	
Total Water Rod Flow (%):	3.1	(of total core flow)	
Source Convergence	0.00009		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR					LHGR									
Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K
1.320	22	43	42	1.772	0.807	22	17	42	8.09	0.724	32.5	20	13	18	5	11.02	0.782	10.1	23	9	20	5
1.319	22	41	44	1.782	0.803	22	41	44	8.04	0.723	33.2	20	15	16	5	10.96	0.777	10.0	22	15	18	5
1.308	22	45	44	1.782	0.802	22	45	22	7.77	0.722	36.4	20	11	20	5	10.96	0.777	9.9	23	19	10	5
1.305	22	43	46	1.784	0.802	22	19	40	7.96	0.717	33.4	20	17	14	5	10.93	0.775	9.9	22	17	16	5
1.302	22	15	40	1.788	0.800	22	21	42	7.99	0.717	32.9	20	17	18	5	10.89	0.772	9.8	22	49	40	5
1.298	22	39	46	1.789	0.799	22	39	46	7.72	0.715	36.2	20	19	12	5	10.88	0.772	9.8	22	47	42	5
1.295	22	47	42	1.796	0.796	22	15	18	7.83	0.715	34.7	21	15	20	5	10.84	0.768	9.7	24	9	22	5
1.287	22	41	48	1.802	0.794	22	17	16	7.59	0.712	37.6	20	11	24	5	10.82	0.768	9.4	22	39	50	5
1.286	22	47	38	1.808	0.791	22	47	42	7.73	0.710	35.4	21	19	16	5	10.81	0.766	9.4	22	41	48	5
1.281	22	37	48	1.813	0.789	23	9	20	7.64	0.708	36.3	21	13	22	5	10.80	0.766	10.0	22	13	16	5

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

**Figure A.18 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and
Axial Distributions at 4,398.1 MWd/MTU**

Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design

Revision 1

Page A-24

Cycle:	19	Core Average Exposure: MWd/MTU	18499.4
Exposure: MWd/MTU (GWd)	4600.0 (633.82)		
Delta E: MWd/MTU, (GWd)	201.9 (27.82)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-25.84		
Flow: Mlb/hr	106.50 (103.90 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top	25 0.197 3.656 14 0.453 0.453 35 2
			24 0.539 10.493 16 0.411 0.613 9 12
			23 0.693 13.857 17 0.376 0.441 59 36
			22 0.790 16.266 18 0.427 0.482 1 30
			21 0.851 17.665 19 0.864 1.139 47 48
			20 0.900 18.496 20 1.114 1.271 43 44
			19 0.927 18.977 21 1.150 1.250 45 42
			18 0.952 19.452 22 1.181 1.321 43 42
			17 0.956 19.678 23 1.071 1.212 51 42
			16 0.977 20.261 24 1.040 1.239 51 40
			15 1.011 20.895
			14 1.026 20.958
			13 1.151 20.005
			12 1.205 20.545
			11 1.235 20.884
			10 1.260 21.277
			9 1.294 21.847
			8 1.321 22.195
			7 1.349 22.434
			6 1.388* 23.047
			5 1.381 23.105*
			4 1.305 22.285
			3 1.166 20.539
			2 0.881 15.786
		Bottom	1 0.247 4.517
			% AXIAL TILT -17.668 -8.770
			AVG BOT 8ft/12ft 1.1004 1.0523
Control Rod Density: %	4.91		
k-effective:	0.99906		
Void Fraction:	0.453		
Core Delta-P: psia	26.329		
Core Plate Delta-P: psia	21.769		
Coolant Temp: Deg-F	548.4		
In Channel Flow: Mlb/hr	93.79	Active Channel Flow: Mlb/hr	90.49
Total Bypass Flow (%):	11.9	(of total core flow)	
Total Water Rod Flow (%):	3.1	(of total core flow)	
Source Convergence	0.00009		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR					LHGR									
Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K
1.321	22	43	42	1.772	0.807	22	43	20	8.08	0.725	32.9	20	13	18	5	11.03	0.782	10.6	23	9	20	5
1.320	22	41	44	1.783	0.802	22	41	44	8.03	0.725	33.6	20	15	16	5	10.96	0.777	10.3	23	19	10	5
1.310	22	45	44	1.784	0.802	22	45	22	7.77	0.724	36.8	20	11	20	5	10.96	0.777	10.5	22	15	18	5
1.306	22	43	46	1.784	0.801	22	19	40	7.95	0.719	33.7	20	17	14	5	10.93	0.775	10.4	22	17	16	5
1.303	22	15	40	1.789	0.799	22	21	42	7.97	0.717	33.2	20	17	18	5	10.90	0.773	10.2	22	49	40	5
1.299	22	39	46	1.791	0.798	22	39	46	7.72	0.717	36.5	20	19	12	5	10.89	0.772	10.3	22	47	42	5
1.297	22	47	42	1.797	0.796	22	15	18	7.81	0.716	35.1	21	15	20	5	10.85	0.769	10.2	24	9	22	5
1.289	22	41	48	1.803	0.793	22	17	16	7.59	0.714	37.9	20	11	24	5	10.82	0.768	9.9	22	39	50	5
1.288	22	47	38	1.808	0.791	22	47	42	7.70	0.710	35.7	21	19	16	5	10.80	0.766	9.9	22	41	48	5
1.282	22	37	48	1.813	0.789	22	49	30	7.63	0.710	36.6	21	13	22	5	10.78	0.764	10.3	22	47	16	5

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

Figure A.19 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and Axial Distributions at 4,600.0 MWd/MTU

Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design

Revision 1

Page A-25

Cycle:	19	Core Average Exposure: Mwd/MTU	18899.5
Exposure: Mwd/MTU (GWd)	5000.0 (688.93)		
Delta E: Mwd/MTU, (GWd)	400.0 (55.11)		
Power: Mwt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-25.84		
Flow: Mlb/hr	106.50 (103.90 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top 25	0.200 3.741 14 0.449 0.449 35 2
		24	0.546 10.725 16 0.409 0.611 9 12
		23	0.701 14.154 17 0.373 0.438 59 36
		22	0.796 16.607 18 0.425 0.480 1 30
		21	0.856 18.032 19 0.862 1.137 47 48
		20	0.904 18.884 20 1.112 1.267 43 44
		19	0.930 19.377 21 1.147 1.247 45 42
		18	0.954 19.862 22 1.184 1.324 43 42
		17	0.958 20.089 23 1.074 1.217 51 42
		16	0.977 20.675 24 1.043 1.246 51 40
		15	1.010 21.324
		14	1.024 21.393
		13	1.147 20.436
		12	1.200 20.997
		11	1.229 21.346
		10	1.256 21.749
		9	1.290 22.333
		8	1.318 22.691
		7	1.347 22.941
		6	1.387* 23.569
		5	1.379 23.624*
		4	1.303 22.775
		3	1.164 20.977
		2	0.878 16.116
		Bottom 1	0.247 4.615
			% AXIAL TILT -17.370 -8.825
			AVG BOT 8ft/12ft 1.0982 1.0525
Control Rod Density: %	4.91		
k-effective:	0.99898		
Void Fraction:	0.452		
Core Delta-P: psia	26.320		
Core Plate Delta-P: psia	21.759		
Coolant Temp: Deg-F	548.4		
In Channel Flow: Mlb/hr	93.80	Active Channel Flow: Mlb/hr	90.49
Total Bypass Flow (%):	11.9	(of total core flow)	
Total Water Rod Flow (%):	3.1	(of total core flow)	
Source Convergence	0.00009		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR							LHGR							
Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K
1.324	22	43	42	1.772	0.807	22	43	20	8.07	0.729	33.6	20	13	18	5	11.05	0.784	11.5	23	9	20	5
1.322	22	41	44	1.782	0.802	22	41	44	7.77	0.728	37.4	20	11	20	5	10.97	0.778	11.3	23	19	10	5
1.314	22	45	44	1.782	0.802	22	45	22	8.00	0.727	34.3	20	15	16	5	10.94	0.776	11.4	22	15	18	5
1.309	22	43	46	1.785	0.801	22	19	40	7.92	0.721	34.4	20	17	14	5	10.93	0.775	11.2	22	49	40	5
1.307	22	15	40	1.791	0.798	22	21	42	7.71	0.720	37.2	20	19	12	5	10.91	0.774	11.3	22	17	16	5
1.302	22	39	46	1.795	0.797	22	39	46	7.93	0.719	33.9	20	17	18	5	10.89	0.773	11.2	22	47	42	5
1.301	22	47	42	1.799	0.795	22	15	18	7.58	0.718	38.5	20	11	24	5	10.87	0.771	11.1	24	9	22	5
1.293	22	41	48	1.806	0.792	22	17	16	7.78	0.717	35.7	21	15	20	5	10.84	0.768	10.8	22	39	50	5
1.293	22	47	38	1.809	0.790	22	47	42	7.61	0.712	37.2	21	13	22	5	10.80	0.766	10.8	22	41	48	5
1.286	22	49	36	1.811	0.790	22	49	30	7.66	0.711	36.3	21	19	16	5	10.79	0.765	10.8	24	21	10	5

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

Figure A.20 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and Axial Distributions at 5,000.0 Mwd/MTU

Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design

Revision 1

Page A-26

Cycle:	19	Core Average Exposure: MWd/MTU	19399.5
Exposure: MWd/MTU (GWd)	5500.0 (757.82)		
Delta E: MWd/MTU, (GWd)	500.0 (68.89)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-25.90		
Flow: Mlb/hr	106.29 (103.70 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top	25 0.203 3.849 14 0.446 0.446 35 2
			24 0.553 11.018 16 0.406 0.608 9 12
			23 0.709 14.531 17 0.371 0.435 59 36
			22 0.802 17.036 18 0.422 0.477 1 30
			21 0.861 18.493 19 0.859 1.135 47 48
			20 0.907 19.371 20 1.109 1.263 43 44
			19 0.932 19.877 21 1.143 1.243 45 42
			18 0.956 20.376 22 1.187 1.327 43 42
			17 0.958 20.604 23 1.078 1.224 51 42
			16 0.977 21.194 24 1.048 1.254 51 40
			15 1.009 21.860
			14 1.020 21.935
			13 1.141 20.973
			12 1.192 21.558
			11 1.222 21.922
			10 1.250 22.338
			9 1.286 22.938
			8 1.315 23.310
			7 1.345 23.573
			6 1.386* 24.220
			5 1.380 24.271*
			4 1.305 23.387
			3 1.164 21.523
			2 0.878 16.529
		Bottom	1 0.247 4.737
			% AXIAL TILT -17.121 -8.883
			AVG BOT 8ft/12ft 1.0960 1.0527
Control Rod Density: %	4.91		
k-effective:	0.99891		
Void Fraction:	0.452		
Core Delta-P: psia	26.238		
Core Plate Delta-P: psia	21.677		
Coolant Temp: Deg-F	548.4		
In Channel Flow: Mlb/hr	93.62	Active Channel Flow: Mlb/hr	90.32
Total Bypass Flow (%):	11.9	(of total core flow)	
Total Water Rod Flow (%):	3.1	(of total core flow)	
Source Convergence	0.00009		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	IR	Value	Margin	Exp.
1.327	22	43	42	1.770	0.808	22	43	7.78	0.735	38.3	20	11	11.08	0.786	12.7
1.326	22	41	44	1.781	0.803	22	41	8.06	0.734	34.4	20	13	11.00	0.780	12.4
1.319	22	45	44	1.781	0.803	22	45	7.98	0.732	35.1	20	15	10.97	0.778	12.3
1.314	22	43	46	1.785	0.801	22	19	7.71	0.727	38.0	20	19	10.95	0.777	12.6
1.311	22	15	40	1.792	0.798	22	21	7.92	0.726	35.2	20	17	10.92	0.775	12.4
1.307	22	47	42	1.795	0.797	22	39	7.58	0.723	39.3	20	11	10.92	0.774	12.3
1.305	22	39	46	1.801	0.794	22	15	7.90	0.721	34.8	20	17	10.92	0.774	12.4
1.299	22	41	48	1.807	0.791	22	43	7.75	0.720	36.6	21	15	10.88	0.772	12.0
1.297	22	47	38	1.809	0.791	22	49	7.59	0.716	38.1	21	13	10.83	0.768	11.9
1.291	22	49	36	1.811	0.790	22	47	7.51	0.715	39.0	20	23	10.82	0.767	12.0

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

Figure A.21 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and Axial Distributions at 5,500.0 MWd/MTU

**Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design**

Revision 1

Page A-27

Cycle:	19	Core Average Exposure: Mwd/MTU	19899.5
Exposure: Mwd/MTU (GWd)	6000.0 (826.72)		
Delta E: Mwd/MTU, (GWd)	500.0 (68.89)		
Power: Mwt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-26.09		
Flow: Mlb/hr	105.58 (103.00 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top 25	0.206 3.958 14 0.442 0.442 35 2
		24	0.559 11.316 16 0.404 0.606 9 12
		23	0.715 14.911 17 0.368 0.431 59 36
		22	0.807 17.468 18 0.420 0.475 1 30
		21	0.864 18.956 19 0.855 1.133 47 48
		20	0.909 19.859 20 1.105 1.258 43 44
		19	0.933 20.379 21 1.139 1.238 45 42
		18	0.956 20.890 22 1.191 1.331 43 42
		17	0.958 21.120 23 1.081 1.231 51 42
		16	0.975 21.712 24 1.053 1.263 51 40
		15	1.006 22.394
		14	1.016 22.475
		13	1.134 21.507
		12	1.184 22.116
		11	1.214 22.493
		10	1.243 22.923
		9	1.281 23.541
		8	1.312 23.927
		7	1.345 24.204
		6	1.388* 24.871
		5	1.384 24.920*
		4	1.310 24.001
		3	1.170 22.071
		2	0.882 16.942
		Bottom 1	0.249 4.860
Control Rod Density: %	4.91		
k-effective:	0.99881		
Void Fraction:	0.452		
Core Delta-P: psia	25.973	% AXIAL TILT	-17.006 -8.933
Core Plate Delta-P: psia	21.412	AVG BOT 8ft/12ft	1.0946 1.0528
Coolant Temp: Deg-F	548.3		
In Channel Flow: Mlb/hr	92.97	Active Channel Flow: Mlb/hr	89.69
Total Bypass Flow (%):	11.9	(of total core flow)	
Total Water Rod Flow (%):	3.1	(of total core flow)	
Source Convergence	0.00010		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	IR	Value	Margin	Exp.
1.331	22	43	42	1.767	0.809	22	43	7.80	0.743	39.1	20	11	11.15	0.791	13.9
1.329	22	41	44	1.776	0.805	22	41	8.06	0.740	35.3	20	13	11.06	0.784	13.6
1.323	22	45	44	1.777	0.805	22	45	7.98	0.737	36.0	20	15	11.04	0.783	13.5
1.319	22	43	46	1.784	0.802	22	19	7.74	0.735	38.8	20	19	10.99	0.779	13.4
1.315	22	15	40	1.791	0.798	22	39	7.92	0.733	36.1	20	17	10.98	0.778	13.7
1.313	22	47	42	1.791	0.798	22	21	7.59	0.730	40.1	20	11	10.96	0.777	13.5
1.309	22	39	46	1.801	0.794	22	15	7.88	0.725	35.6	20	17	10.94	0.776	13.6
1.304	22	41	48	1.804	0.793	22	49	7.74	0.725	37.4	21	15	10.94	0.776	13.1
1.302	22	47	38	1.805	0.792	22	43	7.52	0.721	39.8	20	23	10.90	0.773	13.1
1.296	22	49	36	1.808	0.791	22	47	7.58	0.721	38.9	21	13	10.86	0.770	13.1

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

**Figure A.22 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and
Axial Distributions at 6,000.0 Mwd/MTU**

Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design

Revision 1

Page A-28

Cycle:	19	Core Average Exposure: MWd/MTU	20399.3
Exposure: MWd/MTU (GWd)	6500.0 (895.61)		
Delta E: MWd/MTU, (GWd)	500.0 (68.89)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-26.37		
Flow: Mlb/hr	104.55 (102.00 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top	25 0.209 4.069 14 0.438 0.438 35 2
			24 0.564 11.616 16 0.401 0.604 9 12
			23 0.721 15.295 17 0.365 0.427 59 36
			22 0.810 17.903 18 0.417 0.472 1 30
			21 0.866 19.421 19 0.852 1.131 47 48
			20 0.910 20.348 20 1.102 1.254 43 44
			19 0.933 20.881 21 1.135 1.234 45 42
			18 0.955 21.404 22 1.195 1.335 43 42
			17 0.956 21.634 23 1.085 1.238 51 42
			16 0.972 22.228 24 1.058 1.271 51 40
			15 1.001 22.927
			14 1.010 23.013
			13 1.125 22.037
			12 1.174 22.669
			11 1.204 23.061
			10 1.235 23.505
			9 1.275 24.141
			8 1.309 24.542
			7 1.345 24.836
			6 1.392* 25.524
			5 1.391 25.572*
			4 1.320 24.619
			3 1.180 22.623
			2 0.889 17.357
		Bottom	1 0.252 4.985
Control Rod Density: %	4.91		
k-effective:	0.99872		
Void Fraction:	0.454		
Core Delta-P: psia	25.601	% AXIAL TILT	-17.002 -8.979
Core Plate Delta-P: psia	21.041	AVG BOT 8ft/12ft	1.0937 1.0529
Coolant Temp: Deg-F	548.3		
In Channel Flow: Mlb/hr	92.05	Active Channel Flow: Mlb/hr	88.79
Total Bypass Flow (%):	12.0	(of total core flow)	
Total Water Rod Flow (%):	3.1	(of total core flow)	
Source Convergence	0.00009		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR					LHGR									
Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K
1.335	22	43	42	1.761	0.812	22	17	42	7.84	0.753	39.9	20	11	20	5	11.23	0.796	15.1	23	9	20	5
1.333	22	41	44	1.770	0.808	22	41	44	8.08	0.748	36.1	20	13	18	5	11.14	0.790	14.8	23	19	10	5
1.328	22	45	44	1.772	0.807	22	45	22	7.77	0.744	39.6	20	19	12	5	11.12	0.789	14.7	22	49	40	5
1.324	22	43	46	1.781	0.803	22	19	40	7.99	0.744	36.8	20	15	16	5	11.08	0.786	14.6	24	9	22	5
1.319	22	15	40	1.786	0.801	22	39	46	7.94	0.740	36.9	20	17	14	5	11.02	0.782	14.3	22	39	50	5
1.318	22	47	42	1.790	0.799	22	21	42	7.61	0.739	41.0	20	11	24	5	11.02	0.782	14.7	22	47	42	5
1.313	22	39	46	1.795	0.797	22	15	18	7.87	0.730	36.4	20	17	18	5	11.02	0.781	14.9	22	15	18	5
1.310	22	41	48	1.799	0.795	22	49	30	7.73	0.730	38.2	21	15	20	5	10.99	0.779	14.2	24	21	10	5
1.306	22	47	38	1.801	0.794	22	47	42	7.55	0.729	40.6	20	23	12	5	10.98	0.779	14.8	22	17	16	5
1.302	22	49	40	1.802	0.794	22	43	46	7.60	0.728	39.7	21	9	26	5	10.92	0.775	14.3	22	41	48	5

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

Figure A.23 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and Axial Distributions at 6,500.0 MWd/MTU

Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design

Revision 1

Page A-29

Cycle:	19	Core Average Exposure: MWd/MTU	20827.0
Exposure: MWd/MTU (GWd)	6927.6 (954.53)		
Delta E: MWd/MTU, (GWd)	427.6 (58.92)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-26.71		
Flow: Mlb/hr	103.32 (100.80 %)		
		Axial Profile	Edit Radial Power
		N(PRA) Power Exposure	Zone Avg. Max. IR JR
		Top 25 0.211 4.165	14 0.435 0.435 35 2
		24 0.568 11.874	16 0.399 0.603 9 12
		23 0.725 15.625	17 0.363 0.424 59 36
		22 0.812 18.275	18 0.415 0.470 1 30
		21 0.867 19.819	19 0.849 1.129 47 48
		20 0.910 20.766	20 1.099 1.250 43 44
		19 0.932 21.310	21 1.131 1.230 45 42
		18 0.953 21.843	22 1.198 1.338 43 42
		17 0.953 22.073	23 1.088 1.243 51 42
		16 0.969 22.669	24 1.062 1.279 51 40
		15 0.997 23.380	
		14 1.004 23.470	
		13 1.117 22.487	
		12 1.164 23.139	
		11 1.195 23.543	
		10 1.228 24.000	
		9 1.270 24.652	
		8 1.306 25.068	
		7 1.345 25.376	
		6 1.396 26.084	
		5 1.400* 26.133*	
		4 1.332 25.152	
		3 1.193 23.099	
		2 0.899 17.716	
		Bottom 1 0.255 5.092	
Control Rod Density: %	4.91		
k-effective:	0.99863		
Void Fraction:	0.456		
Core Delta-P: psia	25.162	% AXIAL TILT	-17.097 -9.018
Core Plate Delta-P: psia	20.603	AVG BOT 8ft/12ft	1.0934 1.0530
Coolant Temp: Deg-F	548.3		
In Channel Flow: Mlb/hr	90.94	Active Channel Flow: Mlb/hr	87.71
Total Bypass Flow (%):	12.0	(of total core flow)	
Total Water Rod Flow (%):	3.1	(of total core flow)	
Source Convergence	0.00009		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	Value	Margin	Exp.	FT
1.338	22	43	42	1.753	0.816	22	17	7.88	0.762	40.6	20	11.31	0.802	16.1	23
1.336	22	41	44	1.762	0.812	22	41	8.11	0.756	36.9	20	11.22	0.796	15.8	23
1.333	22	45	44	1.766	0.810	22	45	7.81	0.754	40.4	20	11.21	0.795	15.7	22
1.328	22	43	46	1.778	0.804	22	19	8.01	0.751	37.5	20	11.17	0.792	15.6	24
1.323	22	47	42	1.780	0.803	22	39	7.96	0.748	37.6	20	11.11	0.788	15.3	22
1.322	22	15	40	1.786	0.801	22	45	7.65	0.747	41.6	20	11.09	0.787	15.7	22
1.316	22	39	46	1.786	0.801	22	21	7.58	0.738	41.3	20	11.07	0.785	15.2	24
1.315	22	41	48	1.791	0.798	22	47	7.74	0.736	38.9	21	11.06	0.785	15.9	22
1.310	22	47	38	1.791	0.798	22	43	7.63	0.736	40.4	21	11.03	0.782	15.8	22
1.308	22	49	40	1.792	0.798	22	49	7.87	0.736	37.2	20	8.46	0.781	46.0	20

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

Figure A.24 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and Axial Distributions at 6,927.6 MWd/MTU

Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design

Revision 1

Page A-30

Cycle:	19	Core Average Exposure: MWd/MTU	20830.4
Exposure: MWd/MTU (GWd)	6931.0 (955.00)		
Delta E: MWd/MTU, (GWd)	3.4 (0.47)		
Power: MWt	3952.0 (100.00 %)	Axial Profile	Edit Radial Power
Core Pressure: psia	1050.0	N (PRA)	Power Exposure Zone Avg. Max. IR JR
Inlet Subcooling: Btu/lbm	-25.95	Top 25	0.213 4.166 14 0.419 0.419 35 2
Flow: Mlb/hr	106.09 (103.50 %)	24	0.575 11.876 16 0.382 0.590 11 52
		23	0.735 15.628 17 0.348 0.405 35 60
		22	0.826 18.278 18 0.398 0.447 1 30
		21	0.886 19.822 19 0.814 1.110 47 48
		20	0.928 20.770 20 1.137 1.311 39 40
		19	0.942 21.314 21 1.152 1.261 35 40
		18	0.960 21.846 22 1.227 1.392 41 40
		17	0.962 22.077 23 1.025 1.209 41 52
		16	0.978 22.672 24 0.980 1.227 39 52
		15	1.006 23.384
		14	1.012 23.473
		13	1.125 22.491
		12	1.171 23.142
		11	1.200 23.546
		10	1.230 24.004
		9	1.268 24.657
		8	1.301 25.072
		7	1.337 25.380
		6	1.383* 26.088
		5	1.380 26.137*
		4	1.304 25.156
		3	1.160 23.103
		2	0.872 17.719
		Bottom 1	0.247 5.093
Control Rod Density: %	4.91	% AXIAL TILT	-16.030 -9.018
k-effective:	0.99862	AVG BOT 8ft/12ft	1.0876 1.0530
Void Fraction:	0.448		
Core Delta-P: psia	26.144		
Core Plate Delta-P: psia	21.583		
Coolant Temp: Deg-F	548.3		
In Channel Flow: Mlb/hr	93.46	Active Channel Flow: Mlb/hr	90.17
Total Bypass Flow (%):	11.9	(of total core flow)	
Total Water Rod Flow (%):	3.1	(of total core flow)	
Source Convergence	0.00010		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	Value	Margin	Exp.	FT
1.392	22	41	40	1.685	0.848	22	39	7.81	0.734	37.6	20	10.94	0.776	15.8	23
1.390	22	37	40	1.694	0.844	22	19	7.60	0.734	40.4	20	10.81	0.767	15.8	22
1.387	22	39	38	1.702	0.840	22	21	7.85	0.733	37.2	20	10.78	0.764	13.8	22
1.384	22	39	42	1.704	0.839	22	37	7.77	0.729	37.5	20	10.77	0.764	15.3	22
1.364	22	43	42	1.722	0.831	22	35	7.60	0.727	39.5	21	10.74	0.762	15.3	22
1.364	22	35	38	1.727	0.828	22	41	7.56	0.726	39.9	21	10.70	0.759	15.8	22
1.364	22	41	44	1.728	0.827	22	29	7.69	0.717	37.0	20	10.68	0.758	15.4	22
1.360	22	33	40	1.731	0.826	22	43	7.71	0.712	36.0	20	10.68	0.757	15.6	22
1.357	22	43	38	1.733	0.825	22	43	7.36	0.712	40.6	20	10.67	0.757	15.2	24
1.346	22	31	38	1.736	0.824	22	35	7.41	0.705	38.9	21	10.65	0.755	14.7	22

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

Figure A.25 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and Axial Distributions at 6,931.0 MWd/MTU

Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design

Revision 1

Page A-31

Cycle:	19	Core Average Exposure: MWd/MTU	21399.4
Exposure: MWd/MTU (GWd)	7500.0 (1033.40)		
Delta E: MWd/MTU, (GWd)	569.0 (78.40)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-26.37		
Flow: Mlb/hr	104.55 (102.00 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top	25 0.216 4.297 14 0.416 0.416 35 2
			24 0.581 12.228 16 0.380 0.588 11 52
			23 0.742 16.077 17 0.345 0.402 35 60
			22 0.830 18.784 18 0.396 0.445 1 30
			21 0.888 20.364 19 0.812 1.108 47 48
			20 0.928 21.337 20 1.132 1.302 39 40
			19 0.942 21.890 21 1.147 1.250 35 40
			18 0.959 22.434 22 1.230 1.394 41 40
			17 0.960 22.665 23 1.031 1.218 41 52
			16 0.974 23.262 24 0.986 1.239 39 52
			15 1.000 23.990
			14 1.004 24.082
			13 1.113 23.089
			12 1.158 23.764
			11 1.187 24.184
			10 1.219 24.658
			9 1.261 25.332
			8 1.297 25.766
			7 1.337 26.095
			6 1.389 26.829
			5 1.391* 26.878*
			4 1.318 25.856
			3 1.174 23.726
			2 0.882 18.187
		Bottom	1 0.250 5.233
Control Rod Density: %	4.91		
k-effective:	0.99850		
Void Fraction:	0.450		
Core Delta-P: psia	25.586	% AXIAL TILT	-16.077 -9.040
Core Plate Delta-P: psia	21.026	AVG BOT 8ft/12ft	1.0867 1.0529
Coolant Temp: Deg-F	548.3		
In Channel Flow: Mlb/hr	92.07	Active Channel Flow: Mlb/hr	88.81
Total Bypass Flow (%):	11.9	(of total core flow)	
Total Water Rod Flow (%):	3.1	(of total core flow)	
Source Convergence	0.00008		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	IR	Value	Margin	Exp.
1.394	22	41	40	1.682	0.850	22	39	7.68	0.748	41.3	20	19	11.08	0.786	17.2
1.390	22	37	40	1.688	0.847	22	19	7.87	0.746	38.6	20	17	10.91	0.774	16.6
1.387	22	39	38	1.697	0.843	22	21	7.86	0.741	38.1	20	17	10.89	0.773	17.1
1.386	22	39	42	1.701	0.841	22	37	7.81	0.739	38.5	20	15	10.85	0.770	16.6
1.369	22	43	42	1.721	0.831	22	35	7.62	0.736	40.4	21	19	10.82	0.767	16.5
1.368	22	41	44	1.724	0.829	22	43	7.54	0.731	40.8	21	19	10.80	0.766	16.7
1.362	22	35	38	1.725	0.829	22	41	7.63	0.718	37.9	20	21	10.78	0.765	16.8
1.359	22	43	38	1.726	0.829	22	43	7.35	0.717	41.5	20	17	10.77	0.764	15.1
1.358	22	33	40	1.729	0.827	22	29	7.69	0.717	36.9	20	21	10.76	0.763	17.1
1.343	22	35	42	1.733	0.825	22	35	7.43	0.713	39.8	21	15	8.19	0.762	46.7

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

Figure A.26 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and Axial Distributions at 7,500.0 MWd/MTU

Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design

Revision 1

Page A-32

Cycle:	19	Core Average Exposure: MWd/MTU	21899.4
Exposure: MWd/MTU (GWd)	8000.0 (1102.30)		
Delta E: MWd/MTU, (GWd)	500.0 (68.89)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-26.76		
Flow: Mlb/hr	103.11 (100.60 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top	25 0.219 4.413 14 0.412 0.412 35 2
			24 0.585 12.539 16 0.377 0.587 11 52
			23 0.746 16.474 17 0.343 0.398 35 60
			22 0.832 19.231 18 0.393 0.442 29 60
			21 0.888 20.841 19 0.808 1.106 47 48
			20 0.928 21.836 20 1.128 1.296 39 40
			19 0.940 22.396 21 1.142 1.244 35 40
			18 0.956 22.949 22 1.234 1.398 41 40
			17 0.956 23.180 23 1.035 1.226 41 52
			16 0.969 23.777 24 0.991 1.248 39 52
			15 0.994 24.518
			14 0.996 24.613
			13 1.102 23.609
			12 1.145 24.305
			11 1.175 24.738
			10 1.209 25.229
			9 1.254 25.923
			8 1.294 26.375
			7 1.339 26.723
			6 1.396 27.483
			5 1.404* 27.534*
			4 1.335 26.479
			3 1.191 24.282
			2 0.894 18.604
		Bottom	1 0.254 5.358
Control Rod Density: %	4.91		
k-effective:	0.99850		
Void Fraction:	0.453		
Core Delta-P: psia	25.076	% AXIAL TILT	-16.241 -9.061
Core Plate Delta-P: psia	20.517	AVG BOT 8ft/12ft	1.0865 1.0528
Coolant Temp: Deg-F	548.3		
In Channel Flow: Mlb/hr	90.77	Active Channel Flow: Mlb/hr	87.55
Total Bypass Flow (%):	12.0	(of total core flow)	
Total Water Rod Flow (%):	3.1	(of total core flow)	
Source Convergence	0.00009		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	IR	Value	Margin	Exp.
1.398	22	41	40	1.676	0.853	22	39	7.76	0.762	42.1	20	19	11.21	0.795	18.4
1.393	22	37	40	1.681	0.851	22	19	7.92	0.757	39.4	20	17	11.05	0.783	17.8
1.391	22	39	38	1.690	0.846	22	21	7.88	0.750	38.9	20	17	10.97	0.778	18.3
1.390	22	39	42	1.694	0.844	22	37	7.85	0.749	39.3	20	15	10.96	0.778	17.6
1.373	22	43	42	1.714	0.834	22	35	7.65	0.745	41.2	21	19	10.96	0.777	17.8
1.373	22	41	44	1.716	0.833	22	43	7.55	0.738	41.6	21	19	8.26	0.776	47.5
1.365	22	35	38	1.719	0.832	22	43	7.36	0.724	42.3	20	17	10.91	0.774	17.9
1.363	22	43	38	1.720	0.832	22	41	7.63	0.724	38.7	20	21	8.38	0.772	45.7
1.361	22	33	40	1.724	0.829	22	29	7.69	0.723	37.7	20	21	10.88	0.772	18.0
1.346	22	35	42	1.726	0.828	22	41	9.38	0.721	14.2	24	21	10.82	0.768	18.4

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

Figure A.27 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and Axial Distributions at 8,000.0 MWd/MTU

Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design

Revision 1

Page A-33

Cycle:	19	Core Average Exposure: MWd/MTU	22099.4
Exposure: MWd/MTU (GWd)	8200.0 (1129.80)		
Delta E: MWd/MTU, (GWd)	200.0 (27.56)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-26.94		
Flow: Mlb/hr	102.50 (100.00 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top	25 0.219 4.460 14 0.411 0.411 35 2
			24 0.586 12.665 16 0.377 0.586 11 52
			23 0.747 16.634 17 0.342 0.397 35 60
			22 0.832 19.409 18 0.392 0.441 29 60
			21 0.888 21.032 19 0.807 1.105 47 48
			20 0.927 22.036 20 1.127 1.294 39 40
			19 0.939 22.598 21 1.141 1.242 35 40
			18 0.955 23.154 22 1.236 1.400 41 40
			17 0.954 23.386 23 1.036 1.229 41 52
			16 0.967 23.983 24 0.993 1.252 39 52
			15 0.991 24.729
			14 0.992 24.824
			13 1.097 23.815
			12 1.140 24.519
			11 1.169 24.958
			10 1.205 25.455
			9 1.251 26.158
			8 1.293 26.618
			7 1.340 26.975
			6 1.400 27.745
			5 1.410* 27.798*
			4 1.344 26.731
			3 1.200 24.506
			2 0.900 18.772
		Bottom	1 0.256 5.409
Control Rod Density: %	4.91		
k-effective:	0.99852		
Void Fraction:	0.454		
Core Delta-P: psia	24.861	% AXIAL TILT	-16.358 -9.071
Core Plate Delta-P: psia	20.302	AVG BOT 8ft/12ft	1.0867 1.0528
Coolant Temp: Deg-F	548.3		
In Channel Flow: Mlb/hr	90.21	Active Channel Flow: Mlb/hr	87.00
Total Bypass Flow (%):	12.0	(of total core flow)	
Total Water Rod Flow (%):	3.1	(of total core flow)	
Source Convergence	0.00009		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR					LHGR				
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	IR	Value	Margin	Exp.	FT	IR
1.400	22	41	40	1.673	0.855	22	39	7.79	0.768	42.4	20	19	11.27	0.799	18.8	23	19
1.394	22	37	40	1.678	0.852	22	19	7.95	0.762	39.8	20	17	11.11	0.788	18.2	22	39
1.392	22	39	38	1.686	0.848	22	21	7.87	0.754	39.7	20	15	8.29	0.782	47.9	20	41
1.392	22	39	42	1.691	0.846	22	37	7.89	0.753	39.3	20	17	11.02	0.782	18.1	24	21
1.375	22	43	42	1.711	0.836	22	35	7.67	0.749	41.5	21	19	11.02	0.781	18.7	22	17
1.375	22	41	44	1.712	0.835	22	43	7.56	0.741	42.0	21	19	11.01	0.781	18.2	22	41
1.366	22	35	38	1.716	0.833	22	43	9.46	0.728	14.6	24	21	10.96	0.777	18.3	22	17
1.365	22	43	38	1.717	0.833	22	41	7.37	0.727	42.6	20	17	8.40	0.776	46.1	20	15
1.363	22	33	40	1.722	0.831	22	41	7.63	0.726	39.0	20	21	10.92	0.775	18.5	22	15
1.347	22	41	36	1.722	0.831	22	29	7.70	0.726	38.0	20	21	8.38	0.772	45.9	20	17

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

Figure A.28 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and Axial Distributions at 8,200.0 MWd/MTU

Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design

Revision 1

Page A-34

Cycle:	19	Core Average Exposure: MWd/MTU	22100.4
Exposure: MWd/MTU (GWd)	8201.0 (1130.00)		
Delta E: MWd/MTU, (GWd)	1.0 (0.14)		
Power: MWt	3952.0 (100.00 %)	Axial Profile	Edit Radial Power
Core Pressure: psia	1050.0	N (PRA)	Power Exposure Zone Avg. Max. IR JR
Inlet Subcooling: Btu/lbm	-25.90	Top 25	0.210 4.461 14 0.413 0.413 35 2
Flow: Mlb/hr	106.29 (103.70 %)	24	0.561 12.665 16 0.379 0.590 11 52
		23	0.717 16.634 17 0.344 0.400 35 60
		22	0.802 19.410 18 0.395 0.444 29 60
		21	0.861 21.033 19 0.813 1.114 47 48
		20	0.908 22.037 20 1.122 1.291 39 40
		19	0.927 22.599 21 1.136 1.242 41 42
		18	0.948 23.155 22 1.232 1.401 41 40
		17	0.952 23.387 23 1.044 1.240 41 52
		16	0.969 23.984 24 1.001 1.263 39 52
		15	0.995 24.730
		14	0.999 24.825
		13	1.108 23.816
		12	1.152 24.520
		11	1.183 24.959
		10	1.220 25.456
		9	1.266 26.159
		8	1.309 26.619
		7	1.355 26.976
		6	1.414 27.747
		5	1.423* 27.800*
		4	1.353 26.732
		3	1.206 24.507
		2	0.904 18.773
		Bottom 1	0.257 5.409
Control Rod Density: %	5.09	% AXIAL TILT	-17.552 -9.071
k-effective:	0.99852	AVG BOT 8ft/12ft	1.0960 1.0528
Void Fraction:	0.451		
Core Delta-P: psia	26.291		
Core Plate Delta-P: psia	21.730		
Coolant Temp: Deg-F	548.4		
In Channel Flow: Mlb/hr	93.61	Active Channel Flow: Mlb/hr	90.30
Total Bypass Flow (%):	11.9	(of total core flow)	
Total Water Rod Flow (%):	3.1	(of total core flow)	
Source Convergence	0.00008		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR					LHGR									
Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K
1.401	22	41	40	1.714	0.835	22	19	40	7.87	0.775	42.4	20	19	12	5	11.39	0.808	18.8	23	19	10	5
1.393	22	39	42	1.722	0.830	22	21	42	8.03	0.770	39.8	20	17	14	5	11.23	0.796	18.2	22	39	50	5
1.389	22	37	40	1.724	0.829	22	39	38	7.95	0.762	39.7	20	15	16	5	8.38	0.790	47.9	20	41	50	5
1.385	22	39	38	1.738	0.823	22	37	40	7.98	0.761	39.3	20	17	18	5	11.14	0.790	18.1	24	21	10	5
1.382	22	41	44	1.739	0.822	22	43	42	7.75	0.757	41.5	21	19	16	5	11.14	0.790	18.7	22	17	16	5
1.381	22	43	42	1.749	0.818	22	43	24	7.64	0.749	42.0	21	19	20	5	11.13	0.790	18.2	22	41	48	5
1.366	22	43	38	1.753	0.816	22	41	44	9.56	0.736	14.6	24	21	10	5	11.08	0.786	18.3	22	17	50	5
1.351	22	33	40	1.769	0.808	22	41	36	7.44	0.735	42.6	20	17	22	5	8.49	0.785	46.1	20	15	16	5
1.349	22	35	38	1.772	0.807	22	35	42	7.71	0.734	39.0	20	21	22	5	11.04	0.783	18.5	22	15	48	5
1.348	22	43	46	1.790	0.799	22	35	38	7.78	0.734	38.0	20	21	18	5	8.46	0.780	45.9	20	17	14	5

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

Figure A.29 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and Axial Distributions at 8,201.0 MWd/MTU

Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design

Revision 1

Page A-35

Cycle:	19	Core Average Exposure: MWd/MTU	22599.4
Exposure: MWd/MTU (GWd)	8700.0 (1198.70)		
Delta E: MWd/MTU, (GWd)	499.0 (68.76)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-26.37		
Flow: Mlb/hr	104.55 (102.00 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top	25 0.211 4.573 14 0.410 0.410 35 2
			24 0.563 12.965 16 0.376 0.588 11 52
			23 0.719 17.017 17 0.341 0.396 35 60
			22 0.801 19.840 18 0.392 0.442 29 60
			21 0.859 21.494 19 0.809 1.112 47 48
			20 0.905 22.523 20 1.118 1.285 39 40
			19 0.923 23.096 21 1.132 1.237 41 42
			18 0.943 23.663 22 1.237 1.405 41 40
			17 0.947 23.896 23 1.048 1.248 41 52
			16 0.962 24.495 24 1.005 1.273 39 52
			15 0.987 25.255
			14 0.990 25.351
			13 1.095 24.332
			12 1.138 25.057
			11 1.170 25.511
			10 1.209 26.026
			9 1.259 26.751
			8 1.306 27.232
			7 1.358 27.612
			6 1.424 28.412
			5 1.440* 28.470*
			4 1.376 27.372
			3 1.230 25.078
			2 0.922 19.201
		Bottom	1 0.262 5.538
Control Rod Density: %	5.09		
k-effective:	0.99852		
Void Fraction:	0.455		
Core Delta-P: psia	25.671	% AXIAL TILT	-17.922 -9.126
Core Plate Delta-P: psia	21.110	AVG BOT 8ft/12ft	1.0970 1.0529
Coolant Temp: Deg-F	548.4		
In Channel Flow: Mlb/hr	92.03	Active Channel Flow: Mlb/hr	88.76
Total Bypass Flow (%):	12.0	(of total core flow)	
Total Water Rod Flow (%):	3.1	(of total core flow)	
Source Convergence	0.00009		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR					LHGR									
Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K
1.405	22	41	40	1.705	0.839	22	19	40	7.96	0.791	43.3	20	19	12	5	11.55	0.827	20.1	23	19	10	5
1.397	22	39	42	1.714	0.834	22	21	42	8.10	0.784	40.6	20	17	14	5	11.38	0.811	19.4	22	39	50	5
1.392	22	37	40	1.716	0.833	22	39	38	8.01	0.774	40.5	20	15	16	5	8.47	0.807	48.8	20	41	50	5
1.388	22	39	38	1.729	0.827	22	43	42	8.02	0.772	40.1	20	17	18	5	11.27	0.805	19.6	22	17	16	4
1.386	22	43	42	1.730	0.827	22	37	40	7.81	0.769	42.4	21	19	16	5	11.29	0.803	19.2	24	21	10	5
1.386	22	41	44	1.741	0.821	22	41	44	7.67	0.758	42.8	21	19	20	5	11.27	0.803	19.4	22	41	48	5
1.370	22	43	38	1.741	0.821	22	43	24	9.77	0.755	15.6	24	21	10	5	11.22	0.800	19.5	22	17	50	5
1.354	22	43	46	1.763	0.811	22	41	36	7.76	0.744	39.8	20	13	18	5	11.17	0.797	19.6	22	15	48	5
1.354	22	33	40	1.765	0.810	22	35	42	7.48	0.744	43.4	20	17	22	5	8.54	0.797	47.0	20	15	16	5
1.352	22	35	38	1.782	0.802	22	35	38	7.52	0.743	42.8	21	21	14	5	8.54	0.795	46.7	20	17	14	5

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

Figure A.30 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and Axial Distributions at 8,700.0 MWd/MTU

**Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design**

Revision 1

Page A-36

Cycle:	19	Core Average Exposure: MWd/MTU	22999.4
Exposure: MWd/MTU (GWd)	9100.0 (1253.90)		
Delta E: MWd/MTU, (GWd)	400.0 (55.11)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-26.82		
Flow: Mlb/hr	102.91 (100.40 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top	25 0.212 4.663 14 0.407 0.407 35 2
			24 0.564 13.206 16 0.375 0.587 11 52
			23 0.718 17.324 17 0.339 0.394 35 60
			22 0.799 20.184 18 0.390 0.440 29 60
			21 0.856 21.863 19 0.807 1.110 47 48
			20 0.901 22.912 20 1.115 1.280 39 40
			19 0.919 23.492 21 1.128 1.233 41 42
			18 0.938 24.067 22 1.240 1.409 41 40
			17 0.941 24.302 23 1.051 1.255 41 52
			16 0.955 24.902 24 1.009 1.280 39 52
			15 0.980 25.673
			14 0.981 25.770
			13 1.083 24.741
			12 1.125 25.482
			11 1.158 25.948
			10 1.200 26.478
			9 1.253 27.223
			8 1.304 27.722
			7 1.362 28.123
			6 1.434 28.949
			5 1.458* 29.015*
			4 1.399 27.893
			3 1.254 25.544
			2 0.940 19.550
		Bottom	1 0.268 5.643
Control Rod Density: %	5.09		
k-effective:	0.99851		
Void Fraction:	0.459		
Core Delta-P: psia	25.097	% AXIAL TILT	-18.365 -9.176
Core Plate Delta-P: psia	20.537	AVG BOT 8ft/12ft	1.0985 1.0530
Coolant Temp: Deg-F	548.3		
In Channel Flow: Mlb/hr	90.54	Active Channel Flow: Mlb/hr	87.31
Total Bypass Flow (%):	12.0	(of total core flow)	
Total Water Rod Flow (%):	3.1	(of total core flow)	
Source Convergence	0.00009		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	IR	JR	K	Value
1.409	22	41	40	1.697	0.843	22	19	8.04	0.805	44.0	20	19	12	5	11.73
1.400	22	39	42	1.706	0.838	22	21	8.17	0.796	41.3	20	17	14	5	11.52
1.395	22	37	40	1.709	0.837	22	39	8.08	0.786	41.2	20	15	16	5	11.44
1.391	22	39	38	1.719	0.832	22	43	8.07	0.782	40.8	20	17	18	5	11.50
1.390	22	41	44	1.722	0.830	22	37	7.86	0.779	43.0	21	19	16	5	8.54
1.390	22	43	42	1.729	0.827	22	41	10.00	0.776	16.1	24	21	10	4	11.39
1.373	22	43	38	1.734	0.825	22	43	7.71	0.768	43.4	21	19	20	5	11.41
1.359	22	43	46	1.757	0.814	22	41	9.85	0.764	16.1	23	19	10	4	11.34
1.356	22	33	40	1.759	0.813	22	35	9.83	0.761	15.7	22	17	12	4	11.24
1.353	22	35	38	1.775	0.806	22	35	9.76	0.759	16.5	22	17	16	5	8.59

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

**Figure A.31 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and
Axial Distributions at 9,100.0 MWd/MTU**

Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design

Revision 1

Page A-37

Cycle:	19	Core Average Exposure: MWd/MTU	23000.4
Exposure: MWd/MTU (GWd)	9101.0 (1254.00)		
Delta E: MWd/MTU, (GWd)	1.0 (0.14)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-26.23		
Flow: Mlb/hr	105.06 (102.50 %)		
		Axial Profile	Edit Radial Power
		N(PRA) Power Exposure	Zone Avg. Max. IR JR
		Top 25 0.211 4.663	14 0.409 0.409 35 2
		24 0.562 13.206	16 0.375 0.588 11 52
		23 0.716 17.325	17 0.340 0.395 35 60
		22 0.795 20.184	18 0.391 0.442 29 60
		21 0.849 21.864	19 0.809 1.115 47 48
		20 0.891 22.913	20 1.113 1.279 39 40
		19 0.904 23.493	21 1.127 1.234 41 42
		18 0.923 24.068	22 1.238 1.408 41 40
		17 0.931 24.303	23 1.055 1.262 41 52
		16 0.949 24.903	24 1.012 1.287 39 52
		15 0.977 25.674	
		14 0.980 25.771	
		13 1.085 24.742	
		12 1.129 25.483	
		11 1.164 25.949	
		10 1.207 26.480	
		9 1.261 27.224	
		8 1.312 27.724	
		7 1.371 28.124	
		6 1.443 28.950	
		5 1.466* 29.016*	
		4 1.405 27.894	
		3 1.259 25.545	
		2 0.943 19.551	
		Bottom 1 0.269 5.643	
		% AXIAL TILT -18.991 -9.176	
		AVG BOT 8ft/12ft 1.1025 1.0530	
Control Rod Density: %	5.18		
k-effective:	0.99851		
Void Fraction:	0.456		
Core Delta-P: psia	25.901		
Core Plate Delta-P: psia	21.340		
Coolant Temp: Deg-F	548.4		
In Channel Flow: Mlb/hr	92.47	Active Channel Flow: Mlb/hr	89.18
Total Bypass Flow (%):	12.0	(of total core flow)	
Total Water Rod Flow (%):	3.1	(of total core flow)	
Source Convergence	0.00009		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	Value	Margin	Exp.	FT
1.408	22	41	40	1.719	0.832	22	19	8.09	0.810	44.0	20	11.75	0.849	21.0	23
1.402	22	39	42	1.728	0.827	22	21	8.23	0.801	41.3	20	11.60	0.833	20.4	22
1.395	22	37	40	1.741	0.821	22	37	8.13	0.791	41.2	20	11.50	0.828	20.6	22
1.394	22	41	44	1.742	0.821	22	43	8.12	0.787	40.8	20	11.57	0.826	19.7	24
1.392	22	43	42	1.748	0.818	22	41	7.91	0.784	43.0	21	8.59	0.826	49.5	20
1.387	22	39	38	1.749	0.818	22	39	10.06	0.780	16.1	24	11.47	0.824	20.4	22
1.368	22	43	38	1.775	0.805	22	43	7.76	0.772	43.4	21	11.42	0.821	20.5	22
1.364	22	43	46	1.777	0.805	22	35	9.91	0.769	16.1	23	11.36	0.818	20.6	22
1.357	22	33	40	1.798	0.795	22	43	9.89	0.765	15.7	22	11.30	0.814	20.7	22
1.353	22	35	38	1.798	0.795	22	27	9.82	0.764	16.5	22	8.65	0.814	47.7	20

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

Figure A.32 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and Axial Distributions at 9,101.0 MWd/MTU

**Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design**

Revision 1

Page A-38

Cycle:	19	Core Average Exposure: MWd/MTU	23358.8
Exposure: MWd/MTU (GWd)	9459.4 (1303.40)		
Delta E: MWd/MTU, (GWd)	358.4 (49.38)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-26.65		
Flow: Mlb/hr	103.53 (101.00 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top	25 0.211 4.744 14 0.406 0.406 35 2
			24 0.561 13.421 16 0.374 0.587 11 52
			23 0.714 17.598 17 0.338 0.393 35 60
			22 0.792 20.490 18 0.389 0.440 29 60
			21 0.845 22.190 19 0.807 1.113 47 48
			20 0.886 23.255 20 1.110 1.275 39 40
			19 0.899 23.841 21 1.124 1.231 41 42
			18 0.918 24.423 22 1.241 1.410 41 40
			17 0.925 24.661 23 1.058 1.267 41 52
			16 0.943 25.263 24 1.016 1.293 39 52
			15 0.969 26.044
			14 0.972 26.142
			13 1.074 25.105
			12 1.118 25.861
			11 1.153 26.339
			10 1.199 26.884
			9 1.255 27.648
			8 1.311 28.165
			7 1.374 28.586
			6 1.453 29.438
			5 1.482* 29.512*
			4 1.427 28.371
			3 1.282 25.973
			2 0.961 19.872
		Bottom	1 0.274 5.739
Control Rod Density: %	5.18		
k-effective:	0.99852		
Void Fraction:	0.460		
Core Delta-P: psia	25.362	% AXIAL TILT	-19.452 -9.236
Core Plate Delta-P: psia	20.801	AVG BOT 8ft/12ft	1.1042 1.0532
Coolant Temp: Deg-F	548.4		
In Channel Flow: Mlb/hr	91.07	Active Channel Flow: Mlb/hr	87.82
Total Bypass Flow (%):	12.0	(of total core flow)	
Total Water Rod Flow (%):	3.1	(of total core flow)	
Source Convergence	0.00010		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR					LHGR									
Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K
1.410	22	41	40	1.712	0.835	22	19	40	8.16	0.822	44.6	20	19	12	5	11.97	0.868	21.4	23	19	10	4
1.405	22	39	42	1.721	0.831	22	21	42	8.29	0.813	42.0	20	17	14	5	11.81	0.851	20.8	22	39	50	4
1.398	22	41	44	1.733	0.825	22	43	42	8.18	0.801	41.8	20	15	16	5	11.65	0.845	21.5	22	17	16	4
1.397	22	37	40	1.734	0.824	22	37	40	10.24	0.799	16.8	24	21	10	4	11.71	0.843	20.6	24	21	10	4
1.396	22	43	42	1.738	0.823	22	41	44	8.17	0.797	41.4	20	17	18	5	11.66	0.841	20.8	22	41	48	4
1.389	22	39	38	1.742	0.821	22	39	38	7.96	0.794	43.6	21	19	16	5	11.64	0.840	20.8	22	17	12	4
1.371	22	43	38	1.768	0.809	22	43	24	10.13	0.790	16.8	23	19	10	4	8.65	0.838	50.1	20	41	50	5
1.369	22	43	46	1.772	0.807	22	35	42	10.12	0.788	16.5	22	17	12	4	11.57	0.836	21.0	22	15	14	4
1.359	22	33	40	1.786	0.801	22	43	46	10.02	0.783	16.9	22	17	16	4	11.45	0.831	21.6	22	15	18	4
1.356	22	45	44	1.791	0.799	22	45	44	7.80	0.781	44.0	21	19	20	5	8.72	0.825	48.1	20	17	14	5

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

**Figure A.33 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and
Axial Distributions at 9,459.4 MWd/MTU**

Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design

Revision 1

Page A-39

Cycle:	19	Core Average Exposure: MWd/MTU	23363.3
Exposure: MWd/MTU (GWd)	9463.9 (1304.00)		
Delta E: MWd/MTU, (GWd)	4.6 (0.63)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-25.84		
Flow: Mlb/hr	106.50 (103.90 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top 25	0.220 4.745 14 0.416 0.416 35 2
		24	0.585 13.424 16 0.381 0.580 9 12
		23	0.743 17.602 17 0.345 0.405 59 36
		22	0.818 20.494 18 0.399 0.458 1 30
		21	0.865 22.194 19 0.826 1.093 47 48
		20	0.896 23.259 20 1.102 1.220 39 40
		19	0.904 23.845 21 1.076 1.198 31 48
		18	0.909 24.428 22 1.228 1.347 15 30
		17	0.915 24.665 23 1.091 1.245 53 34
		16	0.933 25.268 24 1.062 1.264 39 52
		15	0.959 26.049
		14	0.961 26.147
		13	1.063 25.110
		12	1.108 25.866
		11	1.144 26.344
		10	1.191 26.890
		9	1.249 27.653
		8	1.307 28.171
		7	1.372 28.592
		6	1.452 29.444
		5	1.482* 29.519*
		4	1.425 28.377
		3	1.276 25.978
		2	0.952 19.876
		Bottom 1	0.271 5.741
Control Rod Density: %	5.59		
k-effective:	0.99850		
Void Fraction:	0.456		
Core Delta-P: psia	26.419	% AXIAL TILT	-18.877 -9.237
Core Plate Delta-P: psia	21.856	AVG BOT 8ft/12ft	1.0983 1.0532
Coolant Temp: Deg-F	548.5		
In Channel Flow: Mlb/hr	93.76	Active Channel Flow: Mlb/hr	90.44
Total Bypass Flow (%):	12.0	(of total core flow)	
Total Water Rod Flow (%):	3.1	(of total core flow)	
Source Convergence	0.00008		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	Value	Margin	Exp.	FT
1.347	22	15	30	1.807	0.791	22	19 40	7.63	0.772	45.1	20	11.23	0.818	22.0	23
1.343	22	49	32	1.810	0.790	22	45 30	7.59	0.766	44.7	20	11.18	0.809	21.3	23
1.342	22	31	46	1.811	0.790	22	49 30	7.81	0.765	41.8	20	11.09	0.804	21.4	23
1.337	22	39	38	1.814	0.788	22	21 38	7.63	0.765	44.1	21	11.08	0.802	21.2	23
1.336	22	37	40	1.817	0.787	22	29 46	9.78	0.763	16.8	24	8.27	0.798	49.9	20
1.333	22	41	40	1.817	0.787	22	21 42	7.64	0.762	43.7	21	11.04	0.798	21.0	22
1.332	22	47	34	1.819	0.786	22	37 40	7.53	0.759	44.6	20	11.00	0.797	21.4	23
1.331	22	31	50	1.828	0.782	22	29 50	7.68	0.758	42.6	21	8.17	0.797	50.7	20
1.329	22	39	42	1.829	0.782	22	19 36	7.79	0.757	41.0	20	11.04	0.795	20.6	22
1.319	22	33	48	1.836	0.779	22	35 42	7.72	0.757	42.0	20	11.00	0.795	21.0	24

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

Figure A.34 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and Axial Distributions at 9,463.9 MWd/MTU

**Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design**

Revision 1

Page A-40

Cycle:	19	Core Average Exposure: MWd/MTU	23899.3
Exposure: MWd/MTU (GWd)	10000.0 (1377.90)		
Delta E: MWd/MTU, (GWd)	536.1 (73.86)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-26.56		
Flow: Mlb/hr	103.83 (101.30 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top	25 0.219 4.871 14 0.412 0.412 35 2
			24 0.583 13.759 16 0.378 0.578 9 12
			23 0.739 18.026 17 0.342 0.401 59 36
			22 0.811 20.963 18 0.397 0.455 1 30
			21 0.857 22.690 19 0.822 1.090 47 48
			20 0.887 23.773 20 1.098 1.214 39 40
			19 0.896 24.364 21 1.071 1.190 31 48
			18 0.900 24.949 22 1.233 1.351 15 30
			17 0.906 25.191 23 1.095 1.250 53 34
			16 0.923 25.795 24 1.066 1.271 39 52
			15 0.947 26.591
			14 0.949 26.690
			13 1.047 25.641
			12 1.091 26.419
			11 1.128 26.916
			10 1.179 27.486
			9 1.242 28.281
			8 1.306 28.829
			7 1.378 29.285
			6 1.467 30.179
			5 1.507* 30.271*
			4 1.460 29.104
			3 1.315 26.630
			2 0.983 20.363
		Bottom	1 0.280 5.887
Control Rod Density: %	5.59		
k-effective:	0.99852		
Void Fraction:	0.463		
Core Delta-P: psia	25.479	% AXIAL TILT	-19.700 -9.324
Core Plate Delta-P: psia	20.917	AVG BOT 8ft/12ft	1.1018 1.0534
Coolant Temp: Deg-F	548.4		
In Channel Flow: Mlb/hr	91.34	Active Channel Flow: Mlb/hr	88.08
Total Bypass Flow (%):	12.0	(of total core flow)	
Total Water Rod Flow (%):	3.1	(of total core flow)	
Source Convergence	0.00008		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	Value	Margin	Exp.	FT
1.351	22	15	30	1.797	0.796	22	49	7.71	0.788	45.9	20	11.43	0.838	22.7	23
1.347	22	49	32	1.797	0.796	22	19	9.99	0.787	17.9	24	11.31	0.828	22.6	23
1.344	22	31	46	1.797	0.796	22	45	7.69	0.782	45.6	20	11.24	0.824	22.7	23
1.341	22	39	38	1.804	0.793	22	21	7.73	0.782	45.0	21	11.35	0.823	21.4	22
1.340	22	37	40	1.806	0.792	22	29	9.90	0.780	17.9	23	11.24	0.820	22.1	23
1.338	22	41	40	1.808	0.791	22	21	7.89	0.779	42.7	20	11.21	0.820	22.4	23
1.337	22	47	34	1.809	0.790	22	37	7.73	0.778	44.6	21	11.18	0.817	22.3	22
1.335	22	31	50	1.816	0.788	22	29	7.62	0.775	45.5	20	11.22	0.816	21.8	24
1.334	22	39	42	1.821	0.785	22	19	7.80	0.772	42.9	20	8.35	0.815	50.9	20
1.323	22	33	48	1.827	0.783	22	35	7.87	0.771	41.9	20	8.24	0.813	51.7	20

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

**Figure A.35 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and
Axial Distributions at 10,000.0 MWd/MTU**

Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design

Revision 1

Page A-41

Cycle:	19	Core Average Exposure: MWd/MTU	24149.3
Exposure: MWd/MTU (GWd)	10250.0 (1412.30)		
Delta E: MWd/MTU, (GWd)	250.0 (34.45)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-26.91		
Flow: Mlb/hr	102.60 (100.10 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top 25	0.219 4.930 14 0.410 0.410 35 2
		24	0.581 13.914 16 0.377 0.578 9 12
		23	0.736 18.223 17 0.341 0.399 59 36
		22	0.808 21.180 18 0.396 0.454 1 30
		21	0.853 22.920 19 0.820 1.089 47 48
		20	0.883 24.011 20 1.096 1.210 39 40
		19	0.891 24.604 21 1.069 1.188 31 48
		18	0.896 25.191 22 1.235 1.353 15 32
		17	0.902 25.434 23 1.097 1.254 53 34
		16	0.918 26.040 24 1.068 1.273 39 52
		15	0.943 26.842
		14	0.943 26.941
		13	1.040 25.886
		12	1.084 26.674
		11	1.122 27.180
		10	1.174 27.762
		9	1.239 28.572
		8	1.305 29.135
		7	1.381 29.609
		6	1.473 30.524
		5	1.518* 30.626*
		4	1.476 29.448
		3	1.333 26.941
		2	0.997 20.595
		Bottom 1	0.284 5.957
Control Rod Density: %	5.59		
k-effective:	0.99853		
Void Fraction:	0.466		
Core Delta-P: psia	25.051	% AXIAL TILT	-20.082 -9.371
Core Plate Delta-P: psia	20.489	AVG BOT 8ft/12ft	1.1035 1.0535
Coolant Temp: Deg-F	548.4		
In Channel Flow: Mlb/hr	90.23	Active Channel Flow: Mlb/hr	86.99
Total Bypass Flow (%):	12.1	(of total core flow)	
Total Water Rod Flow (%):	3.2	(of total core flow)	
Source Convergence	0.00008		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR					LHGR				
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	IR	Value	Margin	Exp.	FT	IR
1.353	22	15	32	1.789	0.799	22	49	7.74	0.795	46.4	20	9	11.47	0.846	23.4	23	19
1.350	22	49	32	1.791	0.798	22	45	10.04	0.794	18.5	24	21	11.43	0.837	22.6	23	9
1.346	22	31	46	1.792	0.798	22	19	9.99	0.791	18.5	23	19	11.44	0.833	22.0	22	23
1.342	22	39	38	1.799	0.795	22	21	7.73	0.790	46.0	20	29	11.36	0.832	22.6	23	25
1.341	22	37	40	1.800	0.795	22	29	7.76	0.789	45.4	21	25	11.32	0.830	22.7	23	23
1.339	22	47	34	1.804	0.793	22	21	7.77	0.786	45.0	21	9	11.27	0.829	23.0	23	7
1.339	22	41	40	1.804	0.792	22	37	7.89	0.783	43.1	20	15	11.24	0.825	22.9	22	9
1.338	22	31	50	1.808	0.791	22	29	9.92	0.782	18.1	22	17	11.25	0.822	22.4	24	21
1.335	22	39	42	1.816	0.787	22	19	9.92	0.781	17.9	22	23	8.36	0.821	51.3	20	39
1.325	22	33	48	1.823	0.784	22	35	7.63	0.779	45.9	20	19	8.28	0.820	52.1	20	9

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

Figure A.36 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and Axial Distributions at 10,250.0 MWd/MTU

**Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design**

Revision 1

Page A-42

Cycle:	19	Core Average Exposure: MWd/MTU	24150.3
Exposure: MWd/MTU (GWd)	10251.0 (1412.40)		
Delta E: MWd/MTU, (GWd)	1.0 (0.14)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-25.84		
Flow: Mlb/hr	106.50 (103.90 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top	25 0.217 4.930 14 0.410 0.410 35 2
			24 0.576 13.915 16 0.377 0.577 9 12
			23 0.729 18.224 17 0.340 0.399 59 36
			22 0.797 21.181 18 0.396 0.454 1 30
			21 0.837 22.921 19 0.822 1.091 47 48
			20 0.859 24.012 20 1.095 1.210 39 40
			19 0.858 24.605 21 1.067 1.190 31 48
			18 0.873 25.192 22 1.234 1.356 15 30
			17 0.887 25.435 23 1.100 1.259 53 34
			16 0.910 26.041 24 1.070 1.275 39 52
			15 0.939 26.843
			14 0.944 26.942
			13 1.045 25.887
			12 1.092 26.675
			11 1.133 27.181
			10 1.187 27.763
			9 1.254 28.573
			8 1.321 29.136
			7 1.398 29.610
			6 1.490 30.526
			5 1.533* 30.628*
			4 1.488 29.450
			3 1.343 26.942
			2 1.004 20.596
		Bottom	1 0.286 5.957
Control Rod Density: %	5.77		
k-effective:	0.99850		
Void Fraction:	0.462		
Core Delta-P: psia	26.522	% AXIAL TILT	-21.298 -9.371
Core Plate Delta-P: psia	21.957	AVG BOT 8ft/12ft	1.1116 1.0535
Coolant Temp: Deg-F	548.5		
In Channel Flow: Mlb/hr	93.72	Active Channel Flow: Mlb/hr	90.38
Total Bypass Flow (%):	12.0	(of total core flow)	
Total Water Rod Flow (%):	3.1	(of total core flow)	
Source Convergence	0.00010		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	Value	Margin	Exp.	FT
1.356	22	15	30	1.830	0.781	22	49	7.83	0.804	46.4	20	11.58	0.854	23.4	23
1.354	22	49	32	1.832	0.781	22	45	10.14	0.802	18.5	24	11.54	0.845	22.6	23
1.349	22	31	46	1.838	0.778	22	21	7.81	0.799	46.0	20	11.56	0.842	22.0	22
1.344	22	39	38	1.839	0.778	22	19	10.09	0.799	18.5	23	11.42	0.841	23.3	23
1.343	22	37	40	1.840	0.777	22	29	7.85	0.797	45.4	21	11.40	0.838	23.0	23
1.342	22	31	50	1.844	0.776	22	37	7.86	0.795	45.0	21	11.43	0.838	22.7	23
1.340	22	47	34	1.850	0.773	22	29	7.98	0.792	43.1	20	11.37	0.835	22.9	22
1.337	22	41	40	1.850	0.773	22	21	10.01	0.790	18.1	22	11.37	0.831	22.4	24
1.333	22	39	42	1.855	0.771	22	19	10.02	0.789	17.9	22	8.46	0.830	51.3	20
1.326	22	33	48	1.862	0.768	22	35	7.72	0.788	45.9	20	8.37	0.829	52.1	20

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

**Figure A.37 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and
Axial Distributions at 10,251.0 MWd/MTU**

**Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design**

Revision 1

Page A-43

Cycle:	19	Core Average Exposure: MWd/MTU	24599.2
Exposure: MWd/MTU (GWd)	10700.0 (1474.30)		
Delta E: MWd/MTU, (GWd)	449.0 (61.87)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-26.37		
Flow: Mlb/hr	104.55 (102.00 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top	25 0.217 5.034 14 0.407 0.407 35 2
			24 0.574 14.190 16 0.375 0.576 9 12
			23 0.726 18.573 17 0.338 0.397 59 36
			22 0.792 21.565 18 0.394 0.453 1 30
			21 0.832 23.323 19 0.819 1.087 47 48
			20 0.854 24.426 20 1.091 1.205 39 40
			19 0.853 25.018 21 1.064 1.186 31 48
			18 0.869 25.612 22 1.237 1.359 15 32
			17 0.882 25.862 23 1.104 1.265 53 34
			16 0.905 26.473 24 1.074 1.278 51 40
			15 0.934 27.289
			14 0.938 27.390
			13 1.037 26.325
			12 1.082 27.133
			11 1.124 27.657
			10 1.181 28.263
			9 1.251 29.101
			8 1.321 29.694
			7 1.401 30.200
			6 1.497 31.155
			5 1.545* 31.277*
			4 1.507 30.081
			3 1.366 27.513
			2 1.023 21.023
		Bottom	1 0.291 6.085
Control Rod Density: %	5.77		
k-effective:	0.99858		
Void Fraction:	0.466		
Core Delta-P: psia	25.825	% AXIAL TILT	-21.753 -9.481
Core Plate Delta-P: psia	21.261	AVG BOT 8ft/12ft	1.1137 1.0539
Coolant Temp: Deg-F	548.5		
In Channel Flow: Mlb/hr	91.95	Active Channel Flow: Mlb/hr	88.66
Total Bypass Flow (%):	12.1	(of total core flow)	
Total Water Rod Flow (%):	3.2	(of total core flow)	
Source Convergence	0.00008		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	Value	Margin	Exp.	FT
1.359	22	15	32	1.818	0.786	22	49	7.85	0.812	47.1	20	11.54	0.859	24.5	23
1.358	22	49	32	1.821	0.785	22	45	10.15	0.809	19.4	23	11.59	0.857	23.7	23
1.353	22	31	46	1.830	0.782	22	29	7.85	0.808	46.7	20	11.55	0.854	23.7	23
1.347	22	31	50	1.831	0.781	22	21	10.13	0.808	19.4	24	11.61	0.854	23.1	22
1.347	22	39	38	1.831	0.781	22	19	7.86	0.805	46.2	21	11.56	0.853	23.4	23
1.346	22	37	40	1.836	0.779	22	37	7.89	0.804	45.7	21	11.46	0.848	23.8	23
1.344	22	47	34	1.837	0.779	22	29	10.13	0.804	18.8	22	11.39	0.844	24.0	22
1.340	22	41	40	1.843	0.776	22	21	10.07	0.801	19.1	22	11.63	0.844	21.5	22
1.336	22	39	42	1.848	0.774	22	19	10.09	0.799	18.5	23	11.37	0.839	23.5	22
1.330	22	33	48	1.855	0.771	22	35	10.09	0.799	18.6	22	11.37	0.839	23.5	22

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

**Figure A.38 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and
Axial Distributions at 10,700.0 MWd/MTU**

Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design

Revision 1

Page A-44

Cycle:	19	Core Average Exposure: MWd/MTU	24899.3
Exposure: MWd/MTU (GWd)	11000.0 (1515.60)		
Delta E: MWd/MTU, (GWd)	300.0 (41.34)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-26.65		
Flow: Mlb/hr	103.53 (101.00 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top	25 0.217 5.104 14 0.405 0.405 35 2
			24 0.574 14.374 16 0.374 0.574 9 12
			23 0.725 18.805 17 0.337 0.395 59 36
			22 0.791 21.820 18 0.392 0.452 1 30
			21 0.831 23.591 19 0.817 1.085 47 48
			20 0.853 24.701 20 1.089 1.201 39 40
			19 0.852 25.294 21 1.062 1.184 31 48
			18 0.868 25.892 22 1.240 1.361 15 32
			17 0.882 26.147 23 1.106 1.268 53 34
			16 0.904 26.761 24 1.075 1.281 51 40
			15 0.933 27.586
			14 0.936 27.689
			13 1.034 26.617
			12 1.079 27.438
			11 1.122 27.973
			10 1.179 28.595
			9 1.250 29.454
			8 1.322 30.066
			7 1.401 30.595
			6 1.497 31.577
			5 1.545* 31.712*
			4 1.510 30.506
			3 1.374 27.899
			2 1.029 21.312
		Bottom	1 0.293 6.172
Control Rod Density: %	5.77		
k-effective:	0.99870		
Void Fraction:	0.468		
Core Delta-P: psia	25.456	% AXIAL TILT	-21.854 -9.557
Core Plate Delta-P: psia	20.893	AVG BOT 8ft/12ft	1.1142 1.0542
Coolant Temp: Deg-F	548.5		
In Channel Flow: Mlb/hr	91.02	Active Channel Flow: Mlb/hr	87.75
Total Bypass Flow (%):	12.1	(of total core flow)	
Total Water Rod Flow (%):	3.2	(of total core flow)	
Source Convergence	0.00010		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	Value	Margin	Exp.	FT
1.361	22	15	32	1.811	0.790	22	49	7.81	0.812	47.6	20	11.52	0.858	24.5	23
1.360	22	49	32	1.815	0.788	22	45	7.83	0.811	47.2	20	11.53	0.858	24.4	23
1.356	22	31	46	1.822	0.785	22	29	10.10	0.810	20.1	23	11.54	0.858	24.2	23
1.350	22	31	50	1.825	0.783	22	21	10.12	0.807	19.5	22	11.57	0.856	23.8	22
1.349	22	39	38	1.826	0.783	22	19	7.83	0.806	46.7	21	11.41	0.855	25.2	23
1.348	22	37	40	1.829	0.782	22	29	7.86	0.806	46.2	21	11.67	0.852	22.2	22
1.346	22	47	34	1.830	0.781	22	37	10.05	0.806	20.1	24	11.40	0.849	24.5	23
1.342	22	41	40	1.837	0.778	22	21	10.12	0.805	19.2	22	11.42	0.847	24.0	22
1.339	22	39	42	1.843	0.776	22	19	10.11	0.805	19.2	23	11.49	0.845	23.1	23
1.333	22	33	48	1.849	0.774	22	47	10.19	0.802	17.9	24	11.41	0.844	23.7	23

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

Figure A.39 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and Axial Distributions at 11,000.0 MWd/MTU

Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design

Revision 1

Page A-45

Cycle:	19	Core Average Exposure: MWd/MTU	25199.3
Exposure: MWd/MTU (GWd)	11300.0 (1557.00)		
Delta E: MWd/MTU, (GWd)	300.0 (41.34)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-26.94		
Flow: Mlb/hr	102.50 (100.00 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top	25 0.217 5.174 14 0.404 0.404 35 2
			24 0.574 14.558 16 0.373 0.573 9 12
			23 0.725 19.038 17 0.336 0.394 59 36
			22 0.791 22.074 18 0.391 0.451 1 30
			21 0.831 23.859 19 0.816 1.083 47 48
			20 0.854 24.976 20 1.086 1.198 39 40
			19 0.853 25.569 21 1.060 1.181 31 48
			18 0.869 26.173 22 1.242 1.363 15 32
			17 0.884 26.431 23 1.108 1.271 53 34
			16 0.906 27.049 24 1.077 1.284 51 40
			15 0.934 27.883
			14 0.937 27.987
			13 1.034 26.908
			12 1.079 27.742
			11 1.121 28.289
			10 1.179 28.928
			9 1.250 29.806
			8 1.322 30.439
			7 1.400 30.989
			6 1.493 31.999
			5 1.540* 32.147*
			4 1.507 30.931
			3 1.375 28.287
			2 1.031 21.602
		Bottom	1 0.294 6.259
Control Rod Density: %	5.77		
k-effective:	0.99879		
Void Fraction:	0.469		
Core Delta-P: psia	25.081	% AXIAL TILT	-21.760 -9.630
Core Plate Delta-P: psia	20.519	AVG BOT 8ft/12ft	1.1138 1.0544
Coolant Temp: Deg-F	548.5		
In Channel Flow: Mlb/hr	90.10	Active Channel Flow: Mlb/hr	86.86
Total Bypass Flow (%):	12.1	(of total core flow)	
Total Water Rod Flow (%):	3.2	(of total core flow)	
Source Convergence	0.00008		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	IR	Value	Margin	Exp.
1.363	22	15	32	1.803	0.793	22	49	7.77	0.809	47.7	20	29	11.47	0.857	24.9
1.362	22	49	32	1.808	0.791	22	45	7.73	0.809	48.1	20	9	11.43	0.857	25.2
1.359	22	31	46	1.814	0.788	22	29	10.07	0.805	19.8	23	9	11.63	0.855	22.9
1.353	22	31	50	1.818	0.786	22	21	10.06	0.805	19.8	22	9	11.39	0.853	25.1
1.352	22	39	38	1.820	0.786	22	29	9.99	0.805	20.7	23	19	11.44	0.853	24.5
1.351	22	37	40	1.820	0.786	22	19	10.03	0.805	20.1	22	23	11.22	0.846	25.9
1.347	22	47	34	1.821	0.785	22	23	7.80	0.804	46.7	21	9	11.43	0.846	23.8
1.344	22	41	40	1.830	0.781	22	21	10.07	0.804	19.5	22	27	11.42	0.846	23.9
1.341	22	39	42	1.836	0.779	22	19	7.76	0.803	47.2	21	25	11.27	0.845	25.2
1.337	22	33	48	1.841	0.777	22	47	10.13	0.802	18.6	24	9	11.34	0.845	24.5

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

Figure A.40 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and Axial Distributions at 11,300.0 MWd/MTU

**Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design**

Revision 1

Page A-46

Cycle:	19	Core Average Exposure: MWd/MTU	25200.3
Exposure: MWd/MTU (GWd)	11301.0 (1557.10)		
Delta E: MWd/MTU, (GWd)	1.0 (0.14)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-26.37		
Flow: Mlb/hr	104.55 (102.00 %)		
		Axial Profile	Edit Radial Power
		N (PRA) Power Exposure	Zone Avg. Max. IR JR
		Top 25 0.213 5.174	14 0.405 0.405 35 2
		24 0.565 14.559	16 0.374 0.575 9 12
		23 0.713 19.038	17 0.337 0.395 59 36
		22 0.775 22.075	18 0.393 0.453 1 30
		21 0.811 23.860	19 0.819 1.087 47 48
		20 0.840 24.977	20 1.084 1.195 39 40
		19 0.844 25.570	21 1.058 1.182 31 48
		18 0.863 26.174	22 1.240 1.365 49 32
		17 0.880 26.432	23 1.113 1.277 53 34
		16 0.905 27.050	24 1.082 1.290 51 40
		15 0.936 27.884	
		14 0.940 27.988	
		13 1.039 26.909	
		12 1.085 27.743	
		11 1.128 28.290	
		10 1.188 28.929	
		9 1.259 29.807	
		8 1.331 30.440	
		7 1.409 30.991	
		6 1.503 32.000	
		5 1.548* 32.148*	
		4 1.514 30.933	
		3 1.381 28.288	
		2 1.035 21.603	
		Bottom 1 0.295 6.260	
Control Rod Density: %	5.86		
k-effective:	0.99879		
Void Fraction:	0.467		
Core Delta-P: psia	25.856	% AXIAL TILT	-22.497 -9.630
Core Plate Delta-P: psia	21.292	AVG BOT 8ft/12ft	1.1193 1.0544
Coolant Temp: Deg-F	548.5		
In Channel Flow: Mlb/hr	91.94	Active Channel Flow: Mlb/hr	88.64
Total Bypass Flow (%):	12.1	(of total core flow)	
Total Water Rod Flow (%):	3.2	(of total core flow)	
Source Convergence	0.00010		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	Value	Margin	Exp.	FT
1.365	22	49	32	1.822	0.785	22	49	7.82	0.814	47.7	20	11.53	0.862	24.9	23
1.363	22	15	32	1.839	0.778	22	29	7.78	0.814	48.1	20	11.49	0.861	25.2	23
1.359	22	31	46	1.839	0.778	22	45	10.12	0.810	19.8	23	11.70	0.859	22.9	22
1.356	22	31	50	1.844	0.775	22	29	10.12	0.810	19.8	22	11.45	0.858	25.1	23
1.349	22	47	34	1.845	0.775	22	19	10.04	0.809	20.7	23	11.51	0.857	24.5	22
1.347	22	21	24	1.854	0.771	22	21	10.09	0.809	20.1	22	11.28	0.851	25.9	23
1.346	22	37	40	1.855	0.771	22	21	7.85	0.809	46.7	21	11.49	0.851	23.8	23
1.343	22	41	40	1.856	0.770	22	23	10.13	0.808	19.5	22	11.49	0.851	23.9	22
1.340	22	39	42	1.860	0.769	22	47	7.80	0.808	47.2	21	11.41	0.849	24.5	23
1.339	22	33	48	1.871	0.764	22	19	10.19	0.807	18.6	24	11.33	0.849	25.2	23

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

**Figure A.41 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and
Axial Distributions at 11,301.0 MWd/MTU**

Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design

Revision 1

Page A-47

Cycle:	19	Core Average Exposure: MWd/MTU	25699.4
Exposure: MWd/MTU (GWd)	11800.0 (1625.90)		
Delta E: MWd/MTU, (GWd)	499.0 (68.76)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-26.79		
Flow: Mlb/hr	103.01 (100.50 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top	25 0.215 5.288 14 0.402 0.402 35 2
			24 0.569 14.861 16 0.372 0.573 9 12
			23 0.717 19.420 17 0.335 0.393 59 36
			22 0.780 22.492 18 0.391 0.451 1 30
			21 0.817 24.296 19 0.816 1.083 47 48
			20 0.846 25.429 20 1.081 1.191 39 40
			19 0.852 26.025 21 1.055 1.178 31 48
			18 0.872 26.639 22 1.243 1.365 49 32
			17 0.890 26.908 23 1.116 1.280 53 34
			16 0.916 27.532 24 1.083 1.293 51 40
			15 0.946 28.382
			14 0.949 28.488
			13 1.046 27.397
			12 1.091 28.252
			11 1.134 28.820
			10 1.193 29.487
			9 1.263 30.398
			8 1.331 31.064
			7 1.402 31.649
			6 1.485 32.700
			5 1.523* 32.868*
			4 1.488 31.636
			3 1.361 28.930
			2 1.022 22.085
		Bottom	1 0.291 6.405
Control Rod Density: %	5.86		
k-effective:	0.99893		
Void Fraction:	0.467		
Core Delta-P: psia	25.265	% AXIAL TILT	-21.775 -9.755
Core Plate Delta-P: psia	20.702	AVG BOT 8ft/12ft	1.1161 1.0549
Coolant Temp: Deg-F	548.5		
In Channel Flow: Mlb/hr	90.57	Active Channel Flow: Mlb/hr	87.31
Total Bypass Flow (%):	12.1	(of total core flow)	
Total Water Rod Flow (%):	3.2	(of total core flow)	
Source Convergence	0.00009		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR					LHGR				
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	IR	Value	Margin	Exp.	FT	IR
1.365	22	49	32	1.809	0.790	22	49	7.62	0.801	48.5	20	29	11.44	0.850	24.1	22	9
1.364	22	15	32	1.823	0.784	22	29	7.56	0.798	48.9	20	9	11.21	0.848	26.1	23	7
1.364	22	31	46	1.826	0.783	22	45	9.87	0.797	20.9	23	9	11.14	0.844	26.4	23	25
1.359	22	31	50	1.827	0.783	22	23	9.89	0.796	20.6	22	27	11.21	0.839	25.0	23	7
1.351	22	21	24	1.828	0.782	22	29	9.99	0.796	19.3	22	9	11.14	0.839	25.7	22	23
1.351	22	37	40	1.831	0.781	22	39	7.65	0.795	47.6	21	9	11.20	0.838	25.0	22	9
1.350	22	47	34	1.833	0.780	22	19	9.85	0.795	20.9	22	9	11.21	0.838	24.9	22	33
1.345	22	41	40	1.840	0.777	22	21	9.87	0.794	20.6	23	7	11.05	0.837	26.3	23	9
1.345	22	39	42	1.846	0.775	22	47	9.94	0.794	19.6	24	9	11.11	0.836	25.6	23	7
1.343	22	33	48	1.857	0.770	22	19	7.60	0.794	48.0	21	25	11.11	0.836	25.6	23	33

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

Figure A.42 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and Axial Distributions at 11,800.0 MWd/MTU

**Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design**

Revision 1

Page A-48

Cycle:	19	Core Average Exposure: MWd/MTU	25890.4
Exposure: MWd/MTU (GWd)	11991.1 (1652.20)		
Delta E: MWd/MTU, (GWd)	191.1 (26.33)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-26.94		
Flow: Mlb/hr	102.50 (100.00 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top 25	0.216 5.332 14 0.402 0.402 35 2
		24	0.571 14.978 16 0.372 0.573 9 12
		23	0.720 19.566 17 0.335 0.392 59 36
		22	0.783 22.653 18 0.391 0.451 1 30
		21	0.820 24.465 19 0.815 1.082 47 48
		20	0.851 25.604 20 1.079 1.189 39 40
		19	0.856 26.200 21 1.054 1.177 31 48
		18	0.877 26.819 22 1.244 1.366 31 46
		17	0.896 27.091 23 1.117 1.281 53 34
		16	0.922 27.719 24 1.084 1.294 51 40
		15	0.952 28.575
		14	0.955 28.681
		13	1.051 27.586
		12	1.096 28.448
		11	1.138 29.024
		10	1.196 29.701
		9	1.265 30.625
		8	1.330 31.303
		7	1.397 31.901
		6	1.476 32.966
		5	1.509* 33.140*
		4	1.472 31.902
		3	1.349 29.173
		2	1.013 22.267
		Bottom 1	0.288 6.460
Control Rod Density: %	5.86		
k-effective:	0.99901		
Void Fraction:	0.467		
Core Delta-P: psia	25.062	% AXIAL TILT	-21.340 -9.797
Core Plate Delta-P: psia	20.499	AVG BOT 8ft/12ft	1.1142 1.0551
Coolant Temp: Deg-F	548.4		
In Channel Flow: Mlb/hr	90.11	Active Channel Flow: Mlb/hr	86.87
Total Bypass Flow (%):	12.1	(of total core flow)	
Total Water Rod Flow (%):	3.2	(of total core flow)	
Source Convergence	0.00009		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	Value	Margin	Exp.	FT
1.366	22	31	46	1.804	0.793	22	49	7.53	0.793	48.9	20	11.30	0.842	24.6	22
1.365	22	49	32	1.816	0.787	22	23	9.88	0.790	19.7	22	11.04	0.838	26.6	23
1.365	22	15	32	1.817	0.787	22	29	7.45	0.789	49.3	20	10.97	0.835	26.8	23
1.359	22	31	50	1.820	0.786	22	39	9.74	0.789	21.3	23	11.06	0.831	25.5	23
1.352	22	37	40	1.821	0.785	22	29	9.75	0.788	21.0	22	11.06	0.830	25.3	22
1.352	22	21	24	1.821	0.785	22	45	7.55	0.788	47.9	21	11.04	0.830	25.5	22
1.350	22	47	34	1.828	0.782	22	19	9.74	0.787	21.0	23	10.96	0.829	26.1	22
1.346	22	39	42	1.832	0.780	22	39	9.74	0.787	20.9	23	10.95	0.827	26.1	23
1.346	22	41	40	1.840	0.777	22	47	9.74	0.786	20.9	23	10.95	0.827	26.0	23
1.345	22	33	48	1.850	0.773	22	19	9.81	0.786	20.0	24	10.87	0.826	26.7	23

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

**Figure A.43 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and
Axial Distributions at 11,991.1 MWd/MTU**

**Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design**

Revision 1

Page A-49

Cycle:	19	Core Average Exposure: MWd/MTU	25896.2
Exposure: MWd/MTU (GWd)	11996.8 (1653.00)		
Delta E: MWd/MTU, (GWd)	5.7 (0.79)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-25.84		
Flow: Mlb/hr	106.50 (103.90 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top 25	0.237 5.334 14 0.402 0.402 35 2
		24	0.629 14.981 16 0.386 0.601 9 12
		23	0.796 19.571 17 0.347 0.398 59 36
		22	0.867 22.658 18 0.395 0.453 59 32
		21	0.911 24.470 19 0.833 1.140 47 48
		20	0.950 25.609 20 1.064 1.210 47 44
		19	0.965 26.206 21 1.048 1.190 45 42
		18	0.975 26.825 22 1.222 1.391 39 50
		17	0.957 27.097 23 1.151 1.334 41 52
		16	0.955 27.724 24 1.127 1.364 39 52
		15	0.964 28.581
		14	0.949 28.687
		13	1.032 27.591
		12	1.066 28.454
		11	1.101 29.030
		10	1.153 29.708
		9	1.217 30.632
		8	1.276 31.310
		7	1.337 31.908
		6	1.405 32.974
		5	1.425* 33.148*
		4	1.378 31.910
		3	1.252 29.180
		2	0.936 22.272
		Bottom 1	0.266 6.461
Control Rod Density: %	6.80		
k-effective:	0.99902		
Void Fraction:	0.448		
Core Delta-P: psia	26.279	% AXIAL TILT	-15.247 -9.798
Core Plate Delta-P: psia	21.712	AVG BOT 8ft/12ft	1.0728 1.0551
Coolant Temp: Deg-F	548.4		
In Channel Flow: Mlb/hr	93.84	Active Channel Flow: Mlb/hr	90.55
Total Bypass Flow (%):	11.9	(of total core flow)	
Total Water Rod Flow (%):	3.1	(of total core flow)	
Source Convergence	0.00006		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	Value	Margin	Exp.	FT
1.391	22	39	50	1.764	0.811	22	41	10.07	0.815	21.2	23	11.36	0.863	26.7	23
1.390	22	45	44	1.764	0.811	22	47	7.73	0.810	48.2	20	11.46	0.859	25.2	22
1.388	22	47	42	1.764	0.811	22	45	9.91	0.809	22.2	23	11.14	0.852	27.4	23
1.382	22	41	48	1.770	0.808	22	39	7.67	0.807	48.7	20	11.22	0.852	26.6	22
1.382	22	43	46	1.770	0.808	22	43	9.96	0.807	21.4	22	11.13	0.845	26.6	22
1.374	22	49	40	1.786	0.800	22	29	10.05	0.806	20.0	24	11.26	0.839	24.6	22
1.364	24	39	52	1.792	0.798	22	49	9.85	0.801	21.7	22	11.37	0.839	23.4	24
1.363	22	37	48	1.792	0.798	22	17	9.78	0.798	22.1	24	11.01	0.837	26.8	22
1.360	24	51	40	1.794	0.797	22	35	9.81	0.794	21.2	22	10.98	0.836	26.9	22
1.360	22	43	42	1.794	0.797	23	41	7.82	0.793	45.3	20	11.03	0.834	26.1	22

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

**Figure A.44 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and
Axial Distributions at 11,996.8 MWd/MTU**

Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design

Revision 1

Page A-50

Cycle:	19	Core Average Exposure: MWd/MTU	26399.3
Exposure: MWd/MTU (GWd)	12500.0 (1722.30)		
Delta E: MWd/MTU, (GWd)	503.2 (69.33)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-26.28		
Flow: Mlb/hr	104.86 (102.30 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top	25 0.240 5.462 14 0.400 0.400 35 2
			24 0.637 15.321 16 0.385 0.598 9 12
			23 0.805 20.001 17 0.345 0.396 59 36
			22 0.878 23.129 18 0.394 0.452 59 32
			21 0.925 24.966 19 0.831 1.134 47 48
			20 0.966 26.128 20 1.062 1.203 47 44
			19 0.984 26.733 21 1.046 1.184 45 42
			18 0.995 27.358 22 1.226 1.390 39 50
			17 0.979 27.621 23 1.152 1.332 51 42
			16 0.977 28.240 24 1.128 1.362 39 52
			15 0.986 29.101
			14 0.969 29.199
			13 1.051 28.083
			12 1.083 28.962
			11 1.116 29.553
			10 1.165 30.256
			9 1.223 31.209
			8 1.273 31.912
			7 1.320 32.536
			6 1.371 33.630
			5 1.376* 33.810*
			4 1.323 32.548
			3 1.202 29.760
			2 0.900 22.706
		Bottom	1 0.256 6.591
Control Rod Density: %	6.80		
k-effective:	0.99918		
Void Fraction:	0.446		
Core Delta-P: psia	25.612	% AXIAL TILT	-13.647 -9.768
Core Plate Delta-P: psia	21.046	AVG BOT 8ft/12ft	1.0657 1.0547
Coolant Temp: Deg-F	548.3		
In Channel Flow: Mlb/hr	92.39	Active Channel Flow: Mlb/hr	89.15
Total Bypass Flow (%):	11.9	(of total core flow)	
Total Water Rod Flow (%):	3.1	(of total core flow)	
Source Convergence	0.00008		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	Value	Margin	Exp.	FT
1.390	22	39	50	1.747	0.818	22	47	9.58	0.782	22.3	23	10.85	0.822	26.4	22
1.387	22	45	44	1.748	0.818	22	41	7.37	0.780	49.1	20	10.73	0.822	27.6	23
1.387	22	47	42	1.751	0.817	22	45	7.29	0.774	49.5	20	10.46	0.811	28.9	23
1.380	22	41	48	1.752	0.816	22	39	9.58	0.774	21.0	24	10.52	0.811	28.2	22
1.378	22	43	46	1.756	0.814	22	43	9.39	0.771	22.9	23	10.74	0.809	25.7	22
1.377	22	49	40	1.770	0.808	22	49	9.43	0.769	22.2	22	7.94	0.808	54.4	20
1.367	22	37	48	1.770	0.808	22	29	9.31	0.761	22.4	22	10.48	0.804	27.7	22
1.362	24	39	52	1.775	0.805	22	35	9.27	0.760	22.8	24	10.79	0.804	24.6	24
1.361	24	51	40	1.777	0.805	22	37	7.43	0.760	46.0	20	7.85	0.802	54.6	20
1.360	22	31	46	1.777	0.805	23	41	9.28	0.759	22.5	22	7.78	0.801	55.2	20

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

Figure A.45 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and Axial Distributions at 12,500.0 MWd/MTU

Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design

Revision 1

Page A-51

Cycle:	19	Core Average Exposure: MWd/MTU	26899.3
Exposure: MWd/MTU (GWd)	13000.0 (1791.20)		
Delta E: MWd/MTU, (GWd)	500.0 (68.89)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-26.71		
Flow: Mlb/hr	103.32 (100.80 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top	25 0.244 5.592 14 0.399 0.399 35 2
			24 0.646 15.664 16 0.384 0.597 9 12
			23 0.816 20.434 17 0.345 0.395 59 36
			22 0.893 23.605 18 0.394 0.452 59 32
			21 0.943 25.468 19 0.829 1.130 47 48
			20 0.987 26.653 20 1.059 1.197 47 44
			19 1.007 27.269 21 1.043 1.178 45 42
			18 1.022 27.900 22 1.228 1.390 39 50
			17 1.006 28.154 23 1.154 1.333 51 42
			16 1.005 28.766 24 1.129 1.363 51 40
			15 1.014 29.632
			14 0.995 29.721
			13 1.076 28.582
			12 1.105 29.476
			11 1.134 30.082
			10 1.179 30.806
			9 1.229 31.785
			8 1.267 32.509
			7 1.297 33.150
			6 1.328* 34.264
			5 1.317 34.442*
			4 1.255 33.153
			3 1.138 30.309
			2 0.854 23.118
		Bottom	1 0.242 6.715
Control Rod Density: %	6.80		
k-effective:	0.99930		
Void Fraction:	0.442		
Core Delta-P: psia	24.973	% AXIAL TILT	-11.569 -9.704
Core Plate Delta-P: psia	20.408	AVG BOT 8ft/12ft	1.0565 1.0541
Coolant Temp: Deg-F	548.2		
In Channel Flow: Mlb/hr	91.05	Active Channel Flow: Mlb/hr	87.86
Total Bypass Flow (%):	11.9	(of total core flow)	
Total Water Rod Flow (%):	3.1	(of total core flow)	
Source Convergence	0.00008		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR					LHGR									
Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K
1.390	22	39	50	1.729	0.833	22	47	42	6.99	0.746	49.9	20	49	20	5	10.19	0.784	28.1	22	49	40	5
1.386	22	47	42	1.730	0.832	22	41	48	9.05	0.744	23.0	23	51	20	4	10.06	0.784	29.4	23	51	20	5
1.385	22	45	44	1.731	0.832	22	39	50	6.96	0.740	49.7	20	41	50	6	7.56	0.778	55.2	20	7	40	5
1.380	22	41	48	1.734	0.830	22	45	44	9.05	0.736	21.8	24	51	22	4	9.95	0.774	29.2	22	39	50	5
1.379	22	49	40	1.740	0.828	22	43	46	8.83	0.733	24.2	23	41	10	5	9.86	0.772	29.9	23	19	52	5
1.376	22	43	46	1.746	0.825	22	49	40	8.85	0.731	23.6	22	49	18	5	10.11	0.769	26.8	22	9	24	4
1.371	22	37	48	1.746	0.825	22	33	18	8.94	0.727	21.8	22	49	22	5	7.44	0.768	55.4	20	49	42	5
1.363	24	51	40	1.746	0.825	22	17	42	8.90	0.727	22.2	22	51	38	5	7.39	0.768	56.0	20	39	8	5
1.362	22	31	46	1.747	0.824	22	37	48	8.80	0.726	23.4	22	39	12	5	9.86	0.767	29.2	22	49	18	5
1.361	24	39	52	1.750	0.823	22	31	16	7.03	0.725	46.8	20	47	18	5	7.41	0.764	55.4	20	41	50	6

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

Figure A.46 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and Axial Distributions at 13,000.0 MWd/MTU

**Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design**

Revision 1

Page A-52

Cycle:	19	Core Average Exposure: MWd/MTU	27299.4
Exposure: MWd/MTU (GWd)	13400.0 (1846.30)		
Delta E: MWd/MTU, (GWd)	400.0 (55.11)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-26.94		
Flow: Mlb/hr	102.50 (100.00 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top 25	0.248 5.697 14 0.398 0.398 35 2
		24	0.655 15.942 16 0.383 0.596 9 12
		23	0.828 20.785 17 0.344 0.394 59 36
		22	0.907 23.992 18 0.393 0.452 59 32
		21	0.960 25.877 19 0.828 1.128 47 48
		20	1.008 27.082 20 1.057 1.193 47 44
		19	1.031 27.707 21 1.040 1.174 45 42
		18	1.047 28.345 22 1.230 1.390 39 50
		17	1.033 28.593 23 1.156 1.334 51 42
		16	1.032 29.198 24 1.130 1.364 51 40
		15	1.041 30.068
		14	1.020 30.148
		13	1.099 28.991
		12	1.126 29.895
		11	1.151 30.511
		10	1.191 31.251
		9	1.233 32.247
		8	1.259 32.983
		7	1.273 33.633
		6	1.288* 34.755
		5	1.261 34.926*
		4	1.192 33.613
		3	1.077 30.725
		2	0.809 23.430
		Bottom 1	0.230 6.808
Control Rod Density: %	6.80		
k-effective:	0.99948		
Void Fraction:	0.438		
Core Delta-P: psia	24.602	% AXIAL TILT	-9.538 -9.624
Core Plate Delta-P: psia	20.037	AVG BOT 8ft/12ft	1.0473 1.0536
Coolant Temp: Deg-F	548.1		
In Channel Flow: Mlb/hr	90.35	Active Channel Flow: Mlb/hr	87.19
Total Bypass Flow (%):	11.9	(of total core flow)	
Total Water Rod Flow (%):	3.1	(of total core flow)	
Source Convergence	0.00007		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	Value	Margin	Exp.	FT
1.390	22	39	50	1.715	0.840	22	47	6.76	0.721	49.9	20	9.70	0.753	29.0	22
1.386	22	47	42	1.716	0.839	22	39	6.71	0.719	50.3	20	9.57	0.751	30.2	23
1.383	22	45	44	1.716	0.839	22	41	8.60	0.715	24.3	23	7.23	0.749	55.8	20
1.381	22	49	40	1.721	0.837	22	33	8.61	0.708	23.1	24	7.18	0.744	55.7	20
1.379	22	41	48	1.722	0.836	22	23	8.43	0.705	25.0	23	7.20	0.743	55.5	20
1.375	22	43	46	1.722	0.836	22	45	6.80	0.703	47.0	20	7.15	0.743	56.0	20
1.373	22	37	48	1.722	0.836	22	17	8.44	0.702	24.3	22	9.47	0.742	30.0	22
1.364	24	51	40	1.725	0.835	22	31	6.52	0.701	50.5	20	9.37	0.739	30.8	23
1.363	22	31	46	1.728	0.834	22	43	8.52	0.699	22.8	22	9.60	0.739	28.2	22
1.361	24	39	52	1.729	0.833	22	49	8.54	0.699	22.5	22	9.38	0.736	30.0	22

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

**Figure A.47 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and
Axial Distributions at 13,400.0 MWd/MTU**

**Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design**

Revision 1

Page A-53

Cycle:	19	Core Average Exposure: MWd/MTU	27300.3
Exposure: MWd/MTU (GWd)	13401.0 (1846.50)		
Delta E: MWd/MTU, (GWd)	1.0 (0.14)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-26.39		
Flow: Mlb/hr	104.45 (101.90 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top	25 0.248 5.698 14 0.392 0.392 35 2
			24 0.655 15.943 16 0.383 0.598 9 12
			23 0.827 20.786 17 0.344 0.396 59 36
			22 0.905 23.993 18 0.392 0.455 59 32
			21 0.955 25.878 19 0.828 1.132 47 48
			20 0.999 27.083 20 1.057 1.199 47 44
			19 1.016 27.708 21 1.039 1.179 45 42
			18 1.032 28.347 22 1.230 1.393 47 42
			17 1.022 28.594 23 1.157 1.343 51 42
			16 1.026 29.199 24 1.132 1.373 51 40
			15 1.038 30.069
			14 1.019 30.149
			13 1.101 28.992
			12 1.130 29.896
			11 1.156 30.512
			10 1.198 31.253
			9 1.240 32.248
			8 1.267 32.984
			7 1.281 33.634
			6 1.295* 34.756
			5 1.268 34.928*
			4 1.198 33.614
			3 1.082 30.726
			2 0.812 23.431
		Bottom	1 0.231 6.809
Control Rod Density: %	6.89		
k-effective:	0.99949		
Void Fraction:	0.436		
Core Delta-P: psia	25.320	% AXIAL TILT	-10.115 -9.624
Core Plate Delta-P: psia	20.754	AVG BOT 8ft/12ft	1.0509 1.0536
Coolant Temp: Deg-F	548.1		
In Channel Flow: Mlb/hr	92.10	Active Channel Flow: Mlb/hr	88.89
Total Bypass Flow (%):	11.8	(of total core flow)	
Total Water Rod Flow (%):	3.1	(of total core flow)	
Source Convergence	0.00009		

Top Ten Thermal Limits Summary - Sorted by Margin

Power			MCPR				APLHGR						LHGR					
Value	FT	IR JR	Value	Margin	FT	IR JR	Value	Margin	Exp.	FT	IR JR	K	Value	Margin	Exp.	FT	IR JR	K
1.393	22	47 42	1.721	0.837	22	47 42	6.81	0.726	49.9	20	49 42	6	9.76	0.758	29.0	22	49 40	5
1.390	22	49 40	1.730	0.833	22	45 44	6.76	0.724	50.3	20	41 50	6	9.63	0.756	30.2	23	51 20	5
1.389	22	45 44	1.730	0.832	22	17 42	8.66	0.719	24.3	23	51 20	5	7.27	0.754	55.8	20	7 40	5
1.387	22	39 50	1.732	0.831	22	49 40	8.66	0.712	23.1	24	51 22	5	7.23	0.749	55.7	20	39 8	6
1.380	22	41 48	1.735	0.830	22	41 48	8.49	0.709	25.0	23	41 10	5	7.20	0.748	56.0	20	41 50	6
1.379	22	43 46	1.738	0.829	22	15 40	6.85	0.708	47.0	20	47 18	6	7.25	0.748	55.5	20	49 42	6
1.373	24	51 40	1.738	0.829	24	51 40	8.50	0.706	24.3	22	49 18	5	9.54	0.748	30.0	22	39 50	5
1.367	22	37 48	1.740	0.827	22	21 50	6.57	0.706	50.5	20	23 12	6	9.43	0.745	30.8	23	19 52	5
1.363	22	45 22	1.741	0.827	22	43 46	8.57	0.703	22.8	22	51 24	5	9.66	0.744	28.2	22	9 24	5
1.362	22	43 42	1.744	0.826	23	51 42	8.59	0.703	22.5	22	49 22	5	9.44	0.740	30.0	22	49 18	5

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

**Figure A.48 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and
Axial Distributions at 13,401.0 MWd/MTU**

Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design

Revision 1

Page A-54

Cycle:	19	Core Average Exposure: MWd/MTU	27799.2
Exposure: MWd/MTU (GWd)	13900.0 (1915.20)		
Delta E: MWd/MTU, (GWd)	499.0 (68.76)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-26.59		
Flow: Mlb/hr	103.73 (101.20 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top	25 0.253 5.831 14 0.391 0.391 35 2
			24 0.668 16.296 16 0.383 0.596 9 12
			23 0.844 21.232 17 0.343 0.395 59 36
			22 0.927 24.484 18 0.391 0.455 59 32
			21 0.981 26.397 19 0.827 1.130 47 48
			20 1.029 27.627 20 1.055 1.194 47 44
			19 1.049 28.263 21 1.036 1.174 45 42
			18 1.068 28.910 22 1.232 1.393 47 42
			17 1.060 29.153 23 1.160 1.344 51 42
			16 1.064 29.752 24 1.134 1.375 51 40
			15 1.076 30.629
			14 1.054 30.698
			13 1.134 29.515
			12 1.159 30.432
			11 1.179 31.059
			10 1.213 31.817
			9 1.243 32.831
			8 1.252* 33.575
			7 1.246 34.227
			6 1.237 35.350
			5 1.192 35.504*
			4 1.111 34.155
			3 0.998 31.214
			2 0.751 23.797
		Bottom	1 0.213 6.918
Control Rod Density: %	6.89		
k-effective:	0.99964		
Void Fraction:	0.429		
Core Delta-P: psia	24.951	% AXIAL TILT	-7.218 -9.493
Core Plate Delta-P: psia	20.386	AVG BOT 8ft/12ft	1.0378 1.0527
Coolant Temp: Deg-F	548.0		
In Channel Flow: Mlb/hr	91.51	Active Channel Flow: Mlb/hr	88.34
Total Bypass Flow (%):	11.8	(of total core flow)	
Total Water Rod Flow (%):	3.1	(of total core flow)	
Source Convergence	0.00006		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	IR	Value	Margin	Exp.
1.393	22	47	42	1.699	0.848	22	47	7.10	0.697	42.1	20	45	7.91	0.742	47.3
1.393	22	49	40	1.702	0.846	22	17	6.47	0.696	50.7	20	49	7.95	0.740	46.8
1.388	22	39	50	1.705	0.844	22	15	7.18	0.695	40.6	20	21	8.06	0.737	45.1
1.388	22	45	44	1.708	0.843	22	49	6.63	0.694	48.2	20	19	7.00	0.725	55.8
1.380	22	41	48	1.710	0.842	24	51	7.10	0.693	41.5	20	47	8.10	0.724	43.0
1.378	22	43	46	1.713	0.841	22	45	7.27	0.688	38.5	20	37	6.89	0.721	56.5
1.375	24	51	40	1.718	0.838	22	23	6.73	0.682	45.1	20	13	6.90	0.719	56.2
1.370	22	37	48	1.719	0.838	22	41	8.13	0.681	25.2	23	51	7.10	0.718	53.8
1.364	22	45	22	1.721	0.837	22	33	6.66	0.680	45.9	20	17	9.23	0.717	29.0
1.361	22	51	38	1.722	0.836	22	21	6.65	0.679	45.9	20	15	9.11	0.717	30.4

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

Figure A.49 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and Axial Distributions at 13,900.0 MWd/MTU

**Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design**

Revision 1

Page A-55

Cycle:	19	Core Average Exposure: MWd/MTU	28129.2
Exposure: MWd/MTU (GWd)	14230.0 (1960.70)		
Delta E: MWd/MTU, (GWd)	330.0 (45.47)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-26.68		
Flow: Mlb/hr	103.42 (100.90 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top	25 0.256 5.921 14 0.391 0.391 35 2
			24 0.677 16.533 16 0.382 0.596 9 12
			23 0.856 21.531 17 0.343 0.395 59 36
			22 0.941 24.815 18 0.391 0.455 59 32
			21 0.998 26.748 19 0.827 1.129 47 48
			20 1.049 27.996 20 1.053 1.192 47 44
			19 1.071 28.639 21 1.034 1.171 45 42
			18 1.092 29.293 22 1.233 1.395 49 40
			17 1.085 29.533 23 1.162 1.346 51 42
			16 1.089 30.129 24 1.136 1.376 51 40
			15 1.101 31.010
			14 1.076 31.071
			13 1.155 29.870
			12 1.177 30.794
			11 1.193 31.426
			10 1.220 32.195
			9 1.242* 33.216
			8 1.241 33.961
			7 1.221 34.609
			6 1.199 35.727
			5 1.143 35.866*
			4 1.057 34.491
			3 0.946 31.515
			2 0.713 24.023
		Bottom	1 0.202 6.986
Control Rod Density: %	6.89	% AXIAL TILT	-5.301 -9.381
k-effective:	0.99973	AVG BOT 8ft/12ft	1.0290 1.0521
Void Fraction:	0.424		
Core Delta-P: psia	24.772		
Core Plate Delta-P: psia	20.207		
Coolant Temp: Deg-F	547.9		
In Channel Flow: Mlb/hr	91.26	Active Channel Flow: Mlb/hr	88.12
Total Bypass Flow (%):	11.8	(of total core flow)	
Total Water Rod Flow (%):	3.0	(of total core flow)	
Source Convergence	0.00007		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	IR	JR	K	Value
1.395	22	49	40	1.679	0.858	22	47	7.19	0.709	42.6	20	45	28	19	8.07
1.393	22	47	42	1.685	0.854	22	17	7.28	0.708	41.1	20	21	44	19	8.00
1.389	22	39	50	1.686	0.854	22	49	7.21	0.707	42.0	20	47	26	19	8.16
1.387	22	45	44	1.686	0.854	22	15	7.34	0.699	39.0	20	37	42	19	8.18
1.380	22	41	48	1.693	0.850	22	15	6.55	0.689	48.7	20	19	12	8	7.02
1.377	22	43	46	1.694	0.850	24	51	6.53	0.686	48.4	20	11	20	8	6.98
1.376	24	51	40	1.698	0.848	22	23	8.55	0.685	20.0	22	39	42	19	6.78
1.371	22	37	48	1.700	0.847	22	41	6.74	0.678	44.5	20	13	18	9	9.57
1.364	22	45	22	1.704	0.845	22	33	6.67	0.677	45.3	20	15	16	9	7.31
1.363	22	51	38	1.709	0.842	22	43	6.67	0.677	45.3	20	17	14	9	6.68

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

**Figure A.50 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and
Axial Distributions at 14,230.0 MWd/MTU**

Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design

Revision 1

Page A-56

Cycle:	19	Core Average Exposure: MWd/MTU	28422.2
Exposure: MWd/MTU (GWd)	14522.9 (2001.10)		
Delta E: MWd/MTU, (GWd)	292.9 (40.36)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-26.65		
Flow: Mlb/hr	103.53 (101.00 %)		
		Axial Profile	Edit Radial Power
		N (PRA) Power Exposure	Zone Avg. Max. IR JR
		Top 25 0.260 6.002	14 0.391 0.391 35 2
		24 0.686 16.746	16 0.382 0.596 9 12
		23 0.867 21.801	17 0.343 0.394 59 36
		22 0.956 25.113	18 0.391 0.455 59 32
		21 1.015 27.064	19 0.827 1.128 47 48
		20 1.068 28.329	20 1.051 1.189 47 44
		19 1.092 28.979	21 1.032 1.167 45 42
		18 1.114 29.641	22 1.234 1.397 49 40
		17 1.107 29.879	23 1.164 1.348 51 42
		16 1.112 30.471	24 1.138 1.378 51 40
		15 1.123 31.356	
		14 1.096 31.409	
		13 1.175 30.190	
		12 1.193 31.120	
		11 1.205 31.756	
		10 1.227 32.531	
		9 1.241* 33.557	
		8 1.229 34.301	
		7 1.198 34.942	
		6 1.164 36.053	
		5 1.098 36.174*	
		4 1.008 34.775	
		3 0.899 31.768	
		2 0.678 24.215	
		Bottom 1 0.193 7.044	
Control Rod Density: %	6.89	% AXIAL TILT	-3.513 -9.264
k-effective:	0.99980	AVG BOT 8ft/12ft	1.0208 1.0515
Void Fraction:	0.418		
Core Delta-P: psia	24.744		
Core Plate Delta-P: psia	20.180		
Coolant Temp: Deg-F	547.8		
In Channel Flow: Mlb/hr	91.39	Active Channel Flow: Mlb/hr	88.25
Total Bypass Flow (%):	11.7	(of total core flow)	
Total Water Rod Flow (%):	3.0	(of total core flow)	
Source Convergence	0.00008		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	IR	JR	K	Value
1.397	22	49	40	1.664	0.865	22	47	7.31	0.720	42.5	20	47	26	19	8.18
1.393	22	47	42	1.668	0.863	22	49	7.26	0.720	43.0	20	45	28	19	8.09
1.390	22	39	50	1.671	0.862	22	15	7.37	0.720	41.5	20	21	44	19	8.26
1.385	22	45	44	1.674	0.860	22	17	7.41	0.708	39.4	20	37	42	19	8.24
1.380	22	41	48	1.679	0.858	22	15	8.67	0.698	20.6	22	39	42	19	7.47
1.378	24	51	40	1.682	0.856	22	23	8.66	0.690	19.3	22	47	28	19	7.44
1.376	22	43	46	1.682	0.856	24	51	6.60	0.689	47.9	20	19	12	9	9.67
1.372	22	37	48	1.684	0.855	22	41	8.61	0.689	19.7	22	45	26	19	7.37
1.366	22	51	38	1.692	0.851	22	33	8.57	0.688	20.2	22	37	44	19	7.34
1.364	22	45	22	1.694	0.850	22	17	6.57	0.684	47.8	20	11	20	9	7.62

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

Figure A.51 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and Axial Distributions at 14,522.9 MWd/MTU

**Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design**

Revision 1

Page A-57

Cycle:	19	Core Average Exposure: MWd/MTU	28427.6
Exposure: MWd/MTU (GWd)	14528.3 (2001.80)		
Delta E: MWd/MTU, (GWd)	5.4 (0.74)		
Power: MWt	3952.0 (100.00 %)	Axial Profile	Edit Radial Power
Core Pressure: psia	1050.0	N (PRA) Power Exposure	Zone Avg. Max. IR JR
Inlet Subcooling: Btu/lbm	-26.88	Top 25 0.232 6.004	14 0.399 0.399 35 2
Flow: Mlb/hr	102.71 (100.20 %)	24 0.612 16.750	16 0.370 0.566 9 12
		23 0.768 21.805	17 0.333 0.389 59 36
		22 0.839 25.119	18 0.390 0.452 1 30
		21 0.876 27.070	19 0.816 1.060 47 48
2 6 10 14 18 22 26 30 34 38 42 46 50 54 58		20 0.917 28.335	20 1.046 1.197 33 34
59		19 0.951 28.985	21 1.074 1.185 29 32
55		18 0.996 29.647	22 1.245 1.396 33 32
51		17 1.033 29.885	23 1.146 1.309 51 42
47		16 1.072 30.478	24 1.113 1.354 51 40
43		15 1.109 31.362	
39		14 1.105 31.415	
35		13 1.201 30.196	
31		12 1.232 31.126	
27		11 1.254 31.762	
23		10 1.284 32.538	
19		9 1.306* 33.564	
15		8 1.303 34.308	
11		7 1.283 34.948	
7		6 1.264 36.059	
3		5 1.213 36.180*	
2 6 10 14 18 22 26 30 34 38 42 46 50 54 58		4 1.132 34.780	
		3 1.022 31.773	
Control Rod Density: %	5.63	2 0.775 24.218	
		Bottom 1 0.221 7.045	
k-effective:	0.99986		
Void Fraction:	0.438		
Core Delta-P: psia	24.752	% AXIAL TILT -11.685 -9.263	
Core Plate Delta-P: psia	20.191	AVG BOT 8ft/12ft 1.0766 1.0515	
Coolant Temp: Deg-F	548.0		
In Channel Flow: Mlb/hr	90.49	Active Channel Flow: Mlb/hr	87.32
Total Bypass Flow (%):	11.9	(of total core flow)	
Total Water Rod Flow (%):	3.1	(of total core flow)	
Source Convergence	0.00006		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	IR	Value	Margin	Exp.
1.396	22	33	32	1.686	0.854	22	33	6.62	0.692	48.1	20	23	7.00	0.718	55.0
1.392	22	31	34	1.706	0.844	22	31	6.64	0.691	47.7	21	25	7.10	0.717	53.7
1.379	22	33	36	1.710	0.842	22	25	6.58	0.690	48.4	20	11	6.84	0.717	56.7
1.378	22	35	34	1.713	0.841	22	33	6.61	0.689	47.8	20	29	7.08	0.717	53.8
1.365	22	51	38	1.748	0.824	22	9	6.56	0.689	48.4	21	9	7.20	0.716	52.4
1.365	22	49	40	1.750	0.823	22	49	6.60	0.687	47.7	20	9	7.11	0.716	53.4
1.360	22	49	36	1.750	0.823	22	49	6.75	0.686	45.4	20	27	7.10	0.715	53.5
1.355	22	51	34	1.751	0.822	22	9	6.55	0.684	47.9	20	19	7.07	0.714	53.7
1.354	24	51	40	1.755	0.821	22	49	6.47	0.683	48.9	20	11	7.01	0.714	54.4
1.354	22	31	50	1.766	0.815	22	39	6.55	0.679	47.4	21	27	6.89	0.714	55.7

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

**Figure A.52 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and
Axial Distributions at 14,528.3 MWd/MTU**

**Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design**

Revision 1

Page A-58

Cycle:	19	Core Average Exposure: MWd/MTU	28599.2
Exposure: MWd/MTU (GWd)	14700.0 (2025.50)		
Delta E: MWd/MTU, (GWd)	171.7 (23.66)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-26.68		
Flow: Mlb/hr	103.42 (100.90 %)		
		Axial Profile	Edit Radial Power
		N (PRA) Power Exposure	Zone Avg. Max. IR JR
		Top 25 0.234 6.046	14 0.399 0.399 35 2
		24 0.617 16.862	16 0.370 0.566 9 12
		23 0.775 21.947	17 0.332 0.389 59 36
		22 0.847 25.274	18 0.390 0.452 1 30
		21 0.885 27.232	19 0.816 1.061 47 48
		20 0.927 28.505	20 1.045 1.196 33 34
		19 0.962 29.162	21 1.073 1.183 29 32
		18 1.008 29.832	22 1.245 1.399 33 32
		17 1.046 30.077	23 1.147 1.310 51 42
		16 1.085 30.674	24 1.114 1.355 51 40
		15 1.123 31.566	
		14 1.117 31.618	
		13 1.213 30.391	
		12 1.243 31.325	
		11 1.262 31.965	
		10 1.288 32.745	
		9 1.305* 33.774	
		8 1.296 34.517	
		7 1.269 35.154	
		6 1.244 36.261	
		5 1.187 36.374*	
		4 1.104 34.960	
		3 0.994 31.936	
		2 0.755 24.341	
		Bottom 1 0.216 7.082	
		% AXIAL TILT -10.664 -9.237	
		AVG BOT 8ft/12ft 1.0720 1.0514	
Control Rod Density: %	5.63		
k-effective:	0.99989		
Void Fraction:	0.434		
Core Delta-P: psia	24.972		
Core Plate Delta-P: psia	20.411		
Coolant Temp: Deg-F	548.0		
In Channel Flow: Mlb/hr	91.16	Active Channel Flow: Mlb/hr	87.97
Total Bypass Flow (%):	11.9	(of total core flow)	
Total Water Rod Flow (%):	3.1	(of total core flow)	
Source Convergence	0.00010		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	IR	Value	Margin	Exp.
1.399	22	33	32	1.683	0.856	22	33	6.61	0.693	48.3	20	23	7.09	0.719	54.0
1.395	22	31	34	1.701	0.847	22	31	6.63	0.692	47.9	21	25	6.97	0.718	55.2
1.381	22	33	36	1.708	0.843	22	25	6.64	0.690	47.5	20	11	7.17	0.717	52.8
1.380	22	35	34	1.711	0.842	22	33	6.68	0.690	46.9	20	29	7.11	0.716	53.4
1.366	22	51	38	1.742	0.827	22	9	6.63	0.689	47.6	21	9	7.08	0.716	53.8
1.366	22	49	40	1.744	0.826	22	49	6.56	0.685	48.0	20	9	6.98	0.715	54.8
1.359	22	49	36	1.747	0.824	22	49	6.55	0.684	48.0	20	11	7.08	0.715	53.6
1.355	22	31	50	1.747	0.824	22	9	6.53	0.684	48.2	20	19	7.09	0.714	53.5
1.355	24	51	40	1.753	0.821	22	49	6.71	0.683	45.7	20	27	7.04	0.713	54.0
1.354	22	51	34	1.759	0.819	22	39	6.52	0.678	47.6	21	27	7.08	0.713	53.4

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

**Figure A.53 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and
Axial Distributions at 14,700.0 MWd/MTU**

Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design

Revision 1

Page A-59

Cycle:	19	Core Average Exposure: MWd/MTU	28999.2
Exposure: MWd/MTU (GWd)	15100.0 (2080.60)		
Delta E: MWd/MTU, (GWd)	400.0 (55.11)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-26.37		
Flow: Mlb/hr	104.55 (102.00 %)		
		Axial Profile	Edit Radial Power
		N (PRA) Power Exposure	Zone Avg. Max. IR JR
		Top 25 0.241 6.148	14 0.398 0.398 35 2
		24 0.635 17.130	16 0.370 0.567 9 12
		23 0.798 22.283	17 0.333 0.388 59 36
		22 0.875 25.644	18 0.390 0.452 1 30
		21 0.916 27.619	19 0.817 1.063 47 48
		20 0.961 28.911	20 1.042 1.191 33 34
		19 0.997 29.583	21 1.070 1.176 29 32
		18 1.044 30.273	22 1.246 1.400 33 32
		17 1.083 30.535	23 1.151 1.314 51 42
		16 1.122 31.143	24 1.117 1.357 51 40
		15 1.158 32.050	
		14 1.148 32.098	
		13 1.242 30.852	
		12 1.266 31.796	
		11 1.278 32.442	
		10 1.294 33.230	
		9 1.298* 34.263	
		8 1.273 35.000	
		7 1.229 35.623	
		6 1.187 36.717	
		5 1.116 36.806*	
		4 1.025 35.360	
		3 0.917 32.295	
		2 0.697 24.614	
		Bottom 1 0.199 7.164	
Control Rod Density: %	5.63		
k-effective:	1.00001		
Void Fraction:	0.424		
Core Delta-P: psia	25.267	% AXIAL TILT	-7.584 -9.148
Core Plate Delta-P: psia	20.705	AVG BOT 8ft/12ft	1.0572 1.0511
Coolant Temp: Deg-F	547.8		
In Channel Flow: Mlb/hr	92.23	Active Channel Flow: Mlb/hr	89.04
Total Bypass Flow (%):	11.8	(of total core flow)	
Total Water Rod Flow (%):	3.1	(of total core flow)	
Source Convergence	0.00005		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	Value	Margin	Exp.	FT
1.400	22	33	32	1.672	0.861	22	33	6.55	0.691	48.9	20	7.38	0.719	50.8	20
1.397	22	31	34	1.689	0.853	22	31	6.58	0.690	48.5	21	7.04	0.719	54.5	21
1.380	22	33	36	1.698	0.848	22	25	6.59	0.689	48.1	20	6.92	0.718	55.8	20
1.380	22	35	34	1.702	0.846	22	33	6.64	0.688	47.2	20	7.04	0.717	54.4	20
1.369	22	51	38	1.720	0.837	22	9	6.57	0.687	48.1	21	7.11	0.716	53.4	20
1.368	22	49	40	1.723	0.836	22	49	6.50	0.684	48.7	20	7.05	0.715	54.0	21
1.357	22	49	36	1.731	0.832	22	9	6.73	0.683	45.4	20	7.04	0.714	54.1	20
1.357	24	51	40	1.733	0.831	22	49	6.50	0.683	48.6	20	7.43	0.714	49.5	20
1.355	22	31	50	1.738	0.829	22	39	6.47	0.677	48.1	21	7.10	0.712	53.1	20
1.354	22	51	34	1.740	0.828	22	23	6.46	0.672	47.5	21	7.12	0.709	52.6	20

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

Figure A.54 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and Axial Distributions at 15,100.0 MWd/MTU

Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design

Revision 1

Page A-60

Cycle:	19	Core Average Exposure: MWd/MTU	29499.2
Exposure: MWd/MTU (GWd)	15600.0 (2149.50)		
Delta E: MWd/MTU, (GWd)	500.0 (68.89)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-25.84		
Flow: Mlb/hr	106.50 (103.90 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top 25	0.248 6.279 14 0.399 0.399 35 2
		24	0.657 17.475 16 0.370 0.567 9 12
		23	0.826 22.717 17 0.333 0.388 59 36
		22	0.908 26.123 18 0.390 0.453 1 30
		21	0.952 28.121 19 0.818 1.065 47 48
		20	0.999 29.438 20 1.039 1.189 33 34
		19	1.036 30.130 21 1.066 1.173 29 32
		18	1.086 30.846 22 1.245 1.407 33 32
		17	1.124 31.129 23 1.157 1.318 51 42
		16	1.162 31.749 24 1.121 1.358 51 40
		15	1.196 32.675
		14	1.181 32.717
		13	1.274 31.442
		12	1.291 32.396
		11	1.292 33.045
		10	1.297* 33.839
		9	1.286 34.870
		8	1.245 35.591
		7	1.182 36.189
		6	1.122 37.260
		5	1.038 37.312*
		4	0.941 35.822
		3	0.837 32.707
		2	0.637 24.927
		Bottom 1	0.182 7.259
Control Rod Density: %	5.63		
k-effective:	0.99998		
Void Fraction:	0.412		
Core Delta-P: psia	25.850	% AXIAL TILT	-4.108 -8.986
Core Plate Delta-P: psia	21.287	AVG BOT 8ft/12ft	1.0402 1.0504
Coolant Temp: Deg-F	547.7		
In Channel Flow: Mlb/hr	94.05	Active Channel Flow: Mlb/hr	90.84
Total Bypass Flow (%):	11.7	(of total core flow)	
Total Water Rod Flow (%):	3.0	(of total core flow)	
Source Convergence	0.00008		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	Value	Margin	Exp.	FT
1.407	22	33	32	1.660	0.868	22	33	6.93	0.712	46.5	20	7.61	0.749	51.5	20
1.404	22	31	34	1.674	0.860	22	31	6.92	0.708	46.1	20	7.54	0.748	52.2	20
1.382	22	35	34	1.690	0.852	22	25	7.02	0.708	44.7	20	7.53	0.747	52.2	20
1.381	22	33	36	1.694	0.850	22	33	6.93	0.708	45.9	20	7.66	0.743	50.3	20
1.372	22	51	38	1.699	0.848	22	9	6.79	0.699	46.6	20	7.48	0.742	52.1	20
1.370	22	49	40	1.706	0.844	22	49	6.76	0.695	46.6	20	7.63	0.742	50.5	20
1.358	24	51	40	1.716	0.839	22	23	6.64	0.692	47.7	21	7.45	0.731	51.3	21
1.355	22	37	52	1.718	0.838	22	9	6.63	0.688	47.5	21	7.45	0.730	51.1	21
1.355	22	31	50	1.718	0.838	22	39	6.69	0.682	45.7	20	7.36	0.729	52.1	20
1.355	22	33	52	1.725	0.835	22	49	6.73	0.681	45.0	20	7.43	0.727	51.0	21

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

Figure A.55 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and Axial Distributions at 15,600.0 MWd/MTU

**Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design**

Revision 1

Page A-61

Cycle:	19	Core Average Exposure: MWd/MTU	29500.3
Exposure: MWd/MTU (GWd)	15601.0 (2149.60)		
Delta E: MWd/MTU, (GWd)	1.0 (0.14)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-26.76		
Flow: Mlb/hr	103.11 (100.60 %)		
		Axial Profile	Edit Radial Power
		N (PRA) Power Exposure	Zone Avg. Max. IR JR
		Top 25 0.253 6.279	14 0.399 0.399 35 2
		24 0.668 17.476	16 0.369 0.564 9 12
		23 0.841 22.718	17 0.332 0.385 59 36
		22 0.929 26.124	18 0.389 0.452 29 60
		21 0.980 28.122	19 0.815 1.057 47 48
		20 1.018 29.439	20 1.042 1.189 33 34
		19 1.048 30.131	21 1.067 1.173 29 32
		18 1.091 30.847	22 1.248 1.405 33 32
		17 1.125 31.130	23 1.151 1.307 51 42
		16 1.159 31.750	24 1.116 1.346 51 40
		15 1.189 32.676	
		14 1.172 32.718	
		13 1.262 31.443	
		12 1.278 32.398	
		11 1.278 33.046	
		10 1.283* 33.840	
		9 1.273 34.872	
		8 1.233 35.592	
		7 1.173 36.191	
		6 1.115 37.261	
		5 1.035 37.313*	
		4 0.940 35.823	
		3 0.837 32.707	
		2 0.638 24.927	
		Bottom 1 0.182 7.259	
		% AXIAL TILT -3.329 -8.985	
		AVG BOT 8ft/12ft 1.0333 1.0504	
Control Rod Density: %	5.50		
k-effective:	0.99998		
Void Fraction:	0.415		
Core Delta-P: psia	24.603		
Core Plate Delta-P: psia	20.043		
Coolant Temp: Deg-F	547.6		
In Channel Flow: Mlb/hr	91.02	Active Channel Flow: Mlb/hr	87.88
Total Bypass Flow (%):	11.7	(of total core flow)	
Total Water Rod Flow (%):	3.0	(of total core flow)	
Source Convergence	0.00009		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	IR	Value	Margin	Exp.
1.405	22	33	32	1.632	0.883	22	33	6.88	0.707	46.5	20	37	7.49	0.745	52.4
1.404	22	31	34	1.641	0.877	22	31	6.98	0.704	44.8	20	29	7.52	0.741	51.5
1.383	22	33	36	1.657	0.869	22	25	6.85	0.701	46.1	20	9	7.46	0.740	52.2
1.381	22	35	34	1.657	0.869	22	33	6.85	0.700	45.9	20	11	7.58	0.738	50.6
1.360	22	51	38	1.697	0.848	22	9	6.74	0.693	46.6	20	41	7.60	0.737	50.3
1.358	22	49	40	1.700	0.847	22	31	6.68	0.687	46.5	20	11	7.39	0.733	52.2
1.357	22	31	50	1.704	0.845	22	49	6.56	0.684	47.7	21	25	7.40	0.726	51.3
1.353	22	33	52	1.706	0.844	22	23	6.54	0.680	47.5	21	9	7.37	0.724	51.3
1.351	22	35	50	1.708	0.843	22	33	6.70	0.678	45.0	20	35	7.39	0.723	51.0
1.351	22	31	38	1.709	0.843	22	39	8.36	0.675	21.0	22	35	7.29	0.723	52.2

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

**Figure A.56 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and
Axial Distributions at 15,601.0 MWd/MTU**

Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design

Revision 1

Page A-62

Cycle:	19	Core Average Exposure: MWd/MTU	29924.2
Exposure: MWd/MTU (GWd)	16025.0 (2208.00)		
Delta E: MWd/MTU, (GWd)	424.0 (58.42)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-25.84		
Flow: Mlb/hr	106.50 (103.90 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top	25 0.261 6.396 14 0.399 0.399 35 2
			24 0.690 17.783 16 0.369 0.564 9 12
			23 0.869 23.105 17 0.332 0.385 25 60
			22 0.961 26.554 18 0.389 0.453 29 60
			21 1.015 28.577 19 0.817 1.060 47 48
			20 1.054 29.912 20 1.039 1.185 27 28
			19 1.083 30.617 21 1.063 1.168 29 32
			18 1.127 31.353 22 1.247 1.408 31 34
			17 1.160 31.651 23 1.158 1.311 51 42
			16 1.191 32.279 24 1.121 1.348 51 40
			15 1.219 33.218
			14 1.197 33.251
			13 1.286 31.950
			12 1.296* 32.910
			11 1.288 33.557
			10 1.282 34.351
			9 1.260 35.376
			8 1.206 36.078
			7 1.130 36.649
			6 1.059 37.694
			5 0.968 37.712*
			4 0.869 36.183
			3 0.771 33.027
			2 0.588 25.171
		Bottom	1 0.168 7.333
Control Rod Density: %	5.50		
k-effective:	0.99997		
Void Fraction:	0.402		
Core Delta-P: psia	25.713	% AXIAL TILT	-0.242 -8.793
Core Plate Delta-P: psia	21.151	AVG BOT 8ft/12ft	1.0174 1.0496
Coolant Temp: Deg-F	547.6		
In Channel Flow: Mlb/hr	94.12	Active Channel Flow: Mlb/hr	90.94
Total Bypass Flow (%):	11.6	(of total core flow)	
Total Water Rod Flow (%):	3.0	(of total core flow)	
Source Convergence	0.00008		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	IR	Value	Margin	Exp.
1.408	22	31	34	1.636	0.880	22	33	7.05	0.729	47.1	20	37	7.69	0.770	53.0
1.408	22	33	32	1.642	0.877	22	31	7.16	0.728	45.5	20	29	7.66	0.766	52.9
1.381	22	33	36	1.665	0.865	22	25	7.02	0.721	46.5	20	11	7.81	0.766	51.3
1.380	22	25	28	1.666	0.865	22	33	7.00	0.721	46.7	20	9	7.70	0.764	52.2
1.363	22	51	38	1.691	0.852	22	9	6.91	0.715	47.2	20	41	7.77	0.760	51.0
1.360	22	49	40	1.691	0.851	22	31	6.86	0.710	47.2	20	11	7.59	0.758	52.8
1.357	22	31	50	1.697	0.848	22	23	8.61	0.697	21.2	22	33	7.63	0.755	51.9
1.356	22	33	52	1.698	0.848	22	49	8.57	0.697	21.7	22	35	7.57	0.747	51.8
1.355	22	37	52	1.702	0.846	22	25	6.84	0.697	45.6	20	35	7.57	0.747	51.7
1.352	22	35	50	1.702	0.846	22	33	8.58	0.696	21.6	22	39	7.55	0.746	52.0

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

Figure A.57 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and Axial Distributions at 16,025.0 MWd/MTU

**Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design**

Revision 1

Page A-63

Cycle:	19	Core Average Exposure: MWd/MTU	29925.2
Exposure: MWd/MTU (GWd)	16026.0 (2208.20)		
Delta E: MWd/MTU, (GWd)	1.0 (0.14)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-26.79		
Flow: Mlb/hr	103.01 (100.50 %)		
		Axial Profile	Edit Radial Power
		N (PRA) Power Exposure	Zone Avg. Max. IR JR
		Top 25 0.265 6.396	14 0.396 0.396 35 2
		24 0.699 17.784	16 0.369 0.566 9 12
		23 0.882 23.106	17 0.332 0.385 59 36
		22 0.979 26.555	18 0.388 0.450 29 60
		21 1.041 28.578	19 0.813 1.062 47 48
		20 1.076 29.913	20 1.042 1.186 27 28
		19 1.097 30.618	21 1.065 1.168 29 32
		18 1.134 31.354	22 1.249 1.408 33 32
		17 1.161 31.652	23 1.152 1.311 51 42
		16 1.188 32.280	24 1.116 1.347 51 40
		15 1.213 33.219	
		14 1.189 33.252	
		13 1.275 31.952	
		12 1.283* 32.911	
		11 1.274 33.558	
		10 1.269 34.352	
		9 1.247 35.377	
		8 1.195 36.079	
		7 1.122 36.650	
		6 1.053 37.695	
		5 0.965 37.713*	
		4 0.868 36.184	
		3 0.770 33.028	
		2 0.588 25.172	
		Bottom 1 0.168 7.333	
		% AXIAL TILT 0.512 -8.793	
		AVG BOT 8ft/12ft 1.0107 1.0496	
Control Rod Density: %	5.36		
k-effective:	0.99998		
Void Fraction:	0.406		
Core Delta-P: psia	24.436		
Core Plate Delta-P: psia	19.877		
Coolant Temp: Deg-F	547.5		
In Channel Flow: Mlb/hr	90.99	Active Channel Flow: Mlb/hr	87.89
Total Bypass Flow (%):	11.7	(of total core flow)	
Total Water Rod Flow (%):	3.0	(of total core flow)	
Source Convergence	0.00010		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	IR	JR	K	Value
1.408	22	33	32	1.604	0.898	22	33	7.00	0.725	47.1	20	37	50	15	7.62
1.407	22	31	34	1.615	0.892	22	31	7.10	0.721	45.4	20	31	52	15	7.62
1.384	22	25	28	1.633	0.882	22	25	7.00	0.720	46.5	20	11	24	15	7.66
1.382	22	33	36	1.638	0.879	22	33	6.97	0.718	46.7	20	9	30	15	7.72
1.363	22	49	40	1.664	0.866	22	49	6.87	0.712	47.2	20	41	50	15	7.57
1.362	22	51	38	1.668	0.863	22	9	6.85	0.709	47.2	20	11	20	15	7.74
1.351	22	23	30	1.682	0.856	22	31	8.53	0.693	21.6	22	39	50	15	7.56
1.348	22	31	50	1.685	0.855	22	49	6.80	0.692	45.6	20	35	48	15	7.53
1.348	22	39	50	1.685	0.855	22	39	8.51	0.692	21.7	22	35	50	15	7.41
1.348	22	31	38	1.689	0.853	22	23	6.74	0.691	46.3	20	13	26	15	7.50

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

**Figure A.58 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and
Axial Distributions at 16,026.0 MWd/MTU**

Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design

Revision 1

Page A-64

Cycle:	19	Core Average Exposure: MWd/MTU	30199.2
Exposure: MWd/MTU (GWd)	16300.0 (2245.90)		
Delta E: MWd/MTU, (GWd)	274.0 (37.75)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-25.98		
Flow: Mlb/hr	105.99 (103.40 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
2 6 10 14 18 22 26 30 34 38 42 46 50 54 58		Top 25	0.271 6.474 14 0.397 0.397 35 2
59		24	0.715 17.991 16 0.369 0.566 9 12
55		23	0.902 23.367 17 0.332 0.384 59 36
51		22	1.003 26.847 18 0.388 0.450 29 60
47		21	1.065 28.888 19 0.815 1.064 47 48
43		20	1.100 30.233 20 1.040 1.183 27 28
39		19	1.120 30.945 21 1.063 1.164 31 30
35		18	1.156 31.692 22 1.248 1.408 33 32
31		17	1.183 31.997 23 1.157 1.315 51 42
27		16	1.208 32.629 24 1.119 1.349 51 40
23		15	1.230 33.574
19		14	1.203 33.600
15		13	1.288 32.281
11		12	1.293* 33.242
7		11	1.279 33.887
3		10	1.267 34.678
		9	1.238 35.697
		8	1.176 36.384
		7	1.094 36.935
		6	1.017 37.961*
		5	0.923 37.956
		4	0.824 36.402
		3	0.730 33.221
		2	0.557 25.319
		Bottom 1	0.160 7.377
Control Rod Density: %	5.36		
k-effective:	0.99997		
Void Fraction:	0.396		
Core Delta-P: psia	25.431	% AXIAL TILT	2.516 -8.642
Core Plate Delta-P: psia	20.871	AVG BOT 8ft/12ft	1.0000 1.0488
Coolant Temp: Deg-F	547.4		
In Channel Flow: Mlb/hr	93.71	Active Channel Flow: Mlb/hr	90.55
Total Bypass Flow (%):	11.6	(of total core flow)	
Total Water Rod Flow (%):	3.0	(of total core flow)	
Source Convergence	0.00009		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	Value	Margin	Exp.	FT
1.408	22	33	32	1.615	0.892	22	33	7.10	0.737	47.5	20	7.73	0.777	53.3	20
1.407	22	31	34	1.623	0.887	22	31	7.21	0.735	45.8	20	7.74	0.777	53.3	20
1.382	22	25	28	1.645	0.875	22	25	7.09	0.732	46.9	20	7.85	0.775	51.7	20
1.379	22	27	26	1.650	0.873	22	33	7.05	0.729	47.1	20	7.76	0.774	52.7	20
1.365	22	51	38	1.663	0.866	22	49	6.98	0.726	47.6	20	7.68	0.771	53.3	20
1.364	22	49	40	1.665	0.865	22	9	6.95	0.722	47.6	20	7.84	0.770	51.4	20
1.351	22	37	52	1.681	0.857	22	31	8.67	0.706	22.0	22	7.70	0.765	52.4	21
1.350	22	39	50	1.682	0.856	22	39	8.68	0.705	21.6	22	7.65	0.759	52.2	21
1.350	22	23	30	1.687	0.853	22	23	8.67	0.705	21.7	22	7.60	0.754	52.1	21
1.349	22	33	52	1.689	0.853	22	49	8.63	0.704	22.2	22	7.58	0.753	52.3	20

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

Figure A.59 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and Axial Distributions at 16,300.0 MWd/MTU

**Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design**

Revision 1

Page A-65

Cycle:	19	Core Average Exposure: MWd/MTU	30200.2
Exposure: MWd/MTU (GWd)	16301.0 (2246.10)		
Delta E: MWd/MTU, (GWd)	1.0 (0.14)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-26.94		
Flow: Mlb/hr	102.50 (100.00 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top	25 0.272 6.475 14 0.396 0.396 35 2
			24 0.717 17.992 16 0.369 0.565 9 12
			23 0.905 23.368 17 0.332 0.382 59 36
			22 1.010 26.848 18 0.388 0.449 29 60
			21 1.078 28.889 19 0.813 1.061 47 48
			20 1.121 30.234 20 1.041 1.177 27 28
			19 1.145 30.946 21 1.065 1.158 31 30
			18 1.172 31.693 22 1.250 1.400 27 30
			17 1.190 31.999 23 1.153 1.308 51 42
			16 1.210 32.630 24 1.116 1.341 51 40
			15 1.227 33.576
			14 1.197 33.601
			13 1.279 32.282
			12 1.282* 33.244
			11 1.267 33.888
			10 1.255 34.680
			9 1.226 35.698
			8 1.166 36.385
			7 1.086 36.936
			6 1.011 37.962*
			5 0.919 37.957
			4 0.822 36.402
			3 0.728 33.222
			2 0.556 25.320
		Bottom	1 0.159 7.378
Control Rod Density: %	5.23		
k-effective:	0.99998		
Void Fraction:	0.400		
Core Delta-P: psia	24.168	% AXIAL TILT	3.230 -8.641
Core Plate Delta-P: psia	19.610	AVG BOT 8ft/12ft	0.9943 1.0488
Coolant Temp: Deg-F	547.3		
In Channel Flow: Mlb/hr	90.57	Active Channel Flow: Mlb/hr	87.50
Total Bypass Flow (%):	11.6	(of total core flow)	
Total Water Rod Flow (%):	3.0	(of total core flow)	
Source Convergence	0.00006		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	IR	Value	Margin	Exp.
1.400	22	27	30	1.599	0.901	22	33	7.06	0.734	47.5	20	23	8.17	0.779	48.9
1.400	22	31	34	1.607	0.896	22	31	7.15	0.730	45.9	20	29	8.23	0.778	48.1
1.375	22	25	28	1.625	0.886	22	25	7.05	0.728	46.9	20	11	7.69	0.775	53.5
1.373	22	27	26	1.630	0.883	22	33	7.34	0.726	42.8	20	43	7.70	0.774	53.3
1.358	22	49	40	1.647	0.875	22	49	7.00	0.724	47.1	20	9	7.80	0.770	51.7
1.357	22	51	38	1.651	0.872	22	9	6.95	0.723	47.6	20	19	7.71	0.769	52.7
1.344	22	39	50	1.666	0.865	22	39	6.92	0.719	47.6	20	11	7.64	0.768	53.3
1.344	22	23	30	1.667	0.864	22	31	7.15	0.705	42.4	21	19	7.80	0.767	51.4
1.343	22	37	52	1.668	0.863	22	49	8.63	0.703	22.0	22	21	7.64	0.760	52.4
1.341	24	51	40	1.673	0.861	22	25	8.63	0.701	21.6	22	37	7.60	0.754	52.2

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

**Figure A.60 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and
Axial Distributions at 16,301.0 MWd/MTU**

Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design

Revision 1

Page A-66

Cycle:	19	Core Average Exposure: MWd/MTU	30499.2
Exposure: MWd/MTU (GWd)	16600.0 (2287.30)		
Delta E: MWd/MTU, (GWd)	299.0 (41.20)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-25.84		
Flow: Mlb/hr	106.50 (103.90 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top	25 0.278 6.563 14 0.396 0.396 35 2
			24 0.735 18.224 16 0.369 0.566 9 12
			23 0.928 23.661 17 0.332 0.382 59 36
			22 1.037 27.177 18 0.388 0.449 29 60
			21 1.106 29.240 19 0.814 1.065 13 14
			20 1.149 30.599 20 1.039 1.172 27 28
			19 1.171 31.319 21 1.061 1.152 31 30
			18 1.196 32.074 22 1.248 1.399 29 28
			17 1.212 32.385 23 1.159 1.313 9 20
			16 1.229 33.017 24 1.120 1.345 9 22
			15 1.244 33.968
			14 1.211 33.983
			13 1.292* 32.643
			12 1.292 33.605
			11 1.271 34.244
			10 1.252 35.032
			9 1.216 36.041
			8 1.146 36.710
			7 1.056 37.237
			6 0.972 38.240*
			5 0.874 38.208
			4 0.775 36.627
			3 0.685 33.420
			2 0.524 25.471
		Bottom	1 0.150 7.423
Control Rod Density: %	5.23		
k-effective:	0.99997		
Void Fraction:	0.389		
Core Delta-P: psia	25.521	% AXIAL TILT	5.416 -8.451
Core Plate Delta-P: psia	20.960	AVG BOT 8ft/12ft	0.9822 1.0479
Coolant Temp: Deg-F	547.3		
In Channel Flow: Mlb/hr	94.22	Active Channel Flow: Mlb/hr	91.07
Total Bypass Flow (%):	11.5	(of total core flow)	
Total Water Rod Flow (%):	3.0	(of total core flow)	
Source Convergence	0.00005		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	IR	Value	Margin	Exp.
1.399	22	29	28	1.617	0.891	22	33	7.16	0.747	47.9	20	23	8.41	0.800	48.6
1.398	22	27	30	1.623	0.887	22	31	7.50	0.745	43.2	20	17	8.27	0.793	49.4
1.371	22	25	28	1.645	0.875	22	25	7.26	0.745	46.3	20	29	7.80	0.791	54.0
1.368	22	27	26	1.650	0.873	22	49	7.14	0.741	47.4	20	11	7.82	0.790	53.8
1.360	22	9	24	1.650	0.873	22	33	7.06	0.737	48.0	20	19	7.94	0.788	52.2
1.360	22	11	22	1.653	0.871	22	9	7.07	0.735	47.6	20	9	7.75	0.784	53.7
1.347	22	37	52	1.665	0.865	22	39	7.02	0.733	48.0	20	11	7.80	0.783	53.2
1.347	22	39	50	1.670	0.862	22	31	7.26	0.718	42.9	21	19	7.72	0.781	53.8
1.345	24	9	22	1.672	0.861	22	23	8.76	0.717	22.5	22	21	7.78	0.778	52.9
1.344	22	33	52	1.675	0.860	22	33	8.79	0.717	22.1	22	23	7.71	0.770	52.7

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

Figure A.61 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and Axial Distributions at 16,600.0 MWd/MTU

Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design

Revision 1

Page A-67

Cycle:	19	Core Average Exposure: MWd/MTU	30500.2
Exposure: MWd/MTU (GWd)	16601.0 (2287.40)		
Delta E: MWd/MTU, (GWd)	1.0 (0.14)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-26.85		
Flow: Mlb/hr	102.81 (100.30 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top	25 0.280 6.563 14 0.394 0.394 35 2
			24 0.739 18.224 16 0.367 0.563 9 12
			23 0.935 23.662 17 0.331 0.381 59 36
			22 1.048 27.178 18 0.386 0.447 29 60
			21 1.124 29.241 19 0.810 1.057 13 14
			20 1.177 30.601 20 1.043 1.175 27 28
			19 1.188 31.320 21 1.063 1.155 31 30
			18 1.205 32.075 22 1.252 1.402 27 32
			17 1.216 32.386 23 1.151 1.306 51 20
			16 1.228 33.018 24 1.114 1.338 9 40
			15 1.239 33.969
			14 1.203 33.985
			13 1.282* 32.645
			12 1.280 33.606
			11 1.259 34.246
			10 1.240 35.033
			9 1.204 36.042
			8 1.136 36.711
			7 1.048 37.238
			6 0.967 38.241*
			5 0.871 38.209
			4 0.774 36.627
			3 0.684 33.421
			2 0.524 25.472
		Bottom	1 0.150 7.424
Control Rod Density: %	5.09		
k-effective:	0.99996		
Void Fraction:	0.392		
Core Delta-P: psia	24.184	% AXIAL TILT	6.096 -8.451
Core Plate Delta-P: psia	19.625	AVG BOT 8ft/12ft	0.9762 1.0479
Coolant Temp: Deg-F	547.2		
In Channel Flow: Mlb/hr	90.90	Active Channel Flow: Mlb/hr	87.83
Total Bypass Flow (%):	11.6	(of total core flow)	
Total Water Rod Flow (%):	3.0	(of total core flow)	
Source Convergence	0.00008		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	IR	Value	Margin	Exp.
1.402	22	27	32	1.579	0.912	22	33	7.60	0.755	43.2	20	17	8.52	0.814	49.0
1.402	22	29	28	1.588	0.907	22	31	7.09	0.740	47.9	20	23	8.50	0.808	48.6
1.377	22	25	34	1.602	0.899	22	25	7.20	0.739	46.3	20	29	7.75	0.786	54.0
1.372	22	33	26	1.609	0.895	22	33	7.46	0.738	42.9	21	19	7.73	0.782	53.8
1.356	22	11	40	1.632	0.882	22	49	7.10	0.737	47.4	20	11	7.87	0.781	52.2
1.354	22	9	38	1.635	0.881	22	9	7.04	0.732	47.6	20	9	7.76	0.779	53.2
1.351	22	23	32	1.642	0.877	22	23	9.05	0.730	20.9	22	17	7.69	0.778	53.7
1.341	22	31	24	1.650	0.873	22	49	6.99	0.730	48.0	20	19	7.68	0.777	53.8
1.340	22	39	12	1.655	0.870	22	31	6.97	0.728	48.0	20	11	7.70	0.770	52.9
1.339	22	23	52	1.656	0.870	22	9	8.99	0.726	21.0	22	19	7.66	0.765	52.7

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

Figure A.62 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and Axial Distributions at 16,601.0 MWd/MTU

**Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design**

Revision 1

Page A-68

Cycle:	19	Core Average Exposure: MWd/MTU	30734.2
Exposure: MWd/MTU (GWd)	16835.0 (2319.60)		
Delta E: MWd/MTU, (GWd)	234.0 (32.24)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-25.84		
Flow: Mlb/hr	106.50 (103.90 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top 25	0.286 6.634 14 0.395 0.395 35 2
		24	0.754 18.411 16 0.367 0.563 9 12
		23	0.955 23.898 17 0.331 0.380 59 36
		22	1.070 27.444 18 0.386 0.448 29 60
		21	1.146 29.526 19 0.812 1.060 13 14
		20	1.199 30.899 20 1.040 1.171 27 28
		19	1.208 31.622 21 1.060 1.150 31 30
		18	1.224 32.381 22 1.250 1.399 29 28
		17	1.232 32.694 23 1.156 1.311 9 42
		16	1.241 33.325 24 1.117 1.341 9 40
		15	1.250 34.278
		14	1.212 34.284
		13	1.291* 32.927
		12	1.286 33.888
		11	1.261 34.522
		10	1.237 35.305
		9	1.195 36.306
		8	1.120 36.959
		7	1.025 37.466
		6	0.937 38.450*
		5	0.837 38.397
		4	0.739 36.794
		3	0.653 33.568
		2	0.500 25.584
		Bottom 1	0.143 7.458
Control Rod Density: %	5.09		
k-effective:	0.99993		
Void Fraction:	0.383		
Core Delta-P: psia	25.442	% AXIAL TILT	7.776 -8.285
Core Plate Delta-P: psia	20.882	AVG BOT 8ft/12ft	0.9667 1.0471
Coolant Temp: Deg-F	547.2		
In Channel Flow: Mlb/hr	94.26	Active Channel Flow: Mlb/hr	91.12
Total Bypass Flow (%):	11.5	(of total core flow)	
Total Water Rod Flow (%):	2.9	(of total core flow)	
Source Convergence	0.00009		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	IR	Value	Margin	Exp.
1.399	22	29	28	1.598	0.901	22	33	7.71	0.768	43.6	20	17	8.59	0.825	49.4
1.399	22	27	30	1.605	0.897	22	31	7.16	0.751	48.3	20	23	8.63	0.825	49.0
1.373	22	25	28	1.622	0.888	22	25	7.27	0.749	46.7	20	29	7.83	0.797	54.4
1.367	22	33	26	1.629	0.884	22	33	7.52	0.747	43.2	21	19	7.82	0.794	54.2
1.357	22	9	24	1.638	0.879	22	49	7.16	0.746	47.7	20	11	7.96	0.794	52.6
1.357	22	11	40	1.638	0.879	22	9	9.18	0.743	21.3	22	17	7.83	0.790	53.5
1.348	22	23	32	1.659	0.868	22	49	7.07	0.741	48.4	20	19	7.77	0.789	54.1
1.343	22	37	10	1.660	0.868	22	23	7.09	0.740	47.9	20	9	7.74	0.787	54.2
1.343	22	39	12	1.660	0.867	22	39	9.12	0.739	21.4	22	19	7.80	0.784	53.2
1.341	24	9	40	1.660	0.867	22	31	7.04	0.738	48.4	20	11	7.75	0.777	53.1

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

**Figure A.63 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and
Axial Distributions at 16,835.0 MWd/MTU**

**Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design**

Revision 1

Page A-69

Cycle:	19	Core Average Exposure: MWd/MTU	30735.2
Exposure: MWd/MTU (GWd)	16836.0 (2319.80)		
Delta E: MWd/MTU, (GWd)	1.0 (0.14)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-26.94		
Flow: Mlb/hr	102.50 (100.00 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top	25 0.286 6.634 14 0.393 0.393 35 2
			24 0.753 18.412 16 0.366 0.563 9 12
			23 0.954 23.899 17 0.329 0.379 35 60
			22 1.073 27.445 18 0.385 0.446 29 60
			21 1.156 29.527 19 0.807 1.060 13 14
			20 1.218 30.901 20 1.044 1.171 27 28
			19 1.233 31.623 21 1.063 1.148 31 30
			18 1.251 32.382 22 1.254 1.399 29 28
			17 1.248 32.696 23 1.149 1.302 9 20
			16 1.249 33.326 24 1.111 1.331 9 22
			15 1.251 34.279
			14 1.209 34.286
			13 1.283* 32.928
			12 1.275 33.889
			11 1.248 34.523
			10 1.224 35.306
			9 1.183 36.307
			8 1.109 36.960
			7 1.015 37.467
			6 0.929 38.451*
			5 0.831 38.398
			4 0.735 36.794
			3 0.649 33.568
			2 0.497 25.585
		Bottom	1 0.143 7.458
Control Rod Density: %	4.91		
k-effective:	1.00005		
Void Fraction:	0.387		
Core Delta-P: psia	24.001	% AXIAL TILT	8.616 -8.284
Core Plate Delta-P: psia	19.443	AVG BOT 8ft/12ft	0.9607 1.0471
Coolant Temp: Deg-F	547.1		
In Channel Flow: Mlb/hr	90.66	Active Channel Flow: Mlb/hr	87.62
Total Bypass Flow (%):	11.5	(of total core flow)	
Total Water Rod Flow (%):	3.0	(of total core flow)	
Source Convergence	0.00008		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	Value	Margin	Exp.	FT
1.399	22	29	28	1.572	0.916	22	33	7.93	0.795	44.2	20	8.89	0.856	49.6	20
1.396	22	27	30	1.573	0.915	22	31	7.67	0.776	45.0	20	8.70	0.848	50.8	21
1.373	22	25	28	1.598	0.901	22	25	9.45	0.768	21.8	22	8.54	0.835	51.0	20
1.372	22	27	26	1.600	0.900	22	27	7.65	0.768	44.2	21	8.38	0.816	50.6	20
1.350	22	11	22	1.622	0.888	22	49	9.43	0.767	21.7	22	7.86	0.798	54.2	20
1.347	22	9	24	1.625	0.886	22	39	7.54	0.763	45.0	20	7.85	0.797	54.1	20
1.345	22	23	30	1.626	0.885	22	9	7.20	0.755	48.3	20	7.94	0.792	52.6	20
1.345	22	29	24	1.630	0.884	22	31	7.28	0.748	46.5	20	10.48	0.789	25.6	22
1.343	22	21	12	1.632	0.882	22	31	7.10	0.745	48.4	20	7.76	0.788	54.2	20
1.340	22	23	10	1.632	0.882	22	23	7.13	0.743	47.7	20	10.47	0.788	25.5	22

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

**Figure A.64 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and
Axial Distributions at 16,836.0 MWd/MTU**

**Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design**

Revision 1

Page A-70

Cycle:	19	Core Average Exposure: MWd/MTU	30953.8
Exposure: MWd/MTU (GWd)	17054.7 (2349.90)		
Delta E: MWd/MTU, (GWd)	218.7 (30.13)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-25.90		
Flow: Mlb/hr	106.29 (103.70 %)		
		Axial Profile	Edit Radial Power
		N (PRA) Power Exposure	Zone Avg. Max. IR JR
2 6 10 14 18 22 26 30 34 38 42 46 50 54 58		Top 25 0.290 6.702	14 0.393 0.393 35 2
59		24 0.767 18.589	16 0.366 0.564 9 12
55		23 0.972 24.124	17 0.329 0.379 35 60
51		22 1.093 27.700	18 0.385 0.447 29 60
47		21 1.177 29.801	19 0.809 1.064 13 14
43		20 1.238 31.189	20 1.042 1.166 27 28
39		19 1.251 31.915	21 1.060 1.143 31 30
35		18 1.267 32.678	22 1.252 1.395 29 28
31		17 1.262 32.991	23 1.155 1.307 9 20
27		16 1.260 33.617	24 1.115 1.334 9 22
23		15 1.261 34.571	
19		14 1.216 34.567	
15		13 1.290* 33.193	
11		12 1.280 34.151	
7		11 1.250 34.780	
3		10 1.222 35.558	
		9 1.174 36.549	
		8 1.094 37.186	
		7 0.994 37.673	
		6 0.902 38.639*	
		5 0.800 38.565	
		4 0.704 36.942	
		3 0.621 33.699	
		2 0.476 25.685	
		Bottom 1 0.137 7.488	
Control Rod Density: %	4.91		
k-effective:	0.99997		
Void Fraction:	0.378		
Core Delta-P: psia	25.296	% AXIAL TILT	10.120 -8.114
Core Plate Delta-P: psia	20.737	AVG BOT 8ft/12ft	0.9520 1.0462
Coolant Temp: Deg-F	547.1		
In Channel Flow: Mlb/hr	94.11	Active Channel Flow: Mlb/hr	90.99
Total Bypass Flow (%):	11.5	(of total core flow)	
Total Water Rod Flow (%):	2.9	(of total core flow)	
Source Convergence	0.00009		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	Value	Margin	Exp.	FT
1.395	22	29	28	1.593	0.904	22	31	8.01	0.807	44.6	20	9.00	0.870	50.0	20
1.392	22	27	30	1.594	0.903	22	33	7.74	0.785	45.3	20	8.74	0.856	51.2	21
1.368	22	25	28	1.620	0.889	22	25	9.54	0.779	22.2	22	8.63	0.847	51.3	20
1.366	22	27	26	1.622	0.888	22	27	9.53	0.777	22.2	22	8.43	0.825	51.0	20
1.352	22	11	22	1.628	0.884	22	39	7.69	0.775	44.6	21	7.93	0.810	54.5	20
1.350	22	9	24	1.629	0.884	22	49	7.59	0.771	45.4	20	7.92	0.808	54.5	20
1.346	22	21	12	1.631	0.883	22	9	7.26	0.763	48.6	20	8.02	0.803	53.0	20
1.345	22	23	10	1.634	0.881	22	23	7.34	0.758	46.9	20	10.59	0.800	26.1	22
1.341	22	23	30	1.637	0.880	22	31	7.17	0.755	48.7	20	7.83	0.799	54.5	20
1.340	22	27	10	1.645	0.875	22	33	7.18	0.751	48.1	20	10.57	0.799	26.0	22

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

**Figure A.65 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and
Axial Distributions at 17,054.7 MWd/MTU**

**Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design**

Revision 1

Page A-71

Cycle:	19	Core Average Exposure: MWd/MTU	30958.2
Exposure: MWd/MTU (GWd)	17059.0 (2350.50)		
Delta E: MWd/MTU, (GWd)	4.4 (0.60)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-26.65		
Flow: Mlb/hr	103.53 (101.00 %)		
		Axial Profile	Edit Radial Power
		N (PRA) Power Exposure	Zone Avg. Max. IR JR
		Top 25 0.236 6.703	14 0.390 0.390 35 2
		24 0.622 18.593	16 0.365 0.566 9 12
		23 0.790 24.128	17 0.327 0.375 25 60
		22 0.895 27.704	18 0.381 0.443 29 60
		21 0.974 29.806	19 0.805 1.078 13 14
		20 1.051 31.195	20 1.054 1.143 35 14
		19 1.108 31.921	21 1.031 1.128 39 14
		18 1.170 32.684	22 1.255 1.373 37 14
		17 1.215 32.997	23 1.153 1.309 41 10
		16 1.252 33.623	24 1.116 1.331 9 40
		15 1.280 34.577	
		14 1.256 34.573	
		13 1.347* 33.198	
		12 1.345 34.157	
		11 1.321 34.785	
		10 1.296 35.563	
		9 1.255 36.554	
		8 1.184 37.191	
		7 1.097 37.678	
		6 1.020 38.643*	
		5 0.931 38.569	
		4 0.841 36.945	
		3 0.756 33.701	
		2 0.587 25.687	
		Bottom 1 0.170 7.489	
		% AXIAL TILT 0.196 -8.111	
		AVG BOT 8ft/12ft 1.0260 1.0462	
Control Rod Density: %	3.11		
k-effective:	0.99995		
Void Fraction:	0.405		
Core Delta-P: psia	24.669		
Core Plate Delta-P: psia	20.117		
Coolant Temp: Deg-F	547.4		
In Channel Flow: Mlb/hr	91.42	Active Channel Flow: Mlb/hr	88.30
Total Bypass Flow (%):	11.7	(of total core flow)	
Total Water Rod Flow (%):	3.0	(of total core flow)	
Source Convergence	0.00009		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	IR	JR	K	Value
1.373	22	37	14	1.630	0.884	22	23	7.35	0.774	48.6	20	23	12	15	8.02
1.365	22	39	12	1.636	0.880	22	39	7.28	0.766	48.7	20	19	12	15	8.00
1.365	22	39	16	1.639	0.879	22	39	7.35	0.758	46.7	20	17	18	15	7.91
1.364	22	11	40	1.647	0.874	22	49	7.34	0.757	46.9	20	29	10	15	7.97
1.355	22	35	12	1.647	0.874	22	25	7.19	0.757	48.7	20	11	20	15	7.95
1.354	22	31	12	1.648	0.874	22	31	7.29	0.757	47.4	20	17	14	15	7.99
1.354	22	33	14	1.648	0.874	22	23	7.23	0.756	48.1	20	11	24	15	7.90
1.349	22	41	14	1.656	0.869	22	41	7.31	0.756	47.1	20	25	14	15	7.84
1.349	22	41	18	1.660	0.868	22	15	7.28	0.754	47.2	20	15	16	15	7.93
1.348	22	37	10	1.661	0.867	22	9	7.32	0.754	46.6	20	13	18	15	7.81

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

**Figure A.66 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and
Axial Distributions at 17,059.0 MWd/MTU**

**Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design**

Revision 1

Page A-72

Cycle:	19	Core Average Exposure: MWd/MTU	31074.2
Exposure: MWd/MTU (GWd)	17175.0 (2366.50)		
Delta E: MWd/MTU, (GWd)	116.0 (15.98)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-25.84		
Flow: Mlb/hr	106.50 (103.90 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
2 6 10 14 18 22 26 30 34 38 42 46 50 54 58		Top 25	0.239 6.732 14 0.390 0.390 35 2
59		24	0.630 18.670 16 0.365 0.566 9 12
55		23	0.800 24.227 17 0.327 0.375 25 60
51		22	0.905 27.816 18 0.381 0.443 29 60
47		21	0.984 29.928 19 0.806 1.080 13 14
43		20	1.061 31.326 20 1.053 1.142 35 14
39		19	1.117 32.059 21 1.030 1.127 39 14
35		18	1.178 32.830 22 1.254 1.372 37 14
31		17	1.222 33.149 23 1.157 1.312 41 10
27		16	1.258 33.778 24 1.118 1.334 9 40
23		15	1.285 34.735
19		14	1.261 34.728
15		13	1.352* 33.345
11		12	1.349 34.303
7		11	1.323 34.929
3		10	1.296 35.704
		9	1.251 36.691
		8	1.177 37.320
		7	1.086 37.796
		6	1.006 38.754*
		5	0.915 38.669
		4	0.824 37.036
		3	0.740 33.783
		2	0.575 25.750
		Bottom 1	0.167 7.508
Control Rod Density: %	3.11	% AXIAL TILT	0.973 -8.055
k-effective:	0.99996	AVG BOT 8ft/12ft	1.0216 1.0460
Void Fraction:	0.399		
Core Delta-P: psia	25.711		
Core Plate Delta-P: psia	21.158		
Coolant Temp: Deg-F	547.5		
In Channel Flow: Mlb/hr	94.12	Active Channel Flow: Mlb/hr	90.93
Total Bypass Flow (%):	11.6	(of total core flow)	
Total Water Rod Flow (%):	3.0	(of total core flow)	
Source Convergence	0.00006		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	Value	Margin	Exp.	FT
1.372	22	37	14	1.643	0.876	22	23	7.38	0.778	48.8	20	8.06	0.824	54.7	20
1.367	22	39	12	1.649	0.873	22	39	7.31	0.771	48.9	20	8.04	0.823	54.8	20
1.365	22	11	40	1.650	0.873	22	39	7.37	0.762	47.1	20	7.95	0.813	54.7	20
1.363	22	39	16	1.657	0.869	22	23	7.23	0.762	48.9	20	8.00	0.809	53.8	20
1.356	22	35	12	1.657	0.869	22	49	7.32	0.761	47.6	20	8.04	0.807	53.2	20
1.355	22	31	12	1.657	0.869	22	25	7.37	0.761	46.9	20	7.98	0.806	53.7	20
1.353	22	33	14	1.658	0.868	22	31	7.26	0.761	48.3	20	7.97	0.802	53.4	20
1.351	22	37	10	1.670	0.862	22	33	7.33	0.759	47.3	20	7.93	0.802	53.8	20
1.349	22	41	14	1.670	0.862	22	9	7.31	0.758	47.4	20	7.88	0.802	54.3	21
1.347	22	41	18	1.672	0.861	22	41	7.35	0.758	46.8	20	7.84	0.801	54.6	20

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

**Figure A.67 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and
Axial Distributions at 17,175.0 MWd/MTU**

**Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design**

Revision 1

Page A-73

Cycle:	19	Core Average Exposure: MWd/MTU	31075.2
Exposure: MWd/MTU (GWd)	17176.0 (2366.60)		
Delta E: MWd/MTU, (GWd)	1.0 (0.14)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-26.85		
Flow: Mlb/hr	102.81 (100.30 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top	25 0.251 6.733 14 0.387 0.387 35 2
			24 0.661 18.671 16 0.363 0.563 9 12
			23 0.836 24.227 17 0.325 0.372 25 60
			22 0.939 27.817 18 0.379 0.439 29 60
			21 1.007 29.929 19 0.801 1.073 13 14
			20 1.075 31.328 20 1.058 1.143 21 18
			19 1.124 32.061 21 1.035 1.122 21 14
			18 1.179 32.832 22 1.258 1.365 23 14
			17 1.218 33.150 23 1.147 1.302 9 20
			16 1.250 33.779 24 1.109 1.326 9 22
			15 1.274 34.736
			14 1.248 34.729
			13 1.337* 33.346
			12 1.333 34.305
			11 1.306 34.930
			10 1.280 35.705
			9 1.236 36.692
			8 1.164 37.321
			7 1.076 37.797
			6 0.998 38.754*
			5 0.909 38.670
			4 0.820 37.037
			3 0.737 33.783
			2 0.574 25.751
		Bottom	1 0.166 7.508
Control Rod Density: %	2.84		
k-effective:	0.99997		
Void Fraction:	0.402		
Core Delta-P: psia	24.349	% AXIAL TILT	1.964 -8.055
Core Plate Delta-P: psia	19.799	AVG BOT 8ft/12ft	1.0127 1.0460
Coolant Temp: Deg-F	547.3		
In Channel Flow: Mlb/hr	90.81	Active Channel Flow: Mlb/hr	87.71
Total Bypass Flow (%):	11.7	(of total core flow)	
Total Water Rod Flow (%):	3.0	(of total core flow)	
Source Convergence	0.00005		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	Value	Margin	Exp.	FT
1.365	22	23	14	1.633	0.882	22	23	7.31	0.770	48.8	20	7.97	0.816	54.7	20
1.360	22	21	16	1.638	0.879	22	39	7.23	0.763	48.9	20	7.94	0.813	54.8	20
1.359	22	11	22	1.638	0.879	22	21	7.16	0.755	48.9	20	7.88	0.806	54.7	20
1.356	22	21	12	1.640	0.878	22	49	7.31	0.754	46.9	20	7.92	0.801	53.8	20
1.347	22	27	14	1.648	0.874	22	31	7.20	0.754	48.3	20	7.91	0.799	53.7	20
1.346	22	25	12	1.650	0.873	22	25	7.29	0.754	47.1	20	7.94	0.797	53.2	20
1.346	22	29	12	1.656	0.870	22	25	7.24	0.753	47.6	20	7.89	0.794	53.4	20
1.345	22	19	18	1.656	0.870	22	15	7.26	0.752	47.3	20	7.80	0.794	54.3	21
1.342	22	13	24	1.656	0.870	22	23	7.24	0.751	47.4	20	7.85	0.794	53.7	20
1.342	22	25	16	1.656	0.869	22	19	7.28	0.751	46.8	20	7.95	0.793	52.7	20

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

**Figure A.68 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and
Axial Distributions at 17,176.0 MWd/MTU**

**Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design**

Revision 1

Page A-74

Cycle:	19	Core Average Exposure: MWd/MTU	31274.2
Exposure: MWd/MTU (GWd)	17375.0 (2394.00)		
Delta E: MWd/MTU, (GWd)	199.0 (27.42)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-25.82		
Flow: Mlb/hr	106.60 (104.00 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top	25 0.258 6.787 14 0.387 0.387 35 2
			24 0.680 18.813 16 0.363 0.563 9 12
			23 0.860 24.408 17 0.325 0.372 25 60
			22 0.965 28.021 18 0.379 0.440 29 60
			21 1.034 30.148 19 0.802 1.075 13 14
			20 1.100 31.560 20 1.056 1.139 21 18
			19 1.147 32.304 21 1.033 1.120 21 14
			18 1.199 33.086 22 1.257 1.363 23 14
			17 1.235 33.413 23 1.152 1.306 9 20
			16 1.263 34.044 24 1.112 1.328 9 22
			15 1.284 35.006
			14 1.255 34.993
			13 1.342* 33.596
			12 1.336 34.554
			11 1.306 35.175
			10 1.275 35.944
			9 1.227 36.922
			8 1.148 37.537
			7 1.053 37.996
			6 0.968 38.938*
			5 0.874 38.837
			4 0.783 37.187
			3 0.702 33.918
			2 0.546 25.855
		Bottom	1 0.158 7.540
Control Rod Density: %	2.84		
k-effective:	0.99992		
Void Fraction:	0.392		
Core Delta-P: psia	25.643	% AXIAL TILT	3.811 -7.945
Core Plate Delta-P: psia	21.091	AVG BOT 8ft/12ft	1.0017 1.0455
Coolant Temp: Deg-F	547.4		
In Channel Flow: Mlb/hr	94.27	Active Channel Flow: Mlb/hr	91.10
Total Bypass Flow (%):	11.6	(of total core flow)	
Total Water Rod Flow (%):	3.0	(of total core flow)	
Source Convergence	0.00009		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	Value	Margin	Exp.	FT
1.363	22	23	14	1.643	0.876	22	39	7.36	0.778	49.1	20	8.04	0.826	55.1	20
1.359	22	11	22	1.646	0.875	22	23	7.29	0.772	49.2	20	8.02	0.823	54.9	20
1.357	22	21	12	1.647	0.874	22	49	7.21	0.763	49.2	20	7.95	0.816	55.0	20
1.356	22	21	16	1.651	0.872	22	21	7.35	0.762	47.4	20	7.98	0.810	54.1	20
1.347	22	25	12	1.656	0.870	22	31	7.25	0.762	48.6	20	8.02	0.808	53.5	20
1.345	22	29	12	1.658	0.869	22	23	7.29	0.761	47.9	20	7.95	0.806	54.0	20
1.344	22	27	14	1.658	0.868	22	25	7.33	0.759	47.2	20	7.96	0.804	53.7	20
1.342	22	23	10	1.662	0.866	22	9	7.30	0.759	47.6	20	7.86	0.803	54.6	21
1.341	22	9	24	1.667	0.864	22	33	7.28	0.758	47.7	20	7.85	0.802	54.7	20
1.340	22	19	18	1.669	0.863	22	41	7.33	0.758	47.1	20	7.90	0.802	54.1	20

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

**Figure A.69 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and
Axial Distributions at 17,375.0 MWd/MTU**

Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design

Revision 1

Page A-75

Cycle:	19	Core Average Exposure: MWd/MTU	31275.3
Exposure: MWd/MTU (GWd)	17376.0 (2394.20)		
Delta E: MWd/MTU, (GWd)	1.0 (0.14)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-26.94		
Flow: Mlb/hr	102.50 (100.00 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top	25 0.263 6.787 14 0.385 0.385 35 2
			24 0.692 18.814 16 0.361 0.559 9 12
			23 0.876 24.409 17 0.324 0.370 25 60
			22 0.989 28.022 18 0.377 0.437 29 60
			21 1.067 30.149 19 0.797 1.066 13 14
			20 1.127 31.561 20 1.060 1.137 21 18
			19 1.163 32.305 21 1.037 1.114 21 14
			18 1.207 33.087 22 1.261 1.355 23 14
			17 1.236 33.414 23 1.142 1.296 9 20
			16 1.259 34.046 24 1.103 1.319 9 22
			15 1.276 35.008
			14 1.244 34.995
			13 1.328* 33.598
			12 1.320 34.555
			11 1.290 35.176
			10 1.259 35.945
			9 1.212 36.923
			8 1.136 37.538
			7 1.043 37.997
			6 0.961 38.939*
			5 0.869 38.837
			4 0.780 37.187
			3 0.700 33.919
			2 0.545 25.856
		Bottom	1 0.158 7.540
Control Rod Density: %	2.66		
k-effective:	0.99992		
Void Fraction:	0.395		
Core Delta-P: psia	24.147	% AXIAL TILT	4.759 -7.944
Core Plate Delta-P: psia	19.597	AVG BOT 8ft/12ft	0.9933 1.0455
Coolant Temp: Deg-F	547.2		
In Channel Flow: Mlb/hr	90.58	Active Channel Flow: Mlb/hr	87.51
Total Bypass Flow (%):	11.6	(of total core flow)	
Total Water Rod Flow (%):	3.0	(of total core flow)	
Source Convergence	0.00006		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	Value	Margin	Exp.	FT
1.355	22	23	14	1.629	0.884	22	23	7.28	0.770	49.1	20	7.95	0.817	55.1	20
1.352	22	11	22	1.630	0.884	22	49	7.21	0.763	49.2	20	7.94	0.814	54.9	20
1.350	22	21	16	1.632	0.882	22	21	7.15	0.757	49.2	20	7.87	0.808	55.0	20
1.346	22	21	12	1.634	0.881	22	39	7.20	0.756	48.6	20	7.90	0.802	54.1	20
1.338	22	13	24	1.643	0.876	22	15	7.27	0.754	47.4	20	7.88	0.799	54.0	20
1.338	22	27	14	1.644	0.876	22	31	7.28	0.754	47.2	20	7.92	0.798	53.5	20
1.337	22	25	12	1.644	0.876	22	47	7.22	0.753	47.9	20	7.79	0.797	54.7	20
1.336	22	19	18	1.645	0.875	22	9	7.23	0.752	47.6	20	7.87	0.795	53.7	20
1.336	22	29	12	1.646	0.875	22	25	7.26	0.751	47.1	20	7.83	0.794	54.1	20
1.336	22	15	22	1.647	0.874	22	25	7.21	0.751	47.7	20	7.78	0.794	54.6	21

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

Figure A.70 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and Axial Distributions at 17,376.0 MWd/MTU

**Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design**

Revision 1

Page A-76

Cycle:	19	Core Average Exposure: MWd/MTU	31459.1
Exposure: MWd/MTU (GWd)	17560.0 (2419.50)		
Delta E: MWd/MTU, (GWd)	184.0 (25.35)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-25.87		
Flow: Mlb/hr	106.39 (103.80 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top 25	0.269 6.839 14 0.385 0.385 35 2
		24	0.709 18.952 16 0.361 0.559 9 12
		23	0.897 24.583 17 0.324 0.370 25 60
		22	1.012 28.220 18 0.377 0.437 29 60
		21	1.090 30.362 19 0.798 1.068 13 14
		20	1.149 31.787 20 1.059 1.134 21 18
		19	1.182 32.537 21 1.036 1.113 21 14
		18	1.224 33.328 22 1.260 1.354 23 14
		17	1.250 33.660 23 1.146 1.300 9 20
		16	1.270 34.293 24 1.106 1.322 9 22
		15	1.284 35.258
		14	1.250 35.238
		13	1.334* 33.828
		12	1.324 34.783
		11	1.290 35.399
		10	1.256 36.163
		9	1.205 37.132
		8	1.122 37.733
		7	1.023 38.176
		6	0.935 39.103*
		5	0.838 38.985
		4	0.747 37.319
		3	0.668 34.037
		2	0.521 25.948
		Bottom 1	0.151 7.569
Control Rod Density: %	2.66		
k-effective:	0.99991		
Void Fraction:	0.386		
Core Delta-P: psia	25.479	% AXIAL TILT	6.364 -7.828
Core Plate Delta-P: psia	20.928	AVG BOT 8ft/12ft	0.9836 1.0450
Coolant Temp: Deg-F	547.3		
In Channel Flow: Mlb/hr	94.13	Active Channel Flow: Mlb/hr	90.98
Total Bypass Flow (%):	11.5	(of total core flow)	
Total Water Rod Flow (%):	3.0	(of total core flow)	
Source Convergence	0.00010		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	IR	JR	K	Value
1.354	22	23	14	1.639	0.879	22	49	7.32	0.777	49.4	20	23	12	15	8.02
1.353	22	11	22	1.641	0.877	22	39	7.26	0.771	49.5	20	19	12	15	7.98
1.348	22	21	16	1.643	0.877	22	23	7.20	0.764	49.5	20	11	20	15	7.93
1.348	22	21	12	1.647	0.874	22	21	7.24	0.763	48.9	20	11	24	15	7.95
1.337	22	25	12	1.652	0.872	22	9	7.32	0.762	47.7	20	29	10	15	7.99
1.337	22	13	24	1.654	0.871	22	31	7.26	0.760	48.2	20	17	14	15	7.92
1.336	22	9	24	1.655	0.870	22	23	7.30	0.758	47.5	20	17	18	15	7.84
1.336	22	27	14	1.657	0.869	22	25	7.30	0.758	47.4	20	13	18	15	7.93
1.336	22	29	12	1.659	0.868	22	15	7.26	0.758	47.9	20	25	14	15	7.83
1.333	22	23	10	1.659	0.868	22	47	7.25	0.758	48.0	20	15	16	15	7.87

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

**Figure A.71 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and
Axial Distributions at 17,560.0 MWd/MTU**

**Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design**

Revision 1

Page A-77

Cycle:	19	Core Average Exposure: MWd/MTU	31460.1
Exposure: MWd/MTU (GWd)	17561.0 (2419.70)		
Delta E: MWd/MTU, (GWd)	1.0 (0.14)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-26.94		
Flow: Mlb/hr	102.50 (100.00 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top 25	0.270 6.840 14 0.381 0.381 35 2
		24	0.711 18.953 16 0.358 0.555 9 12
		23	0.902 24.584 17 0.321 0.367 25 60
		22	1.021 28.221 18 0.375 0.433 29 60
		21	1.106 30.363 19 0.792 1.059 13 14
		20	1.175 31.788 20 1.063 1.132 21 18
		19	1.207 32.538 21 1.041 1.105 21 14
		18	1.244 33.329 22 1.264 1.346 23 14
		17	1.261 33.661 23 1.137 1.290 9 20
		16	1.273 34.294 24 1.097 1.313 9 22
		15	1.282 35.259
		14	1.244 35.240
		13	1.324* 33.829
		12	1.312 34.785
		11	1.277 35.400
		10	1.243 36.164
		9	1.192 37.133
		8	1.111 37.734
		7	1.014 38.177
		6	0.927 39.104*
		5	0.832 38.986
		4	0.742 37.320
		3	0.664 34.037
		2	0.518 25.948
		Bottom 1	0.150 7.569
Control Rod Density: %	2.48		
k-effective:	1.00001		
Void Fraction:	0.389		
Core Delta-P: psia	24.069	% AXIAL TILT	7.242 -7.827
Core Plate Delta-P: psia	19.520	AVG BOT 8ft/12ft	0.9768 1.0450
Coolant Temp: Deg-F	547.1		
In Channel Flow: Mlb/hr	90.62	Active Channel Flow: Mlb/hr	87.57
Total Bypass Flow (%):	11.6	(of total core flow)	
Total Water Rod Flow (%):	3.0	(of total core flow)	
Source Convergence	0.00007		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	Value	Margin	Exp.	FT
1.346	22	23	14	1.624	0.886	22	49 40	7.26	0.770	49.4	20	7.93	0.818	55.4	20
1.346	22	11	22	1.628	0.885	22	23 14	7.19	0.763	49.5	20	7.92	0.815	55.2	20
1.342	22	21	16	1.630	0.884	22	21 16	7.22	0.761	48.9	20	7.88	0.812	55.4	20
1.336	22	21	12	1.634	0.881	22	47 24	7.15	0.759	49.5	20	8.04	0.805	52.9	20
1.335	22	13	24	1.634	0.881	22	15 40	7.26	0.755	47.5	20	7.88	0.803	54.4	20
1.331	22	15	22	1.634	0.881	22	39 50	7.24	0.754	47.7	20	7.82	0.803	55.0	20
1.330	22	27	14	1.638	0.879	22	9 24	7.20	0.753	48.2	20	7.87	0.801	54.3	20
1.329	22	25	16	1.639	0.879	22	25 16	7.22	0.753	47.9	20	7.90	0.800	53.8	20
1.329	22	19	18	1.643	0.876	22	19 18	7.25	0.752	47.4	20	7.85	0.796	54.0	20
1.328	22	9	24	1.644	0.876	22	31 50	7.20	0.752	48.0	20	7.81	0.796	54.4	20

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

**Figure A.72 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and
Axial Distributions at 17,561.0 MWd/MTU**

**Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design**

Revision 1

Page A-78

Cycle:	19	Core Average Exposure: MWd/MTU	31639.1
Exposure: MWd/MTU (GWd)	17740.0 (2444.30)		
Delta E: MWd/MTU, (GWd)	179.0 (24.66)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-25.82		
Flow: Mlb/hr	106.60 (104.00 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top	25 0.275 6.892 14 0.382 0.382 35 2
			24 0.726 19.090 16 0.358 0.556 9 12
			23 0.921 24.758 17 0.321 0.367 25 60
			22 1.042 28.419 18 0.375 0.434 29 60
			21 1.126 30.578 19 0.794 1.062 13 14
			20 1.194 32.016 20 1.062 1.129 21 18
			19 1.224 32.772 21 1.039 1.105 21 14
			18 1.259 33.570 22 1.263 1.347 11 22
			17 1.272 33.905 23 1.141 1.294 9 20
			16 1.282 34.537 24 1.100 1.316 9 22
			15 1.289 35.503
			14 1.248 35.476
			13 1.329* 34.052
			12 1.315 35.005
			11 1.278 35.614
			10 1.240 36.372
			9 1.185 37.333
			8 1.098 37.920
			7 0.996 38.346
			6 0.904 39.258*
			5 0.805 39.123
			4 0.714 37.442
			3 0.638 34.147
			2 0.497 26.033
		Bottom	1 0.144 7.595
Control Rod Density: %	2.48	% AXIAL TILT	8.633 -7.702
k-effective:	0.99994	AVG BOT 8ft/12ft	0.9684 1.0444
Void Fraction:	0.380		
Core Delta-P: psia	25.480		
Core Plate Delta-P: psia	20.930		
Coolant Temp: Deg-F	547.2		
In Channel Flow: Mlb/hr	94.35	Active Channel Flow: Mlb/hr	91.21
Total Bypass Flow (%):	11.5	(of total core flow)	
Total Water Rod Flow (%):	2.9	(of total core flow)	
Source Convergence	0.00007		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	Value	Margin	Exp.	FT
1.347	22	11	22	1.635	0.881	22	49 40	7.29	0.776	49.7	20	7.99	0.827	55.7	20
1.345	22	23	14	1.642	0.877	22	23 14	7.24	0.770	49.8	20	7.95	0.823	55.6	20
1.340	22	21	16	1.643	0.877	22	39 50	7.25	0.767	49.1	20	7.93	0.821	55.7	20
1.339	22	21	12	1.646	0.875	22	21 16	7.19	0.766	49.7	20	8.09	0.813	53.2	20
1.333	22	13	24	1.646	0.875	22	9 24	7.29	0.761	48.0	20	7.93	0.811	54.7	20
1.331	22	9	24	1.650	0.873	22	13 24	7.23	0.760	48.5	20	7.86	0.810	55.3	20
1.328	22	15	22	1.651	0.872	22	15 40	7.28	0.759	47.8	20	7.96	0.809	54.1	20
1.328	22	27	14	1.654	0.871	22	23 10	7.29	0.759	47.7	20	7.90	0.807	54.6	20
1.328	22	25	12	1.655	0.870	22	25 16	7.24	0.758	48.1	20	7.91	0.805	54.3	20
1.327	22	29	12	1.655	0.870	22	31 50	7.23	0.758	48.3	20	7.80	0.803	55.2	21

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

**Figure A.73 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and
Axial Distributions at 17,740.0 MWd/MTU**

**Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design**

Revision 1

Page A-79

Cycle:	19	Core Average Exposure: MWd/MTU	31640.1
Exposure: MWd/MTU (GWd)	17741.0 (2444.50)		
Delta E: MWd/MTU, (GWd)	1.0 (0.14)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-26.94		
Flow: Mlb/hr	102.50 (100.00 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top	25 0.263 6.892 14 0.376 0.376 35 2
			24 0.693 19.091 16 0.354 0.548 9 12
			23 0.878 24.759 17 0.317 0.361 25 60
			22 0.996 28.420 18 0.370 0.427 29 60
			21 1.079 30.579 19 0.783 1.047 13 14
			20 1.148 32.017 20 1.072 1.135 17 26
			19 1.183 32.774 21 1.040 1.097 13 22
			18 1.225 33.572 22 1.271 1.354 17 28
			17 1.251 33.906 23 1.126 1.279 9 20
			16 1.271 34.538 24 1.086 1.302 9 22
			15 1.284 35.504
			14 1.250 35.478
			13 1.334* 34.053
			12 1.322 35.007
			11 1.287 35.616
			10 1.251 36.374
			9 1.199 37.334
			8 1.118 37.921
			7 1.023 38.347
			6 0.940 39.259*
			5 0.850 39.124
			4 0.766 37.443
			3 0.691 34.147
			2 0.541 26.034
		Bottom	1 0.157 7.595
Control Rod Density: %	1.71	% AXIAL TILT	5.827 -7.702
k-effective:	1.00004	AVG BOT 8ft/12ft	0.9873 1.0444
Void Fraction:	0.392		
Core Delta-P: psia	24.126		
Core Plate Delta-P: psia	19.579		
Coolant Temp: Deg-F	547.1		
In Channel Flow: Mlb/hr	90.59	Active Channel Flow: Mlb/hr	87.53
Total Bypass Flow (%):	11.6	(of total core flow)	
Total Water Rod Flow (%):	3.0	(of total core flow)	
Source Convergence	0.00009		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	IR	Value	Margin	Exp.
1.354	22	17	28	1.634	0.881	22	17	7.16	0.762	49.7	20	23	7.84	0.811	55.7
1.353	22	19	30	1.637	0.880	22	41	7.19	0.760	49.1	20	11	7.81	0.808	55.7
1.339	22	21	28	1.641	0.877	22	49	7.10	0.756	49.8	20	19	7.81	0.807	55.5
1.339	22	19	26	1.641	0.877	22	15	7.08	0.754	49.7	20	11	7.80	0.804	55.3
1.337	22	13	24	1.642	0.877	22	13	7.13	0.751	48.8	20	13	7.79	0.797	54.7
1.336	22	11	22	1.648	0.874	22	15	7.17	0.747	47.8	20	17	7.69	0.794	55.4
1.335	22	15	26	1.651	0.872	22	19	7.17	0.746	47.7	20	13	7.77	0.794	54.6
1.334	22	23	30	1.653	0.871	22	9	7.15	0.746	48.0	20	29	7.81	0.793	54.1
1.328	22	15	22	1.655	0.870	22	23	7.10	0.746	48.5	20	17	7.76	0.790	54.3
1.326	22	23	14	1.656	0.869	22	15	7.14	0.745	47.9	20	15	7.78	0.788	53.9

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

**Figure A.74 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and
Axial Distributions at 17,741.0 MWd/MTU**

Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design

Revision 1

Page A-80

Cycle:	19	Core Average Exposure: MWd/MTU	31799.2
Exposure: MWd/MTU (GWd)	17900.0 (2466.40)		
Delta E: MWd/MTU, (GWd)	159.0 (21.91)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-25.82		
Flow: Mlb/hr	106.60 (104.00 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top 25	0.268 6.937 14 0.376 0.376 35 2
		24	0.707 19.210 16 0.354 0.549 9 12
		23	0.896 24.910 17 0.317 0.362 25 60
		22	1.014 28.592 18 0.370 0.428 29 60
		21	1.097 30.765 19 0.785 1.050 13 14
		20	1.165 32.215 20 1.070 1.130 17 26
		19	1.198 32.977 21 1.038 1.096 13 22
		18	1.238 33.782 22 1.269 1.349 19 30
		17	1.261 34.121 23 1.131 1.283 9 20
		16	1.278 34.753 24 1.089 1.305 9 22
		15	1.290 35.722
		14	1.254 35.689
		13	1.338* 34.252
		12	1.325 35.204
		11	1.287 35.808
		10	1.249 36.560
		9	1.193 37.513
		8	1.107 38.087
		7	1.007 38.498
		6	0.919 39.397*
		5	0.827 39.249
		4	0.741 37.556
		3	0.668 34.249
		2	0.524 26.113
		Bottom 1	0.152 7.619
Control Rod Density: %	1.71		
k-effective:	0.99996		
Void Fraction:	0.384		
Core Delta-P: psia	25.545	% AXIAL TILT	7.044 -7.599
Core Plate Delta-P: psia	20.997	AVG BOT 8ft/12ft	0.9799 1.0439
Coolant Temp: Deg-F	547.2		
In Channel Flow: Mlb/hr	94.32	Active Channel Flow: Mlb/hr	91.17
Total Bypass Flow (%):	11.5	(of total core flow)	
Total Water Rod Flow (%):	3.0	(of total core flow)	
Source Convergence	0.00005		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	Value	Margin	Exp.	FT
1.349	22	19	30	1.654	0.871	22	49 40	7.19	0.767	49.9	20	7.89	0.820	55.9	20
1.349	22	17	28	1.660	0.867	22	13 24	7.21	0.765	49.4	20	7.86	0.816	55.9	20
1.338	22	11	22	1.660	0.867	22	17 34	7.14	0.763	50.0	20	7.84	0.814	55.9	20
1.335	22	13	24	1.663	0.866	22	9 24	7.12	0.760	50.0	20	7.83	0.810	55.5	20
1.334	22	21	28	1.664	0.865	22	15 26	7.14	0.754	49.0	20	7.83	0.803	55.0	20
1.334	22	19	26	1.665	0.865	22	39 50	7.19	0.752	48.2	20	7.86	0.801	54.4	20
1.331	22	15	26	1.665	0.865	22	41 32	7.20	0.752	48.0	20	7.80	0.799	54.9	20
1.330	22	23	30	1.667	0.864	22	15 40	7.14	0.751	48.7	20	7.72	0.799	55.7	20
1.326	22	23	14	1.669	0.863	22	23 14	7.19	0.751	48.0	20	7.81	0.798	54.6	20
1.325	22	15	22	1.673	0.861	22	21 16	7.14	0.750	48.5	20	7.83	0.796	54.2	20

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

Figure A.75 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and Axial Distributions at 17,900.0 MWd/MTU

**Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design**

Revision 1

Page A-81

Cycle:	19	Core Average Exposure: MWd/MTU	31800.2
Exposure: MWd/MTU (GWd)	17901.0 (2466.50)		
Delta E: MWd/MTU, (GWd)	1.0 (0.14)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-26.94		
Flow: Mlb/hr	102.50 (100.00 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top	25 0.268 6.938 14 0.374 0.374 35 2
			24 0.704 19.210 16 0.351 0.545 9 12
			23 0.893 24.911 17 0.315 0.360 25 60
			22 1.015 28.593 18 0.367 0.426 29 60
			21 1.103 30.766 19 0.779 1.040 13 14
			20 1.179 32.216 20 1.074 1.135 21 30
			19 1.223 32.978 21 1.045 1.092 21 26
			18 1.265 33.784 22 1.274 1.352 19 30
			17 1.277 34.123 23 1.120 1.270 9 20
			16 1.285 34.754 24 1.079 1.292 9 22
			15 1.290 35.723
			14 1.250 35.690
			13 1.330* 34.254
			12 1.314 35.205
			11 1.275 35.809
			10 1.237 36.562
			9 1.181 37.514
			8 1.097 38.088
			7 0.999 38.499
			6 0.914 39.398*
			5 0.823 39.250
			4 0.739 37.556
			3 0.666 34.249
			2 0.522 26.114
			1 0.152 7.619
		Bottom	
Control Rod Density: %	1.53	% AXIAL TILT	7.735 -7.598
k-effective:	0.99997	AVG BOT 8ft/12ft	0.9749 1.0439
Void Fraction:	0.388		
Core Delta-P: psia	24.070		
Core Plate Delta-P: psia	19.523		
Coolant Temp: Deg-F	547.1		
In Channel Flow: Mlb/hr	90.62	Active Channel Flow: Mlb/hr	87.57
Total Bypass Flow (%):	11.6	(of total core flow)	
Total Water Rod Flow (%):	3.0	(of total core flow)	
Source Convergence	0.00008		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR										
Value	FT	IR	JR	Value	Margin	FT	IR	JR	Value	Margin	Exp.	FT	IR	JR	K	Value	Margin	Exp.	FT	IR	JR	K
1.352	22	19	30	1.630	0.884	22	41	32	7.17	0.765	49.9	20	23	12	15	7.84	0.814	56.0	20	19	12	15
1.347	22	17	28	1.631	0.883	22	17	34	7.15	0.758	49.4	20	11	24	15	7.83	0.812	55.8	20	23	12	15
1.344	22	23	30	1.632	0.882	22	23	32	7.09	0.757	50.0	20	19	12	15	7.78	0.807	55.9	20	11	20	15
1.344	22	21	28	1.636	0.880	22	39	34	7.05	0.752	50.0	20	11	20	15	7.76	0.802	55.5	20	11	24	15
1.338	22	19	26	1.641	0.878	22	19	26	7.15	0.750	48.4	20	25	14	15	7.77	0.797	55.0	20	15	16	15
1.326	22	13	24	1.646	0.875	22	23	14	7.09	0.749	49.0	20	13	26	15	7.82	0.797	54.4	20	31	10	15
1.326	22	11	22	1.647	0.875	22	25	16	7.16	0.749	48.2	20	29	10	15	7.76	0.795	54.9	20	17	18	15
1.325	22	15	26	1.647	0.874	22	21	16	7.17	0.749	48.0	20	17	18	15	8.06	0.795	51.7	21	25	22	19
1.323	22	23	14	1.647	0.874	22	15	26	7.09	0.746	48.7	20	17	14	15	8.15	0.795	50.8	21	33	24	19
1.320	22	21	16	1.648	0.874	22	49	40	7.14	0.745	48.0	20	13	18	15	7.75	0.794	54.9	20	25	14	15

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

**Figure A.76 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and
Axial Distributions at 17,901.0 MWd/MTU**

**Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design**

Revision 1

Page A-82

Cycle:	19	Core Average Exposure: MWd/MTU	31949.2
Exposure: MWd/MTU (GWd)	18050.0 (2487.00)		
Delta E: MWd/MTU, (GWd)	149.0 (20.53)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-25.82		
Flow: Mlb/hr	106.60 (104.00 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top	25 0.272 6.981 14 0.374 0.374 35 2
			24 0.717 19.324 16 0.351 0.545 9 12
			23 0.910 25.054 17 0.315 0.360 25 60
			22 1.034 28.757 18 0.367 0.426 29 60
			21 1.121 30.944 19 0.780 1.043 13 14
			20 1.196 32.406 20 1.072 1.130 21 30
			19 1.238 33.176 21 1.043 1.087 13 22
			18 1.277 33.987 22 1.273 1.346 19 30
			17 1.287 34.328 23 1.125 1.274 9 20
			16 1.293 34.958 24 1.082 1.295 9 22
			15 1.296 35.928
			14 1.254 35.888
			13 1.334* 34.440
			12 1.318 35.390
			11 1.276 35.987
			10 1.235 36.734
			9 1.176 37.679
			8 1.087 38.241
			7 0.983 38.638
			6 0.893 39.525*
			5 0.798 39.364
			4 0.713 37.658
			3 0.641 34.341
			2 0.503 26.186
		Bottom	1 0.146 7.641
Control Rod Density: %	1.53	% AXIAL TILT	8.983 -7.494
k-effective:	0.99999	AVG BOT 8ft/12ft	0.9673 1.0434
Void Fraction:	0.379		
Core Delta-P: psia	25.485		
Core Plate Delta-P: psia	20.938		
Coolant Temp: Deg-F	547.1		
In Channel Flow: Mlb/hr	94.35	Active Channel Flow: Mlb/hr	91.21
Total Bypass Flow (%):	11.5	(of total core flow)	
Total Water Rod Flow (%):	2.9	(of total core flow)	
Source Convergence	0.00009		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	Value	Margin	Exp.	FT
1.346	22	19	30	1.655	0.870	22	17	7.20	0.770	50.2	20	7.89	0.822	56.2	20
1.342	22	17	28	1.656	0.870	22	41	7.13	0.764	50.2	20	7.87	0.819	56.0	20
1.340	22	23	30	1.656	0.869	22	23	7.18	0.763	49.6	20	7.83	0.815	56.2	20
1.339	22	21	28	1.660	0.868	22	49	7.09	0.759	50.2	20	7.80	0.809	55.8	20
1.333	22	19	26	1.660	0.868	22	23	7.19	0.755	48.4	20	7.87	0.804	54.6	20
1.327	22	11	22	1.661	0.867	22	39	7.17	0.754	48.6	20	7.81	0.804	55.2	20
1.325	22	13	24	1.662	0.867	22	39	7.19	0.753	48.3	20	8.11	0.802	52.0	21
1.323	22	23	14	1.663	0.866	22	21	7.11	0.753	49.3	20	7.79	0.801	55.1	20
1.322	22	15	26	1.663	0.866	22	25	7.13	0.752	48.9	20	8.19	0.801	51.0	21
1.319	22	21	16	1.664	0.865	22	19	7.17	0.751	48.2	20	7.78	0.801	55.2	20

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

**Figure A.77 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and
Axial Distributions at 18,050.0 MWd/MTU**

Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design

Revision 1

Page A-83

Cycle:	19	Core Average Exposure: MWd/MTU	31950.2
Exposure: MWd/MTU (GWd)	18051.0 (2487.20)		
Delta E: MWd/MTU, (GWd)	1.0 (0.14)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-26.82		
Flow: Mlb/hr	102.91 (100.40 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top	25 0.269 6.981 14 0.372 0.372 35 2
			24 0.707 19.324 16 0.349 0.541 9 12
			23 0.897 25.055 17 0.313 0.358 25 60
			22 1.021 28.758 18 0.365 0.424 29 60
			21 1.111 30.945 19 0.774 1.035 13 14
			20 1.190 32.408 20 1.076 1.137 21 30
			19 1.239 33.177 21 1.050 1.099 23 28
			18 1.288 33.989 22 1.277 1.353 23 30
			17 1.312 34.329 23 1.115 1.262 9 20
			16 1.320 34.960 24 1.074 1.283 9 22
			15 1.313 35.929
			14 1.262 35.889
			13 1.337* 34.441
			12 1.316 35.391
			11 1.272 35.989
			10 1.229 36.736
			9 1.169 37.680
			8 1.081 38.242
			7 0.979 38.639
			6 0.890 39.525*
			5 0.797 39.364
			4 0.713 37.659
			3 0.642 34.341
			2 0.504 26.186
		Bottom	1 0.146 7.642
Control Rod Density: %	1.35		
k-effective:	0.99996		
Void Fraction:	0.384		
Core Delta-P: psia	24.175	% AXIAL TILT	9.249 -7.494
Core Plate Delta-P: psia	19.628	AVG BOT 8ft/12ft	0.9685 1.0434
Coolant Temp: Deg-F	547.0		
In Channel Flow: Mlb/hr	91.01	Active Channel Flow: Mlb/hr	87.96
Total Bypass Flow (%):	11.6	(of total core flow)	
Total Water Rod Flow (%):	3.0	(of total core flow)	
Source Convergence	0.00006		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	Value	Margin	Exp.	FT
1.353	22	23	30	1.612	0.893	22	23	9.67	0.799	23.6	22	8.78	0.874	52.5	21
1.349	22	19	30	1.620	0.889	22	39	7.74	0.790	45.8	21	8.70	0.871	53.0	21
1.348	22	21	28	1.629	0.884	22	41	9.53	0.789	24.0	22	8.14	0.820	53.4	20
1.340	22	17	28	1.634	0.881	22	17	7.71	0.788	46.0	21	7.88	0.819	56.0	20
1.337	22	19	26	1.635	0.881	22	25	7.56	0.776	46.4	20	8.20	0.819	52.8	20
1.325	22	27	30	1.636	0.880	22	33	7.52	0.775	46.7	20	7.85	0.818	56.2	20
1.320	22	23	14	1.637	0.880	22	19	7.20	0.770	50.2	20	10.62	0.815	27.8	22
1.317	22	21	16	1.642	0.877	22	25	7.24	0.762	48.6	20	7.76	0.808	56.2	20
1.317	22	15	26	1.643	0.876	22	23	7.10	0.760	50.2	20	7.84	0.806	55.2	20
1.316	22	25	28	1.643	0.876	22	31	7.26	0.759	48.0	20	10.47	0.805	28.1	22

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

Figure A.78 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and Axial Distributions at 18,051.0 MWd/MTU

**Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design**

Revision 1

Page A-84

Cycle:	19	Core Average Exposure: MWd/MTU	32099.2
Exposure: MWd/MTU (GWd)	18200.0 (2507.70)		
Delta E: MWd/MTU, (GWd)	149.0 (20.53)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-25.68		
Flow: Mlb/hr	107.11 (104.50 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
2 6 10 14 18 22 26 30 34 38 42 46 50 54 58		Top 25	0.273 7.024 14 0.373 0.373 35 2
59		24	0.720 19.438 16 0.349 0.542 9 12
55		23	0.914 25.199 17 0.313 0.358 25 60
51		22	1.039 28.923 18 0.365 0.424 29 60
47		21	1.129 31.125 19 0.776 1.038 13 14
43		20	1.206 32.599 20 1.074 1.132 21 30
39		19	1.252 33.377 21 1.048 1.094 23 28
35		18	1.299 34.196 22 1.276 1.348 23 30
31		17	1.320 34.540 23 1.120 1.267 9 20
27		16	1.325 35.169 24 1.077 1.286 9 22
23		15	1.317 36.137
19		14	1.265 36.089
15		13	1.340* 34.629
11		12	1.318 35.575
7		11	1.272 36.167
3		10	1.227 36.907
		9	1.163 37.843
		8	1.071 38.393
		7	0.964 38.775
		6	0.871 39.649*
		5	0.775 39.474
		4	0.690 37.757
		3	0.620 34.430
		2	0.487 26.255
		Bottom 1	0.142 7.663
Control Rod Density: %	1.35		
k-effective:	0.99990		
Void Fraction:	0.375		
Core Delta-P: psia	25.633	% AXIAL TILT	10.398 -7.384
Core Plate Delta-P: psia	21.086	AVG BOT 8ft/12ft	0.9614 1.0429
Coolant Temp: Deg-F	547.1		
In Channel Flow: Mlb/hr	94.83	Active Channel Flow: Mlb/hr	91.69
Total Bypass Flow (%):	11.5	(of total core flow)	
Total Water Rod Flow (%):	2.9	(of total core flow)	
Source Convergence	0.00009		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	IR	JR	K	Value
1.348	22	23	30	1.638	0.879	22	23	9.66	0.800	23.9	22	27	22	17	8.75
1.344	22	19	30	1.646	0.875	22	39	9.52	0.790	24.3	22	25	24	17	8.69
1.343	22	21	28	1.653	0.871	22	25	7.71	0.789	46.0	21	27	24	17	7.90
1.336	22	17	28	1.655	0.870	22	41	7.69	0.788	46.3	21	25	22	17	7.91
1.332	22	19	26	1.658	0.869	22	17	7.55	0.777	46.6	20	29	22	17	8.15
1.320	22	23	14	1.658	0.868	22	23	7.52	0.777	47.0	20	27	20	17	8.20
1.319	22	27	30	1.661	0.867	22	21	7.23	0.775	50.4	20	23	12	15	10.62
1.318	22	11	22	1.661	0.867	22	19	7.14	0.766	50.5	20	19	12	15	7.81
1.316	22	21	16	1.661	0.867	22	33	7.26	0.765	48.8	20	25	14	15	7.87
1.315	22	13	24	1.663	0.866	22	23	7.15	0.762	49.8	20	11	24	15	7.90

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

**Figure A.79 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and
Axial Distributions at 18,200.0 MWd/MTU**

**Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design**

Revision 1

Page A-85

Cycle:	19	Core Average Exposure: MWd/MTU	32100.2
Exposure: MWd/MTU (GWd)	18201.0 (2507.80)		
Delta E: MWd/MTU, (GWd)	1.0 (0.14)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-27.08		
Flow: Mlb/hr	101.99 (99.50 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top	25 0.254 7.024 14 0.364 0.364 35 2
			24 0.669 19.439 16 0.342 0.531 9 12
			23 0.848 25.200 17 0.306 0.350 25 60
			22 0.965 28.924 18 0.357 0.415 29 60
			21 1.050 31.126 19 0.760 1.015 13 14
			20 1.125 32.601 20 1.081 1.144 29 26
			19 1.173 33.378 21 1.069 1.122 23 28
			18 1.224 34.197 22 1.288 1.370 23 30
			17 1.254 34.542 23 1.096 1.239 9 20
			16 1.277 35.170 24 1.054 1.258 9 22
			15 1.291 36.138
			14 1.259 36.091
			13 1.346* 34.630
			12 1.332 35.576
			11 1.293 36.168
			10 1.253 36.909
			9 1.197 37.844
			8 1.114 38.394
			7 1.020 38.776
			6 0.942 39.650*
			5 0.861 39.475
			4 0.789 37.758
			3 0.724 34.430
			2 0.573 26.256
		Bottom	1 0.168 7.663
Control Rod Density: %	0.00	% AXIAL TILT	4.743 -7.383
k-effective:	1.00006	AVG BOT 8ft/12ft	0.9964 1.0429
Void Fraction:	0.395		
Core Delta-P: psia	24.010		
Core Plate Delta-P: psia	19.468		
Coolant Temp: Deg-F	547.1		
In Channel Flow: Mlb/hr	90.10	Active Channel Flow: Mlb/hr	87.03
Total Bypass Flow (%):	11.7	(of total core flow)	
Total Water Rod Flow (%):	3.0	(of total core flow)	
Source Convergence	0.00006		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	IR	Value	Margin	Exp.
1.370	22	23	30	1.629	0.884	22	31	7.00	0.751	50.4	20	23	7.65	0.800	56.4
1.369	22	29	28	1.629	0.884	22	23	7.04	0.743	48.8	20	25	7.66	0.799	56.3
1.367	22	29	24	1.634	0.882	22	31	6.92	0.742	50.5	20	19	7.57	0.791	56.4
1.363	22	25	28	1.641	0.877	22	25	7.08	0.741	48.2	20	23	7.66	0.785	54.8
1.361	22	27	30	1.642	0.877	22	33	6.94	0.740	49.8	20	11	7.55	0.785	56.0
1.361	22	27	26	1.643	0.876	22	27	7.10	0.739	47.6	20	25	7.60	0.785	55.4
1.358	22	21	28	1.645	0.875	22	39	6.86	0.736	50.4	20	11	7.58	0.782	55.5
1.353	22	23	26	1.646	0.875	22	23	7.00	0.735	48.5	20	17	7.63	0.782	54.9
1.346	22	29	20	1.647	0.874	22	29	7.03	0.735	48.1	20	27	7.57	0.780	55.4
1.345	22	25	20	1.650	0.873	22	25	6.98	0.735	48.7	20	29	7.85	0.780	52.3

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

**Figure A.80 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and
Axial Distributions at 18,201.0 MWd/MTU**

**Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design**

Revision 1

Page A-86

Cycle:	19	Core Average Exposure: MWd/MTU	32289.4
Exposure: MWd/MTU (GWd)	18390.1 (2533.90)		
Delta E: MWd/MTU, (GWd)	189.1 (26.06)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1050.0		
Inlet Subcooling: Btu/lbm	-25.55		
Flow: Mlb/hr	107.62 (105.00 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top	25 0.260 7.077 14 0.364 0.364 35 2
			24 0.687 19.576 16 0.342 0.531 9 12
			23 0.871 25.374 17 0.306 0.350 25 60
			22 0.990 29.123 18 0.357 0.415 29 60
			21 1.074 31.342 19 0.763 1.020 13 14
			20 1.147 32.832 20 1.079 1.136 29 26
			19 1.192 33.619 21 1.067 1.115 23 28
			18 1.239 34.448 22 1.286 1.362 23 30
			17 1.266 34.798 23 1.102 1.246 9 20
			16 1.284 35.427 24 1.059 1.264 9 22
			15 1.297 36.398
			14 1.262 36.344
			13 1.349* 34.869
			12 1.334 35.813
			11 1.293 36.397
			10 1.250 37.131
			9 1.188 38.056
			8 1.100 38.590
			7 1.001 38.955
			6 0.917 39.815*
			5 0.833 39.626
			4 0.760 37.895
			3 0.695 34.556
			2 0.551 26.356
		Bottom	1 0.161 7.694
Control Rod Density: %	0.00	% AXIAL TILT	6.275 -7.271
k-effective:	0.99994	AVG BOT 8ft/12ft	0.9868 1.0424
Void Fraction:	0.384		
Core Delta-P: psia	25.972		
Core Plate Delta-P: psia	21.430		
Coolant Temp: Deg-F	547.2		
In Channel Flow: Mlb/hr	95.22	Active Channel Flow: Mlb/hr	92.03
Total Bypass Flow (%):	11.5	(of total core flow)	
Total Water Rod Flow (%):	3.0	(of total core flow)	
Source Convergence	0.00006		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	IR	Value	Margin	Exp.
1.362	22	23	30	1.668	0.863	22	23	7.04	0.757	50.7	20	23	7.71	0.809	56.8
1.360	22	29	28	1.672	0.861	22	31	6.97	0.750	50.7	20	19	7.71	0.807	56.6
1.358	22	29	24	1.677	0.859	22	31	7.06	0.746	49.1	20	25	7.64	0.801	56.7
1.354	22	25	28	1.685	0.855	22	25	6.98	0.746	50.1	20	11	7.59	0.793	56.3
1.353	22	27	30	1.685	0.854	22	39	7.09	0.744	48.5	20	23	7.69	0.791	55.2
1.352	22	27	26	1.686	0.854	22	29	6.91	0.744	50.7	20	11	7.64	0.791	55.7
1.351	22	21	28	1.686	0.854	22	33	7.02	0.741	48.9	20	29	7.63	0.790	55.8
1.345	22	23	26	1.687	0.854	22	23	7.09	0.740	47.9	20	25	7.68	0.790	55.1
1.338	22	29	20	1.687	0.854	22	27	7.02	0.739	48.8	20	17	7.60	0.787	55.7
1.338	22	25	20	1.687	0.854	22	25	6.95	0.738	49.4	20	17	7.62	0.786	55.4

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

**Figure A.81 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and
Axial Distributions at 18,390.1 MWd/MTU**

**Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design**

Revision 1

Page A-87

Cycle:	19	Core Average Exposure: MWd/MTU	32297.3
Exposure: MWd/MTU (GWd)	18398.1 (2535.00)		
Delta E: MWd/MTU, (GWd)	8.0 (1.10)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1048.0		
Inlet Subcooling: Btu/lbm	-29.54		
Flow: Mlb/hr	102.24 (99.75 %)		
		Axial Profile	Edit Radial Power
		N (PRA) Power Exposure	Zone Avg. Max. IR JR
		Top 25 0.256 7.079	14 0.366 0.366 35 2
		24 0.673 19.581	16 0.344 0.535 9 12
		23 0.854 25.381	17 0.308 0.351 25 60
		22 0.971 29.131	18 0.359 0.417 29 60
		21 1.054 31.351	19 0.767 1.021 13 14
		20 1.127 32.841	20 1.078 1.133 29 26
		19 1.172 33.629	21 1.065 1.112 23 28
		18 1.220 34.458	22 1.283 1.358 23 30
		17 1.248 34.809	23 1.104 1.245 9 20
		16 1.269 35.438	24 1.061 1.262 9 22
		15 1.284 36.409	
		14 1.253 36.354	
		13 1.344* 34.879	
		12 1.333 35.823	
		11 1.297 36.407	
		10 1.260 37.140	
		9 1.204 38.065	
		8 1.121 38.599	
		7 1.024 38.963	
		6 0.942 39.822*	
		5 0.858 39.632	
		4 0.783 37.901	
		3 0.718 34.562	
		2 0.569 26.360	
		Bottom 1 0.166 7.695	
		% AXIAL TILT	4.668 -7.266
		AVG BOT 8ft/12ft	0.9957 1.0424
Control Rod Density: %	0.00		
k-effective:	0.99980		
Void Fraction:	0.384		
Core Delta-P: psia	23.895		
Core Plate Delta-P: psia	19.342		
Coolant Temp: Deg-F	546.3		
In Channel Flow: Mlb/hr	90.41	Active Channel Flow: Mlb/hr	87.38
Total Bypass Flow (%):	11.6	(of total core flow)	
Total Water Rod Flow (%):	3.0	(of total core flow)	
Source Convergence	0.00005		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	Value	Margin	Exp.	FT
1.358	22	23	30	1.660	0.868	22	23	6.96	0.749	50.7	20	7.63	0.801	56.8	20
1.355	22	29	28	1.662	0.866	22	31	6.89	0.742	50.7	20	7.62	0.798	56.6	20
1.353	22	29	24	1.666	0.864	22	31	6.90	0.738	50.1	20	7.55	0.792	56.7	20
1.350	22	25	28	1.674	0.860	22	25	6.97	0.738	49.1	20	7.51	0.784	56.3	20
1.348	22	27	30	1.675	0.860	22	39	6.83	0.736	50.7	20	7.60	0.782	55.2	20
1.348	22	27	26	1.676	0.859	22	33	7.00	0.735	48.5	20	7.55	0.782	55.8	20
1.347	22	21	28	1.677	0.859	22	27	6.94	0.733	49.0	20	7.54	0.781	55.7	20
1.341	22	23	26	1.677	0.859	22	23	6.94	0.731	48.8	20	7.59	0.780	55.1	20
1.334	22	25	20	1.677	0.859	22	29	7.00	0.730	47.9	20	7.52	0.778	55.7	20
1.334	22	29	20	1.679	0.858	22	25	6.88	0.730	49.5	20	7.54	0.777	55.4	20

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

**Figure A.82 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and
Axial Distributions at 18,398.1 MWd/MTU**

Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design

Revision 1

Page A-88

Cycle:	19	Core Average Exposure: MWd/MTU	32442.5
Exposure: MWd/MTU (GWd)	18543.2 (2555.00)		
Delta E: MWd/MTU, (GWd)	145.2 (20.00)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1048.0		
Inlet Subcooling: Btu/lbm	-28.10		
Flow: Mlb/hr	107.11 (104.50 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top 25	0.261 7.119 14 0.366 0.366 35 2
		24	0.689 19.687 16 0.344 0.535 9 12
		23	0.874 25.515 17 0.307 0.351 25 60
		22	0.992 29.284 18 0.359 0.417 29 60
		21	1.075 31.517 19 0.768 1.024 13 14
		20	1.146 33.019 20 1.076 1.128 29 26
		19	1.189 33.813 21 1.063 1.108 23 28
		18	1.234 34.650 22 1.282 1.353 23 30
		17	1.260 35.005 23 1.109 1.250 9 20
		16	1.278 35.634 24 1.064 1.266 9 22
		15	1.291 36.607
		14	1.258 36.548
		13	1.349* 35.062
		12	1.337 36.005
		11	1.299 36.584
		10	1.258 37.312
		9	1.199 38.229
		8	1.110 38.751
		7	1.007 39.101
		6	0.919 39.949*
		5	0.830 39.747
		4	0.753 38.006
		3	0.688 34.658
		2	0.545 26.436
		Bottom 1	0.160 7.719
Control Rod Density: %	0.00		
k-effective:	0.99990		
Void Fraction:	0.374		
Core Delta-P: psia	25.574	% AXIAL TILT	6.099 -7.181
Core Plate Delta-P: psia	21.021	AVG BOT 8ft/12ft	0.9870 1.0420
Coolant Temp: Deg-F	546.4		
In Channel Flow: Mlb/hr	94.84	Active Channel Flow: Mlb/hr	91.70
Total Bypass Flow (%):	11.5	(of total core flow)	
Total Water Rod Flow (%):	2.9	(of total core flow)	
Source Convergence	0.00006		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	Value	Margin	Exp.	FT
1.353	22	23	30	1.690	0.852	22	23	7.00	0.755	50.9	20	7.69	0.810	57.0	20
1.350	22	29	28	1.694	0.850	22	31	6.94	0.749	51.0	20	7.67	0.806	56.8	20
1.347	22	29	24	1.698	0.848	22	31	6.94	0.744	50.3	20	7.62	0.801	57.0	20
1.345	22	25	28	1.703	0.845	22	25	6.88	0.743	50.9	20	7.56	0.791	56.6	20
1.343	22	27	30	1.706	0.844	22	29	7.00	0.743	49.4	20	7.66	0.791	55.4	20
1.342	22	21	28	1.706	0.844	22	39	7.02	0.740	48.7	20	7.60	0.790	56.0	20
1.342	22	27	26	1.706	0.844	22	25	6.99	0.739	49.2	20	7.59	0.788	56.0	20
1.335	22	23	26	1.707	0.844	22	25	6.92	0.736	49.7	20	7.60	0.786	55.6	20
1.330	22	25	20	1.707	0.843	22	33	6.97	0.736	49.0	20	7.56	0.786	56.0	21
1.329	22	29	20	1.708	0.843	22	33	7.02	0.734	48.1	20	7.63	0.786	55.3	20

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

Figure A.83 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and Axial Distributions at 18,543.2 MWd/MTU

**Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design**

Revision 1

Page A-89

Cycle:	19	Core Average Exposure: MWd/MTU	32449.6
Exposure: MWd/MTU (GWd)	18550.5 (2556.00)		
Delta E: MWd/MTU, (GWd)	7.3 (1.00)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1046.0		
Inlet Subcooling: Btu/lbm	-31.84		
Flow: Mlb/hr	102.50 (100.00 %)		
		Axial Profile	Edit Radial Power
		N (PRA) Power Exposure	Zone Avg. Max. IR JR
2 6 10 14 18 22 26 30 34 38 42 46 50 54 58		Top 25 0.256 7.121	14 0.367 0.367 35 2
59		24 0.677 19.692	16 0.346 0.539 9 12
55		23 0.859 25.522	17 0.308 0.352 25 60
51		22 0.976 29.292	18 0.360 0.418 29 60
47		21 1.058 31.525	19 0.772 1.025 13 14
43		20 1.128 33.028	20 1.075 1.126 29 26
39		19 1.172 33.822	21 1.062 1.106 23 28
35		18 1.218 34.660	22 1.280 1.349 23 30
31		17 1.244 35.014	23 1.111 1.249 9 20
27		16 1.264 35.644	24 1.066 1.265 9 22
23		15 1.280 36.617	
19		14 1.250 36.557	
15		13 1.345* 35.072	
11		12 1.338 36.014	
7		11 1.304 36.593	
3		10 1.269 37.321	
		9 1.214 38.237	
		8 1.129 38.758	
		7 1.027 39.108	
		6 0.940 39.955*	
		5 0.850 39.753	
		4 0.772 38.011	
		3 0.706 34.662	
		2 0.560 26.440	
		Bottom 1 0.163 7.720	
Control Rod Density: %	0.00	% AXIAL TILT	4.685 -7.177
k-effective:	0.99990	AVG BOT 8ft/12ft	0.9950 1.0420
Void Fraction:	0.374		
Core Delta-P: psia	23.792		
Core Plate Delta-P: psia	19.228		
Coolant Temp: Deg-F	545.5		
In Channel Flow: Mlb/hr	90.73	Active Channel Flow: Mlb/hr	87.71
Total Bypass Flow (%):	11.5	(of total core flow)	
Total Water Rod Flow (%):	2.9	(of total core flow)	
Source Convergence	0.00010		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	Value	Margin	Exp.	FT
1.349	22	23	30	1.684	0.855	22	23	6.93	0.748	50.9	20	7.62	0.803	57.0	20
1.346	22	29	28	1.687	0.854	22	31	6.88	0.743	51.0	20	7.60	0.798	56.8	20
1.343	22	29	24	1.691	0.852	22	31	6.87	0.737	50.4	20	7.54	0.794	57.0	20
1.341	22	25	28	1.699	0.848	22	39	6.82	0.736	51.0	20	7.59	0.784	55.4	20
1.339	22	21	28	1.699	0.848	22	25	6.93	0.735	49.4	20	7.48	0.784	56.6	20
1.339	22	27	30	1.700	0.847	22	25	6.92	0.733	49.2	20	7.53	0.783	56.0	20
1.338	22	27	26	1.700	0.847	22	29	6.95	0.732	48.7	20	7.51	0.781	56.0	20
1.332	22	23	26	1.701	0.847	22	33	6.86	0.730	49.7	20	7.53	0.779	55.6	20
1.326	22	25	20	1.701	0.847	22	25	6.90	0.729	49.0	20	7.49	0.779	56.0	21
1.326	22	29	20	1.702	0.846	22	23	6.89	0.727	48.9	20	7.49	0.778	55.9	20

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

**Figure A.84 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and
Axial Distributions at 18,550.5 MWd/MTU**

**Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design**

Revision 1

Page A-90

Cycle:	19	Core Average Exposure: MWd/MTU	32543.9
Exposure: MWd/MTU (GWd)	18644.8 (2569.00)		
Delta E: MWd/MTU, (GWd)	94.3 (13.00)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1046.0		
Inlet Subcooling: Btu/lbm	-30.53		
Flow: Mlb/hr	106.60 (104.00 %)		
		Axial Profile	Edit Radial Power
		N (PRA) Power Exposure	Zone Avg. Max. IR JR
		Top 25 0.260 7.147	14 0.366 0.366 35 2
		24 0.688 19.761	16 0.345 0.538 9 12
		23 0.873 25.609	17 0.308 0.351 25 60
		22 0.991 29.392	18 0.359 0.418 29 60
		21 1.073 31.633	19 0.772 1.027 13 14
		20 1.143 33.143	20 1.074 1.123 29 26
		19 1.184 33.942	21 1.061 1.103 23 28
		18 1.229 34.784	22 1.279 1.346 23 30
		17 1.254 35.141	23 1.114 1.253 9 20
		16 1.272 35.771	24 1.068 1.268 9 22
		15 1.286 36.746	
		14 1.255 36.683	
		13 1.350* 35.191	
		12 1.343 36.133	
		11 1.307 36.708	
		10 1.270 37.433	
		9 1.211 38.345	
		8 1.121 38.858	
		7 1.014 39.199	
		6 0.921 40.037*	
		5 0.827 39.827	
		4 0.747 38.078	
		3 0.681 34.724	
		2 0.540 26.488	
		Bottom 1 0.158 7.735	
		% AXIAL TILT	5.791 -7.122
		AVG BOT 8ft/12ft	0.9885 1.0417
Control Rod Density: %	0.00		
k-effective:	1.00018		
Void Fraction:	0.366		
Core Delta-P: psia	25.200		
Core Plate Delta-P: psia	20.636		
Coolant Temp: Deg-F	545.6		
In Channel Flow: Mlb/hr	94.45	Active Channel Flow: Mlb/hr	91.35
Total Bypass Flow (%):	11.4	(of total core flow)	
Total Water Rod Flow (%):	2.9	(of total core flow)	
Source Convergence	0.00007		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	Value	Margin	Exp.	FT
1.346	22	23	30	1.708	0.843	22	23	6.97	0.753	51.1	20	7.68	0.810	57.2	20
1.343	22	29	28	1.713	0.841	22	31	6.92	0.749	51.1	20	7.65	0.805	57.0	20
1.340	22	29	24	1.717	0.839	22	31	6.91	0.742	50.5	20	7.60	0.801	57.1	20
1.337	22	25	28	1.718	0.838	22	25	6.86	0.742	51.1	20	7.65	0.791	55.6	20
1.336	22	21	28	1.719	0.838	22	21	6.96	0.739	49.5	20	7.53	0.790	56.7	20
1.336	22	27	30	1.721	0.837	22	23	6.96	0.738	49.3	20	7.58	0.790	56.2	20
1.334	22	27	26	1.723	0.836	22	29	6.98	0.736	48.9	20	7.59	0.787	55.8	20
1.328	22	23	26	1.724	0.835	22	25	6.90	0.735	49.8	20	7.55	0.787	56.2	21
1.324	22	25	20	1.724	0.835	22	33	6.93	0.733	49.1	20	7.56	0.786	56.1	20
1.323	22	29	20	1.724	0.835	22	11	6.93	0.733	49.1	20	7.53	0.783	56.1	20

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

**Figure A.85 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and
Axial Distributions at 18,644.8 MWd/MTU**

**Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design**

Revision 1

Page A-91

Cycle:	19	Core Average Exposure: MWd/MTU	32551.2
Exposure: MWd/MTU (GWd)	18652.1 (2570.00)		
Delta E: MWd/MTU, (GWd)	7.3 (1.00)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1044.6		
Inlet Subcooling: Btu/lbm	-33.54		
Flow: Mlb/hr	102.50 (100.00 %)		
		Axial Profile	Edit Radial Power
		N (PRA) Power Exposure	Zone Avg. Max. IR JR
2 6 10 14 18 22 26 30 34 38 42 46 50 54 58		Top 25 0.256 7.149	14 0.367 0.367 35 2
59		24 0.678 19.766	16 0.347 0.541 9 12
55		23 0.861 25.616	17 0.309 0.353 25 60
51		22 0.978 29.399	18 0.361 0.419 29 60
47		21 1.059 31.641	19 0.775 1.027 13 14
43		20 1.129 33.152	20 1.074 1.121 21 30
39		19 1.170 33.951	21 1.061 1.102 23 28
35		18 1.215 34.793	22 1.278 1.343 23 30
31		17 1.241 35.151	23 1.115 1.252 9 20
27		16 1.261 35.781	24 1.070 1.266 9 22
23		15 1.277 36.755	
19		14 1.249 36.692	
15		13 1.346* 35.200	
11		12 1.342 36.142	
7		11 1.310 36.717	
3		10 1.277 37.442	
		9 1.222 38.353	
		8 1.135 38.866	
		7 1.030 39.206	
		6 0.939 40.044*	
		5 0.845 39.833	
		4 0.765 38.083	
		3 0.699 34.728	
		2 0.554 26.492	
		Bottom 1 0.162 7.736	
Control Rod Density: %	0.00		
k-effective:	0.99997		
Void Fraction:	0.367		
Core Delta-P: psia	23.659	% AXIAL TILT	4.628 -7.118
Core Plate Delta-P: psia	19.087	AVG BOT 8ft/12ft	0.9950 1.0417
Coolant Temp: Deg-F	544.9		
In Channel Flow: Mlb/hr	90.78	Active Channel Flow: Mlb/hr	87.79
Total Bypass Flow (%):	11.4	(of total core flow)	
Total Water Rod Flow (%):	2.9	(of total core flow)	
Source Convergence	0.00009		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	IR	Value	Margin	Exp.
1.343	22	23	30	1.701	0.847	22	23	6.91	0.747	51.1	20	23	7.62	0.804	57.2
1.340	22	29	28	1.703	0.845	22	31	6.87	0.743	51.1	20	19	7.59	0.798	57.0
1.337	22	29	24	1.707	0.844	22	31	6.81	0.736	51.1	20	11	7.54	0.795	57.1
1.334	22	25	28	1.712	0.841	22	25	6.85	0.736	50.5	20	11	7.59	0.785	55.6
1.334	22	21	28	1.715	0.840	22	39	6.90	0.733	49.5	20	25	7.52	0.784	56.2
1.333	22	27	30	1.715	0.840	22	21	6.91	0.732	49.3	20	29	7.47	0.783	56.8
1.331	22	27	26	1.715	0.839	22	29	6.85	0.730	49.8	20	17	7.53	0.781	55.8
1.326	22	23	26	1.716	0.839	22	25	6.91	0.729	48.9	20	23	7.49	0.780	56.2
1.321	22	25	20	1.716	0.839	22	25	6.87	0.727	49.2	20	17	7.49	0.780	56.1
1.320	22	27	18	1.716	0.839	22	33	6.88	0.727	49.1	20	13	7.47	0.777	56.1

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

**Figure A.86 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and
Axial Distributions at 18,652.1 MWd/MTU**

**Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design**

Revision 1

Page A-92

Cycle:	19	Core Average Exposure: MWd/MTU	32725.4
Exposure: MWd/MTU (GWd)	18826.3 (2594.00)		
Delta E: MWd/MTU, (GWd)	174.2 (24.00)		
Power: MWt	3952.0 (100.00 %)		
Core Pressure: psia	1044.6		
Inlet Subcooling: Btu/lbm	-31.83		
Flow: Mlb/hr	107.62 (105.00 %)		
		Axial Profile	Edit Radial Power
		N (PRA) Power Exposure	Zone Avg. Max. IR JR
		Top 25 0.263 7.197	14 0.367 0.367 35 2
		24 0.697 19.894	16 0.347 0.540 9 12
		23 0.884 25.778	17 0.308 0.352 25 60
		22 1.003 29.585	18 0.360 0.419 29 60
		21 1.084 31.842	19 0.776 1.030 13 14
		20 1.152 33.365	20 1.072 1.117 21 30
		19 1.190 34.172	21 1.059 1.098 23 28
		18 1.232 35.022	22 1.276 1.339 23 30
		17 1.254 35.385	23 1.119 1.257 9 20
		16 1.271 36.015	24 1.073 1.270 9 22
		15 1.285 36.992	
		14 1.254 36.924	
		13 1.352* 35.421	
		12 1.346 36.362	
		11 1.312 36.932	
		10 1.274 37.651	
		9 1.214 38.552	
		8 1.120 39.050	
		7 1.008 39.372	
		6 0.910 40.195*	
		5 0.813 39.968	
		4 0.732 38.206	
		3 0.667 34.840	
		2 0.529 26.581	
		Bottom 1 0.155 7.763	
		% AXIAL TILT	6.289 -7.018
		AVG BOT 8ft/12ft	0.9849 1.0412
Control Rod Density: %	0.00		
k-effective:	0.99988		
Void Fraction:	0.356		
Core Delta-P: psia	25.409		
Core Plate Delta-P: psia	20.837		
Coolant Temp: Deg-F	545.0		
In Channel Flow: Mlb/hr	95.44	Active Channel Flow: Mlb/hr	92.35
Total Bypass Flow (%):	11.3	(of total core flow)	
Total Water Rod Flow (%):	2.9	(of total core flow)	
Source Convergence	0.00009		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	IR	JR	K	Value
1.339	22	23	30	1.723	0.836	22	23	6.96	0.754	51.3	20	23	12	15	7.69
1.336	22	29	28	1.724	0.835	22	21	6.92	0.751	51.4	20	19	12	15	7.63
1.332	22	29	24	1.731	0.832	22	11	6.86	0.744	51.4	20	11	20	15	7.61
1.330	22	25	28	1.731	0.832	22	23	6.90	0.743	50.8	20	11	24	15	7.65
1.329	22	21	28	1.732	0.831	22	9	6.95	0.739	49.6	20	29	10	15	7.58
1.328	22	27	30	1.733	0.831	22	25	6.93	0.739	49.8	20	25	14	15	7.52
1.326	22	27	26	1.734	0.830	22	31	6.89	0.737	50.1	20	17	14	15	7.60
1.321	22	23	26	1.738	0.828	22	31	6.94	0.735	49.1	20	23	16	15	7.56
1.317	22	25	20	1.739	0.828	22	23	6.93	0.734	49.3	20	13	18	15	7.54
1.317	22	27	18	1.743	0.826	22	21	6.88	0.733	49.9	20	15	16	15	7.59

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

**Figure A.87 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and
Axial Distributions at 18,826.3 MWd/MTU**

Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design

Revision 1

Page A-93

Cycle:	19	Core Average Exposure: MWd/MTU	32805.3
Exposure: MWd/MTU (GWd)	18906.1 (2605.00)		
Delta E: MWd/MTU, (GWd)	79.8 (11.00)		
Power: MWt	3888.8 (98.40 %)		
Core Pressure: psia	1043.4		
Inlet Subcooling: Btu/lbm	-31.26		
Flow: Mlb/hr	107.62 (105.00 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top 25	0.265 7.220 14 0.367 0.367 35 2
		24	0.705 19.954 16 0.347 0.540 9 12
		23	0.894 25.854 17 0.309 0.352 25 60
		22	1.014 29.671 18 0.360 0.419 29 60
		21	1.095 31.935 19 0.777 1.032 13 14
		20	1.162 33.465 20 1.071 1.115 21 30
		19	1.199 34.275 21 1.058 1.096 23 28
		18	1.239 35.129 22 1.276 1.337 23 30
		17	1.260 35.493 23 1.122 1.259 9 20
		16	1.275 36.122 24 1.074 1.272 9 22
		15	1.288 37.101
		14	1.256 37.030
		13	1.354* 35.522
		12	1.348 36.463
		11	1.312 37.030
		10	1.273 37.746
		9	1.210 38.643
		8	1.113 39.134
		7	0.998 39.448
		6	0.898 40.263*
		5	0.799 40.029
		4	0.718 38.260
		3	0.654 34.890
		2	0.519 26.620
		Bottom 1	0.152 7.775
			% AXIAL TILT 7.027 -6.969
			AVG BOT 8ft/12ft 0.9804 1.0410
Control Rod Density: %	0.00		
k-effective:	0.99999		
Void Fraction:	0.352		
Core Delta-P: psia	25.315		
Core Plate Delta-P: psia	20.745		
Coolant Temp: Deg-F	544.9		
In Channel Flow: Mlb/hr	95.50	Active Channel Flow: Mlb/hr	92.42
Total Bypass Flow (%):	11.3	(of total core flow)	
Total Water Rod Flow (%):	2.9	(of total core flow)	
Source Convergence	0.00010		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	Value	Margin	Exp.	FT
1.337	22	23	30	1.744	0.826	22	23	6.86	0.745	51.5	20	7.59	0.805	57.6	20
1.334	22	29	28	1.745	0.825	22	21	6.83	0.742	51.5	20	7.53	0.798	57.5	20
1.331	22	29	24	1.753	0.822	22	11	6.77	0.735	51.5	20	7.51	0.796	57.5	20
1.328	22	25	28	1.754	0.821	22	9	6.80	0.733	50.9	20	7.55	0.785	56.0	20
1.327	22	21	28	1.759	0.819	22	25	6.86	0.730	49.7	20	7.48	0.783	56.6	20
1.326	22	27	30	1.761	0.818	22	23	6.84	0.729	49.9	20	7.42	0.783	57.2	20
1.324	22	27	26	1.762	0.817	22	31	6.80	0.728	50.2	20	7.50	0.782	56.2	20
1.319	22	23	26	1.763	0.817	22	23	6.83	0.725	49.5	20	7.47	0.782	56.6	21
1.315	22	25	20	1.766	0.815	22	31	6.85	0.725	49.3	20	7.44	0.778	56.5	20
1.315	22	27	18	1.768	0.815	22	21	6.78	0.724	50.0	20	7.50	0.777	55.8	20

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

Figure A.88 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and Axial Distributions at 18,906.1 MWd/MTU

Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design

Revision 1

Page A-94

Cycle:	19	Core Average Exposure: MWd/MTU	32932.9
Exposure: MWd/MTU (GWd)	19033.7 (2622.60)		
Delta E: MWd/MTU, (GWd)	127.6 (17.58)		
Power: MWt	3782.1 (95.70 %)		
Core Pressure: psia	1041.4		
Inlet Subcooling: Btu/lbm	-30.29		
Flow: Mlb/hr	107.62 (105.00 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top	25 0.270 7.256 14 0.368 0.368 35 2
			24 0.719 20.051 16 0.347 0.540 9 12
			23 0.912 25.977 17 0.309 0.352 25 60
			22 1.034 29.812 18 0.361 0.420 29 60
			21 1.114 32.087 19 0.778 1.034 13 14
			20 1.179 33.625 20 1.070 1.112 21 30
			19 1.213 34.440 21 1.056 1.093 23 28
			18 1.251 35.299 22 1.275 1.334 23 30
			17 1.269 35.666 23 1.125 1.262 9 20
			16 1.282 36.296 24 1.077 1.275 9 22
			15 1.293 37.276
			14 1.259 37.200
			13 1.356* 35.685
			12 1.349 36.624
			11 1.311 37.187
			10 1.268 37.898
			9 1.202 38.788
			8 1.100 39.266
			7 0.981 39.566
			6 0.878 40.369*
			5 0.778 40.123
			4 0.697 38.345
			3 0.634 34.967
			2 0.504 26.681
		Bottom	1 0.147 7.794
Control Rod Density: %	0.00	% AXIAL TILT	8.241 -6.888
k-effective:	1.00012	AVG BOT 8ft/12ft	0.9727 1.0406
Void Fraction:	0.345		
Core Delta-P: psia	25.158		
Core Plate Delta-P: psia	20.590		
Coolant Temp: Deg-F	544.8		
In Channel Flow: Mlb/hr	95.58	Active Channel Flow: Mlb/hr	92.54
Total Bypass Flow (%):	11.2	(of total core flow)	
Total Water Rod Flow (%):	2.8	(of total core flow)	
Source Convergence	0.00009		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	IR	JR	K	Value
1.334	22	23	30	1.781	0.809	22	23	6.70	0.729	51.7	20	23	12	15	7.42
1.331	22	29	28	1.783	0.808	22	21	6.68	0.727	51.7	20	19	12	15	7.35
1.327	22	29	24	1.792	0.804	22	9	6.62	0.720	51.7	20	11	20	15	7.34
1.324	22	25	28	1.792	0.803	22	11	6.64	0.717	51.1	20	11	24	15	7.38
1.324	22	21	28	1.805	0.798	22	25	6.70	0.714	49.9	20	29	10	15	7.31
1.323	22	27	30	1.807	0.797	22	23	6.66	0.712	50.1	20	25	14	15	7.34
1.321	22	27	26	1.809	0.796	22	33	6.64	0.712	50.4	20	17	14	15	7.30
1.316	22	23	26	1.810	0.795	22	23	6.67	0.710	49.6	20	13	18	15	7.25
1.312	22	27	18	1.812	0.795	22	31	6.62	0.709	50.2	20	15	16	15	7.33
1.312	22	25	20	1.813	0.794	22	21	6.67	0.708	49.5	20	23	16	15	7.26

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

Figure A.89 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and Axial Distributions at 19,033.7 MWd/MTU

Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design

Revision 1

Page A-95

Cycle:	19	Core Average Exposure: MWd/MTU	33400.4
Exposure: MWd/MTU (GWd)	19501.2 (2687.00)		
Delta E: MWd/MTU, (GWd)	467.5 (64.42)		
Power: MWt	3414.5 (86.40 %)		
Core Pressure: psia	1034.2		
Inlet Subcooling: Btu/lbm	-26.98		
Flow: Mlb/hr	107.62 (105.00 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
2 6 10 14 18 22 26 30 34 38 42 46 50 54 58		Top 25	0.289 7.396 14 0.368 0.368 35 2
59		24	0.775 20.424 16 0.347 0.541 9 12
55		23	0.982 26.450 17 0.309 0.353 25 60
51		22	1.108 30.350 18 0.361 0.421 29 60
47		21	1.184 32.664 19 0.783 1.042 13 14
43		20	1.243 34.234 20 1.065 1.100 29 26
39		19	1.265 35.063 21 1.051 1.081 23 28
35		18	1.293 35.939 22 1.271 1.322 23 30
31		17	1.300 36.312 23 1.138 1.275 9 20
27		16	1.301 36.936 24 1.086 1.284 9 22
23		15	1.305 37.920
19		14	1.264 37.826
15		13	1.360* 36.281
11		12	1.348 37.216
7		11	1.301 37.760
3		10	1.246 38.450
		9	1.165 39.308
		8	1.049 39.738
		7	0.918 39.983
		6	0.808 40.739*
		5	0.707 40.449
		4	0.629 38.636
		3	0.572 35.231
		2	0.456 26.892
		Bottom 1	0.134 7.859
Control Rod Density: %	0.00	% AXIAL TILT	12.589 -6.557
k-effective:	0.99996	AVG BOT 8ft/12ft	0.9446 1.0390
Void Fraction:	0.321		
Core Delta-P: psia	24.627		
Core Plate Delta-P: psia	20.068		
Coolant Temp: Deg-F	544.2		
In Channel Flow: Mlb/hr	95.89	Active Channel Flow: Mlb/hr	92.95
Total Bypass Flow (%):	10.9	(of total core flow)	
Total Water Rod Flow (%):	2.7	(of total core flow)	
Source Convergence	0.00010		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	Value	Margin	Exp.	FT
1.322	22	23	30	1.927	0.747	22	23	6.28	0.670	50.0	20	6.81	0.731	58.6	20
1.319	22	29	28	1.935	0.744	22	21	6.11	0.669	52.4	20	6.74	0.723	58.5	20
1.315	22	29	24	1.944	0.741	22	9	6.05	0.664	52.4	20	6.72	0.721	58.5	20
1.311	22	21	28	1.948	0.739	22	11	6.31	0.659	48.0	20	6.76	0.711	57.0	20
1.311	22	25	28	1.967	0.732	22	33	6.05	0.659	51.8	20	6.70	0.710	57.6	21
1.310	22	27	30	1.978	0.728	22	25	6.20	0.657	49.3	20	6.73	0.710	57.2	20
1.308	22	27	26	1.980	0.727	22	29	6.21	0.653	48.7	20	6.68	0.708	57.5	20
1.302	22	23	26	1.981	0.727	23	41	6.05	0.652	50.8	20	6.84	0.708	55.6	20
1.302	22	27	18	1.981	0.727	22	23	6.15	0.652	49.4	20	6.62	0.707	58.1	20
1.301	22	11	22	1.987	0.725	22	25	6.05	0.647	50.2	20	6.73	0.706	56.7	20

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

Figure A.90 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and Axial Distributions at 19,501.2 MWd/MTU

Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design

Revision 1

Page A-96

Cycle:	19	Core Average Exposure: MWd/MTU	33535.2
Exposure: MWd/MTU (GWd)	19636.0 (2705.60)		
Delta E: MWd/MTU, (GWd)	134.8 (18.57)		
Power: MWt	3351.3 (84.80 %)		
Core Pressure: psia	1033.0		
Inlet Subcooling: Btu/lbm	-26.42		
Flow: Mlb/hr	107.62 (105.00 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top 25	0.293 7.438 14 0.369 0.369 35 2
		24	0.785 20.537 16 0.348 0.541 9 12
		23	0.995 26.593 17 0.310 0.353 25 60
		22	1.123 30.511 18 0.362 0.421 29 60
		21	1.198 32.836 19 0.784 1.044 13 14
		20	1.254 34.415 20 1.064 1.098 29 26
		19	1.274 35.247 21 1.049 1.078 23 28
		18	1.299 36.127 22 1.270 1.319 23 30
		17	1.303 36.501 23 1.141 1.278 19 10
		16	1.302 37.122 24 1.088 1.286 9 22
		15	1.304 38.107
		14	1.262 38.007
		13	1.358* 36.453
		12	1.345 37.387
		11	1.296 37.925
		10	1.240 38.608
		9	1.157 39.455
		8	1.039 39.870
		7	0.908 40.099
		6	0.798 40.841*
		5	0.698 40.538
		4	0.620 38.715
		3	0.564 35.303
		2	0.451 26.949
		Bottom 1	0.132 7.877
Control Rod Density: %	0.00		
k-effective:	1.00014		
Void Fraction:	0.317		
Core Delta-P: psia	24.539	% AXIAL TILT	13.296 -6.453
Core Plate Delta-P: psia	19.981	AVG BOT 8ft/12ft	0.9396 1.0385
Coolant Temp: Deg-F	544.2		
In Channel Flow: Mlb/hr	95.94	Active Channel Flow: Mlb/hr	93.02
Total Bypass Flow (%):	10.9	(of total core flow)	
Total Water Rod Flow (%):	2.7	(of total core flow)	
Source Convergence	0.00008		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	IR	JR	K	Value
1.319	22	23	30	1.954	0.737	22	23	6.19	0.662	50.2	20	19	12	17	6.68
1.317	22	29	28	1.964	0.733	22	21	6.17	0.660	50.1	20	23	12	17	6.61
1.312	22	29	24	1.973	0.730	22	9	5.94	0.653	52.6	20	11	20	15	6.59
1.309	22	21	28	1.978	0.728	22	11	6.21	0.650	48.3	20	29	10	17	6.88
1.308	22	25	28	1.998	0.721	22	33	6.16	0.648	48.7	20	17	14	18	6.80
1.308	22	27	30	2.007	0.717	23	41	5.94	0.648	52.0	20	11	24	15	6.60
1.305	22	27	26	2.009	0.717	22	25	6.11	0.644	48.9	20	13	18	17	6.73
1.301	22	11	22	2.013	0.715	22	29	6.10	0.643	48.8	20	15	16	18	6.55
1.300	22	21	12	2.015	0.715	22	23	5.93	0.640	51.0	20	25	14	15	6.48
1.300	22	23	10	2.016	0.714	22	17	5.93	0.636	50.4	20	23	16	15	6.60

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

Figure A.91 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and Axial Distributions at 19,636.0 MWd/MTU

**Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference
Fuel Cycle Design**

Revision 1

Page A-97

Cycle:	19	Core Average Exposure: MWd/MTU	34137.4
Exposure: MWd/MTU (GWd)	20238.3 (2788.60)		
Delta E: MWd/MTU, (GWd)	602.3 (82.99)		
Power: MWt	2802.0 (70.90 %)		
Core Pressure: psia	1022.4		
Inlet Subcooling: Btu/lbm	-21.53		
Flow: Mlb/hr	107.62 (105.00 %)		
		Axial Profile	Edit Radial Power
		N (PRA)	Power Exposure Zone Avg. Max. IR JR
		Top	25 0.323 7.637 14 0.369 0.369 35 2
			24 0.878 21.072 16 0.348 0.541 9 12
			23 1.112 27.270 17 0.310 0.353 25 60
			22 1.247 31.278 18 0.362 0.423 29 60
			21 1.314 33.649 19 0.791 1.057 13 14
			20 1.358 35.260 20 1.057 1.085 23 12
			19 1.357 36.100 21 1.040 1.068 25 10
			18 1.365* 36.990 22 1.264 1.317 23 10
			17 1.350 37.360 23 1.161 1.301 19 10
			16 1.330 37.964 24 1.102 1.303 9 22
			15 1.318 38.945
			14 1.265 38.815
			13 1.357 37.220
			12 1.335 38.144
			11 1.268 38.650
			10 1.190 39.295
			9 1.085 40.089
			8 0.949 40.433
			7 0.807 40.584
			6 0.693 41.263*
			5 0.597 40.904
			4 0.526 39.039
			3 0.478 35.598
			2 0.384 27.185
		Bottom	1 0.113 7.950
Control Rod Density: %	0.00		
k-effective:	1.00042		
Void Fraction:	0.279		
Core Delta-P: psia	23.786	% AXIAL TILT	20.268 -5.931
Core Plate Delta-P: psia	19.240	AVG BOT 8ft/12ft	0.8933 1.0358
Coolant Temp: Deg-F	543.4		
In Channel Flow: Mlb/hr	96.40	Active Channel Flow: Mlb/hr	93.64
Total Bypass Flow (%):	10.4	(of total core flow)	
Total Water Rod Flow (%):	2.6	(of total core flow)	
Source Convergence	0.00010		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	IR	JR	K	Value
1.317	22	23	10	2.261	0.637	22	23	5.54	0.592	50.0	20	19	12	18	6.19
1.312	22	9	24	2.280	0.632	22	21	5.49	0.586	50.0	20	23	12	18	6.13
1.311	22	21	12	2.288	0.629	22	9	5.43	0.580	50.2	20	11	20	18	6.05
1.310	22	11	22	2.302	0.626	22	11	5.44	0.579	49.7	20	17	14	18	6.09
1.303	24	9	22	2.309	0.624	23	41	5.52	0.578	48.3	20	29	10	18	6.04
1.302	24	21	10	2.321	0.620	22	17	5.38	0.573	49.7	20	13	18	18	6.17
1.301	23	19	10	2.324	0.619	23	9	5.38	0.572	49.7	20	15	16	18	6.32
1.299	22	23	30	2.328	0.619	22	33	6.74	0.570	26.3	22	23	10	18	6.01
1.299	23	9	20	2.336	0.616	22	11	5.29	0.567	50.3	20	11	24	18	5.97
1.296	22	29	28	2.352	0.612	22	25	6.66	0.567	27.0	22	21	12	18	5.98

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

**Figure A.92 Browns Ferry Unit 3 Cycle 19 Control Rod Pattern and
Axial Distributions at 20,238.3 MWd/MTU**

Appendix B Elevation Views of the Browns Ferry Unit 3 Cycle 19 Fresh Reload Batch Fuel Assemblies

[

]

**Figure B.1 Elevation View for the Browns Ferry Unit 3 Cycle 19
Fresh Fuel Reload Batch BFE ATRIUM 10XM
[CGU Fuel Assembly Design**

[

]

**Figure B.2 Elevation View for the Browns Ferry Unit 3 Cycle 19
Fresh Fuel Reload Batch BFE ATRIUM 10XM
[BLEU Fuel Assembly Design]**

[

]

**Figure B.3 Elevation View for the Browns Ferry Unit 3 Cycle 19
Fresh Fuel Reload Batch BFE ATRIUM 10XM
[CGU Fuel Assembly Design**

Appendix C Browns Ferry Unit 3 Cycle 19 Fresh Fuel Locations

**Table C.1 Browns Ferry Unit 3 Cycle 19 Reload Fuel Identification
 and Locations (Core Coordinates)**

Assembly Type: ATRIUM 10XM Bundle Description: [] Number Loaded: 224							
Fuel ID	Core Coord.	Fuel ID	Core Coord.	Fuel ID	Core Coord.	Fuel ID	Core Coord.
FCH001	13-38	FCH039	27-18	FCH077	33-30	FCH115	33-40
FCH002	23-48	FCH040	17-28	FCH078	31-28	FCH116	39-34
FCH003	37-48	FCH041	5-34	FCH079	29-28	FCH117	39-28
FCH004	47-38	FCH042	27-56	FCH080	27-30	FCH118	33-22
FCH005	47-24	FCH043	33-56	FCH081	21-38	FCH119	27-22
FCH006	37-14	FCH044	55-34	FCH082	23-40	FCH120	21-28
FCH007	23-14	FCH045	55-28	FCH083	37-40	FCH121	17-42
FCH008	13-24	FCH046	33- 6	FCH084	39-38	FCH122	19-44
FCH009	13-34	FCH047	27- 6	FCH085	39-24	FCH123	41-44
FCH010	27-48	FCH048	5-28	FCH086	37-22	FCH124	43-42
FCH011	33-48	FCH049	17-38	FCH087	23-22	FCH125	43-20
FCH012	47-34	FCH050	23-44	FCH088	21-24	FCH126	41-18
FCH013	47-28	FCH051	37-44	FCH089	13-46	FCH127	19-18
FCH014	33-14	FCH052	43-38	FCH090	15-48	FCH128	17-20
FCH015	27-14	FCH053	43-24	FCH091	45-48	FCH129	11-36
FCH016	13-28	FCH054	37-18	FCH092	47-46	FCH130	25-50
FCH017	15-44	FCH055	23-18	FCH093	47-16	FCH131	35-50
FCH018	17-46	FCH056	17-24	FCH094	45-14	FCH132	49-36
FCH019	43-46	FCH057	11-40	FCH095	15-14	FCH133	49-26
FCH020	45-44	FCH058	21-50	FCH096	13-16	FCH134	35-12
FCH021	45-18	FCH059	39-50	FCH097	13-42	FCH135	25-12
FCH022	43-16	FCH060	49-40	FCH098	19-48	FCH136	11-26
FCH023	17-16	FCH061	49-22	FCH099	41-48	FCH137	25-34
FCH024	15-18	FCH062	39-12	FCH100	47-42	FCH138	27-36
FCH025	9-34	FCH063	21-12	FCH101	47-20	FCH139	33-36
FCH026	27-52	FCH064	11-22	FCH102	41-14	FCH140	35-34
FCH027	33-52	FCH065	15-40	FCH103	19-14	FCH141	35-28
FCH028	51-34	FCH066	21-46	FCH104	13-20	FCH142	33-26
FCH029	51-28	FCH067	39-46	FCH105	15-36	FCH143	27-26
FCH030	33-10	FCH068	45-40	FCH106	25-46	FCH144	25-28
FCH031	27-10	FCH069	45-22	FCH107	35-46	FCH145	19-40
FCH032	9-28	FCH070	39-16	FCH108	45-36	FCH146	21-42
FCH033	17-34	FCH071	21-16	FCH109	45-26	FCH147	39-42
FCH034	27-44	FCH072	15-22	FCH110	35-16	FCH148	41-40
FCH035	33-44	FCH073	27-32	FCH111	25-16	FCH149	41-22
FCH036	43-34	FCH074	29-34	FCH112	15-26	FCH150	39-20
FCH037	43-28	FCH075	31-34	FCH113	21-34	FCH151	21-20
FCH038	33-18	FCH076	33-32	FCH114	27-40	FCH152	19-22

Table C.1 Browns Ferry Unit 3 Cycle 19 Reload Fuel Identification

and Locations (Core Coordinates) (Continued)

Assembly Type: ATRIUM 10XM
Bundle Description: [
Number Loaded: 224
]

Fuel ID	Core Coord.	Fuel ID	Core Coord.	Fuel ID	Core Coord.	Fuel ID	Core Coord.
FCH153	23-36	FCH171	31-50	FCH189	51-24	FCH207	29-20
FCH154	25-38	FCH172	49-32	FCH190	37-10	FCH208	19-30
FCH155	35-38	FCH173	49-30	FCH191	23-10	FCH209	7-32
FCH156	37-36	FCH174	31-12	FCH192	9-24	FCH210	29-54
FCH157	37-26	FCH175	29-12	FCH193	15-32	FCH211	31-54
FCH158	35-24	FCH176	11-30	FCH194	29-46	FCH212	53-32
FCH159	25-24	FCH177	11-44	FCH195	31-46	FCH213	53-30
FCH160	23-26	FCH178	17-50	FCH196	45-32	FCH214	31- 8
FCH161	19-36	FCH179	43-50	FCH197	45-30	FCH215	29- 8
FCH162	25-42	FCH180	49-44	FCH198	31-16	FCH216	7-30
FCH163	35-42	FCH181	49-18	FCH199	29-16	FCH217	23-32
FCH164	41-36	FCH182	43-12	FCH200	15-30	FCH218	29-38
FCH165	41-26	FCH183	17-12	FCH201	19-32	FCH219	31-38
FCH166	35-20	FCH184	11-18	FCH202	29-42	FCH220	37-32
FCH167	25-20	FCH185	9-38	FCH203	31-42	FCH221	37-30
FCH168	19-26	FCH186	23-52	FCH204	41-32	FCH222	31-24
FCH169	11-32	FCH187	37-52	FCH205	41-30	FCH223	29-24
FCH170	29-50	FCH188	51-38	FCH206	31-20	FCH224	23-30

Assembly Type: ATRIUM 10XM
Bundle Description: []
Number Loaded: 96

AREVA Inc.

Assembly Type: ATRIUM 10XM
Bundle Description: []
Number Loaded: 32


AREVA Inc.

Appendix D Browns Ferry Unit 3 Cycle 19 Radial Exposure and Power Distributions

	1	3	5	7	9	11	13	15	17	19	21	23	25	27	29
60				37.684	39.462	41.035	37.885	41.212	41.091	38.140	36.897	35.882	36.045	35.254	31.869
58				32.377	32.377			21.470	34.051	17.932	17.221	21.392	21.368	20.292	0.000
56						37.875	22.085	0.000	0.000	0.000	0.000	0.000	17.841	0.000	20.872
54						31.776	0.000	21.972	0.000	0.000	23.092	0.000	0.000	0.000	0.000
52						19.614	0.000	0.000	0.000	0.000	0.000	0.000	23.731	0.000	23.180
50								0.000	0.000	23.972	0.000	24.000	0.000	23.267	0.000
48						0.000	19.613	0.000	22.359	0.000	24.066	0.000	22.875	0.000	22.346
46						21.894	0.000	21.904	0.000	22.748	0.000	22.798	0.000	21.926	0.000
44	41.043	41.574				0.000	0.000	0.000	22.041	0.000	23.028	0.000	22.645	0.000	22.052
42	38.765	17.816	0.000	0.000	0.000	24.047	0.000	21.901	0.000	23.847	0.000	20.208	0.000	23.290	0.000
40	37.442	17.167	0.000	23.052	0.000	0.000	23.958	0.000	21.004	0.000	20.863	0.000	22.768	0.000	22.652
38	36.076	21.287	0.000	0.000	0.000	23.972	0.000	22.622	0.000	20.248	0.000	22.690	0.000	23.365	0.000
36	36.878	21.342	18.032	0.000	23.445	0.000	23.202	0.000	22.172	0.000	22.573	0.000	22.803	0.000	23.550
34	34.916	20.367	0.000	0.000	0.000	22.281	0.000	21.926	0.000	23.084	0.000	23.423	0.000	22.935	0.000
32	32.110	0.000	20.801	0.000	23.111	0.000	22.792	0.000	23.405	0.000	22.604	0.000	23.351	0.000	23.713
30	31.883	0.000	20.612	0.000	23.050	0.000	22.764	0.000	23.394	0.000	22.579	0.000	23.185	0.000	23.790
28	35.369	19.900	0.000	0.000	0.000	22.106	0.000	21.905	0.000	23.017	0.000	23.422	0.000	22.890	0.000
26	36.979	21.332	17.548	0.000	23.329	0.000	23.180	0.000	22.080	0.000	22.473	0.000	22.667	0.000	23.447
24	35.795	21.177	0.000	0.000	0.000	23.900	0.000	22.545	0.000	19.849	0.000	22.664	0.000	23.327	0.000
22	37.278	16.969	0.000	23.032	0.000	0.000	23.847	0.000	22.818	0.000	20.917	0.000	22.673	0.000	22.612
20	38.507	17.756	0.000	0.000	0.000	23.964	0.000	21.752	0.000	23.695	0.000	20.269	0.000	23.218	0.000
18	39.805	34.045	0.000	21.860	0.000	0.000	21.641	0.000	21.822	0.000	20.601	0.000	22.566	0.000	22.009
16		41.138	21.375	0.000	21.627	0.000	0.000	21.935	0.000	22.642	0.000	22.714	0.000	21.895	0.000
14			37.950	21.578	0.000		19.335	0.000	22.266	0.000	23.975	0.000	22.785	0.000	22.339
12			41.143	40.385	31.825	19.519	0.000	0.000	0.000	23.943	0.000	23.909	0.000	23.185	0.000
10					41.192	32.377	0.000	21.918	0.000	0.000	0.000	0.000	23.637	0.000	23.051
8					40.493	40.493	22.099	0.000	21.951	0.000	22.991	0.000	0.000	0.000	0.000
6					40.823	40.823	37.592	21.333	0.000	0.000	16.988	0.000	21.926	0.000	20.716
4								41.268	34.266	17.709	16.988	21.210	17.303	20.405	0.000
2								41.263	37.750	36.629	35.749	37.134	35.498	32.461	32.461

	31	33	35	37	39	41	43	45	47	49	51	53	55	57	59
60	32.364	35.496	36.063	35.822	36.727	37.749	37.858								
58	0.000	20.378	21.327	21.245	17.097	17.753	34.216	41.290							
56	20.749	0.000	17.927	0.000	0.000	0.000	0.000	21.352	37.703	40.899					
54	0.000	0.000	0.000	0.000	22.999	0.000	21.948	0.000	22.065	40.597					
52	23.057	0.000	23.618	0.000	0.000	0.000	0.000	21.893	0.000	32.350	41.242				
50	0.000	23.162	0.000	23.907	0.000	23.932	0.000	0.000	0.000	19.515	31.947	39.805	41.337		
48	22.347	0.000	22.786	0.000	23.964	0.000	22.268	0.000	19.364	0.000	0.000	21.571	38.490		
46	0.000	21.901	0.000	22.710	0.000	22.612	0.000	21.947	0.000	0.000	21.624	0.000	21.373	41.196	
44	22.028	0.000	22.575	0.000	20.589	0.000	21.821	0.000	21.626	0.000	0.000	21.834	0.000	34.247	37.800
42	0.000	23.206	0.000	20.218	0.000	23.697	0.000	21.720	0.000	23.926	0.000	0.000	0.000	17.789	37.632
40	22.625	0.000	22.650	0.000	20.894	0.000	22.801	0.000	23.811	0.000	0.000	23.014	0.000	17.034	37.367
38	0.000	23.339	0.000	22.666	0.000	19.858	0.000	22.530	0.000	23.868	0.000	0.000	0.000	21.184	35.964
36	23.435	0.000	22.659	0.000	22.441	0.000	22.046	0.000	23.164	0.000	23.291	0.000	17.576	21.337	35.843
34	0.000	22.897	0.000	23.403	0.000	22.983	0.000	21.887	0.000	22.077	0.000	0.000	0.000	19.915	35.498
32	23.760	0.000	23.158	0.000	22.551	0.000	23.350	0.000	22.732	0.000	23.029	0.000	20.629	0.000	32.032
30	23.697	0.000	23.345	0.000	22.573	0.000	23.369	0.000	22.765	0.000	23.113	0.000	20.767	0.000	32.393
28	0.000	22.925	0.000	23.412	0.000	23.073	0.000	21.903	0.000	22.302	0.000	0.000	0.000	20.432	35.083
26	23.593	0.000	22.773	0.000	22.590	0.000	22.095	0.000	23.177	0.000	23.447	0.000	18.186	21.361	35.713
24	0.000	23.348	0.000	22.673	0.000	20.246	0.000	22.619	0.000	23.973	0.000	0.000	0.000	21.277	35.927
22	22.628	0.000	22.788	0.000	20.969	0.000	21.225	0.000	23.955	0.000	0.000	23.057	0.000	17.115	37.445
20	0.000	23.278	0.000	20.513	0.000	23.837	0.000	21.955	0.000	24.032	0.000	0.000	0.000	17.857	37.770
18	22.024	0.000	22.612	0.000	23.040	0.000	22.018	0.000	21.694	0.000	0.000	21.884	0.000	34.222	40.982
16	0.000	21.908	0.000	22.790	0.000	22.829	0.000	21.889	0.000	0.000	21.877	0.000	21.430	41.167	
14	22.329	0.000	22.848	0.000	24.063	0.000	22.326	0.000	19.774	0.000	0.000	21.933	38.281		
12	0.000	23.345	0.000	23.989	0.000	23.956	0.000	0.000	0.000	19.571	32.433	40.203	40.464		
10	23.168	0.000	23.743	0.000	0.000	0.000	0.000	22.125	0.000	32.497	38.055				
8	0.000	0.000	0.000	0.000	23.069	0.000	21.986	0.000	22.333	39.623					
6	20.947	0.000	18.342	0.000	0.000	0.000	0.000	0.000	38.147	41.158					
4	0.000	20.721	21.334	21.410	17.307	17.895	34.421	40.917							
2	32.686	35.498	34.944	36.024	36.909	37.908	41.197								

Figure D.1 Browns Ferry Unit 3 Cycle 19 BOC Exposure Distribution (GWD/MTU) (Continued)



	31	33	35	37	39	41	43	45	47	49	51	53	55	57	59
60	41.385	44.039	44.096	43.672	44.160	44.181	43.090								
58	16.904	36.051	36.663	36.282	32.064	31.370	43.731	48.206							
56	40.397	21.068	37.760	20.988	20.364	19.049	16.939	34.143	45.398	45.391					
54	23.308	23.828	23.897	23.684	43.856	22.333	40.785	18.166	35.368	48.214					
52	44.860	24.470	45.483	24.610	24.511	24.322	22.951	41.275	18.294	43.996	48.746				
50	24.255	45.221	24.797	46.277	24.887	46.194	24.209	23.474	21.466	36.463	43.633	47.252	45.778		
48	44.684	24.321	44.784	23.831	45.293	24.905	44.917	24.323	40.910	21.466	18.303	34.926	46.132		
46	24.637	43.910	23.875	44.197	23.829	44.900	25.112	44.753	24.343	23.482	41.038	18.144	34.122	47.871	
44	43.884	23.298	43.821	23.514	42.590	24.482	44.452	25.202	44.473	24.202	22.902	40.632	16.873	43.726	43.014
42	23.414	44.226	23.274	42.193	24.002	45.554	24.732	44.379	24.986	46.106	24.158	22.210	18.974	31.365	44.068
40	43.394	23.576	44.160	24.579	43.794	25.110	45.546	24.184	45.214	24.321	23.890	43.724	20.302	31.987	44.717
38	22.299	44.188	23.741	44.764	24.633	42.843	24.805	44.383	23.949	45.849	24.072	23.595	20.993	36.255	43.816
36	43.255	22.597	43.581	22.777	43.180	23.342	43.665	24.262	45.356	24.939	45.288	24.011	37.558	36.767	43.948
34	21.267	43.167	22.442	43.335	22.390	43.820	23.332	44.145	24.707	44.698	24.869	24.130	21.300	35.791	44.133
32	42.766	21.762	43.322	21.915	42.870	22.935	44.767	24.765	45.333	25.252	45.656	23.743	40.542	17.101	41.187
30	42.705	21.766	43.490	21.914	42.889	22.931	44.779	24.760	45.356	25.239	45.718	23.729	40.649	17.082	41.518
28	21.258	43.222	22.476	43.335	22.375	43.896	23.328	44.148	24.687	44.870	24.835	24.088	21.245	36.213	43.734
26	43.379	22.614	43.692	22.757	43.285	23.325	43.702	24.250	45.357	24.905	45.388	23.955	38.027	36.735	43.801
24	22.279	44.169	23.702	44.727	24.570	43.145	24.806	44.454	23.923	45.908	24.027	23.542	20.934	36.292	43.754
22	43.374	23.527	44.222	24.490	43.787	25.044	44.189	24.163	45.310	24.274	23.846	43.721	20.253	32.020	44.776
20	23.377	44.233	23.174	42.328	23.850	45.565	24.635	44.525	24.924	46.154	24.110	22.166	18.933	31.393	44.154
18	43.842	23.224	43.751	23.333	44.537	24.1314	44.511	25.110	44.469	24.141	22.852	40.641	16.842	43.667	46.071
16	24.592	43.845	23.762	44.135	23.663	44.960	24.994	44.623	24.264	23.416	41.213	18.103	34.160	47.814	
14	44.624	24.240	44.740	23.717	45.277	24.782	44.876	24.221	41.184	21.401	18.252	35.228	45.930		
12	24.199	45.314	24.706	46.263	24.786	46.129	24.114	23.376	21.373	36.464	44.056	47.846	44.976		
10	44.906	24.396	45.521	24.523	24.424	24.236	22.867	41.406	18.222	44.108	45.748				
8	23.252	23.755	23.818	23.600	43.847	22.251	40.751	18.089	35.570	47.067					
6	40.523	21.001	38.056	20.911	20.282	18.963	16.851	34.156	45.801	45.764					
4	16.848	36.324	36.642	36.390	32.186	31.417	43.838	47.564							
2	41.653	44.043	43.290	43.842	44.295	44.267	46.215								

Figure D.2 Browns Ferry Unit 3 Cycle 19 EOC Exposure Distribution (19.6 GWD/MTU) (Continued)

	1	3	5	7	9	11	13	15	17	19	21	23	25	27	29
50			0.420	0.406	0.611	0.891	1.011	1.028	1.149	1.088	1.086	0.909	1.181	1.254	1.281
51			0.484	0.708	0.878	1.086	1.130	1.184	1.184	1.136	0.922	0.932	1.202	1.280	1.295
52		0.369	0.821	0.959	1.055	1.098	1.161	1.188	1.221	1.213	1.197	1.209	1.253	1.277	1.297
53	0.298	0.503	0.821	0.931	1.008	1.092	1.116	1.153	1.217	1.228	1.274	1.303	1.279	1.251	1.216
54	0.358	0.736	0.907	1.031	1.100	1.088	0.873	0.929	1.221	1.277	1.322	1.307	1.265	1.212	0.944
55	0.417	0.816	0.977	1.047	1.108	1.182	0.913	0.939	1.215	1.306	1.308	1.304	1.270	1.184	0.934
56	0.450	0.834	1.019	1.109	1.124	1.108	0.913	0.939	1.215	1.306	1.308	1.304	1.270	1.184	0.934
57	0.466	0.864	1.063	1.140	1.143	1.182	1.182	1.204	1.262	1.281	1.268	1.271	1.254	1.210	1.162
58	0.491	0.874	1.033	1.153	1.192	1.222	1.254	1.279	1.275	1.252	1.212	1.183	1.211	1.199	1.154
59	0.505	0.865	1.063	1.140	1.213	1.253	1.275	1.289	1.273	1.210	0.942	0.934	1.164	1.155	0.973
60	0.506	0.866	1.065	1.141	1.214	1.254	1.275	1.290	1.273	1.210	0.942	0.934	1.166	1.155	0.972
61	0.491	0.879	1.036	1.155	1.194	1.224	1.255	1.279	1.275	1.253	1.213	1.184	1.211	1.200	1.155
62	0.467	0.866	1.070	1.143	1.146	1.184	1.182	1.204	1.263	1.282	1.271	1.272	1.256	1.211	1.162
63	0.452	0.848	1.024	1.111	1.126	1.110	0.913	0.938	1.213	1.310	1.310	1.306	1.272	1.185	0.934
64	0.419	0.820	0.979	1.049	1.110	1.090	0.874	0.928	1.204	1.278	1.324	1.309	1.268	1.214	0.943
65	0.422	0.820	0.979	1.049	1.110	1.090	0.874	0.928	1.204	1.278	1.324	1.309	1.268	1.214	0.943
66	0.359	0.738	0.911	1.033	1.102	1.138	1.118	1.156	1.219	1.234	1.280	1.307	1.282	1.253	1.216
67	0.292	0.505	0.823	0.961	1.057	1.100	1.165	1.191	1.226	1.219	1.226	1.216	1.257	1.278	1.297
68	0.292	0.505	0.823	0.961	1.057	1.100	1.165	1.191	1.226	1.219	1.226	1.216	1.257	1.278	1.297
69	0.370	0.370	0.682	0.879	0.991	1.089	1.133	1.187	1.188	1.142	0.929	0.938	1.205	1.281	1.294
70	0.415	0.415	0.710	0.882	1.015	1.109	1.131	1.153	1.153	1.114	0.872	0.912	1.185	1.255	1.280
71	0.415	0.415	0.710	0.882	1.015	1.109	1.131	1.153	1.153	1.114	0.872	0.912	1.185	1.255	1.280
72	0.252	0.418	0.252	0.418	0.616	0.895	1.014	1.087	1.097	1.091	1.087	1.107	1.180	1.207	1.251
73	0.441	0.441	0.613	0.879	0.879	0.879	0.879	0.986	1.054	1.098	1.107	1.121	1.137	1.188	1.208
74	0.416	0.416	0.416	0.416	0.705	0.705	0.705	0.877	0.957	1.030	1.046	1.107	1.137	1.149	1

60	31	33	35	37	39	41	43	45	47	49	51	53	55	57	59
58	0.500	0.487	0.466	0.452	0.423	0.360	0.296								
56	0.861	0.871	0.863	0.835	0.818	0.737	0.505	0.381							
54	1.060	1.030	1.063	1.018	0.977	0.910	0.821	0.681	0.416	0.249					
52	1.136	1.150	1.138	1.107	1.047	1.031	0.958	0.877	0.705	0.413					
50	1.210	1.189	1.138	1.122	1.107	1.099	1.054	0.986	0.878	0.610	0.423				
48	1.252	1.209	1.181	1.107	1.087	1.091	1.097	1.086	1.108	1.014	0.880	0.403			
46	1.282	1.256	1.186	0.912	0.872	1.114	1.153	1.131	1.108	1.089	0.990	0.709	0.414		
44	1.296	1.283	1.206	0.938	0.928	1.143	1.188	1.187	1.133	1.089	0.990	0.879	0.681	0.371	0.296
42	1.299	1.279	1.258	1.217	1.226	1.219	1.226	1.191	1.165	1.100	1.057	0.961	0.822	0.505	0.362
40	1.217	1.254	1.283	1.308	1.280	1.234	1.219	1.156	1.119	1.095	1.102	1.033	0.911	0.738	0.419
38	0.944	1.214	1.268	1.309	1.324	1.278	1.204	0.928	0.875	1.090	1.110	1.050	0.979	0.819	0.453
36	0.934	1.184	1.271	1.305	1.308	1.309	1.213	0.938	0.913	1.110	1.126	1.111	1.022	0.838	0.469
34	1.163	1.210	1.254	1.268	1.267	1.279	1.262	1.203	1.182	1.184	1.146	1.143	1.070	0.866	0.490
32	1.154	1.197	1.207	1.177	1.205	1.248	1.273	1.278	1.254	1.225	1.194	1.155	1.035	0.878	0.504
30	0.972	1.151	1.157	0.921	0.930	1.202	1.270	1.288	1.275	1.253	1.214	1.140	1.065	0.864	0.502
28	1.153	1.195	1.205	1.175	1.203	1.246	1.271	1.277	1.253	1.221	1.192	1.152	1.032	0.872	0.490
26	1.160	1.207	1.250	1.265	1.263	1.277	1.260	1.202	1.181	1.182	1.142	1.139	1.061	0.863	0.468
24	0.933	1.181	1.267	1.300	1.303	1.303	1.212	0.938	0.912	1.107	1.123	1.108	1.018	0.834	0.451
22	0.943	1.210	1.262	1.303	1.318	1.274	1.217	0.927	0.873	1.088	1.108	1.047	0.976	0.816	0.418
20	1.215	1.249	1.276	1.297	1.271	1.226	1.215	1.151	1.115	1.091	1.099	1.030	0.909	0.735	0.359
18	1.296	1.275	1.251	1.206	1.195	1.211	1.219	1.186	1.161	1.097	1.054	0.958	0.820	0.503	0.291
16	1.293	1.278	1.200	0.931	0.921	1.134	1.182	1.182	1.129	1.085	0.986	0.876	0.680	0.368	
14	1.279	1.252	1.180	0.908	0.867	1.108	1.147	1.126	1.100	1.011	0.877	0.705	0.414		
12	1.250	1.203	1.176	1.102	1.082	1.087	1.092	1.081	1.008	0.890	0.877	0.610			
10	1.206	1.185	1.133	1.118	1.103	1.095	1.049	0.980	0.874	0.609	0.431				
8	1.134	1.146	1.134	1.103	1.043	1.026	0.954	0.873	0.701	0.403					
6	1.056	1.027	1.056	1.015	0.973	0.905	0.817	0.677	0.413	0.255					
4	0.859	0.867	0.861	0.832	0.813	0.732	0.499	0.366							
2	0.497	0.486	0.482	0.451	0.420	0.356	0.285								

Figure D.3 Browns Ferry Unit 3 Cycle 19 Radial Power Distribution
 at 0.0 MWd/MTU (Continued)

[illegible]

60	31	33	35	37	39	41	43	45	47	49	51	53	55	57	59
	0.413	0.381	0.350	0.338	0.324	0.282	0.227								
58	0.873	0.731	0.701	0.694	0.698	0.638	0.436	0.308							
56	0.943	1.097	0.941	1.072	1.048	0.986	0.870	0.602	0.343	0.194					
54	1.219	1.226	1.224	1.215	1.010	1.151	0.901	0.924	0.623	0.338					
52	1.067	1.266	1.045	1.273	1.252	1.239	1.172	0.927	0.937	0.526	0.324	0.334	0.191		
50	1.279	1.052	1.277	1.074	1.284	1.057	1.238	1.188	1.087	0.793	0.528	0.627	0.342		
48	1.063	1.292	1.087	1.300	1.062	1.266	1.054	1.227	1.016	1.087	0.938	0.902	0.601	0.295	
46	1.297	1.100	1.310	1.097	1.299	1.051	1.255	1.049	1.227	1.188	0.929	0.925	0.601	0.435	0.226
44	1.112	1.330	1.115	1.319	1.110	1.284	1.073	1.254	1.058	1.238	1.173	0.902	0.870	0.435	0.283
42	1.334	1.118	1.333	1.124	1.305	1.057	1.275	1.052	1.263	1.057	1.242	1.154	0.987	0.637	0.319
40	1.127	1.332	1.091	1.306	1.097	1.281	1.069	1.281	1.056	1.289	1.260	1.010	1.048	0.696	0.335
38	1.354	1.099	1.326	1.098	1.303	1.103	1.283	1.081	1.286	1.072	1.276	1.213	1.070	0.691	0.408
36	1.134	1.349	1.123	1.342	1.104	1.325	1.104	1.287	1.067	1.262	1.037	1.215	0.935	0.696	0.347
34	1.359	1.132	1.353	1.114	1.349	1.116	1.316	1.080	1.266	1.040	1.244	1.210	1.085	0.725	0.376
32	1.096	1.352	1.131	1.362	1.133	1.332	1.088	1.273	1.036	1.241	1.037	1.196	0.929	0.862	0.408
30	1.096	1.352	1.130	1.361	1.133	1.332	1.088	1.273	1.035	1.240	1.036	1.196	0.928	0.861	0.407
28	1.359	1.131	1.352	1.113	1.349	1.115	1.315	1.080	1.266	1.039	1.243	1.209	1.084	0.722	0.376
26	1.135	1.349	1.121	1.341	1.103	1.325	1.104	1.287	1.068	1.261	1.036	1.214	0.931	0.694	0.347
24	1.357	1.100	1.326	1.098	1.303	1.101	1.285	1.081	1.286	1.072	1.276	1.212	1.069	0.689	0.334
22	1.130	1.334	1.091	1.306	1.097	1.281	1.080	1.283	1.055	1.289	1.259	1.009	1.047	0.695	0.318
20	1.338	1.119	1.334	1.121	1.304	1.056	1.276	1.052	1.263	1.057	1.242	1.154	0.987	0.636	0.280
18	1.115	1.334	1.115	1.318	1.092	1.284	1.072	1.254	1.059	1.239	1.173	0.902	0.870	0.435	0.220
16	1.301	1.103	1.312	1.096	1.298	1.050	1.256	1.050	1.228	1.189	0.928	0.925	0.601	0.299	
14	1.066	1.296	1.088	1.301	1.062	1.267	1.054	1.228	1.014	1.087	0.938	0.625	0.343		
12	1.283	1.053	1.280	1.075	1.286	1.058	1.239	1.188	1.087	0.793	0.526	0.341	0.195		
10	1.069	1.269	1.047	1.275	1.254	1.241	1.173	0.926	0.937	0.526	0.329				
8	1.222	1.229	1.226	1.217	1.011	1.152	0.902	0.924	0.623	0.335					
6	0.944	1.099	0.941	1.074	1.048	0.986	0.869	0.601	0.344	0.202					
4	0.873	0.731	0.703	0.694	0.696	0.637	0.434	0.301							
2	0.412	0.382	0.364	0.339	0.323	0.281	0.222								

Figure D.4 Browns Ferry Unit 3 Cycle 19 Radial Power Distribution
 at 18,390.1 MWd/MTU (EOFP) (Continued)

**Appendix E Browns Ferry Unit 3 Cycle 18 EOC Projection Control Rod Patterns and Core Average
Axial Power and Exposure Distributions**

Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference Fuel Cycle Design

Cycle:	18	Core Average Exposure: MWd/MTU	33188.5
Exposure: MWd/MTU (Gwd)	16975.7 (2317.80)		
Delta E: MWd/MTU, (Gwd)	175.7 (23.99)		
Power: MWt	3192.1 (92.31 %)		
Core Pressure: psia	1038.9		
Inlet Subcooling: Btu/lbm	-26.97		
Flow: Mlb/hr	107.62 (105.00 %)		
		Axial Profile	Edit Radial Power
		N(PRA) Power Exposure Zone Avg. Max. IR JR	
		Top 25 0.278 6.809 12 0.321 0.628 49 12	
		24 0.793 19.574 13 0.242 0.281 7 50	
		23 1.012 25.854 14 0.307 0.764 47 10	
		22 1.154 29.984 15 0.468 0.657 11 50	
		21 1.219 32.438 16 1.024 1.221 25 26	
		20 1.257 33.806 17 1.046 1.132 47 26	
		19 1.280 34.869 18 1.119 1.269 37 28	
		18 1.304 35.583 19 1.191 1.327 11 44	
		17 1.308 35.590 20 1.394 1.477 37 26	
		16 1.380 36.071 21 1.340 1.374 31 46	
		15 1.392 36.935	
		14 1.358 37.066	
		13 1.405* 36.414	
		12 1.382 37.065	
		11 1.328 37.502	
		10 1.254 37.936	
		9 1.164 38.903	
		8 1.032 39.372	
		7 0.881 39.418	
		6 0.749 40.284	
		5 0.625 40.304*	
		4 0.525 38.913	
		3 0.455 36.030	
		2 0.360 28.135	
		Bottom 1 0.105 8.336	
Control Rod Density: %	0.00		
k-effective:	0.99995		
Void Fraction:	0.284		
Core Delta-P: psia	24.342	% AXIAL TILT	16.418 -7.262
Core Plate Delta-P: psia	19.777	AVG BOT 8ft/12ft	0.9341 1.0428
Coolant Temp: Deg-F	543.7		
In Channel Flow: Mlb/hr	96.10	Active Channel Flow: Mlb/hr	93.28
Total Bypass Flow (%):	10.7	(of total core flow)	
Total Water Rod Flow (%):	2.6	(of total core flow)	
Source Convergence	0.00008		

Top Ten Thermal Limits Summary - Sorted by Margin

Power			MCPR			APLHGR					LHGR				
Value	FT	IR JR	Value	Margin	FT	IR JR	Value	Margin	Exp. FT	IR JR K	Value	Margin	Exp. FT	IR JR K	
1.477	20	37 26	1.915	0.741	20	37 26	7.86	0.650	23.8	20 37 26 15	6.61	0.681	51.5	17 13 36 18	
1.475	20	35 28	1.924	0.738	20	39 24	7.83	0.650	24.2	20 39 28 15	6.77	0.677	48.9	18 49 24 18	
1.470	20	27 36	1.926	0.737	20	41 26	7.76	0.649	25.1	20 41 26 15	6.54	0.674	51.5	16 47 22 18	
1.463	20	35 38	1.927	0.737	20	39 28	7.81	0.649	24.3	20 39 24 15	6.34	0.671	53.8	16 49 28 18	
1.463	20	39 28	1.930	0.736	20	25 34	7.75	0.648	25.0	20 35 42 15	8.63	0.671	29.2	20 41 26 15	
1.459	20	37 30	1.931	0.735	20	35 38	7.74	0.648	25.1	20 27 40 15	6.48	0.671	51.9	17 35 14 18	
1.456	20	39 24	1.933	0.735	20	33 26	7.78	0.648	24.4	20 23 40 15	6.45	0.670	52.2	16 49 20 18	
1.456	20	29 38	1.936	0.733	20	33 40	7.80	0.647	24.2	20 31 42 15	8.60	0.669	29.3	20 25 42 15	
1.453	20	33 30	1.937	0.733	20	23 40	7.75	0.647	24.9	20 25 38 15	6.57	0.669	50.4	18 45 24 18	
1.452	20	37 40	1.939	0.733	20	37 30	7.74	0.647	25.0	20 37 30 15	6.66	0.668	49.1	18 23 50 18	

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

Figure E.1 Browns Ferry Unit 3 Cycle 18 Control Rod Pattern and Axial Distributions at 16,975.7 MWd/MTU

Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference Fuel Cycle Design

Cycle:	18	Core Average Exposure: MWd/MTU	33720.2
Exposure: MWd/MTU (Gwd)	17507.6 (2390.40)		
Delta E: MWd/MTU, (Gwd)	257.6 (35.17)		
Power: MWt	2793.4 (80.78 %)		
Core Pressure: psia	1030.1		
Inlet Subcooling: Btu/lbm	-23.27		
Flow: Mlb/hr	107.62 (105.00 %)		
		Axial Profile	Edit Radial Power
		N(PRA) Power Exposure	Zone Avg. Max. IR JR
		Top 25	0.296 6.978 12 0.318 0.625 49 12
		24	0.850 20.037 13 0.240 0.279 7 50
		23	1.082 26.444 14 0.304 0.762 47 10
		22	1.225 30.656 15 0.464 0.655 11 50
		21	1.283 33.145 16 1.022 1.218 25 26
		20	1.313 34.533 17 1.049 1.131 47 26
		19	1.326 35.607 18 1.117 1.266 37 28
		18	1.341 36.332 19 1.199 1.338 11 44
		17	1.335 36.338 20 1.395 1.474 37 26
		16	1.402 36.816 21 1.339 1.369 31 46
		15	1.407 37.684
		14	1.365 37.795
		13	1.408* 37.126
		12	1.378 37.764
		11	1.310 38.170
		10	1.220 38.563
		9	1.113 39.480
		8	0.971 39.879
		7	0.815 39.847
		6	0.684 40.647*
		5	0.567 40.606
		4	0.475 39.166
		3	0.412 36.249
		2	0.327 28.308
		Bottom 1	0.096 8.390
Control Rod Density: %	0.00		
k-effective:	0.99997		
Void Fraction:	0.260		
Core Delta-P: psia	23.830	% AXIAL TILT	20.595 -6.783
Core Plate Delta-P: psia	19.274	AVG BOT 8ft/12ft	0.9076 1.0405
Coolant Temp: Deg-F	543.2		
In Channel Flow: Mlb/hr	96.41	Active Channel Flow: Mlb/hr	93.70
Total Bypass Flow (%):	10.4	(of total core flow)	
Total Water Rod Flow (%):	2.5	(of total core flow)	
Source Convergence	0.00008		

Top Ten Thermal Limits Summary - Sorted by Margin

Power			MCPH			APLHGR					LHGR				
Value	FT	IR JR	Value	Margin	FT	IR JR	Value	Margin	Exp. FT	IR JR K	Value	Margin	Exp. FT	IR JR K	
1.474	20	37 26	2.176	0.653	20	37 26	5.59	0.584	44.2 18	49 24 18	5.95	0.621	52.4 17	13 36 18	
1.472	20	35 28	2.181	0.651	20	39 24	6.98	0.583	24.9 20	37 26 15	6.11	0.618	49.9 18	49 24 18	
1.467	20	27 36	2.185	0.650	20	41 26	6.94	0.582	25.3 20	39 28 15	5.91	0.616	52.5 16	47 22 18	
1.460	20	35 38	2.188	0.649	20	39 28	6.88	0.581	26.1 20	41 26 15	5.83	0.613	53.1 16	49 20 18	
1.459	20	39 28	2.193	0.647	20	25 34	6.93	0.581	25.4 20	39 24 15	5.84	0.611	52.7 17	35 48 18	
1.457	20	37 30	2.194	0.647	20	35 38	6.87	0.580	26.1 20	37 30 15	5.70	0.610	54.7 16	49 28 18	
1.453	20	39 24	2.196	0.647	20	33 40	6.86	0.580	26.2 20	27 40 15	6.01	0.609	50.1 18	23 50 18	
1.453	20	29 38	2.196	0.647	20	33 26	6.88	0.580	26.0 20	25 38 15	5.82	0.607	52.6 18	45 24 18	
1.450	20	33 30	2.198	0.646	20	23 40	6.87	0.580	26.1 20	35 42 15	5.80	0.607	52.7 16	45 20 18	
1.449	20	37 40	2.201	0.645	20	49 26	6.90	0.580	25.5 20	23 40 15	7.69	0.605	30.4 20	41 26 15	

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

Figure E.2 Browns Ferry Unit 3 Cycle 18 Control Rod Pattern and Axial Distributions at 17,507.6 MWd/MTU

Browns Ferry Unit 3 Cycle 19 EPU (120% OLTP) LAR Reference Fuel Cycle Design

Cycle:	18	Core Average Exposure: MWd/MTU	34075.0
Exposure: MWd/MTU (Gwd)	17862.2 (2438.80)		
Delta E: MWd/MTU, (Gwd)	354.6 (48.41)		
Power: MWt	2538.0 (73.40 %)		
Core Pressure: psia	1024.4		
Inlet Subcooling: Btu/lbm	-20.92		
Flow: Mlb/hr	107.62 (105.00 %)		
		Axial Profile	Edit Radial Power
		N(PRA) Power Exposure Zone Avg. Max. IR JR	
		Top 25 0.310 7.097 12 0.316 0.624 49 12	
		24 0.893 20.365 13 0.238 0.277 7 50	
		23 1.134 26.860 14 0.302 0.761 47 10	
		22 1.277 31.128 15 0.462 0.654 11 50	
		21 1.330 33.638 16 1.021 1.216 25 26	
		20 1.352 35.036 17 1.051 1.132 9 40	
		19 1.358 36.113 18 1.116 1.264 37 28	
		18 1.366 36.843 19 1.204 1.345 11 44	
		17 1.353 36.846 20 1.396 1.472 37 26	
		16 1.414 37.318 21 1.338 1.366 31 46	
		15 1.414* 38.188	
		14 1.366 38.282	
		13 1.405 37.601	
		12 1.368 38.228	
		11 1.291 38.609	
		10 1.190 38.970	
		9 1.075 39.849	
		8 0.927 40.199	
		7 0.771 40.115	
		6 0.644 40.871*	
		5 0.531 40.791	
		4 0.445 39.321	
		3 0.386 36.383	
		2 0.307 28.415	
		Bottom 1 0.090 8.423	
Control Rod Density: %	0.00		
k-effective:	0.99997		
Void Fraction:	0.243		
Core Delta-P: psia	23.507	% AXIAL TILT	23.491 -6.435
Core Plate Delta-P: psia	18.957	AVG BOT 8ft/12ft	0.8886 1.0387
Coolant Temp: Deg-F	543.0		
In Channel Flow: Mlb/hr	96.61	Active Channel Flow: Mlb/hr	93.96
Total Bypass Flow (%):	10.2	(of total core flow)	
Total Water Rod Flow (%):	2.5	(of total core flow)	
Source Convergence	0.00009		

Top Ten Thermal Limits Summary - Sorted by Margin

Power				MCPR				APLHGR				LHGR			
Value	FT	IR	JR	Value	Margin	FT	IR	Value	Margin	Exp.	FT	Value	Margin	Exp.	FT
1.472	20	37	26	2.383	0.596	20	37	5.19	0.545	44.8	18	5.51	0.579	53.1	17
1.470	20	35	28	2.387	0.595	20	39	6.40	0.538	25.6	20	5.67	0.578	50.5	18
1.465	20	27	36	2.389	0.594	20	41	5.10	0.537	45.1	18	5.47	0.575	53.1	16
1.458	20	35	38	2.394	0.593	20	49	5.02	0.537	46.4	18	5.41	0.573	53.8	16
1.457	20	39	28	2.395	0.593	20	39	6.37	0.537	26.0	20	5.41	0.570	53.4	17
1.455	20	37	30	2.400	0.592	20	25	6.35	0.536	26.1	20	5.57	0.569	50.7	18
1.451	20	29	38	2.401	0.591	20	9	6.30	0.536	26.9	20	5.27	0.569	55.3	16
1.450	20	39	24	2.402	0.591	20	35	6.30	0.535	26.9	20	5.38	0.566	53.2	18
1.448	20	33	30	2.402	0.591	20	33	6.31	0.535	26.7	20	5.36	0.565	53.4	16
1.446	20	29	34	2.403	0.591	20	33	6.29	0.535	27.0	20	5.33	0.564	53.7	16

* LHGR calculated with pin-power reconstruction

* CPR calculated with pin-power reconstruction & CPR limit type 3

Figure E.3 Browns Ferry Unit 3 Cycle 18 Control Rod Pattern and Axial Distributions at 17,862.2 MWd/MTU