

NRR-PMDAPem Resource

From: Rankin, Jennivine
Sent: Monday, October 19, 2015 4:27 PM
To: Alan I Hassoun (hassouna@dteenergy.com)
Cc: Hardgrove, Matthew; Goetz, Sujata; RidsNRRLIC109 Resource
Subject: FERMI 2 - Acceptance Review for License Amendment to Revise TS 3.5.1, "ECCS - Operating" (CAC No. MF6757)

Mr. Hassoun,

By letter dated September 24, 2015 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML15268A422), DTE Electric Company submitted a license amendment request (LAR) for Fermi 2. The proposed LAR would delete the note associated with Surveillance Requirement 3.5.1.4 to reflect the Residual Heat Removal (RHR) system design and ensure the RHR system operation is consistent with Technical Specification (TS) section 3.5.1 Limiting Condition for Operation requirements.

The purpose of this e-mail is to provide the results of the U.S. Nuclear Regulatory Commission (NRC) staff's acceptance review of this LAR. The acceptance review was performed to determine if there is sufficient technical information in scope and depth to allow the NRC staff to complete its detailed technical review. The acceptance review is also intended to identify whether the application has any readily apparent information insufficiencies in its characterization of the regulatory requirements or the licensing basis of the plant.

Consistent with Section 50.90 of Title 10 of the *Code of Federal Regulations* (10 CFR), an amendment to the license (including the TS) must fully describe the changes requested, and following as far as applicable, the form prescribed for original applications. Section 50.34 of 10 CFR addresses the content of technical information required. This section stipulates that the submittal address the design and operating characteristics, unusual or novel design features, and principal safety considerations.

The NRC staff has reviewed your application and concluded that it does provide technical information in sufficient detail to enable the NRC staff to complete its detailed technical review and make an independent assessment regarding the acceptability of the proposed amendment in terms of regulatory requirements and the protection of public health and safety and the environment. Given the lesser scope and depth of the acceptance review as compared to the detailed technical review, there may be instances in which issues that impact the NRC staff's ability to complete the detailed technical review are identified despite completion of an adequate acceptance review. If additional information is needed for the staff to complete its technical review, you will be advised by separate correspondence.

If you have any questions, please contact me at (301) 415-1530.

Thanks,
Jennie

Jennie Rankin, Project Manager
Plant Licensing Branch III-1
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Hearing Identifier: NRR_PMDA
Email Number: 2468

Mail Envelope Properties (Jennivine.Rankin@nrc.gov20151019162600)

Subject: FERMI 2 - Acceptance Review for License Amendment to Revise TS 3.5.1, "ECCS - Operating" (CAC No. MF6757)
Sent Date: 10/19/2015 4:26:52 PM
Received Date: 10/19/2015 4:26:00 PM
From: Rankin, Jennivine

Created By: Jennivine.Rankin@nrc.gov

Recipients:

"Hardgrove, Matthew" <Matthew.Hardgrove@nrc.gov>

Tracking Status: None

"Goetz, Sujata" <Sujata.Goetz@nrc.gov>

Tracking Status: None

"RidsNRRLIC109 Resource" <RidsNRRLIC109.Resource@nrc.gov>

Tracking Status: None

"Alan I Hassoun (hassouna@dteenergy.com)" <hassouna@dteenergy.com>

Tracking Status: None

Post Office:

Files	Size	Date & Time
MESSAGE	2601	10/19/2015 4:26:00 PM

Options

Priority: Standard

Return Notification: No

Reply Requested: No

Sensitivity: Normal

Expiration Date:

Recipients Received: