

KHNPDCDRAIsPEm Resource

From: Ciocco, Jeff
Sent: Thursday, August 13, 2015 10:58 AM
To: KHNPDCDRAIsPEm Resource
Subject: FW: APR1400 Design Certification Application RAI 107-8039 (18 - Human Factors Engineering)
Attachments: APR1400 DC RAI 107 COLB 8039.pdf

From: Ciocco, Jeff
Sent: Thursday, July 23, 2015 9:11 AM
To: apr1400rai@khnp.co.kr; KHNPDCDRAIsPEm Resource <KHNPDCDRAIsPEm.Resource@nrc.gov>; Harry (Hyun Seung) Chang <hyunseung.chang@gmail.com>; Yunho Kim <yshh8226@gmail.com>; erin.wisler@aecom.com
Cc: Pieringer, Paul <Paul.Pieringer@nrc.gov>; Junge, Michael <Michael.Junge@nrc.gov>; Ward, William <William.Ward@nrc.gov>; Lee, Samuel <Samuel.Lee@nrc.gov>
Subject: APR1400 Design Certification Application RAI 107-8039 (18 - Human Factors Engineering)

KHNP

The attachment contains the subject request for additional information (RAI). This RAI was sent to you in draft form. Your licensing review schedule assumes technically correct and complete responses within 30 days of receipt of RAIs. However, KHNP requests, and we grant, the following days to respond to the RAI's questions. We may adjust the schedule accordingly.

18-11: 45 days

18-12: 60 days

Please submit your RAI response to the NRC Document Control Desk.

Thank you,

Jeff Ciocco
New Nuclear Reactor Licensing
301.415.6391
jeff.ciocco@nrc.gov



Hearing Identifier: KHNP_APR1400_DCD_RAI_Public
Email Number: 188

Mail Envelope Properties (5db152e37e324dae94b8c965d968dcb1)

Subject: FW: APR1400 Design Certification Application RAI 107-8039 (18 - Human Factors Engineering)
Sent Date: 8/13/2015 10:58:13 AM
Received Date: 8/13/2015 10:58:14 AM
From: Ciocco, Jeff

Created By: Jeff.Ciocco@nrc.gov

Recipients:
"KHNPDCDRAIsPEm Resource" <KHNPDCDRAIsPEm.Resource@nrc.gov>
Tracking Status: None

Post Office: HQPWMSMRS08.nrc.gov

Files	Size	Date & Time
MESSAGE	1207	8/13/2015 10:58:14 AM
APR1400 DC RAI 107 COLB 8039.pdf		91909
image001.jpg	5056	

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

REQUEST FOR ADDITIONAL INFORMATION 107-8039

Issue Date: 07/23/2015
Application Title: APR1400 Design Certification Review – 52-046
Operating Company: Korea Hydro & Nuclear Power Co. Ltd.
Docket No. 52-046
Review Section: 18 - Human Factors Engineering
Application Section: Staffing and Qualification

QUESTIONS

18-11

Regulation: Title 10 CFR 50.54(m)(2) specifies staffing requirements to be met by a nuclear power plant licensee.

Evaluation: APR1400-K-I-NR-14005, Rev. 0, Section 4.3.1, "Initial S&Q Assumption" states that the initial S&Q assumption meets the minimum manning requirements of 10 CFR 50.54. This appears to conflict with a second statement in the same section that says the initial staffing assumption is based on the staffing constraint of the HFE program plan. APR1400-E-I-NR-14001, Rev. 0, "Human Factors Engineering Program Plan," Section 4.1, Assumptions and Constraints," lists the control room positions. This list is one Senior Reactor Operator short of minimum manning requirements identified in 10 CFR 50.54.

The S&Q Implementation Plan is also not clear whether the subsequent S&Q analysis could result in control room staffing levels less than the regulatory requirements

Question: Clarify whether minimum control room manning will conform to 50.54(m)(2).

18-12

Evaluation: NUREG-0711, Section 6.4, Criterion 6 lists specific staffing-related issues that should be considered in the staffing and qualification analysis. The staff did not find mention of the following items in the sections identified by the conformance table or in the associated implementation plans.

Operating Experience

- initial staffing goals and their bases, including staffing levels of predecessor designs and a description of significant similarities and differences between predecessor and current designs
- possible impact on staffing of requirements of limits to work hours, required break times, and required days off, as specified in 10 CFR 26.205, Work Hours, as part of the Fitness for Duty Rule
- Regulatory Issue Summary (RIS) 2009-10, Communications Between the NRC and Reactor Licensees During Emergencies and Significant Events

Task Analysis

- staffing considerations described by the application of ANSI/ANS 58.8-1994, "Time Response Design Criteria for Safety-Related Operator Actions" (ANS, 1994), if used by the applicant

Treatment of Important Human Action

- NUREG/CR-6753, Review of Findings for Human Performance Contribution to Risk in Operating Events

REQUEST FOR ADDITIONAL INFORMATION 107-8039

Question: Explain how these issues are used in the staffing analysis. If they are not used, explain why.



U.S.NRC

United States Nuclear Regulatory Commission

Protecting People and the Environment