

KHNPDCDRAIsPEm Resource

From: Ciocco, Jeff
Sent: Thursday, October 22, 2015 7:09 AM
To: apr1400rai@khnp.co.kr; KHNPDCDRAIsPEm Resource; Harry (Hyun Seung) Chang; Andy Jiyong Oh; Christopher Tyree
Cc: Gran, Zachary; McCoppin, Michael; Olson, Bruce; Lee, Samuel
Subject: APR1400 Design Certification Application RAI 262-8296 (11.05 - Process and Effluent Radiological Monitoring Instrumentation and Sampling Systems)
Attachments: APR1400 DC RAI 262 RPAC 8296.pdf

KHNP,

The attachment contains the subject request for additional information (RAI). This RAI was sent to you in draft form. Your licensing review schedule assumes technically correct and complete responses within 30 days of receipt of RAIs.

Please submit your RAI response to the NRC Document Control Desk.

Thank you,

Jeff Ciocco
New Nuclear Reactor Licensing
301.415.6391
jeff.ciocco@nrc.gov



Hearing Identifier: KHNP_APR1400_DCD_RAI_Public
Email Number: 310

Mail Envelope Properties (ef21d37b34454f15913360a373972049)

Subject: APR1400 Design Certification Application RAI 262-8296 (11.05 - Process and Effluent Radiological Monitoring Instrumentation and Sampling Systems)
Sent Date: 10/22/2015 7:08:57 AM
Received Date: 10/22/2015 7:08:57 AM
From: Ciocco, Jeff

Created By: Jeff.Ciocco@nrc.gov

Recipients:

"Gran, Zachary" <Zachary.Gran@nrc.gov>
Tracking Status: None
"McCoppin, Michael" <Michael.McCoppin@nrc.gov>
Tracking Status: None
"Olson, Bruce" <Bruce.Olson@nrc.gov>
Tracking Status: None
"Lee, Samuel" <Samuel.Lee@nrc.gov>
Tracking Status: None
"apr1400rai@khnp.co.kr" <apr1400rai@khnp.co.kr>
Tracking Status: None
"KHNPDCDRAIsPEM Resource" <KHNPDCDRAIsPEM.Resource@nrc.gov>
Tracking Status: None
"Harry (Hyun Seung) Chang" <hyunseung.chang@gmail.com>
Tracking Status: None
"Andy Jiyong Oh" <jiyong.oh5@gmail.com>
Tracking Status: None
"Christopher Tyree" <Christopher.tyree@aecom.com>
Tracking Status: None

Post Office: HQPWMSMRS07.nrc.gov

Files	Size	Date & Time
MESSAGE	498	10/22/2015 7:08:57 AM
APR1400 DC RAI 262 RPAC 8296.pdf	78280	
image001.jpg	5040	

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

REQUEST FOR ADDITIONAL INFORMATION 262-8296

Issue Date: 10/22/2015

Application Title: APR1400 Design Certification Review – 52-046

Operating Company: Korea Hydro & Nuclear Power Co. Ltd.

Docket No. 52-046

Review Section: 11.05 - Process and Effluent Radiological Monitoring Instrumentation and Sampling Systems

Application Section:

QUESTIONS

11.05-5

In DCD section 11.5.1.2.l, the applicant provides information concerning the offsite dose calculation manual (ODCM). In the discussion the applicant references COL item 11.5(5) when discussing the ODCM requirements. However upon review of the COL action items provided in 11.5.5 the staff finds that COL 11.5(4) discusses the ODCM. The staff request the applicant to address the discussion pertaining to the ODCM as seen in COL 11.5(4) in the text of section 11.5 and confirm the appropriate reference of COL 11.5(5) in DCD section 11.5.1.2.l.

Please address this item and provide a markup for the proposed DCD changes.

11.05-6

In DCD section 11.5.1.2.m, the applicant provides a discussion on the radiological and environmental monitoring program (REMP). In this discussion the applicant notes the description of COL item 11.5(7) but the staff does not find reference to COL item 11.5(9). The staff is requesting clarification in DCD section 11.5 that addresses information pertaining to the REMP and COL 11.5(9). The staff also requests that the applicant confirm the appropriate inclusion of COL items in the text of section 11.5.1.2.m.

Please address this item and provide a markup for the proposed DCD changes.



U.S.NRC

United States Nuclear Regulatory Commission

Protecting People and the Environment