

Jon A. Franke
Site Vice President

Susquehanna Nuclear, LLC
769 Salem Boulevard
Berwick, PA 18603
Tel. 570.542.2904 Fax 570.542.1504
jon.franke@talenergy.com



NOV 04 2015

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555-0001

**SUSQUEHANNA STEAM ELECTRIC STATION
SUBMITTAL OF REVISED UNIT 1 CYCLE 19 AND
UNIT 2 CYCLE 18 CORE OPERATING LIMITS REPORTS
PLA-7396**

**Docket No. 50-387
and 50-388**

Technical Specification Section 5.6.5 requires that the Core Operating Limits Report (COLR), including any mid-cycle supplements or revisions, be provided upon issuance to the NRC in accordance with 10 CFR 50.4. In compliance with this requirement, revisions to the Unit 1 Cycle 19 and Unit 2 Cycle 18 COLRs are provided in the attachments to this letter. The revisions provide new operating limits for one Turbine Stop Valve or one Turbine Control Valve closed.

There are no new or revised regulatory commitments contained in this submittal.

If you have any questions regarding this submittal, please contact
Mr. Jeffery N. Grisewood, Manager, Nuclear Regulatory Affairs, at (570) 542-1330.

A handwritten signature in dark ink, appearing to read "Jon Franke", written over a horizontal line.

Jon Franke

Attachment: Revised Unit 1 Cycle 19 COLR
Revised Unit 2 Cycle 18 COLR

Copy: NRC Region I
Mr. J. E. Greives, NRC Sr. Resident Inspector
Mr. M. Shields, PA DEP/BRP
Mr. J. A. Whited, NRC Project Manager

Attachment 1 to PLA-7396

Revised Unit 1 Cycle 19 COLR

Susquehanna SES Unit 1 Cycle 19

CORE OPERATING LIMITS REPORT

**Nuclear Fuels
Engineering**

September 2015

CORE OPERATING LIMITS REPORT REVISION DESCRIPTION INDEX		
Rev. No.	Affected Sections	Description/Purpose of Revision
0	ALL	Issuance of this COLR is in support of Unit 1 Cycle 19 operation.
1	ALL	New COLR required due to Power/Flow Map revision.
2	ALL	New COLR required for the inclusion of operating limits regarding a Turbine Stop Valve (TSV) or Turbine Control Valve (TCV) closure event.

**SUSQUEHANNA STEAM ELECTRIC STATION
Unit 1 Cycle 19
CORE OPERATING LIMITS REPORT**

Table of Contents

1.0	<u>INTRODUCTION</u>	4
2.0	<u>DEFINITIONS</u>	5
3.0	<u>SHUTDOWN MARGIN</u>	6
4.0	<u>AVERAGE PLANAR LINEAR HEAT GENERATION RATE (APLHGR)</u>	7
5.0	<u>MINIMUM CRITICAL POWER RATIO (MCPR)</u>	9
6.0	<u>LINEAR HEAT GENERATION RATE (LHGR)</u>	27
7.0	<u>ROD BLOCK MONITOR (RBM) SETPOINTS AND OPERABILITY REQUIREMENTS</u>	38
8.0	<u>RECIRCULATION LOOPS - SINGLE LOOP OPERATION</u>	40
9.0	<u>POWER / FLOW MAP</u>	58
10.0	<u>OPRM SETPOINTS</u>	60
11.0	<u>REFERENCES</u>	61

1.0 INTRODUCTION

This CORE OPERATING LIMITS REPORT for Susquehanna Unit 1 Cycle 19 is prepared in accordance with the requirements of Susquehanna Unit 1, Technical Specification 5.6.5. As required by Technical Specifications 5.6.5, core shutdown margin, the core operating limits, RBM setpoints, and OPRM setpoints presented herein were developed using NRC-approved methods and are established such that all applicable limits of the plant safety analysis are met.

2.0 DEFINITIONS

Terms used in this COLR but not defined in Section 1.0 of the Technical Specifications or Section 1.1 of the Technical Requirements Manual are provided below.

- 2.1 The AVERAGE PLANAR EXPOSURE at a specified height shall be equal to the total energy produced per unit length at the specified height divided by the total initial weight of uranium per unit length at that height.
- 2.2 The PELLET EXPOSURE shall be equal to the total energy produced per unit length of fuel rod at the specified height divided by the total initial weight of uranium per unit length of that rod at that height.
- 2.3 FDLRX is the ratio of the maximum LHGR calculated by the core monitoring system for each fuel bundle divided by the LHGR limit for the applicable fuel bundle type.
- 2.4 LHGRFAC_f is a multiplier applied to the LHGR limit when operating at less than 108 Mlbm/hr core flow. The LHGRFAC_f multiplier protects against both fuel centerline melting and cladding strain during anticipated system transients initiated from core flows less than 108 Mlbm/hr.
- 2.5 LHGRFAC_p is a multiplier applied to the LHGR limit when operating at less than RATED THERMAL POWER. The LHGRFAC_p multiplier protects against both fuel centerline melting and cladding strain during anticipated system transients initiated from partial power conditions.
- 2.6 MFLCPR is the ratio of the applicable MCPR operating limit for the applicable fuel bundle type divided by the MCPR calculated by the core monitoring system for each fuel bundle.
- 2.7 MAPRAT is the ratio of the maximum APLHGR calculated by the core monitoring system for each fuel bundle divided by the APLGHR limit for the applicable fuel bundle type.
- 2.8 OPRM is the Oscillation Power Range Monitor. The Oscillation Power Range Monitor (OPRM) will reliably detect and suppress anticipated stability related power oscillations while providing a high degree of confidence that the MCPR safety limit is not violated.
- 2.9 N_p is the OPRM setpoint for the number of consecutive confirmations of oscillation half-cycles that will be considered evidence of a stability related power oscillation.
- 2.10 S_p is the OPRM trip setpoint for the peak to average OPRM signal.
- 2.11 F_p is the core flow, in Mlbm / hr, below which the OPRM RPS trip is activated.

3.0 SHUTDOWN MARGIN

3.1 Technical Specification Reference

Technical Specification 3.1.1

3.2 Description

The SHUTDOWN MARGIN shall be equal to or greater than:

- a) 0.38% $\Delta k/k$ with the highest worth rod analytically determined

OR

- b) 0.28% $\Delta k/k$ with the highest worth rod determined by test

Since core reactivity will vary during the cycle as a function of fuel depletion and poison burnup, Beginning of Cycle (BOC) SHUTDOWN MARGIN (SDM) tests must also account for changes in core reactivity during the cycle. Therefore, the SDM measured at BOC must be equal to or greater than the applicable requirement from either 3.2.a or 3.2.b plus an adder, "R". The adder, "R", is the difference between the calculated value of maximum core reactivity (that is, minimum SDM) during the operating cycle and the calculated BOC core reactivity. If the value of "R" is zero (that is, BOC is the most reactive point in the cycle) no correction to the BOC measured value is required.

The SHUTDOWN MARGIN limits provided in 3.2a and 3.2b are applicable in MODES 1, 2, 3, 4, and 5. This includes core shuffling.

4.0 AVERAGE PLANAR LINEAR HEAT GENERATION RATE (APLHGR)

4.1 Technical Specification Reference


Technical Specification 3.2.1

4.2 Description

The APLHGRs for ATRIUMTM-10 fuel shall not exceed the limit shown in Figure 4.2-1.

The APLHGR limits in Figure 4.2-1 are valid for Main Turbine Bypass Operable and Inoperable, EOC-RPT Operable and Inoperable, and Backup Pressure Regulator Operable and Inoperable in Two Loop operation. The APLHGR limits for Single Loop operation are provided in Section 8.0.

SSSES UNIT 1 CYCLE 19



AVERAGE PLANAR LINEAR HEAT GENERATION RATE LIMIT VERSUS
AVERAGE PLANAR EXPOSURE - TWO LOOP OPERATION
ATRIUM™-10 FUEL
FIGURE 4.2-1

5.0 MINIMUM CRITICAL POWER RATIO (MCPR)

5.1 Technical Specification Reference

Technical Specification 3.2.2, 3.3.4.1, 3.7.6, and 3.7.8

5.2 Technical Requirements Manual Reference

Technical Requirements Manual 3.3.7

5.3 Description

The MCPR limit is specified as a function of core power, core flow, average scram insertion time per Section 5.3 and plant equipment operability status. The MCPR limits for all fuel types (ATRIUM™-10) shall be the greater of the Flow-Dependent or the Power-Dependent MCPR, depending on the applicable equipment operability status.

a) Main Turbine Bypass / EOC-RPT / Backup Pressure Regulator Operable

Figure 5.2-1: Flow-Dependent MCPR value determined from BOC to EOC

Figure 5.2-2: Power-Dependent MCPR value determined from BOC to EOC

b) Main Turbine Bypass Inoperable

Figure 5.2-3: Flow-Dependent MCPR value determined from BOC to EOC

Figure 5.2-4: Power-Dependent MCPR value determined from BOC to EOC

c) EOC-RPT Inoperable

Figure 5.2-5: Flow-Dependent MCPR value determined from BOC to EOC

Figure 5.2-6: Power-Dependent MCPR value determined from BOC to EOC

d) Backup Pressure Regulator Inoperable

Figure 5.2-7: Flow-Dependent MCPR value determined from BOC to EOC

Figure 5.2-8: Power Dependent MCPR value determined from BOC to EOC

e) One Turbine Stop Valve (TSV) or Turbine Control Valve (TCV) Closed

Figure 5.2-9: Flow-Dependent MCPR value determined from BOC to EOC

Figure 5.2-10: Power-Dependent MCPR value determined from BOC to EOC

The MCPR limits in Figures 5.2-1 through 5.2-10 are valid for Two Loop operation.

The MCPR limits for Single Loop operation are provided in Section 8.0.

5.4 Average Scram Time Fraction

If the average measured scram times are greater than the Realistic Scram times listed in Table 5.3-1 then the MCPR operating limits corresponding to the Maximum Allowable Average Scram Insertion Time must be implemented. Determining MCPR operating limits based on interpolation between scram insertion times is not permitted. The evaluation of scram insertion time data, as it relates to the attached table should be performed per Reactor Engineering procedures.


Main Turbine Bypass / EOC-RPT / Backup Pressure Regulator Operable

SSSES UNIT 1 CYCLE 19

SUSQUEHANNA UNIT 1

TRM/3.2-13

EFFECTIVE DATE 11/04/2015




MCPR OPERATING LIMIT VERSUS TOTAL CORE FLOW
MAIN TURBINE BYPASS / EOC-RPT / BACKUP PRESSURE REGULATOR OPERABLE
TWO LOOP OPERATION (BOC TO EOC)
FIGURE 5.2-1

Rev. 16

PL-NF-14-001
Rev. 2

Page 12 of 62

SSSES UNIT 1 CYCLE 19



MCPR OPERATING LIMIT VERSUS CORE POWER
MAIN TURBINE BYPASS / EOC-RPT / BACKUP PRESSURE REGULATOR OPERABLE
TWO LOOP OPERATION (BOC TO EOC)
FIGURE 5.2-2

SUSQUEHANNA UNIT 1

TRM/3.2-14

EFFECTIVE DATE 11/04/2015

Rev. 16

PL-NF-14-001

Rev. 2

Page 13 of 62


Main Turbine Bypass Inoperable

SSES UNIT 1 CYCLE 19

SUSQUEHANNA UNIT 1

TRM/3.2-16

EFFECTIVE DATE 11/04/2015



MCPR OPERATING LIMIT VERSUS TOTAL CORE FLOW
MAIN TURBINE BYPASS INOPERABLE
TWO LOOP OPERATION (BOC TO EOC)
FIGURE 5.2-3

Rev. 16


PL-NF-14-001
Rev. 2
Page 15 of 62

SSSES UNIT 1 CYCLE 19

SUSQUEHANNA UNIT 1

TRM/3.2-17

EFFECTIVE DATE 11/04/2015



MCPR OPERATING LIMIT VERSUS CORE POWER
MAIN TURBINE BYPASS INOPERABLE
TWO LOOP OPERATION (BOC to EOC)
FIGURE 5.2-4

Rev. 16

PL-NF-14-001
Rev. 2
Page 16 of 62


EOC-RPT Inoperable

SSSES UNIT 1 CYCLE 19

SUSQUEHANNA UNIT 1

TRM/3.2-19

EFFECTIVE DATE 11/04/2015



MCPR OPERATING LIMIT VERSUS TOTAL CORE FLOW
EOC-RPT INOPERABLE
TWO LOOP OPERATION (BOC TO EOC)
FIGURE 5.2-5

Rev. 16


PL-NF-14-001
Rev. 2
Page 18 of 62

SSS UNIT 1 CYCLE 19

SUSQUEHANNA UNIT 1

TRM/3.2-20

EFFECTIVE DATE 11/04/2015




MCPR OPERATING LIMIT VERSUS CORE POWER
EOC-RPT INOPERABLE
TWO LOOP OPERATION (BOC to EOC)
FIGURE 5.2-6

Rev. 16

PL-NF-14-001
Rev. 2
Page 19 of 62

Backup Pressure Regulator Inoperable




MCPR OPERATING LIMIT VERSUS TOTAL CORE FLOW
 BACKUP PRESSURE REGULATOR INOPERABLE
 TWO LOOP OPERATION (BOC TO EOC)
 FIGURE 5.2-7

SSS UNIT 1 CYCLE 19

SUSQUEHANNA UNIT 1

TRM/3.2-23

EFFECTIVE DATE 11/04/2015




MCPR OPERATING LIMIT VERSUS CORE POWER
BACKUP PRESSURE REGULATOR INOPERABLE
TWO LOOP OPERATION (BOC to EOC)
FIGURE 5.2-8

Rev. 16

One TSV or TCV Closed

SSS UNIT 1 CYCLE 19




MCPR OPERATING LIMIT VERSUS TOTAL CORE FLOW
ONE TSV OR TCV CLOSED*
TWO LOOP OPERATION (BOC TO EOC)

FIGURE 5.2-9

*Operation with one TSV or TCV closed is only supported at power levels $\leq 75\%$ rated power.

SSSES UNIT 1 CYCLE 19



MCPR OPERATING LIMIT VERSUS CORE POWER
ONE TSV OR TCV CLOSED
TWO LOOP OPERATION (BOC TO EOC)
FIGURE 5.2-10

SUSQUEHANNA UNIT 1

TRM/3.2-26

EFFECTIVE DATE 11/04/2015

Rev. 16

PL-NF-14-001
Rev. 2

Page 25 of 62

Table 5.3-1

**Average Scram Time Fraction Table For Use With Scram Time Dependent
MCPR Operating Limits**

Control Rod Position	Average Scram Time to Position (seconds)		
45	0.470		0.520
39	0.630		0.860
25	1.500		1.910
5	2.700		3.440
Average Scram Insertion Time	Realistic		Maximum Allowable

6.0 LINEAR HEAT GENERATION RATE (LHGR)

6.1 Technical Specification Reference

Technical Specification 3.2.3, 3.3.4.1, 3.7.6, and 3.7.8

6.2 Technical Requirements Manual Reference

Technical Requirements Manual 3.3.7

6.3 Description

The maximum LHGR for ATRIUM™-10 fuel shall not exceed the LHGR limit determined from Figure 6.2-1. The LHGR limit in Figure 6.2-1 is valid for Main Turbine Bypass Operable and Inoperable, EOC-RPT Operable and Inoperable, and Backup Pressure Regulator Operable and Inoperable.

To protect against both fuel centerline melting and cladding strain during anticipated system transients initiated from reduced power and flow conditions, power and flow dependent LHGR limit multipliers are provided in the following figures:

a) Main Turbine Bypass Operable

Figure 6.2-2: Flow-Dependent LHGR Limit Multiplier

Figure 6.2-3: Power-Dependent LHGR Limit Multiplier

b) Main Turbine Bypass Inoperable

Figure 6.2-4: Flow-Dependent LHGR Limit Multiplier

Figure 6.2-5: Power-Dependent LHGR Limit Multiplier

c) One Turbine Stop Valve (TSV) or Turbine Control Valve (TCV) Closed


Figure 6.2-6: Flow-Dependent LHGR Limit Multiplier

Figure 6.2-7: Power-Dependent LHGR Limit Multiplier

The LHGR limits and LHGR limit multipliers in Figures 6.2-2 and 6.2-3 are applicable to EOC-RPT Operable and Inoperable and Backup Pressure Regulator Operable and Inoperable.

The LHGR limits and LHGR limit multipliers in Figures 6.2-1 through 6.2-7 are valid for both Two Loop and Single Loop operation.


SSES UNIT 1 CYCLE 19



LINEAR HEAT GENERATION RATE LIMIT VERSUS PELLET EXPOSURE
ATRIUM™-10 FUEL
FIGURE 6.2-1


Main Turbine Bypass Operable

SSES UNIT 1 CYCLE 19




FLOW DEPENDENT LHGR LIMIT MULTIPLIER
MAIN TURBINE BYPASS OPERABLE
ATRIUM™-10 FUEL
FIGURE 6.2-2

SSES UNIT 1 CYCLE 19




POWER DEPENDENT LHGR LIMIT MULTIPLIER
MAIN TURBINE BYPASS OPERABLE
ATRIUM™-10 FUEL
FIGURE 6.2-3

Main Turbine Bypass Inoperable



FLOW DEPENDENT LHGR LIMIT MULTIPLIER
MAIN TURBINE BYPASS INOPERABLE
ATRIUM™-10 FUEL
FIGURE 6.2-4


SSSES UNIT 1 CYCLE 19



POWER DEPENDENT LHGR LIMIT MULTIPLIER
MAIN TURBINE BYPASS INOPERABLE
ATRIUM™-10 FUEL
FIGURE 6.2-5

One TSV or TCV Closed


SSES UNIT 1 CYCLE 19



FLOW DEPENDENT LHGR LIMIT MULTIPLIER
ONE TSV OR TCV CLOSED*
ATRIUM™-10 FUEL
FIGURE 6.2-6

*Operation with one TSV or TCV closed is only supported at power levels $\leq 75\%$ rated power.

SSES UNIT 1 CYCLE 19



POWER DEPENDENT LHGR LIMIT MULTIPLIER
ONE TSV OR TCV CLOSED
ATRIUM™-10 FUEL
FIGURE 6.2-7

7.0 **ROD BLOCK MONITOR (RBM) SETPOINTS AND OPERABILITY REQUIREMENTS**

7.1 Technical Specification Reference

Technical Specification 3.3.2.1

7.2 Description

The RBM Allowable Value and Trip Setpoints for;

- a) Low Power Range Setpoint,
- b) Intermediate Power Range Setpoint,
- c) High Power Range Setpoint,
- d) Low Power Range - Upscale,
- e) Intermediate Power Range - Upscale, and
- f) High Power Range - Upscale

shall be established as specified in Table 7.2-1. The RBM setpoints are valid for Two Loop and Single Loop Operation, Main Turbine Bypass Operable and Inoperable, EOC-RPT Operable and Inoperable, and Backup Pressure Regulator Operable and Inoperable.

The RBM system design objective is to block erroneous control rod withdrawal initiated by the operator before fuel design limits are violated. If the full withdrawal of any control rod would not violate a fuel design limit, then the RBM system is not required to be operable. Table 7.2-2 provides RBM system operability requirements to ensure that fuel design limits are not violated.

Table 7.2-1
RBM Setpoints

Function	Allowable Value ⁽¹⁾	Nominal Trip Setpoint
Low Power Range Setpoint	28.0	24.9
Intermediate Power Range Setpoint	63.0	61.0
High Power Range Setpoint	83.0	81.0
Low Power Range - Upscale	123.4	123.0
Intermediate Power Range - Upscale	117.4	117.0
High Power Range - Upscale	107.6	107.2

- ⁽¹⁾ Power setpoint function (Low, Intermediate, and High Power Range Setpoints) determined in percent of RATED THERMAL POWER. Upscale trip setpoint function (Low, Intermediate, and High Power Range - Upscale) determined in percent of reference level.

Table 7.2-2
RBM System Operability Requirements

Thermal Power (% of Rated)	MCPR ^(2,3)
≥ 28 and < 90	< 1.76
≥ 90 and < 95	< 1.47
≥ 95	< 1.70

- ⁽²⁾ Applicable to Main Turbine Bypass Operable and Inoperable, EOC-RPT Operable and Inoperable, and Backup Pressure Regulator Operable and Inoperable.

- ⁽³⁾ Applicable to both Two Loop and Single Loop Operation.

8.0 RECIRCULATION LOOPS - SINGLE LOOP OPERATION

8.1 Technical Specification Reference

Technical Specification 3.2.1, 3.2.2, 3.2.3, 3.3.4.1, 3.4.1, 3.7.6, and 3.7.8

8.2 Technical Requirements Manual Reference

Technical Requirements Manual 3.3.7

8.3 Description

APLHGR

The APLHGR limit for ATRIUM™-10 fuel shall be equal to the APLHGR Limit from Figure 8.2-1.

The APLHGR limits in Figure 8.2-1 are valid for Main Turbine Bypass Operable and Inoperable, EOC-RPT Operable and Inoperable, and Backup Pressure Regulator Operable and Inoperable in Single Loop operation.

Minimum Critical Power Ratio Limit

The MCPR limit is specified as a function of core power, core flow, and plant equipment operability status. The MCPR limits for all fuel types (ATRIUM™-10) shall be the greater of the Flow-Dependent or the Power-Dependent MCPR, depending on the applicable equipment operability status.

a) Main Turbine Bypass / EOC-RPT / Backup Pressure Regulator Operable

Figure 8.2-2: Flow-Dependent MCPR value determined from BOC to EOC

Figure 8.2-3: Power-Dependent MCPR value determined from BOC to EOC

b) Main Turbine Bypass Inoperable

Figure 8.2-4: Flow-Dependent MCPR value determined from BOC to EOC

Figure 8.2-5: Power-Dependent MCPR value determined from BOC to EOC

c) EOC-RPT Inoperable

Figure 8.2-6: Flow-Dependent MCPR value determined from BOC to EOC

Figure 8.2-7: Power-Dependent MCPR value determined from BOC to EOC

d) Backup Pressure Regulator Inoperable

Figure 8.2-8: Flow-Dependent MCPR value determined from BOC to EOC

Figure 8.2-9: Power-Dependent MCPR value determined from BOC to EOC

e) One Turbine Stop Valve (TSV) or Turbine Control Valve (TCV) Closed

Figure 8.2-10: Flow-Dependent MCPR value determined from BOC to EOC

Figure 8.2-11: Power-Dependent MCPR value determined from BOC to EOC

The MCPR limits in Figures 8.2-2 through 8.2-11 are valid only for Single Loop operation.

Linear Heat Generation Rate Limit

The LHGR limits for Single Loop Operation are defined in Section 6.0.

RBM Setpoints and Operability Requirements


The RBM setpoints and operability requirements for Single Loop Operation are defined in Section 7.0.

SSSES UNIT 1 CYCLE 19

SUSQUEHANNA UNIT 1

TRM/3.2-43

EFFECTIVE DATE 11/04/2015



AVERAGE PLANAR LINEAR HEAT GENERATION RATE LIMIT VERSUS
AVERAGE PLANAR EXPOSURE - SINGLE LOOP OPERATION
ATRIUM™-10 FUEL
FIGURE 8.2-1

Rev. 16

PL-NF-14-001
Rev. 2

Page 42 of 62


Main Turbine Bypass / EOC-RPT / Backup Pressure Regulator Operable

SSS UNIT 1 CYCLE 19

SUSQUEHANNA UNIT 1

TRM/3.2-45

EFFECTIVE DATE 11/04/2015



MCPR OPERATING LIMIT VERSUS TOTAL CORE FLOW
MAIN TURBINE BYPASS / EOC-RPT / BACKUP PRESSURE REGULATOR OPERABLE
SINGLE LOOP OPERATION (BOC to EOC)
FIGURE 8.2-2

Rev. 16


PL-NF-14-001
Rev. 2
Page 44 of 62

SSSES UNIT 1 CYCLE 19

SUSQUEHANNA UNIT 1

TRM/3.2-46

EFFECTIVE DATE 11/04/2015



MCPR OPERATING LIMIT VERSUS CORE POWER
MAIN TURBINE BYPASS / EOC-RPT / BACKUP PRESSURE REGULATOR OPERABLE
SINGLE LOOP OPERATION (BOC to EOC)
FIGURE 8.2-3

Rev. 16

PL-NF-14-001
Rev. 2
Page 45 of 62


Main Turbine Bypass Inoperable

SSS UNIT 1 CYCLE 19

SUSQUEHANNA UNIT 1

TRM/3.2-48

EFFECTIVE DATE 11/04/2015



MCPR OPERATING LIMIT VERSUS TOTAL CORE FLOW
MAIN TURBINE BYPASS INOPERABLE
SINGLE LOOP OPERATION (BOC to EOC)
FIGURE 8.2-4

Rev. 16


PL-NF-14-001
Rev. 2
Page 47 of 62

SSSES UNIT 1 CYCLE 19

SUSQUEHANNA UNIT 1

TRM/3.2-49

EFFECTIVE DATE 11/04/2015



MCPR OPERATING LIMIT VERSUS CORE POWER
MAIN TURBINE BYPASS INOPERABLE
SINGLE LOOP OPERATION (BOC to EOC)
FIGURE 8.2-5

Rev. 16

PL-NF-14-001
Rev. 2
Page 48 of 62


EOC-RPT Inoperable

SSS UNIT 1 CYCLE 19

SUSQUEHANNA UNIT 1

TRM/3.2-51

EFFECTIVE DATE 11/04/2015




MCPR OPERATING LIMIT VERSUS TOTAL CORE FLOW
 EOC-RPT INOPERABLE
 SINGLE LOOP OPERATION (BOC to EOC)
 FIGURE 8.2-6

Rev. 16

PL-NF-14-001
 Rev. 2
 Page 50 of 62

SSSES UNIT 1 CYCLE 19



MCPR OPERATING LIMIT VERSUS CORE POWER
EOC-RPT INOPERABLE
SINGLE LOOP OPERATION (BOC to EOC)
FIGURE 8.2-7

SUSQUEHANNA UNIT 1

TRM/3.2-52

EFFECTIVE DATE 11/04/2015


Rev. 16

PL-NF-14-001


Rev. 2

Page 51 of 62

Backup Pressure Regulator Inoperable



SSSES UNIT 1 CYCLE 19



MCPR OPERATING LIMIT VERSUS CORE POWER
BACKUP PRESSURE REGULATOR INOPERABLE
SINGLE LOOP OPERATION (BOC to EOC)
FIGURE 8.2-9

SUSQUEHANNA UNIT 1

TRM/3.2-55

EFFECTIVE DATE 11/04/2015


Rev. 16

PL-NF-14-001
Rev. 2

Page 54 of 62

One TSV or TCV Closed

SSS UNIT 1 CYCLE 19



MCPR OPERATING LIMIT VERSUS TOTAL CORE FLOW
ONE TSV OR TCV CLOSED*
SINGLE LOOP OPERATION (BOC to EOC)
FIGURE 8.2-10


*Operation with one TSV or TCV closed is only supported at power levels $\leq 75\%$ rated power.

SSSES UNIT 1 CYCLE 19

SUSQUEHANNA UNIT 1

TRM/3.2-58

EFFECTIVE DATE 11/04/2015



MCPR OPERATING LIMIT VERSUS CORE POWER
ONE TSV OR TCV CLOSED
SINGLE LOOP OPERATION (BOC to EOC)
FIGURE 8.2-11

Rev. 16

PL-NF-14-001
Rev. 2
Page 57 of 62

9.0 POWER / FLOW MAP

9.1 Technical Specification Reference

Technical Specification 3.3.1.1

9.2 Description

Monitor reactor conditions to maintain THERMAL POWER / core flow outside of Stability Regions I and II of the Power / Flow map, Figure 9.1.

If the OPRM Instrumentation is OPERABLE per TS 3.3.1.1, Region I of the Power / Flow map is considered an immediate exit region.

If the OPRM Instrumentation is inoperable per TS 3.3.1.1, Region I of the Power / Flow map is considered an immediate scram region.

Region II of the Power / Flow map is considered an immediate exit region regardless of the operability of the OPRM Instrumentation.




Figure 9.1
SSES Unit 1 Cycle 19 Power / Flow Map

10.0 OPRM SETPOINTS

10.1 Technical Specification Reference

Technical Specification 3.3.1.1

10.2 Description

Setpoints for the OPRM Instrumentation are established that will reliably detect and suppress anticipated stability related power oscillations while providing a high degree of confidence that the MCPR Safety limit is not violated. The setpoints are described in Section 2.0 and are listed below:

$$S_P = 1.11$$

$$N_P = 15$$

$$F_P = 60 \text{ Mlbm / hr}$$

11.0 REFERENCES

- 11.1 The analytical methods used to determine the core operating limits shall be those previously reviewed and approved by the NRC, specifically those described in the following documents:
1. XN-NF-81-58(P)(A), Revision 2 and Supplements 1 and 2, "RODEX2 Fuel Rod Thermal-Mechanical Response Evaluation Model," Exxon Nuclear Company, March 1984.
 2. EMF-2361(P)(A), Revision 0, "EXEM BWR-2000 ECCS Evaluation Model," Framatome ANP, May 2001.
 3. EMF-2292(P)(A), Revision 0, "ATRIUM™-10: Appendix K Spray Heat Transfer Coefficients," Siemens Power Corporation, September 2000.
 4. XN-NF-84-105(P)(A), Volume 1 and Volume 1 Supplements 1 and 2, "XCOBRA-T: A Computer Code for BWR Transient Thermal-Hydraulic Core Analysis," Exxon Nuclear Company, February 1987.
 5. XN-NF-80-19(P)(A), Volume 1 and Supplements 1 and 2, "Exxon Nuclear Methodology for Boiling Water Reactors: Neutronic Methods for Design and Analysis," Exxon Nuclear Company, March 1983.
 6. XN-NF-80-19(P)(A), Volumes 2, 2A, 2B, and 2C "Exxon Nuclear Methodology for Boiling Water Reactors: EXEM BWR ECCS Evaluation Model," Exxon Nuclear Company, September 1982.
 7. XN-NF-80-19(P)(A), Volume 3 Revision 2 "Exxon Nuclear Methodology for Boiling Water Reactors Thermex: Thermal Limits Methodology Summary Description," Exxon Nuclear Company, January 1987.
 8. XN-NF-80-19(P)(A), Volume 4, Revision 1, "Exxon Nuclear Methodology for Boiling Water Reactors: Application of the ENC Methodology to BWR Reloads," Exxon Nuclear Company, June 1986.
 9. XN-NF-85-67(P)(A), Revision 1, "Generic Mechanical Design for Exxon Nuclear Jet Pump BWR Reload Fuel," Exxon Nuclear Company, Inc., September 1986.
 10. ANF-524(P)(A), Revision 2 and Supplements 1 and 2, "Advanced Nuclear Fuels Corporation Critical Power Methodology for Boiling Water Reactors," November 1990.
 11. NE-092-001A, Revision 1, "Licensing Topical Report for Power Uprate With Increased Core Flow," Pennsylvania Power & Light Company, December 1992 and NRC SER (November 30, 1993).
 12. ANF-89-98(P)(A) Revision 1 and Supplement 1, "Generic Mechanical Design Criteria for BWR Fuel Designs," Advanced Nuclear Fuels Corporation, May 1995.

13. EMF-2209(P)(A), Revision 3, "SPCB Critical Power Correlation," AREVA NP, September 2009.
14. EMF-85-74(P)(A), Revision 0, Supplement 1(P)(A) and Supplement 2(P)(A), "RODEX2A (BWR) Fuel Rod Thermal-Mechanical Evaluation Model," Siemens Power Corporation, February 1998.
15. EMF-2158(P)(A), Revision 0, "Siemens Power Corporation Methodology for Boiling Water Reactors: Evaluation and Validation of CASMO-4/Microburn-B2," Siemens Power Corporation, October 1999.
16. EMF-CC-074(P)(A), Volume 4, Revision 0, "BWR Stability Analysis - Assessment of STAIF with Input from MICROBURN-B2," Siemens Power Corporation, August 2000.
17. NEDO-32465-A, "BWROG Reactor Core Stability Detect and Suppress Solutions Licensing Basis Methodology for Reload Applications," August 1996.
18. ANF-913(P)(A), Volume 1 Revision 1 and Volume 1 Supplements 2, 3, and 4, "COTRANSA2: A Computer Program for Boiling Water Reactor Transient Analyses," Advanced Nuclear Fuels Corporation, August 1990.
19. ANF-1358(P)(A), Revision 3, "The Loss of Feedwater Heating Transient in Boiling Water Reactors," Framatome ANP, September 2005.