



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

November 23, 2015

Mr. Mano Nazar
President and Chief Nuclear Officer
Nuclear Division
NextEra Energy
P.O. Box 14000
Juno Beach, FL 33408-0420

SUBJECT: ST. LUCIE PLANT, UNIT NOS. 1 AND 2 - REQUEST FOR ADDITIONAL INFORMATION RE: LICENSE AMENDMENT REQUEST FOR CHANGES TO THE REQUIRED ACTIONS FOR INOPERABILITY OF AUXILIARY FEEDWATER PUMPS (CAC NOS. MF6491 AND MF6492)

Dear Mr. Nazar:

By letter dated July 15, 2015 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML15198A028), Florida Power & Light Company (FPL or the licensee) requested changes to the technical specifications for the St. Lucie Plant, Unit Nos. 1 and 2. The proposed amendment would revise the required actions for inoperability of auxiliary feedwater pumps.

The U.S. Nuclear Regulatory Commission (NRC) staff reviewed the information provided by the licensee and determined that additional information is needed to complete the review of the subject license amendment request. A request for additional information (RAI) is enclosed.

A draft of this question was sent to Mr. Eric Katzman of your staff on November 4, 2015 (ADAMS Accession No. ML15309A226), with an opportunity to have a teleconference to ensure that FPL understands the question and its regulatory basis, as well as to verify that the information was not previously docketed.

By e-mail dated November 10, 2015 (ADAMS Accession No. ML15322A314), Mr. Ken Frehafer of your staff stated that a conference call was not necessary, and the staff agreed that FPL would respond to the RAI within 45 days of the date of this letter. Please note that if you do not respond to the RAI by the agreed upon date, the NRC staff may reject your license amendment request under the provisions of Title 10 of the *Code of Federal Regulations*, Section 2.108, "Denial of application for failure to supply information."

M. Nazar

- 2 -

If you have any questions, please contact me at (301) 415-1447 or Farideh.Saba@nrc.gov.

Sincerely,

A handwritten signature in black ink, appearing to read "Farideh E. Saba". The signature is fluid and cursive, with a large initial "F" and "S".

Farideh E. Saba, Senior Project Manager
Plant Licensing Branch II-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket Nos. 50-335 and 50-389

Enclosure:
Request for Additional Information

cc w/enclosure: Distribution via Listserv

REQUEST FOR ADDITIONAL INFORMATION
LICENSE AMENDMENT REQUEST FOR CHANGES TO
THE REQUIRED ACTIONS FOR INOPERABILITY OF AUXILIARY FEEDWATER PUMPS
FLORIDA POWER & LIGHT COMPANY
ST. LUCIE PLANT, UNIT NOS. 1 AND 2
DOCKET NOS. 50-335 AND 50-389

1.0 SCOPE

By letter dated July 15, 2015 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML15198A028), Florida Power & Light Company (FPL or the licensee) requested changes to the technical specifications (TSs) for the St. Lucie Plant, Unit Nos. 1 and Unit 2 (SL-1 and 2). The proposed amendment would revise the required actions for inoperability of auxiliary feedwater (AFW) pumps.

The U.S. Nuclear Regulatory Commission (NRC) staff has determined that additional information is required to complete its review.

2.0 REQUEST FOR ADDITIONAL INFORMATION

On June 22, 2015 (ADAMS Accession No. ML15127A066), the NRC issued Amendment No. 223 to Renewed Facility Operating License No. DPR-67 and Amendment No. 173 to Renewed Facility Operating License No. NPF-16 for SL-1 and 2, respectively. The amendments revised the SL-1 and 2 TSs by relocating specific surveillance frequencies to a licensee-controlled program. Amendment No. 223 for SL-1 replaced the surveillance requirements (SRs) of SR 4.7.1.2.a that stated, "At least once per 31 days by:" with, "In accordance with the Surveillance Frequency Control Program by:". Amendment No. 173 for SL-2 replaced the SRs of SR 4.7.1.2.a that stated, "At least once per 31 days by:" with, "In accordance with the Surveillance Frequency Control Program by:".

By letter dated July 15, 2015, FPL submitted the auxiliary feedwater pumps license amendment request. In Attachment 1, "Unit 1 Technical Specifications Page Markup"; Attachment 2, "Unit 2 Technical Specifications Page Markup"; Attachment 3, "Revised Unit 1 Technical Specifications Page"; and Attachment 4, "Revised Unit 2 Technical Specifications Page," FPL has the incorrect SR 4.7.1.2.a that does not reflect Amendment No. 223 for SL-1 and Amendment No. 173 for SL-2.

Please correct these errors.

Enclosure

M. Nazar

- 2 -

If you have any questions, please contact me at (301) 415-1447 or Farideh.Saba@nrc.gov.

Sincerely,

/RA by JLamb for/

Farideh E. Saba, Senior Project Manager
Plant Licensing Branch II-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket Nos. 50-335 and 50-389

Enclosure:
Request for Additional Information

cc w/enclosure: Distribution via Listserv

DISTRIBUTION:

PUBLIC
RidsNrrLABClayton Resource
RidsNrrDorlLpl2-2 Resource
MHamm, NRR
RidsACRS_MailCTR Resource
RidsNrrDorlDpr Resource

LPL2-2 r/f
RidsNrrDssScvb Resource
RidsRgn2MailCenter Resource
RidsNrrPMStLucie Resource
GBedi, NRR

ADAMS Accession No.: ML15308A615

OFFICE	NRR/DORL/LPL1-2/PM	NRR/DORL/LPL2-2/LA	NRR/DORL/LPL2-2/BC
NAME	JLamb	BClayton (LRonewicz for)	BBeasley
DATE	11/4/15	11/5/15	11/23/15
OFFICE	NRR/DORL/LPL2-2/PM		
NAME	FSaba (JLamb for)		
DATE	11/23/15		

OFFICIAL RECORD COPY