



International Isotopes Inc.

October 23, 2015

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555-0001

Subject: Response to NRC's June 22, 2015 Generic Letter 2015-01, *Treatment of Natural Phenomena Hazards in Fuel Cycle Facilities*

Docket No.: 40-9086

The purpose of this letter is to provide International Isotopes Fluorine Products Inc. (IIFP), a wholly owned subsidiary of International Isotopes Inc. (INIS) response to the U.S. Nuclear Regulatory Commission's (NRC) June 22, 2015 Generic Letter (GL) 2015-01.

The NRC requested in GL 2015-01 that licensees submit information to demonstrate compliance with regulatory requirements and applicable license conditions regarding the treatment of natural phenomena events in the facilities' integrated safety analysis (ISA). Specifically GL-2015-01 requests that all addresses take the following actions:

- (1) Within 90 days of the date of this letter, all addressees are requested to:
 - a. Submit the definitions of "unlikely," "highly unlikely," and "credible" in evaluating natural phenomena events in the ISA such as earthquakes, tornadoes, tornado missile impacts, floods, hurricanes, and other wind storms.
 - b. Submit a description of the licensee's safety assessment for the licensing and design basis natural phenomena events, including the following information:
 - i. likelihood and severity of the natural phenomena events, such as earthquakes, tornadoes, floods, hurricanes, and other wind storms
 - ii. accident sequences as a result of natural phenomena event impacts to facility structures and internal components
 - iii. assessment of the consequences for the accident sequences from item ii that result in intermediate and/or high consequence events
 - iv. items relied on for safety to prevent or mitigate the consequences of the events from items ii and iii
 - c. For facilities subject to 10 CFR Part 70, Subpart H requirements, submit a description of the results of the ISA review used to comply with 10 CFR 70.62(c). This requested documentation should have identified the characteristics of the licensing and design basis natural phenomena events applicable to the site. Additionally, the documentation should have evaluated possible changes in the methodology, likelihood, and severity of natural phenomena events with those used in the original design, evaluation, and licensing of the facility.

4137 Commerce Circle, Idaho Falls, Idaho 83401
Phone: 208-524-5300, 800-699-3108 Fax: 208-524-1411
Website: www.intisoid.com

MMSS33
MMSS

- d. Submit for staff review a summary of the results of any facility assessments or walk downs, if performed, to identify and address degraded, nonconforming, or unanalyzed conditions that can affect the performance of the facility under natural phenomena and have available for NRC inspection the documentation of the qualifications of the team

IIFP Response to (1) a.:

The definitions for “unlikely,” “highly unlikely,” and “credible” were provided in Chapter 3, Integrated Safety Analysis, Table 3-5 of the license application.

Table 3-1 Event Likelihood Categories

| Likelihood | Likelihood Category | Frequency or Probability of Occurrence |
|-------------------------|---------------------|--|
| Not Unlikely (Credible) | 3 | More than or equal to 10^{-4} per-event per-year |
| Unlikely (Credible) | 2 | Between 10^{-4} and 10^{-5} per-event per-year |
| Highly Unlikely | 1 | Less than or equal to 10^{-5} per-event per-year |

Detailed discussion is provided in Section 3.2.5.5. Natural phenomena hazards (NPH) considered for evaluation included, earthquakes, hurricanes (including topical storms), tornados (including tornado missiles and extreme straight wind), volcanoes, flooding, snow and ice and precipitation.

IIFP Response to (1) b. i.-iv:

The IIFP Facility will have five (5) process buildings or other structures that contain licensed material or have processes or materials potentially affecting licensed materials and that may have IROFS and related Systems, structures and components (SSCs). These process buildings are: 1) the Autoclave Process Building, 2) the DUF₆ to DUF₄ Process Building, 3) the FEP Process Building, 4) the DUF₄ Container Storage Building and 5) the FEP Oxide Storage Building.

The IIFP Facility design has been developed with natural phenomena hazards (NPH) considered such that if an external event should occur, the health and safety of the public and the workforce from licensed material or chemicals produced from licensed material are maintained. SSCs that are determined to be IROFS are designed to withstand the effects of, and be compatible with, the environmental conditions associated with the IIFP Facility operation, maintenance, shutdown, testing and accidents for which the IROFS are required to function. Applicable federal, state and local codes and standards will be used by IIFP and the Design/Build Contractor during detailed design, engineering and construction of the IIFP Facility to ensure protection of the safety and health of the workers and the public. A listing of those codes and standards is provided above in Section 3.1.5 of the Chapter 3, Integrated Safety Analysis of the License Application (LA).

Discussions of natural phenomena hazards relative to extreme weather and related hazard assessments and design bases are provided in the IIFP LA Revision B: 1) Chapter 1 Section 1.7.3.3 and the ISA Summary Section 1.3.2.3 for extreme winds, including tornadoes and

straight winds, 2) the ISA Summary Section 1.3.2.6 and Chapter 1 Sections 1.7.3.3 and 1.7.3.4 for floods, 3) the ISA Summary Section 1.3.2.7 and Chapter 1 Section 1.7.3.3 for snow and 4) Chapter 1 Section 1.7.3.3 for lightning.

IIFP will follow the guidance in DOE-STD-1020-2002 to determine seismic design criteria for IROFS including the process buildings. The process buildings will be designed based on, and consistent with, the methods outlined in DOE-STD-1020-2002. By definition, DOE Performance Category 3 (PC-3) buildings and other structures are buildings and other common structures not classified as PC-4 structures but do contain sufficient quantities of toxic or explosive substances to be dangerous to the public if released. PC-4 SSCs are designated as "reactor like" in that the quantity of hazardous material and energy is similar to a large Category A reactor ($>200\text{MW}_t$). For the purposes of evaluating risks and determining design basis criteria relative to NPH events, IIFP conservatively used DOE-STD-1020-2002 and the equivalent PC-3 category for the IIFP process buildings and other structures containing licensed material or for process buildings containing processes or materials potentially affecting licensed materials. DOE-1020-2002 outlines a methodology to demonstrate compliance to a target performance goal of 1×10^{-4} annual probability for a PC-3 facility by designing to a seismic hazard of 4×10^{-4} annual probability. The difference between the design level and the performance target is accounted for in the detailed design process by using a risk reduction factor of 4. The risk reduction factor is obtained through conservatism in the design as detailed in Appendix "C" of DOE-1020-2002.

The design basis earthquake (DBE) for the IIFP process buildings that are assumed to withstand seismic events has been selected as the 2,500-year return period earthquake. IIFP will apply, at a minimum, the risk reduction factor of 4 to achieve the PC-3 performance goal of 1×10^{-4} . Therefore, consistent with guidance in NUREG-1520 Revision 1, using the DOE-STD-1020-2002 standard approach will satisfy the "highly unlikely" requirement for accidents caused by the bounding NPH that involves a building collapse or a structural deformation that may compromise the effective function of an IROFS SSC. In this approach, the affected process building designs that prevent the accident as an engineered feature for reducing the likelihood of the consequences of the NPH event are designated as IROFS.

The process buildings and the IROFS within those buildings will be designed and maintained and will have management measures to remain available and reliable during any of the postulated NPH events. IIFP is committed to the use of management measures as stated in Section 3.1.3 of LA Chapter 3. The process buildings IROFS design integrity will be maintained using: 1) graded Quality Level 1 (QL-1) or Quality Level 2 (QL-2) requirements and 2) the management measures applied as described in Revision B of the IIFP Quality Assurance Program Description and in Chapter 11 Revision B of the IIFP License Application.

Accident sequences from a natural phenomenon events that result in intermediate and/or high consequence events are included in Tables 3-7, 3.8, and 3-9 of the ISA Summary and have been provided below.

| Accident Identifier | Description |
|---|--|
| 101.09 Solid DUF ₆ cylinder impacted by tornado missile | Missile generated by tornado event results in cylinder breach and release of DUF ₆ and HF. |
| 101.16 Design-basis earthquake | Earthquake causes multiple DUF ₆ cylinders and process equipment to breach and release of DUF ₆ and HF. |
| 102.38 Design-basis earthquake | NPH event causes DUF ₆ liquid release. |
| 103.30 Design-basis earthquake | NPH at DUF ₆ Autoclave Building causing release of process equipment vapor. |
| 104.30 Design-basis earthquake | NPH event at DUF ₄ to DUF ₆ Process Building causes DUF ₄ product storage bin or process equipment breach and release of DUF ₄ , DUF ₆ , HF and H ₂ . |
| 104.31 Design-basis earthquake | NPH event at DUF ₄ Container Storage Building. Multiple DUF ₄ drums stored in secondary containment box are damaged and leak/spill contents when containment box and drums are impacted by building structural member. |
| 106.51 Design-basis earthquake | NPH event at DUF ₄ Process Building causes HF Recovery system process equipment breach and release of liquid/vapor HF and H ₂ . |
| 107.19 Design-basis earthquake | NPH event at DUF ₄ Process Building causes dust collection system process equipment breach and release of uranium particulates. |
| 201.44 Design-basis earthquake | NPH event at FEP Process Building causes calciner process equipment breach and release of uranium particulates, SiF ₄ and HF. |
| 202.28 Design-basis earthquake | NPH event at FEP Process Building causes oxide collection system process equipment breach and UO ₂ , SiO ₂ , SiF ₄ and HF release. |
| 204.70 Design-basis earthquake | NPH event at FEP Process Building causes SiF ₄ collection system process equipment breach and SiF ₄ release. |
| 301.52 Design-basis earthquake | NPH event at FEP Process Building causes BF ₃ reaction system process equipment breach and UO ₂ , B ₂ O ₃ , BF ₃ and HF release. |
| 302.20 Design-basis earthquake | NPH event at FEP Process Building causes oxide collection system process equipment breach and UO ₂ , B ₂ O ₃ , BF ₃ and HF release. |
| 302.21 Multi-drums of oxide breached during NPH event | Multiple steel drums of oxide stored in the FEP Oxide Staging Building are damaged and leak/spill contents when impacted by building structural member. |

A reference list of IROFS was provided in Table 4.2 of the ISA Summary. Those IROFS associated with mitigating the consequences of an NPH event are provided below:

| IROFS Identifier | IROFS | IROFS Safety Function |
|------------------|--|--|
| DUF-60 | DUF ₆ Autoclave Building Design | Building structure and foundation is designed to withstand the design basis earthquake and the design integrity is maintained in accordance with the IIFP QAPD and Management Measures |
| DUF-61 | DUF ₆ to DUF ₄ Process Building Design | |
| DUF-62 | DUF ₄ Container Storage Building Design | |
| SF4-60 | FEP Process Building Design | |
| SF4-61 | FEP Oxide Staging Building Design | |
| APS-12 | Process Buildings Evacuation Procedure | Written procedure contains specific actions and workers are trained for evacuation in the event of natural hazard events including seismic event. |

The results of the Risk Assessment performed for each accident sequence identified in the Process Hazard Analysis as having Consequence Categories of 2 or 3 are summarized in Table 4-3, Table 4-4, Table 4-5 and Table 4-6 of the ISA Summary. The table below was developed from these tables.

| Accident Identifier | Initiating Event ⁽¹⁾ | U/C ⁽²⁾ | Likelihood ⁽³⁾⁽⁴⁾ | | Consequence ⁽⁵⁾ | | Risk Index ⁽⁶⁾ |
|--|--|--------------------|------------------------------|----------|----------------------------|----------|---------------------------|
| | | | Index | Category | Evaluation Number | Category | |
| 101.09 | Tornado-generated missile impact | U | -4 | 2 | DUF-CH-01 | 2 | 4 |
| Solid DUF ₆ cylinder damaged by tornado missile | | C | -4 | 2 | | 2 | 4 |
| 101.16 | NPH at Full Cylinder Storage Area | U | >-4 | 3 | DUF-CH-03 | 2 | 6 |
| A design-basis earthquake occurs | | C | -4 | 2 | | 2 | 4 |
| | | | C | -8 | 1 | | 3 |
| 102.38 | NPH at DUF ₆ Autoclave Building causes DUF ₆ release | U | >-4 | 3 | DUF-CH-04 | 3 | 9 |
| A design-basis earthquake occurs | | C | -5 | 1 | | 3 | 3 |

| Accident Identifier | Initiating Event ⁽¹⁾ | U/C ⁽²⁾ | Likelihood ⁽³⁾⁽⁴⁾ | | Consequence ⁽⁵⁾ | | Risk Index ⁽⁶⁾ |
|----------------------------------|--|--------------------|------------------------------|----------|----------------------------|----------|---------------------------|
| | | | Index | Category | Evaluation Number | Category | |
| 103.30 | NPH at DUF ₆ Autoclave Building causes release of vapor DUF ₆ from process equipment | U | >-4 | 3 | DUF-CH-10 | 3 | 9 |
| A design-basis earthquake occurs | | C | -5 | 1 | | 2 | 2 |
| 104.30 | NPH at DUF ₆ to DUF ₄ Process Building | U | >-4 | 3 | DUF-CH-12 | 3 | 9 |
| A design-basis earthquake occurs | | C | -5 | 1 | | 2 | 2 |
| 104.31 | NPH at DUF ₄ Container Storage Building | U | >-4 | 3 | APS-CH-14 | 3 | 9 |
| A design-basis earthquake occurs | | C | -5 | 1 | | 2 | 2 |
| 106.51 | NPH at DUF ₆ to DUF ₄ Process Building | U | >-4 | 3 | DUF-CH-25 | 2 | 6 |
| A design-basis earthquake occurs | | C | -5 | 1 | | 1 | 1 |
| 107.19 | NPH at DUF ₆ to DUF ₄ Process Building | U | >-4 | 3 | DUF-CH-29 | 2 | 6 |
| A design-basis earthquake occurs | | C | -5 | 1 | | 1 | 1 |
| 201.44 | NPH at FEP Process Building | U | -4 | 3 | SF4-CH-03 | 2 | 6 |
| A design-basis earthquake occurs | | C | -5 | 1 | | 1 | 1 |
| 204.70 | NPH at FEP Process Building | U | >-4 | 3 | SF4-CH-10 | 2 | 6 |
| A design-basis earthquake occurs | | C | -5 | 1 | | 1 | 1 |
| 301.52 | NPH at FEP Oxide Staging Building | U | >-4 | 3 | BF3-CH-05 | 2 | 6 |
| A design-basis earthquake occurs | | C | -5 | 1 | | 1 | 1 |
| 302.20 | NPH at FEP Oxide Staging Building | U | >-4 | 3 | BF3-CH-08 | 3 | 9 |
| A design-basis earthquake occurs | | C | -5 | 1 | | 2 | 2 |

| Accident Identifier | Initiating Event ⁽¹⁾ | U/C ⁽²⁾ | Likelihood ⁽³⁾⁽⁴⁾ | | Consequence ⁽⁵⁾ | | Risk Index ⁽⁶⁾ |
|----------------------------------|--|--------------------|------------------------------|----------|----------------------------|----------|---------------------------|
| | | | Index | Category | Evaluation Number | Category | |
| 302.21 | NPH at FEP Oxide Staging Building | U | -2 | 3 | APS-CH-01 | 3 | 9 |
| A design-basis earthquake occurs | | C | -5 | 1 | | 2 | 2 |
| (1) | Consistent with the methods outlined in DOE-STD-1020-2002, "Natural Phenomena Hazards Design and Evaluation Criteria for U.S. Department of Energy Facilities", the IIFP process buildings will be designed to withstand a 10,000 year earthquake. The affected process buildings are determined to be Performance Category 3 (PC-3) as defined in the DOE standard. Based on this approach, the building collapse or a structural deformation that might compromise the effective function of an IROFS SSC is considered "highly unlikely" per NUREG-1520, Rev 1. | | | | | | |
| (2) | Uncontrolled "U" and Controlled "C" (following application of prevention IROFS) | | | | | | |
| (3) | Likelihood index is a summation of the failure frequency index and IROFS failure probability indices | | | | | | |
| (4) | Likelihood Category: 3 = not unlikely, 2 = unlikely, 1 = highly unlikely | | | | | | |
| (5) | Comparison of the accident consequences to the performance requirements of 10 CFR 70.61 and designation of each as a high consequence event (i.e., Consequence Category 3) or intermediate consequence event (i.e., Consequence Category 2). Accident sequences with consequences that are of no regulatory concern (i.e., Consequence Category 1) are not included. | | | | | | |
| (6) | Risk index that is the product of Likelihood Category and Consequence Category | | | | | | |

IIFP Response to (1) c.:

The IIFP Facility design will be developed with natural phenomena hazards considered such that if an external event should occur, the health and safety of the public and the workforce from licensed material (or chemicals that may affect licensed materials) are maintained. IROFS will be designed to withstand the effects of, and be compatible with, the environmental conditions associated with operation, maintenance, shutdown, testing and accidents for which the IROFS will be required to function. Consideration of the effects of natural phenomena hazards on the IIFP Plant is included in Section 3 and also summarized in the IIFP LA, Revision B Chapter 3 Subsection 3.2.4.3. Discussion includes impacts of earthquake, tornado, flood, lightning, ice and snow, extreme temperatures and high winds on operations, such as the following criteria:

- Design and engineering with respect to seismic events and consequences will be based on "g-force" lateral movement relative to a minimum 2,500 year-return period. Consistent with the methods outlined in DOE-STD-1020-2002, and applying engineering safety margins as provided by the DOE-1020 standard, the IIFP process buildings will be designed to withstand a 10,000 year earthquake. The process buildings will be IROFS that will be maintained at the design integrity by the use of management measures and graded levels of quality assurance to be reliable and available to function as discussed in the IIFP LA, Revision B Chapter 3 Subsection 3.2.4.3. The process building IROFS are SF4-60, SF4-61, DUF-60, DUF-61 and DUF-62.

- Storm water sewer systems will be designed for a 100-year return period maximum 1-hour rainstorm.

Engineering design requirements for all active and passive IROFS will include adequate protection from natural phenomena events. Seismic, wind and lightning hazards will be specifically addressed through implementation of building code design requirements. Table 4-10 and Table 4-11 present examples of how the design incorporates natural phenomena hazards for engineered IROFS.

In Section 3.1.2 of Chapter 3 of the LA, IIFP commits to implementing programs to maintain the ISA and supporting documentation so that it is accurate and up-to-date. After the IIFP License is approved, changes to the ISA Summary are submitted to the NRC in accordance with 10 CFR 70.72, *Facility Changes and Change Process*. The ISA update process accounts for design safety basis changes made relative to licensed materials or hazards, including natural phenomena hazards, potentially affecting licensed materials. The update will also verify that the initiating event likelihoods and IROFS reliability values that are assumed in the ISA remain valid. Any changes to the ISA required as a result of the update process will be included in a revision to the ISA and ISA Summary. Change management measures used to prepare and document revisions to the ISA are described in LA, Revision B Chapter 11. ISA methods are used for the evaluation of any facility changes or changes in the process safety information that may alter the parameters of an accident sequence.

IIFP Response to (1) d.:

The IIFP facility has not yet been constructed or designed, as such IIFP has not conducted any additional assessments to identify and address degraded, nonconforming or unanalyzed conditions that could affect the performance of the facility under natural phenomena events.

Please contact me at 208.524.5300 or via email at jjmiller@intisoid.com if you have any questions or comments regarding this request.

Sincerely,



John J. Miller, CHP
Radiation Safety and Regulatory Compliance Officer
JJM-2015-36

I declare under penalty of perjury that the information provided herein is true and correct.
Executed on 23 October 2015

cc: Mr. Osiris Siurano-Perez
TWFN, Mailstop 4 A60, NMSS/FCSE/ECB