

NRR-PMDAPEm Resource

From: Goetz, Sujata
Sent: Wednesday, November 04, 2015 3:18 PM
To: hassouna@dteenergy.com
Cc: Rankin, Jennivine; Hamm, Matthew; RidsNRRLIC109 Resource; Goetz, Sujata
Subject: FERMI 2 - Acceptance Review to (CAC No. MF6756)

Mr. Hassoun,

By letter dated September 24, 2015 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML15268A149), DTE Electric Company submitted a license amendment request (LAR) for Fermi 2. The proposed LAR would revise the Technical Specifications (TS) to adopt TSTF-523, "Generic Letter 2008-01, Managing Gas Accumulation."

The purpose of this e-mail is to provide the results of the U.S. Nuclear Regulatory Commission (NRC) staff's acceptance review of this LAR. The acceptance review was performed to determine if there is sufficient technical information in scope and depth to allow the NRC staff to complete its detailed technical review. The acceptance review is also intended to identify whether the application has any readily apparent information insufficiencies in its characterization of the regulatory requirements or the licensing basis of the plant.

Consistent with Section 50.90 of Title 10 of the *Code of Federal Regulations* (10 CFR), an amendment to the license (including the TS) must fully describe the changes requested, and following as far as applicable, the form prescribed for original applications. Section 50.34 of 10 CFR addresses the content of technical information required. This section stipulates that the submittal address the design and operating characteristics, unusual or novel design features, and principal safety considerations.

The NRC staff has reviewed your application and concluded that it does provide technical information in sufficient detail to enable the NRC staff to complete its detailed technical review and make an independent assessment regarding the acceptability of the proposed amendment in terms of regulatory requirements and the protection of public health and safety and the environment. Given the lesser scope and depth of the acceptance review as compared to the detailed technical review, there may be instances in which issues that impact the NRC staff's ability to complete the detailed technical review are identified despite completion of an adequate acceptance review. If additional information is needed for the staff to complete its technical review, you will be advised by separate correspondence.

If you have any questions, please contact me at 301-415-8004.

Thanks,

Sue

Sujata Goetz
Project Manager
NRC, Office of Nuclear Reactor Regulation

NRC/NRR/DORL/LPL3-1, O8C10
Washington, DC 20555-0001
301.415.8004, 301.415.3313 (fax)
Mail Stop O8H4A

Hearing Identifier: NRR_PMDA
Email Number: 2491

Mail Envelope Properties (f7100c527c4f440dac18d6e3d77646a5)

Subject: FERMI 2 - Acceptance Review to (CAC No. MF6756)
Sent Date: 11/4/2015 3:17:30 PM
Received Date: 11/4/2015 3:17:30 PM
From: Goetz, Sujata

Created By: Sujata.Goetz@nrc.gov

Recipients:

"Rankin, Jennivine" <Jennivine.Rankin@nrc.gov>
Tracking Status: None
"Hamm, Matthew" <Matthew.Hamm@nrc.gov>
Tracking Status: None
"RidsNRRLIC109 Resource" <RidsNRRLIC109.Resource@nrc.gov>
Tracking Status: None
"Goetz, Sujata" <Sujata.Goetz@nrc.gov>
Tracking Status: None
"hassouna@dteenergy.com" <hassouna@dteenergy.com>
Tracking Status: None

Post Office: HQPWMSMRS05.nrc.gov

Files	Size	Date & Time
MESSAGE	2487	11/4/2015 3:17:30 PM

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received: