

## **KHNPDCDRAIsPEm Resource**

---

**From:** Ciocco, Jeff  
**Sent:** Wednesday, November 04, 2015 3:23 PM  
**To:** apr1400rai@khnp.co.kr; KHNPDCDRAIsPEm Resource; Harry (Hyun Seung) Chang; Andy Jiyong Oh; James Ross  
**Cc:** Makar, Gregory; Mitchell, Matthew; Ward, William; Lee, Samuel; Umana, Jessica  
**Subject:** APR1400 Design Certification Application RAI 292-8306 (05.04.02.01 - Steam Generator Materials)  
**Attachments:** APR1400 DC RAI 292 MCB 8306.pdf

KHNP,

The attachment contains the subject request for additional information (RAI). This RAI was sent to you in draft form. Your licensing review schedule assumes technically correct and complete responses within 30 days of receipt of RAIs.

Please submit your RAI response to the NRC Document Control Desk.

Thank you,

Jeff Ciocco  
New Nuclear Reactor Licensing  
301.415.6391  
[jeff.ciocco@nrc.gov](mailto:jeff.ciocco@nrc.gov)



**Hearing Identifier:** KHNP\_APR1400\_DCD\_RAI\_Public  
**Email Number:** 341

**Mail Envelope Properties** (db7d55ea5b7e4f15b0daa6637577ce4b)

**Subject:** APR1400 Design Certification Application RAI 292-8306 (05.04.02.01 - Steam Generator Materials)  
**Sent Date:** 11/4/2015 3:22:48 PM  
**Received Date:** 11/4/2015 3:22:51 PM  
**From:** Ciocco, Jeff  
**Created By:** Jeff.Ciocco@nrc.gov

**Recipients:**

"Makar, Gregory" <Gregory.Makar@nrc.gov>  
Tracking Status: None  
"Mitchell, Matthew" <Matthew.Mitchell@nrc.gov>  
Tracking Status: None  
"Ward, William" <William.Ward@nrc.gov>  
Tracking Status: None  
"Lee, Samuel" <Samuel.Lee@nrc.gov>  
Tracking Status: None  
"Umana, Jessica" <Jessica.Umana@nrc.gov>  
Tracking Status: None  
"apr1400rai@khnp.co.kr" <apr1400rai@khnp.co.kr>  
Tracking Status: None  
"KHNPDCDRAIsPEM Resource" <KHNPDCDRAIsPEM.Resource@nrc.gov>  
Tracking Status: None  
"Harry (Hyun Seung) Chang" <hyunseung.chang@gmail.com>  
Tracking Status: None  
"Andy Jiyong Oh" <jiyong.oh5@gmail.com>  
Tracking Status: None  
"James Ross" <james.ross@aecom.com>  
Tracking Status: None

**Post Office:** HQPWMSMRS07.nrc.gov

<b>Files</b>	<b>Size</b>	<b>Date &amp; Time</b>
MESSAGE	498	11/4/2015 3:22:51 PM
APR1400 DC RAI 292 MCB 8306.pdf		91222
image001.jpg	5040	

**Options**

**Priority:** Standard  
**Return Notification:** No  
**Reply Requested:** No  
**Sensitivity:** Normal  
**Expiration Date:**  
**Recipients Received:**

## REQUEST FOR ADDITIONAL INFORMATION 292-8306

Issue Date: 11/04/2015  
Application Title: APR1400 Design Certification Review – 52-046  
Operating Company: Korea Hydro & Nuclear Power Co. Ltd.  
Docket No. 52-046  
Review Section: 05.04.02.01 - Steam Generator Materials  
Application Section: SRP 5.4.2.1

### QUESTIONS

05.04.02.01-1

General Design Criterion 4 of Appendix A to 10 CFR 50 Part 50 requires, in part, that structures, systems, and components, important to safety should be designed to accommodate the effects of, and to be compatible with, the environmental conditions associated with normal operation, maintenance, testing, and postulated accidents. The staff requests that the applicant identify the materials used for the feedwater rings, spray nozzles, thermal sleeves, and the economizer, and the potential forms of degradation considered for these components (e.g., flow accelerated corrosion). This information is needed as part of the staff's evaluation of how the potential degradation of SG components are designed to address compatibility with the coolant and the potential for loose parts.

05.04.02.01-2

The August 4, 2015, response (ML15216A447) to MCB Issue 5.4.2.1-16 (KHNP issue AI 5-6.16) includes a proposed revision to FSAR Subsection 5.4.2.1.5 that states, "The primary water chemistry is controlled at a level comparable to the guidelines in the EPRI ..." This seems to be inconsistent with FSAR Subsections 5.4.2.2.7 and 5.4.2.2.8, which state the water chemistry will be controlled "in accordance with" the EPRI guidelines. If the APR1400 design is going to follow the EPRI guidelines, please revise the FSAR where appropriate to make that clear.. This information is needed for consistency within FSAR Subsection 5.4.2 and with other parts of the FSAR. The staff's review of the adequacy of the primary water chemistry requirements is in other FSAR Subsections (5.2.3 and 9.3.4).

05.04.02.01-3

In the August 4, 2015, response (ML15216A447) to MCB Issue 5.4.2.1-11 (KHNP issue AI 5-6.11), Table 1 provides corrosion rate measurements in units of "mdm" and "mpy." The original source of the data identified "mdm" as milligrams per square decimeter per month. The response stated that the "mpy" values (mils per year) are based on a conversion factor of  $1 \text{ mdm} = 5 \times 10^{-4} \text{ mpy}$ . The staff confirmed the mdm values in the original paper but could not reproduce the conversion factor of  $1 \text{ mdm} = 5 \times 10^{-4} \text{ mpy}$ . (The staff calculated a value of  $5.8 \times 10^{-3}$  as shown below, using a density of 8.2 grams per cubic centimeter for Alloy 690.) The staff requests that the applicant show how the conversion to mpy of  $5 \times 10^{-4}$  was derived, or provide a corrected response to AI 5-6.11 if appropriate. The purpose of the original question was compliance with ASME Code Section III, which requires an appropriate allowance for corrosion and other forms of degradation. The additional information is needed for clarification or correction of the August 4, 2015 response.

## REQUEST FOR ADDITIONAL INFORMATION 292-8306

$$1 \text{ (mg/dm}^2\text{-month)} \times (12 \text{ month/year}) \times (g/1000 \text{ mg}) \times (\text{dm}^2/100 \text{ cm}^2) \times (\text{inch}/2.54 \text{ cm}) \times (\text{cm}^3/8.2 \text{ g}) \times (1000 \text{ mils/inch}) = 5.8 \times 10^{-3} \text{ mils/year}$$



**U.S.NRC**

United States Nuclear Regulatory Commission

*Protecting People and the Environment*