

**From:** [Klett, Audrey](mailto:Klett.Audrey)  
**To:** ["Mitch.Guth@fpl.com"](mailto:Mitch.Guth@fpl.com)  
**Cc:** ["Hanek, Olga"](mailto:Hanek.Olga) ([Olga.Hanek@fpl.com](mailto:Olga.Hanek@fpl.com))  
**Subject:** Request for Additional Information re. Turkey Point Unit 3 and 4 LAR 232 (CACs MF6423 and MF6424)  
**Date:** Friday, November 13, 2015 2:02:00 PM

---

Hi Mitch,

By application dated July 2, 2015 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML15198A153), Florida Power & Light Company (FPL, the licensee) submitted License Amendment Request No. 232 for Turkey Point Nuclear Generating Unit Nos. 3 and 4. The U.S. Nuclear Regulatory Commission staff reviewed the application and identified areas where it needs additional information to support its review. The Request for Additional Information (RAI) is provided below. As discussed with Ms. Olga Hanek of the licensee's staff on November 13, 2015, the NRC is requesting a response to the RAI by November 30, 2015.

### **RAI-1**

In its application dated July 2, 2015, the licensee proposed deleting two technical specifications relating to communications systems and the manipulator crane used during refueling operations. The application indicates that the Updated Final Safety Analysis Report (UFSAR) and related procedures, changes to which are controlled in accordance with 10 CFR 50.50, will be used to ensure that refueling communications and manipulator crane operations are conducted safely; however, the application does not show exactly what information will be placed into the UFSAR, procedures, or other administrative controls.

Please provide a description of the content to be relocated from the technical specifications to the UFSAR and related procedures. Describe and justify any changes to aspects of the technical specifications that will be changed or deleted (if the content will be relocated in its entirety, please indicate this). Alternatively, you may provide marked up draft copies of the UFSAR/administrative controls/procedures that show how specific elements of the technical specifications will be relocated.

Audrey Klett  
Project Manager  
NRR/DORL/LPLII-2  
301-415-0489