

# **Official Transcript of Proceedings**

## **NUCLEAR REGULATORY COMMISSION**

Title: In the Matter of:  
The 629th Meeting of the Advisory Committee  
on Reactor Safeguards (ACRS)

Docket Number: N/A

Location: Rockville, Maryland

Date: November 4, 2015

Work Order No.: NRC-2011

Pages 1-225

**NEAL R. GROSS AND CO., INC.**  
**Court Reporters and Transcribers**  
**1323 Rhode Island Avenue, N.W.**  
**Washington, D.C. 20005**  
**(202) 234-4433**

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S  
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, as reported herein, is a record of the discussions recorded at the meeting.

This transcript has not been reviewed, corrected, and edited, and it may contain inaccuracies.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION

+ + + + +

629TH MEETING

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

(ACRS)

+ + + + +

WEDNESDAY

NOVEMBER 4, 2015

+ + + + +

ROCKVILLE, MARYLAND

+ + + + +

The Advisory Committee met at the Nuclear  
Regulatory Commission, Two White Flint North, Room  
T2B1, 11545 Rockville Pike, at 8:30 a.m., John W.  
Stetkar, Chairman, presiding.

COMMITTEE MEMBERS:

JOHN W. STETKAR, Chairman

DENNIS C. BLEY, Vice Chairman

MICHAEL L. CORRADINI, Member-at-Large

RONALD G. BALLINGER, Member

CHARLES H. BROWN, JR. Member

DANA A. POWERS, Member

HAROLD B. RAY, Member

JOY REMPE, Member

PETER RICCARDELLA, Member

STEPHEN P. SCHULTZ, Member

GORDON R. SKILLMAN, Member

DESIGNATED FEDERAL OFFICIALS:

KENT L. HOWARD, SR.

MICHAEL SNODDERLY

ALSO PRESENT:

VICTORIA ANDERSON, NEI

DENNIS BLAKELY, FENOC

BRIAN BOLES, FENOC

KEN BYRD, FENOC

CHONG CHIU, FENOC

PHYLLIS CLARK, NRR/DLR/RPB1

CLIFF CUSTER, FENOC

STEVE DORT, FENOC

RICHARD DUDLEY, NRR/DPR/PRMB

RAYMOND FINE, PWR Owners Group

JOE GIITTER, NRR/DRA

TRENT HENLINE, FENOC

ACE HOFFMAN \*

JON HOOK, FENOC

KEVIN KAMPS, Beyond Nuclear

MARVIN LEWIS \*

1 JOHN MONNINGER, NRO/DSRA  
2 JAVEED MUNSHI, FENOC  
3 JAMES NEURAUTER, R-III/DRS/EB1  
4 RICK PLASSE, NRR/DLR/RPB1  
5 BOB RISHEL, BWR Owners' Group  
6 GEORGE THOMAS, NRR

7

8

9 \*Present via telephone

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

## A G E N D A

	<u>Page</u>
Opening Remarks by the ACRS Chairman. . . . .	5
Risk Management Regulatory Framework. . . . .	6
Davis-Besse Nuclear Power Station License	
Renewal.. . . .	112
Harold Ray.. . . .	112
Jane Marshall, FENOC.. . . .	115
Brian Boles, FENOC.. . . .	116
Ken Byrd, FENOC. . . . .	117
Cliff Custer, FENOC. . . . .	121
Trent Henline, FENOC.. . . .	123
Dennis Blakely, FENOC. . . . .	124
Jon Hook, FENOC. . . . .	129
Rick Plasse, NRC staff.. . . .	168
Public Comment. . . . .	210
Adjournment.. . . .	225

## P R O C E E D I N G S

8:34 a.m.

CHAIR STETKAR: The meeting will now come to order. This is the 629th meeting of the Advisory Committee on Reactor Safeguards. During today's meeting, the Committee will consider the following: Risk management regulatory framework, Davis-Besse nuclear power station license renewal and preparation of ACRS reports.

This meeting is being conducted in accordance with the provisions of the Federal Advisory Committee Act. Mr. Michael Snodderly is the Designated Federal Official for the initial portion of the meeting. We've received no written comments. Actually, that's not true. We have received written comments, and we have received requests to make an oral statement from a member of the public regarding today's sessions.

There will be a phone bridge line. To preclude interruption of the meeting, the phone will be placed in a listen-in mode during the presentations and Committee discussion. I'll remind you all to please check your communications devices and silence them please. A transcript of portions of the meeting is being kept and it is requested that the speakers

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

1 use one of the microphones, identify themselves and  
2 speak with sufficient clarity and volume so that they  
3 can be readily heard.

4 I also want to make folks aware that  
5 theoretically, this is the first meeting of the ACRS  
6 that will be webcast, with the ability to view our  
7 presentation slides on the web.

8 Those of you out there on the bridge line  
9 who may want to do that, can dial into the -- or  
10 connect through the NRC's Public Meeting website and  
11 click on the link, I've been told, and it should work.  
12 It doesn't call our office and harass them.

13 With that, unless any of the members have  
14 any comments that you'd like to make. The first item  
15 on our agenda for today is the Risk Management  
16 Regulatory Framework, and I'll lead us through that  
17 session.

18 CHAIR STETKAR: We've had numerous  
19 meetings on this topic over the last oh three years or  
20 more. It's a long and arduous process that started  
21 with the Risk Management Task Force being assembled in  
22 really 2011, just before the Fukushima accident. It  
23 was linked somewhat to the Near Term Task Force  
24 Recommendation 1, and is now coming to some sort of  
25 closure, I think.



1 I don't want to steal too much of the  
2 staff's thunder, so I'll turn it over to Joe Giitter  
3 of the staff, who will make some introductory remarks.  
4 Joe?

5 MR. GIITTER: Okay, good morning. Today  
6 you're going to hear a short presentation from the  
7 staff on several options that were considered for the  
8 Risk Management Regulatory Framework.

9 These options include the full  
10 implementation of the regulatory framework discussed  
11 in NUREG-2150, an optional voluntary approach that  
12 would allow licensees to risk-inform certain aspects  
13 of the current deterministic requirements, and finally  
14 an option to advance risk-informed decision-making  
15 without making changes to the current framework.

16 As the Chairman Stetkar mentioned, there  
17 have been a number of public meetings and  
18 opportunities for public input, and input from our  
19 stakeholders on the different approaches. As you  
20 know, the Risk Management Regulatory Framework  
21 envisioned in NUREG-2150 was not something to be  
22 implemented in a matter of months, but rather a vision  
23 for the future, 15 years or more from now.

24 While the recommendations of the staff are  
25 influenced by the current reality facing the NRC and

1 the industry, which is admittedly near-term focus,  
2 they also support sustaining and increasing risk-  
3 informed decision-making within the agency.

4 It is imperative in the current  
5 environment of declining resources that we focus our  
6 attention on issues of greatest safety significance.  
7 As you will hear later this morning, we are actively  
8 leverage risk insights to become a more effective and  
9 efficient regulator.

10 Finally, I want to recognize all of the  
11 hard work and dedication that the staff has put into  
12 this effort. In particular, I want to recognize Dick  
13 Dudley, who has put off his retirement to help us  
14 develop the SECY paper. So with that, I'm going to  
15 turn it over to Dick.

16 MR. DUDLEY: Thanks Joe. On Slide 2 is an  
17 outline, if I show it, of the presentation that we'll  
18 be giving you today. First, I'll talk about the  
19 background of the effort and our next steps. Then I  
20 will go through the RMRF, Risk Management Regulatory  
21 Framework SECY paper. It has four sections.

22 Section 1 is on RMRF implementation  
23 options for power reactors, the three options that Joe  
24 discussed with you. Section 2 is a reevaluation of  
25 Near Term Task Force Recommendation 1, Improvement

1 Activities 1 and 2 that was deferred to this RMRF  
2 effort by the Commission. Section 3 is a discussion  
3 of an agency-wide risk management policy statement.

4 After that, I will briefly discuss changes  
5 that were made to the SECY paper during the office  
6 concurrence process, and then finally I will discuss  
7 Section 4 just briefly on the interrelationships  
8 between the risk-informed -- ongoing risk-informed  
9 activities for nuclear power reactors.

10 After that, Joe Gitter will begin a  
11 discussion of the Risk Informed Steering Committee  
12 oversight activities. I just want to point out that  
13 there are four sections to the paper. Sections 1, 2  
14 and 4 apply only to power reactor safety, and only  
15 Section 3 is applicable on an agency-wide basis to all  
16 program areas.

17 As Chairman Stetkar said, there's been a  
18 long history behind this, and we've had a significant  
19 level of public interaction on the NUREG-2150 RMRF.  
20 We've held four public meetings. We've had five ACRS  
21 Subcommittee meetings. I believe I counted right. I  
22 know we've had three written public comment periods  
23 and we released white papers in November 2013 and May  
24 2015.

25 We met with the Reliability and PRA

1 Subcommittee most recently on October 19th, where we  
2 discussed our draft final RMRF SECY paper. We're  
3 meeting with the full Committee today with the purpose  
4 of receiving an ACRS letter some time around mid-  
5 November.

6 Our response to that ACRS letter will be  
7 delivered in December, and I hope to bundle all the  
8 letters together in the RMRF SECY and provide it to  
9 the Commission by December 18th, 2015. On Slide 4, as  
10 Joe said, we considered three options.

11 I'm going to give them in a different  
12 order, but Option 1 was maintain the current  
13 regulatory framework; Option 2 was to implement a  
14 voluntary alternative licensing basis that would be  
15 done on a plant-specific basis; and Option 3 would be  
16 to implement the approach recommended in NUREG-2150.

17 Discussing Option 1 in a little more  
18 detail, Option 1 would be no extensive revision to our  
19 current regulatory framework. We believe that the  
20 current regulatory framework meets the four criteria  
21 in NUREG-2150 for what they characterized as a Risk  
22 Management Regulatory Framework, and that it has a  
23 mission and objective, and the goal -- the goal we  
24 would utilize --

25 The goal is to provide sufficient risk-

1 informed and performance-based protections to ensure  
2 risks are acceptably low. We can use the  
3 Commission's safety goal policy statement and  
4 subsidiary risk metrics to do that, and decision-  
5 making processes that include monitoring and feedback,  
6 and we have those in -- this is all for power  
7 reactors. We have those in LIC-504 and in Regulatory  
8 Guide 1.174.

9 Power reactor Option 2 is to maintain the  
10 existing generic regulatory structure, but we would  
11 then write a rule and this rule would allow licensees  
12 who choose to upgrade their PRAs to apply for NRC  
13 approval of a risk-informed alternative licensing  
14 basis.

15 Now under this licensing basis, licensees  
16 could select a plant-specific set of compliance issues  
17 or design changes or things they wanted to change that  
18 their PRA show are of low risk significance. For  
19 these, they'd be allowed to deviate from certain of  
20 the current deterministic requirements, but with the  
21 condition that they would mitigate all known plant-  
22 specific risk vulnerabilities that would meet NRC  
23 specified criteria.

24 So this could potentially bring a  
25 currently unregulated event that for some reason was

1 a risk outlier at a specific facility. It could bring  
2 that into its licensing basis. The rule would also  
3 require mandatory monitoring and feedback, to make  
4 sure that the changes in risk were acceptable  
5 throughout the lifetime of the facility.

6 Now we were not able to develop  
7 implementation details for this approach, and there  
8 are substantial implementation uncertainties with it,  
9 and they're listed here. We'd have to review the  
10 power reactor regulations and decide which of the  
11 rules are amenable to risk-informing or which are not.

12 We'd have to determine the minimum scope  
13 and technical accuracy of a suitable PRA. Would that  
14 include certification or review of the PRA? We don't  
15 know. We'd have to determine the selection and scope  
16 of permissible design changes, and the processes for  
17 staff review of those design changes.

18 We'd have to determine reporting,  
19 documentation requirements and then the whole effort  
20 would have to be structured in a way as to ensure  
21 transparency, both to the NRC and to the public of the  
22 process that the licensee was using to maintain risk  
23 acceptably low at his facility, because facilities of  
24 starting with seemingly identical designs could evolve  
25 and look different from one another over time under

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 this approach.

2 CHAIR STETKAR: Dick?

3 MR. DUDLEY: Yes.

4 CHAIR STETKAR: If I -- if this option  
5 were invoked, and I were a new plant licensee, whether  
6 that's an SMR or maybe even the next generation of  
7 plants, this would allow me to voluntarily come in and  
8 use a risk-informed basis for my entire licensing  
9 basis, would it not?

10 MR. DUDLEY: I would hope that -- I can't  
11 really speak.

12 CHAIR STETKAR: I mean that's perhaps a  
13 bit too strong when I say the entire licensing basis,  
14 but it would certainly open that door to those types  
15 of applicants, wouldn't it?

16 MR. DUDLEY: I mean I think it's true,  
17 that this approach would be more useful for new  
18 reactor designs than it would be for these current  
19 plants that are already built for the -- and in  
20 accordance with the criteria that were established,  
21 you know, some 30 or more years ago.

22 CHAIR STETKAR: Yeah, yeah. Okay, thank  
23 you.

24 MEMBER SCHULTZ: But it would seem that  
25 what you've outlined is what implementation details

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 would be necessary to move forward with the  
2 alternative, that in fact the expectation associated  
3 with that long list of things that would need to be  
4 done is that you're looking for the process to, if you  
5 will, totally change to a risk-informed regulatory  
6 framework for that licensee, and that that could be  
7 used, should be used for their licensing approach  
8 moving forward.

9 I mean it's a very daunting list of  
10 implementation details that have not been developed.

11 MR. DUDLEY: Yeah, that's correct.

12 MEMBER SCHULTZ: Therefore, one would  
13 assume that the benefit, the product would in fact be  
14 that allowance, in terms of the regulatory approach  
15 following satisfying all the implementation  
16 requirements.

17 MR. DUDLEY: I'm not sure I understand --  
18 is there a question or --

19 MEMBER SCHULTZ: Well, I'm trying to  
20 understand -- you set up to say the implementation  
21 details are as such, and that the expectation is that  
22 the approach will be for a licensee to mitigate all  
23 known plant-specific vulnerabilities meeting NRC  
24 specified criteria yet to be determined.

25 So if one were to jump all of those



1 hurdles, one would expect there would be a substantial  
2 benefit at the end.

3 MR. DUDLEY: Well, it would -- it works  
4 both ways, and so once we set the risk criteria, if  
5 that brings in an unregulated event, then that event  
6 would be regulated and the risk will be mitigated.  
7 But it would also go other ways and allow licensees to  
8 remove certain protections that exist now by the  
9 deterministic regulations, that show -- that are shown  
10 by the PRA to not be risk-significant.

11 So the -- it would really work both ways,  
12 and the net change in safety could be none.

13 MEMBER CORRADINI: But so just to ask  
14 these --

15 MR. DUDLEY: By the way, it would be more  
16 economical for licensees.

17 MEMBER CORRADINI: So can I ask Steve's  
18 question differently? So Option 2, you list all the  
19 things that have got to be done. So are there  
20 practical technical questions that are taking this  
21 route now? The one that comes to mind is GSI-191.  
22 Certain plant licensees are going to approach this  
23 from a risk-informed process.

24 So instead of trying to sit down and  
25 change the whole regulatory framework in Option 2, are

1       there certain technical issues that are being pursued  
2       this way that staff is already addressing?

3               MR. GIITTER: I can address that Dick, if  
4       you want.

5               MEMBER CORRADINI: Yes.

6               MR. GIITTER: Yeah. We do have some  
7       examples, and I just wanted to comment on something  
8       Dick said. I don't think that safety would be  
9       neutral. I think safety would be improved, because  
10      you're looking at -- with this approach, because  
11      you're not focusing on those things that are  
12      compliance issues of a low safety-significant issue,  
13      and you're addressing vulnerabilities that aren't  
14      currently addressed.

15              So I want to just be on the record to make  
16      sure that I think this is -- this would result in  
17      improvement in safety.

18              MR. DUDLEY: We really don't know, and so  
19      yeah, we don't know.

20              MR. GIITTER: Well, but I think  
21      theoretically anyway that's -- that would be the  
22      result.

23              MEMBER CORRADINI: Well, the reason I  
24      asked my question, I guess, is just repeating Steve's  
25      question a little differently, is that from a process

1 standpoint, it seems to me this is attractive if there  
2 are certain technical issues that are already out  
3 there that in current plants --

4 MR. GIITTER: So we do have -- I'll give  
5 you some examples. Probably the biggest example is  
6 NFPA-805. About half the fleet went from a  
7 deterministic, prescriptive requirement --

8 MEMBER CORRADINI: That's a good example?

9 MR. GIITTER: They came out, you know, and  
10 --

11 CHAIR STETKAR: It's an example.

12 MR. GIITTER: But the other example is  
13 50.69, you know. When we looked at the Vogtle pilot  
14 and then prior to that the South Texas exemption for  
15 50.69, the categorization of safety-related structure  
16 systems and components, we found that 75 percent of  
17 systems, SSCs that were originally considered to be  
18 safety-related were in fact that important to safety,  
19 when you look at it from a risk perspective.

20 But there were also systems, for example  
21 like RCIC and the BWR and other examples of non-safety  
22 related systems that were actually pretty important to  
23 safety. So it's looking at the list of SSCs that were  
24 determined based on a very stylized accident, design-  
25 basis accident. With a risk perspective, you see they

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 don't necessarily match up.

2 So the treatment requirements for those  
3 previously -- the 75 percent of the safety-related  
4 SSCs could be different and, you know, I've heard  
5 anecdotally from South Texas and Vogtle that, you  
6 know, saving of millions of dollars a year in how they  
7 treat those safety-related SSCs.

8 CHAIR STETKAR: I also look at what's been  
9 done for some of the new reactor design  
10 certifications, where there's a bit of analogy here,  
11 where the concept of regulatory treatment of non-  
12 safety systems that are important to safety falls  
13 within this kind of intermediate range.

14 So things that do not meet the traditional  
15 criteria for the designation of safety-related mean  
16 they're not absolutely required to meet the  
17 deterministic criteria for mitigation of design basis  
18 accidents.

19 But the risk assessments indeed do show  
20 that they're important to safety, and there's -- there  
21 are now in place various monitoring and treatment  
22 mechanisms for those that are not as stringent as, for  
23 example, technical specifications.

24 But in many cases, in practice have many  
25 of the same types of practical implications on the way

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 people operate the systems and monitor them in the  
2 plant. So there is sort of this notion building, I  
3 think among the industry and the staff, of some sort  
4 of comfort with the use of risk information to more  
5 finely focus, if I can call it that, on the equipment  
6 and the systems that are shown to be, at least through  
7 the risk assessment, important.

8 Those words "important to safety" rather  
9 than strictly safety-related, according to the  
10 traditional licensing definitions of that term.

11 MR. DUDLEY: On Slide 7, because of these  
12 implementation uncertainties, the staff held a public  
13 meeting on July 29th, specifically on Option 2, to try  
14 to discuss in more detail these implementation issues.  
15 The staff presented additional details on Option 2,  
16 and thoughts and approach for what it might take to  
17 develop a suitable PRA.

18 The industry stakeholders at that meeting  
19 were still concerned about the lack of implementation  
20 details on Option 2, and they said without further  
21 information on these areas of uncertainty, that they  
22 could not assess the safety benefits and the costs of  
23 Option 2.

24 Because they couldn't do that with the  
25 information before them, industry said it was not able

1 to support the approach until we developed more  
2 details.

3 MEMBER CORRADINI: Are there -- so let me  
4 just go back to topical areas, and I'll keep on coming  
5 back to GSI-191. Are there particular attributes of  
6 what currently is being considered with that as an  
7 example, with certain plants thinking they want to  
8 essentially approach it that way, that could be  
9 generalized?

10 MR. DUDLEY: GSI-191 is being looked at in  
11 50.46(c) for long term cooling on the debris issue.  
12 So there is a risk-informed alternative included in  
13 the draft --

14 MEMBER CORRADINI: Draft final?

15 MR. DUDLEY: --of 50.46(c).

16 MEMBER CORRADINI: Okay.

17 MR. DUDLEY: So and 50.46(a) on risk-  
18 informed ECCS five years ago, also has a risk-informed  
19 alternative for emergency core cooling, and that would  
20 be reconsidered by the staff after RMRF is completed.

21 MEMBER CORRADINI: Well but I guess --

22 MR. DUDLEY: After the Commission  
23 decision.

24 MEMBER CORRADINI: Yeah. But I guess what  
25 I'm asking is so you have these examples. Are there

1 actually some examples that are common, so that you  
2 see a common framework could develop from what already  
3 as ad hoc has occurred or is occurring?

4 MR. DUDLEY: You know, these are pretty  
5 specific applications. I'm not sure that -- well,  
6 maybe Joe will answer that.

7 MEMBER CORRADINI: But let me -- I mean  
8 you guys are much more adept at the process part of  
9 this. But it just strikes me that if this one, based  
10 on whatever slide you just left, the stakeholders are  
11 not in favor of it, conversely are there attributes in  
12 what it's already being applied to that can be  
13 generalized that actually develops an ad hoc approach  
14 to this.

15 So that if the next one pops up, it ought  
16 to have certain attributes that are similar to the  
17 past ones so you don't re, you know, re-earth and go  
18 through all, a lot of wasted effort?

19 MR. DUDLEY: I think we do that naturally,  
20 but Joe.

21 MR. GIITTER: Yes. No, I would agree.  
22 That's something that, you know, we don't necessarily  
23 want to adopt exactly what we did before, because I  
24 mean I could use NFPA-805 as an example. We learned  
25 a lot of lessons from NFPA-805.

1           So you know, we're a learning organization  
2           and -- well, I'll talk a little bit about that when I  
3           talk about the Risk-Informed Steering Committee. But  
4           yeah, I mean there are certain attributes that are  
5           common to all of these, and I think would be included  
6           or would be considered if we were to try to implement  
7           Option 2.

8           MEMBER CORRADINI: Does -- well, we can  
9           ask industry that. Okay, fine. Thank you.

10          MR. DUDLEY: On Slide 8, I discuss power  
11          reactor Option 3 to implement the NUREG-2150  
12          recommended RMRF. Under that recommended approach by  
13          the Risk Management Task Force, we would issue a  
14          regulation that requires all operating reactors to  
15          upgrade their PRAs to specify criteria, and then they  
16          would develop a plant-specific licensing basis, based  
17          on their plant-specific risk profiles.

18          They would have to meet NRC specified risk  
19          management objectives. But we would also have to  
20          develop enhanced criteria for determining adequacy of  
21          non-risk factors, such as defense indepth and safety  
22          margins. We have to have better criteria for these  
23          non-risk factors, or this would become a risk-based  
24          approach and not a risk-informed approach, which is  
25          the NRC's policy.



1           So based on the risk profile, licensees  
2 would implement a plant-specific licensing basis by  
3 determining on their own how they want to meet the  
4 risk objective, ensure the necessary protections are  
5 there, demonstrate the adequacy of the non-risk  
6 factors, establish a risk-informed decision-making  
7 process and a monitoring and feedback process.

8           CHAIR STETKAR: But to be clear for the  
9 members who weren't at the Subcommittee meetings, the  
10 functional difference between Option 2 and Option 3 is  
11 Option 3 would be required for all licensees, required  
12 for all licensees.

13           MR. DUDLEY: Right, that's the difference.

14           CHAIR STETKAR: Whereas Option 2 --

15           MR. DUDLEY: Option 2 is voluntary.

16           CHAIR STETKAR: Is functionally the same,  
17 but it's voluntary.

18           MR. DUDLEY: Well, the scope of the PRA  
19 for Option 3 might be larger, I think. Option 2 a  
20 licensee, based on their desired design changes, might  
21 be able to limit the scope of the PRA.

22           CHAIR STETKAR: Okay.

23           MR. DUDLEY: So the difference is one is  
24 mandatory, one is voluntary, and depending on what  
25 design changes the plant would choose, the scope of

1 the PRA might be different.

2 CHAIR STETKAR: Thanks. Thanks for the  
3 clarification.

4 MR. DUDLEY: So on Slide 9, I discuss the  
5 written public comments we got on these three options  
6 for power reactors. On Option 1, maintain the current  
7 framework. Four commenters specifically addressed  
8 Option 1, and all four of the commenters that  
9 addressed Option 1 supported maintaining the current  
10 regulatory framework.

11 On Option 2, the voluntary alternative  
12 risk-informed licensing basis, three commenters  
13 addressed Option 2 specifically, and all three again  
14 expressed some level of interest, but said the NRC  
15 hadn't developed sufficient implementation details to  
16 analyze costs and benefits.

17 Option 3 was specifically addressed by two  
18 commenters, and neither of those commenters supported  
19 Option 3 for currently operating power reactors. One  
20 commenter said the approach was simply not viable, and  
21 another thought even though there is insufficient  
22 information, in that commenter's judgment they  
23 believed Option 3 was unlikely to be justifiable for  
24 the current fleet of operating reactors.

25 So what was the staff's conclusion? The

1 staff concluded that we should not pursue Option 2 at  
2 the present time, because industry and staff do not  
3 have the resources to develop and support the  
4 approach. We determined that we should not pursue  
5 Option 3 for the operating reactor fleet, because the  
6 modest potential safety benefits are unlikely to  
7 justify the substantial implementation costs.

8 Therefore the staff, for -- under Section  
9 1 of the paper, RMRF options for nuclear power reactor  
10 safety, recommends Option 1, to maintain the current  
11 regulatory framework. We want to emphasize that  
12 Option 1 is not a do-nothing approach. All ongoing  
13 and planned risk-informed initiatives will continue,  
14 and the staff will continue to make incremental risk-  
15 informed regulatory improvements whenever appropriate.

16 By making these incremental improvements,  
17 we're maybe moving closer to a point that we could  
18 reduce some of these implementation uncertainties of  
19 Option 2. So we may get to a point where we can then  
20 -- Option 2 becomes less of a daunting challenge.

21 Okay. Section 2 of the paper is  
22 different. It addresses a reevaluation of two  
23 improvement activities recommended by the staff in  
24 Near Term Task Force Recommendation 1. Improvement  
25 Activity 1 was to establish a new design basis

1 extension category of events and regulatory  
2 requirements.

3 And the staff has determined that creating  
4 a new design basis extension category is not  
5 necessary. Instead, what the staff intends to do is  
6 to develop clear internal rulemaking guidance to make  
7 sure that all new regulations, and specifically  
8 regulations that are in the beyond design basis area,  
9 specify all of the necessary regulatory attributes  
10 that are needed.

11 That would include quality assurance  
12 requirements, treatment requirements, sorry. Quality  
13 assurance, treatment, sorry. This is embarrassing.  
14 It will -- I'll come back to that. I'm really  
15 disappointed. Okay, reporting requirements, change  
16 processes. That's right. The change process in 50.59  
17 only applies to design basis requirements. You would  
18 need to develop your own change process for beyond  
19 design basis requirements.

20 So there are six or seven different  
21 regulatory attributes that are necessary to be  
22 addressed for beyond design basis requirements, that  
23 are not necessarily required to be addressed for  
24 design basis requirements.

25 Now Improvement Activity 2 is to develop

1 criteria for -- a definition and criteria for  
2 determining the adequacy of defense indepth. While  
3 this effort could potentially succeed and we believe  
4 it could potentially succeed in establishing  
5 predictable objective criteria for adequacy of defense  
6 indepth, the resources for developing these criteria  
7 would be substantial.

8 We estimated six FTE over a period of  
9 three to four years in the SECY 13-0132 on  
10 Recommendation 1. We also note that it's possible  
11 that after having spent these resources, the staff  
12 might be unable to establish predictable objective  
13 criteria that were found acceptable to the Commission.

14 So given the current environment, as Joe  
15 was discussing, the staff recommends that the NRC  
16 should not undertake the defense indepth activity at  
17 the present time. That does not mean we recommend  
18 against never undertaking it, and in fact defense  
19 indepth criteria developing a better definition and  
20 criteria was supported by a number of public and  
21 industry commenters.

22 So this is an activity that is -- it has  
23 some stakeholder support, but at the present time we  
24 think would be -- resources are insufficient to  
25 undertake it. We will, however, go forward to update

1 the defense indepth guidance in Reg Guide 1.174 that  
2 was directed by the Commission in the SECY paper on  
3 containment accident pressure.

4 MEMBER CORRADINI: So can I summarize what  
5 I hear here, at least for Activity 1? So Activity 1  
6 basically says there will be no gray zone. There will  
7 be a black zone and a white zone, and if we come up  
8 with an issue that was beyond design basis, we're  
9 going to stick it inside the design basis with a  
10 special -- with a special event.

11 MR. DUDLEY: I don't think so.

12 MEMBER CORRADINI: My example is already  
13 you have special events. That was SBO. We've added  
14 to them FLEX. We have a hydrogen rule. All these  
15 things were considered beyond design basis and now  
16 they've been pulled in based on experience and  
17 judgment. But there shall not be a gray zone. That's  
18 how I read Activity 1.

19 MR. DUDLEY: No. I'm trying to find the  
20 right slide. Hold on. Here it is. Okay. There is  
21 the gray zone. All right. You can see the top three  
22 boxes, the green box, the yellow box and the blue box.  
23 That's the design basis. That's what we understand.  
24 That's what we note Appendix B applies to that. We  
25 have clear existing criteria for all the regulatory

1 attributes for the -- for design basis requirements in  
2 these three boxes.

3 But yet we have additional regulations  
4 that exceed the design basis. Some of them are for  
5 adequate protection and some of them are cost-  
6 justified substantial safety increases. So those  
7 regulations exist in this space, which is currently  
8 undefined.

9 The category, the Recommendation 1 was to  
10 well, let's invent a category and call them design  
11 basis extension. Well what's the utility of that?  
12 Well, it tells you that you need to specify the  
13 regulatory attributes for all of those rules.

14 Well, if I tell all the rulemakers in the  
15 rulemaking guidance that hey, if I'm beyond these  
16 three boxes, that I have to specify all those  
17 regulatory attributes in a rule, then the intent of  
18 that category is satisfied, just by us knowing how to  
19 make better rules.

20 MEMBER CORRADINI: Okay.

21 MR. DUDLEY: And we don't officially name  
22 it.

23 MEMBER CORRADINI: That's subtle enough.

24 So again --

25 MR. DUDLEY: It's there by default.

1 (Simultaneous speaking.)

2 MEMBER CORRADINI: But I guess I'm -- but  
3 I guess I'm -- the way I read Activity 1 is we've done  
4 it in an ad hoc manner. There is no reason to go back  
5 and reevaluate it, that some things may fall in and  
6 somethings may fall out.

7 MR. DUDLEY: Well, I think everything  
8 that's not within the design basis by default is in  
9 this gray area, and some of those rules that we --  
10 when we initially started writing beyond design basis  
11 requirements, I think the ATWS rule might have been  
12 the first one.

13 I think it said that the shunt trip  
14 breakers had to be reliable, and that was it. That  
15 was all that they -- those were the only regulatory  
16 parameters specified. What does reliable mean, and  
17 you know, and what if they wanted to change that  
18 design? 50.59 doesn't apply to beyond design basis  
19 requirements.

20 So over time, we started to add more and  
21 more regulatory attributes when we would write our  
22 next beyond design basis rule. We still haven't  
23 gotten it right. I think the aircraft impact rule I  
24 can't remember. It might have been quality assurance  
25 that it left out.



1 But you know, we're getting better and  
2 better. On the mitigating systems rule, knowing the  
3 full list of regulatory attributes, when we issue that  
4 rule it should be the first rule that we will issue  
5 that satisfies all of these regulatory attributes, and  
6 it will indeed have its own regulatory change process  
7 that would allow licensees to make changes to this --  
8 to the beyond design basis requirements that they're  
9 committing to under the mitigating systems for the  
10 beyond design basis events rule.

11 MEMBER CORRADINI: Okay.

12 MEMBER RAY: When you use the term "rule,"  
13 you mean to do that deliberately and not -- because  
14 there are of course a lot many things in the hierarchy  
15 of guidance, in the staff guidance and regulatory  
16 guidance and so on and so forth. But at this point,  
17 you're talking just rules.

18 MR. DUDLEY: This is -- it will be  
19 actually in the rule language for the mitigating  
20 systems rule. There will be a change process for --

21 MEMBER RAY: But I think this figure is  
22 helpful, very helpful actually. But again, we're just  
23 -- you're talking about rules. That's what we're  
24 talking about now and not --

25 MR. DUDLEY: Just about rules, yeah. Just

1 about -- when you write a regulation, that's why we  
2 can do it by putting it in the rulemaking guidance for  
3 power reactors. We have LIC-300. That's where we'll  
4 put it.

5 MEMBER RAY: And there's a presumption  
6 that rules are the basis for everything else we do I  
7 guess here.

8 MR. DUDLEY: Yes.

9 MEMBER RAY: Yeah.

10 MEMBER RICCARDELLA: Are there design  
11 basis, beyond design basis considerations or events  
12 that we have to address that aren't covered by rules?

13 MR. DUDLEY: Well, some things are  
14 voluntary --

15 MEMBER RICCARDELLA: Well no. The example  
16 that comes to mind is the seismic upgrades, the 2.1  
17 activities. Is there going to be a rule addressing  
18 this?

19 MR. DUDLEY: I can't speak to that. I  
20 really don't know. I think there are going to be  
21 rules, but I'm not knowledgeable about how that's  
22 going on.

23 MR. GIITTER: But currently those are  
24 being done under 50.54(f), as you're aware.

25 MEMBER CORRADINI: Which is an order.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. GIITTER: So what the regulatory  
2 footprint would be beyond that, I think, is still  
3 undetermined.

4 MEMBER CORRADINI: So to modify Harold's  
5 question, it's rules and orders. So what you just  
6 said is an order. So it will be done, period.

7 MR. DUDLEY: Right.

8 MEMBER CORRADINI: So okay.

9 MR. DUDLEY: Well actually the rulemaking  
10 guidance may not apply to an order, but it would  
11 certainly be good practice if we did.

12 MEMBER RICCARDELLA: To have these  
13 regulatory attributes that you listed?

14 MR. DUDLEY: Yes.

15 MEMBER RICCARDELLA: Yeah. Thank you.

16 MEMBER CORRADINI: But I'm sorry that I'm  
17 -- so on a particular issue, I get it. But when you  
18 start giving me these colored zones, in the colored  
19 zones there that are either adequate protection or  
20 cost justified, I write down the ones that I remember.  
21 ATWS, SBO, FLEX, EDMGs.

22 I'm sorry? Oh and sorry, Reactivity-  
23 Initiated Accident, RIAs. There are a list of these  
24 things that fall somewhere in the gray?

25 MR. DUDLEY: Yes, there are. Yeah, and I

1 think --

2 MEMBER CORRADINI: What I'm trying to  
3 understand, the staff's view is there's no reason to  
4 look at the various colors of gray again. They're  
5 there, we understand them, no need to regularize them,  
6 no safety benefit.

7 MR. DUDLEY: No. They're also different  
8 that, you know, if you threw them all in the gray box  
9 and said these are the requirements for the stuff in  
10 the gray, then it might not be right, because each  
11 rule has a different level of specificity, a different  
12 level of risk associated with it.

13 We're just saying that when you're in that  
14 gray area or exceeding the design basis, there are  
15 many additional regulatory parameters the rule should  
16 address for it to be full and complete.

17 MEMBER CORRADINI: I understand, okay.

18 MR. DUDLEY: And we're not telling you --  
19 in this guidance it won't tell the rulemakers what  
20 those parameters should be, you know, what the level  
21 of quality assurance could be. It just says you're  
22 going to have to decide in the rule.

23 Otherwise, when we issued all those other  
24 rules that weren't complete, we had to work it all out  
25 with guidance and it was kind of messy. We need to

1 write a rule that's clear and specific, and we're  
2 going to just do that by specifying these regulatory  
3 attributes in the rulemaking guidance. Let's see,  
4 where I am?

5 MEMBER RAY: This is what we sometimes  
6 call process. We don't like to dwell on it, but it is  
7 important, to spend some time on it.

8 MR. DUDLEY: Yes, yeah.

9 MEMBER CORRADINI: So last question, then  
10 the Chairman told me that I have to be quiet. So is  
11 there any activity inside the staff that one could  
12 evaluate this decision based on a Level 3 PRA, like  
13 the Level 3 PRA activity?

14 In other words, can one almost use the  
15 activity that you're undergoing now to actually see  
16 the various colors of gray and see if they were there  
17 and if they weren't there how to assess risk?

18 MR. GIITTER: It's a hypothetical question  
19 because --

20 MEMBER CORRADINI: I know it is but --

21 MR. GIITTER: We don't really have a lot  
22 of plants out there at Level 3 PRAs. But certainly --

23 MEMBER CORRADINI: Say the last part, I'm  
24 sorry?

25 MR. GIITTER: I said there's not a lot of

1 plants that have a Level 3 PRA.

2 (Simultaneous speaking.)

3 MEMBER CORRADINI: Yeah. But staff is  
4 doing a specific activity.

5 MR. GIITTER: Okay. Yeah, I think you  
6 could. I think the question you're asking is could I  
7 take what I know about the risk of a plant and compare  
8 it to the chart that Dick had up, and decide, you  
9 know, for that particular plant anyway whether  
10 something that was beyond design basis or design  
11 basis, where it stacked up in terms of relative risk.  
12 Yeah, certainly you could do that.

13 MEMBER CORRADINI: So instead of -- so my  
14 interpretation of the staff's opinion here is it isn't  
15 worth the effort. It is what it is right now, various  
16 levels of gray. There are rules or orders and we just  
17 live with it, and to go back and re-analyze it  
18 generically is a lot of work for little benefit.

19 But if you already have an activity where  
20 you're actually looking at it in detail, it seems to  
21 me this would be an interesting pilot to actually see  
22 where all this stuff stacks up.

23 MR. DUDLEY: Okay.

24 MEMBER CORRADINI: I have to be quiet.

25 CHAIR STETKAR: No, and for the record, I

1 didn't tell you you have to be quiet. We have ample  
2 time this morning for a fulsome discussion of this  
3 issue. So please continue if you feel that you have  
4 something pertinent to add.

5 (Off mic comment.)

6 CHAIR STETKAR: No. This is not up to  
7 vote.

8 (Off mic comment.)

9 MR. DUDLEY: Okay. So that's -- those  
10 improvement activities constitute Section 2 of the  
11 paper. Section 3 of the paper again is the only  
12 section that applies on an agency-wide basis. So it  
13 applies to all program areas. It also applies to both  
14 radiological safety and common defense and security.

15 We believe that an agency-wide risk  
16 management policy statement could potentially improve  
17 and make more consistent the regulatory framework used  
18 for all program areas. That was in the Risk  
19 Management Task Force report.

20 I mean I think it's true. It's perhaps  
21 debatable, but I believe it's clearly in the Risk  
22 Management Task Force report. The NRC requested  
23 public comments on two different draft example policy  
24 statements. We issued one in November of 2013 and we  
25 issued another in May of 2015.

1           The public comments on both of those draft  
2       example policy statements were generally not  
3       supportive, and on the most recent draft, only one of  
4       ten commenters supported an agency-wide risk  
5       management policy statement.

6           Generally, the reasons for not supporting  
7       one were that the commenters believed that NRC can  
8       appropriately risk-inform its regulations under the  
9       current policy and guidance, that you don't need to  
10      establish an agency-wide policy statement before you  
11      can go and risk inform individual programs.

12          There were also concerns expressed about  
13      the use of NRC and licensee resources to do this, to  
14      try to get a one-size-fits-all policy statement that  
15      would apply across all program areas, and would that  
16      be useful. To have it apply to everything, it might  
17      have to be at such a high level that it might not  
18      really be useful or very insightful.

19          The staff's evaluation is that we agree  
20      with the public commenters, that NRC programs can be  
21      appropriately risk-informed without an agency-wide  
22      risk management policy statement. We believe it would  
23      not be appropriate to divert NRC and licensee  
24      resources to work on such a policy statement, and  
25      therefore the staff recommends against developing a



1 agency-wide policy statement. Are there any questions  
2 on Section 3 of the paper?

3 And you'll be hearing or you were given a  
4 non-concurrence by one of the members on the working  
5 group, that the agency-wide policy statement is one of  
6 the elements of that non-concurrence.

7 So I was also asked to tell you what  
8 changes. When I met with the Subcommittee on October  
9 19th, the paper was an office concurrence, and I was  
10 also asked then to tell them what did we change as a  
11 result of office concurrence. You can -- the most  
12 significant changes are shown in the changes to our  
13 recommendations.

14 The text in red is added text as a result  
15 of office concurrence. So Recommendation 1 is  
16 maintain the existing regulatory framework and we made  
17 it clearer, throughout the paper, that this is for the  
18 nuclear power reactor safety program area. So there  
19 were a number of additional changes made throughout  
20 the text of the paper, to make clear that when we say  
21 maintain the existing framework, we mean for nuclear  
22 power reactor safety only.

23 But we also added, and I'm just going to  
24 read this, that the NRC will continue its long-held  
25 commitment to the defense indepth concept, to the

1 regulation of nuclear reactor issues beyond the  
2 traditional design basis events where appropriate, and  
3 to the inclusion of the defense indepth concept as the  
4 central component of risk-informed regulation.

5 Although we're not recommending going  
6 forward today to develop the definition and criteria  
7 for defense indepth, we added these words to make it  
8 very clear that we're not going backwards either. We  
9 maintain our long-held commitment to defense indepth.

10 In Recommendation 2, the recommendation is  
11 to refrain from developing an over-arching agency-wide  
12 risk management policy statement. But we also added  
13 language that ongoing staff activities to implement  
14 risk-informed approaches within NRC program areas will  
15 continue to move forward, and are not impacted by the  
16 staff's recommendation against developing an  
17 overarching agency-wide risk management policy  
18 statement.

19 There was some concern that some might  
20 think that if we say don't do an agency-wide  
21 statement, that might mean that other offices that are  
22 working on risk informing things other than nuclear  
23 power reactor safety, that that would affect their  
24 ongoing efforts. We want to make it clear that no,  
25 those efforts can and should proceed.

1           The last section of the paper, the  
2           Commission asked to explain the interrelationships  
3           between a number of ongoing risk-informed initiatives  
4           for nuclear power reactor safety. That was in the SRM  
5           on SECY 13-0132.

6           We've done that in Section 4 of the SECY  
7           paper, where we've listed the risk-informed  
8           initiatives that we're aware of and we've tried to  
9           explain how they're related to one another.

10          So that completes my presentation. Next,  
11          Joe Giitter is going to talk about the Risk-Informed  
12          Steering Committee and how it does forward-looking  
13          planning actions. Joe.

14          CHAIR STETKAR: Thanks Dick.

15          MR. DUDLEY: Sure.

16          CHAIR STETKAR: Before we let you off the  
17          hook, do any of the members have any other questions  
18          for Dick, on the material we've heard about? If not,  
19          Joe you're up.

20          MR. GIITTER: Okay. I'm just going to  
21          talk from here. I just have one slide. I wanted to  
22          point out, this should be in quotes, but this comes  
23          right out of the charter for the Risk-Informed  
24          Steering Committee, and one of the taskings or one of  
25          the charter items is to provide strategic direction to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 the NRC staff, to advance the use of risk-informed  
2 decision-making in all aspects of our -- how we  
3 regulate in licensing oversight, rulemaking, other  
4 regulatory areas. So pretty broad direction.

5 As I'll talk about in just a minute  
6 though, I think the focus right now of the Risk-  
7 Informed Steering Committee, although it is forward-  
8 focused in a number of areas, I think the primary  
9 focus is to remove some of the obstacles to risk-  
10 informed decision-making, and I'll talk a little bit  
11 about those.

12 The chairman of the Risk-Informed Steering  
13 Committee is the office director of NRR, Bill Dean,  
14 and we have representatives or other members or deputy  
15 office directors from the offices, as you see up  
16 there, Research, NMSS, NSER, NRO and we also have a  
17 regional -- a Region I regional administrator to have  
18 regional representation.

19 So the focus so far of the Risk-Informed  
20 Steering Committee is to deal with some of what are  
21 viewed as obstacles to future risk-informed decision-  
22 making. Probably the biggest focus area coming out of  
23 NPFA-805 was PRA technical adequacy.

24 One of the issues, and I know we've talked  
25 to the ACRS about this before, with NFPA-805 was the

1 peer review process that was envisioned didn't exactly  
2 work out the way that people expected it to. Those  
3 are my words. But I'll give you an example. When  
4 fire PRAs were developed by licensees, typically by  
5 contractors, they used new methods, and the new  
6 methods were methods that the NRC had never seen  
7 before.

8 In some cases, they used the screening  
9 methods in NUREG CR 6850, but in many cases they felt  
10 those were too conservative, so they used new methods.  
11 The peer review would come in and in the process of  
12 identifying facts and observations, they would note  
13 the new methods.

14 They would turn the facts and observations  
15 over to the licensee. So when NRC received an  
16 application, one of the things they would do is go out  
17 and do an audit, and one of the things they noted was  
18 that a lot of the facts and observations weren't  
19 closed out. A number of RAIs we had pertained to the  
20 licensees, you know, with the steps they had taken to  
21 close out some of the facts and observations.

22 In many cases, the facts and observations  
23 that were open related to these new methods. So the  
24 NRC found itself during the NFPA-805 review of trying  
25 to resolve the new methods initially as part of the

1 individual licensing reviews, and then in parallel.  
2 So some of the changes that are being proposed under  
3 this PRA technical adequacy is just to develop a  
4 vetting panel, and then the vetting panel would  
5 include some NRC membership on it.

6 It ultimately would decide when there's a  
7 new method, what is the appropriate process for  
8 dealing with that new method, and that could be a wide  
9 range of things. Something as substantial as going to  
10 a separate EPRI panel, if it's a very complicated or  
11 technically detailed method, to the possibility that  
12 it's a method that's well-established, but perhaps not  
13 widely used in the nuclear industry.

14 So the vetting panel, I think, is one step  
15 to address the new methods issue. The other one is to  
16 provide better direction on closing out the F&Os. So  
17 those are some issues that are being addressed under  
18 technical adequacy.

19 Another area is the treatment of  
20 uncertainties and decision-making. We had working  
21 groups, by the way, for PRA -- we have working groups  
22 for PRA technical adequacy and for treatment of  
23 uncertainties, and there's white papers that the NRC  
24 has been reviewing that industry has prepared.

25 I think we're, you know, we've had a

1 number of public meetings to address these. So I  
2 think we're pretty close on both of these. Treatment  
3 of uncertainties, we already came and addressed the  
4 ACRS Subcommittee on reliability and PRA on the work  
5 going on and for that particular working group. That  
6 issue has largely to do with the fact that when you're  
7 looking at the risk contribution from different  
8 initiators, you're going to have different  
9 uncertainties associated with that.

10 So for example, with internal events,  
11 you're going to have, you know, a much narrow band of  
12 uncertainties than you might with an external event  
13 like flooding or seismic, where there's a great deal  
14 of uncertainty in the frequency.

15 So how do you deal with that in an  
16 integrated decision-making process? You don't just  
17 add those initiators together and say well this is the  
18 total risk of the plant, because the uncertainties  
19 associated with those different initiators varies  
20 widely. So that's what the working group number two  
21 is looking at.

22 Another area that the Risk-Informed  
23 Steering Committee is looking at is how do we provide  
24 PRA credit for mitigating strategies? There are a  
25 number of licensees that are making changes to their

1 PRA models to model FLEX. So the question is how do  
2 we do that? What are the -- we need to make sure that  
3 whatever we do it's consistent.

4 So that's an effort that's currently  
5 ongoing right now with the Risk-Informed Steering  
6 Committee. Then the last thing I listed here, and  
7 these aren't all the things the Risk-Informed Steering  
8 Committee is looking at, but these are just examples.  
9 The last one is RMRF, and we did brief the Risk-  
10 Informed Steering Committee on the recommendations of  
11 the RMRF and received their feedback and comments.

12 So again, I think these are all short-term  
13 focused areas. But they're viewed as things that we  
14 need to address now, and that will set the stage, I  
15 think, for being able to think further into the  
16 future, once we've removed -- once some of these  
17 obstacles to risk-informed decision-making are  
18 addressed.

19 MEMBER SCHULTZ: Joe, what I've heard in  
20 your discussions and see on the slide is that what the  
21 Committee has been working on is kind of the tools of  
22 the process, and improving the way things are done.  
23 Was there established at any point a goal or an  
24 objective, a long-term focus for where the Committee  
25 intends to go? A risk management regulatory framework



1 might have been that, but in concluding that we're  
2 going to go with Option 1, to say well, we'll just  
3 move forward and do what we have been doing, it seems  
4 to negate the opportunity to have some structure.

5 In other words, we're kind of working on  
6 the tools, on the plumbing and a little bit of  
7 electrical, but we don't seem to have a picture of  
8 what the house is going to look like when we're all  
9 done. It would be helpful.

10 MR. GIITTER: Yeah, no. I think that's a  
11 fair statement. I mean they are looking right now at  
12 the tools, if you will. But there is a recognition,  
13 as stated in the charter, that they are to provide  
14 strategic direction of -- let me use an example -- of  
15 what, how we see risk playing a role in the future.

16 So we're doing that not -- I wouldn't say  
17 at a visionary level necessarily, but we're doing that  
18 more at a tactical or maybe somewhat strategic level.  
19 An example of that is a current focus within NRR. We  
20 spent a lot of time and energy on compliance issues of  
21 very low safety significance as measured by risk.

22 So one of the things that we're looking at  
23 is how do we -- early on in the process, let's say a  
24 CDBI inspection uncovers non-compliance. How do we  
25 bring risk insights into evaluating the significance

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 of that early on? If we can bring risk insights into  
2 evaluating the significance of that early on, it can  
3 save us from spending a lot of resources, if it turns  
4 out that that particular issue is of low safety  
5 significance.

6 But right now, compliance equals safety,  
7 and it doesn't matter whether it's a low safety  
8 significant item or something, you know, that's highly  
9 safety significant. We treat everything the same. So  
10 what we're trying to do is to take a measured approach  
11 and to work smarter using risk as a tool, if you will,  
12 for doing that, for making those decisions.

13 MEMBER SCHULTZ: It seems like a start,  
14 but I appreciate the comment back. Thank you.

15 MEMBER CORRADINI: So can I ask it  
16 slightly differently His house analogy is great. I  
17 want to write that one down. So today you have a  
18 three bedroom home, a tract home and you have 100,  
19 plus or minus, depending who's up and down and closing  
20 and not closing.

21 You have 100 tract homes that look  
22 approximately the same. Some three bedroom split  
23 level, some three bedroom ranch style, and there's no  
24 reason to go in and rethink about how you're going to  
25 architecturally change these, but you can do them

1 little by little, as you said plumbing, whatever.

2 So are there any new homes on the market  
3 that actually could benefit from this? So new plants,  
4 or is NuScale and mPower so similar to current things  
5 there's no benefit there?

6 MR. GIITTER: Do you want me to try to  
7 comment on that?

8 MEMBER CORRADINI: And then I'm going to  
9 ask you something else about, since you had the  
10 workshop with DOE on September 1st, and everybody was  
11 all over you about your regulatory process for advance  
12 plants, and there's going to be another activity this  
13 week again on that, I'm curious on how you're looking  
14 forward to the new home designs?

15 MR. GIITTER: I don't know if we have  
16 anybody from NRO here, but I can give you -- this is  
17 my own personal observation, because early in my  
18 career, I worked on the licensing of a liquid metal  
19 fast breeder reactor. It was my job to go through  
20 NUREG-0800, the Standard Review Plan, and to show how  
21 it applied or didn't apply to this particular design.

22 Personally, I feel strongly that looking  
23 at, especially Gen IV reactors, we can't adopt the  
24 current paradigm of light water reactors. I think  
25 it's an opportunity to take a fresh look, and I had

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 some discussions with Mike Mayfield. We have a  
2 statement in the SECY paper that talks about possibly  
3 using something like an RMR type framework, you know,  
4 for these types of reactors.

5 It doesn't say you can't use a current  
6 framework, but personally I think it takes more effort  
7 and more work and, you know, now that we have a clean  
8 slate, why not look at that as an opportunity. But  
9 that's my personal view, and I want to make it clear  
10 I'm not speaking for NRO.

11 MEMBER CORRADINI: So looking down the  
12 pike, this is not the right time to start that, or is  
13 it a matter of resources that it's inappropriate to  
14 use current resources on licensing fees to do it? I'm  
15 looking for --

16 So I'm totally in process mode now. But  
17 it strikes me that if you're saying I've got the  
18 current 100 plants and things ad hoc are perfectly  
19 fine, if I look down the road, do I want to do  
20 something for the next things that I'm expecting to  
21 have to deal with now, and is it simply a matter of  
22 resources that we can't do it now?

23 CHAIR STETKAR: I didn't see John was  
24 here. John.

25 MR. MONNINGER: Good morning. This is

1 John Monninger from the staff. I'm the director of  
2 the Division of Safety Systems and Risk Assessment in  
3 NRO. We are doing various activities to hopefully  
4 improve the regulatory framework for advanced reactors  
5 and SMRs. I think it depends a lot about the  
6 different categories of plants you're talking about.

7 One of the activities underway for the Gen  
8 IV reactors is a re-look at the GDC, the general  
9 design criteria. The Department of Energy submitted  
10 a report earlier this year and we're going through the  
11 GDC and looking at which of those GDC apply to the  
12 advanced reactor designs, what should be modified and  
13 what should potentially be added.

14 When you look at something like the SMRs,  
15 for example, most likely the closest design coming in  
16 would be the NuScale design, to a large extent they're  
17 proposing to follow the current approach. Each  
18 applicant with their submittal with their application,  
19 they are to propose GDC that are applicable to their  
20 plant.

21 The GDC in effect were developed in the  
22 70's, based upon the experience at that time. So  
23 NuScale has come in and they've defined certain  
24 technical issues that they believe they need  
25 departures from or, I guess in a similar manner, the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 staff is looking at the NuScale design to see whether  
2 it introduces any new policy issues associated with  
3 their design.

4 So there is some activities underway, but  
5 I wouldn't say a significant amount is not underway.

6 MEMBER CORRADINI: So John, since you're  
7 there, so is it a matter of if there were resources  
8 there to think of the future for the Gen IV, it would  
9 be worth doing, or it's just too early?

10 MR. MONNINGER: So I think one of the big  
11 issues for the advanced reactors is resources, and you  
12 know, how much can the agency plan for the future not  
13 quite sure whether the future will occur or not. You  
14 know, there are quite a few small corporations out  
15 there interested in advanced reactors and talking  
16 advanced reactors, but it's very difficult to know,  
17 you know, which direction it will ultimately go.

18 MEMBER CORRADINI: Okay, thank you.

19 CHAIR STETKAR: Anything else for Dick or  
20 Joe? If not, I'd like to thank the staff for  
21 providing us a good overview of the paper, and next up  
22 we're going to hear from the owners groups.

23 They have several comments and had some  
24 quite interesting material at our Subcommittee  
25 meeting. So we felt it would be good for the full

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 Committee to hear from them. I don't know which one  
2 is -- apparently the Pressurized Water Owners Group is  
3 up first. So I'll call them up.

4 MR. FINE: Good morning. My name is  
5 Raymond Fine. I'm lead supervisor of PRA at  
6 FirstEnergy Nuclear Operating Company, and I'm also  
7 the vice chair of the Risk Management Committee for  
8 the PRA Owners Group. I'll be presenting today on the  
9 PWR perspective and Bob Rishel will be presenting from  
10 the BWR perspective, and then Victoria will finish up.

11 So overview. We have the current state,  
12 successful applications, challenges and recommended  
13 path forward. The current state is we have a  
14 tremendous number of applications and guidance through  
15 the Reg Guides, through Reg Guide 1.200, through peer  
16 review activities, and everything that is working  
17 currently in process to allow us to get into the more  
18 advanced risk-informed applications.

19 And all of this framework that's currently  
20 in place we've worked very hard to create the game, so  
21 we know what we have to play to get to the goal. So  
22 these set the criteria for how we move forward, and  
23 then we have to get our management and staff and  
24 everybody moving in that direction, and that's a  
25 tremendous amount of momentum.

1           So the successful applications that we do  
2 now and many plants are going after are surveillance  
3 frequency control program, risk-informed completion  
4 times, 50.69 maintenance rule, MSPI and so forth, and  
5 as we develop new and advanced models, we'll start  
6 asking for more things. It's the unknown unknowns  
7 that we don't know what we're going to ask for next.

8           But we'll keep asking and we'll keep  
9 moving. You know, we'll talk about a couple, like you  
10 know, now that we have FLEX, we're going to start  
11 going after FLEX and then we'll go after the next  
12 thing when it comes up. So this is an evolving  
13 process that we're working on.

14           You know, we have challenges, but none of  
15 our challenges are insurmountable. All these  
16 challenges are the natural progression and natural  
17 learning process that we go through with the staff and  
18 our own management. You know, we have PRA technical  
19 adequacy, treatment of uncertainty, incorporation of  
20 FLEX, risk aggregation, all these the staff just  
21 discussed.

22           All of these we're moving forward on  
23 through the Risk Committee, and none of these were on  
24 our radar a few years ago. They're on our radar now.  
25 So you know, as we evolve, we learn more, the more we



1 change, the more we adapt and everybody learns.

2 We have -- wrong way. So our recommended  
3 path forward, because we have so much invested in this  
4 and we need regulatory certainty and stability to move  
5 forward, we recommend that they stay on the path that  
6 we're on right now.

7 You know, I should say, you know, me and  
8 many of my peers are change agents. PRA is very much  
9 about change and adapting and learning and growing,  
10 and you know. So we're not saying that staying the  
11 current path is not change. We absolutely want  
12 change. It's just we want controlled change,  
13 predictable change, something we can manage, not just  
14 throw out everything and start over, you know.

15 That's too much change and everything will  
16 stop with that change. So we have a significant  
17 effort that's already been extended by both us and the  
18 NRC. The current framework is well understood. We're  
19 leveraging existing lessons learned and improving, and  
20 we continue to improve.

21 Now the 10 C.F.R. 50.46(a), risk-informed  
22 emergency core cooling and so forth, these are all  
23 evolutionary, revolutionary ways of looking at things.  
24 So you know, we continue to challenge and you know,  
25 even though we today don't know what we want to do

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 next, we will continue to move forward, because that's  
2 what we do.

3 So in conclusion, the PWR Owners Group  
4 endorses the staff's recommendations in the draft SECY  
5 paper, to maintain the current regulatory framework.  
6 The NTTF Recommendation 1 improvement activities,  
7 development of an overarching agency-wide policy  
8 statement is not needed.

9 We think the current policy statement is  
10 sufficient, and the PWR Owners Group will continue to  
11 work with the staff and ensure appropriate methods are  
12 available to develop, implement and regulate risk-  
13 informed applications and risk-informed regulation.  
14 So much faster than the last time, but --

15 CHAIR STETKAR: That was efficient.

16 (Laughter.)

17 MR. FINE: Well you wanted it faster so --

18 CHAIR STETKAR: I don't know. We're  
19 actually very -- we're well ahead of schedule. So we  
20 don't need to rush through this.

21 MEMBER CORRADINI: So can I ask the same  
22 question I asked of the staff relative to a Level 3  
23 PRA. So are there Level 3 PRAs that are within the  
24 PWR Owners Group that you've actually used as a way to  
25 gauge all of these various individual risk-informed

1 activities, or current things that are beyond the  
2 design base? Well, I'll say this wrong. That are  
3 kind of extensions into the beyond the design base,  
4 ATWS, Station Blackout, etcetera, that the various  
5 risk, if you were to risk categorize them as to which  
6 one improves the most, which one improves the less in  
7 terms of safety?

8 MR. FINE: The only example we have  
9 undergoing right now is Vogtle. Just we're piloting  
10 it with the NRC.

11 MEMBER CORRADINI: Would that be an  
12 interesting activity to at least -- I'm looking for --  
13 I can't come up with the right word. I want to just  
14 say "categorize," but essentially rank order some of  
15 the things that are being required by order or rule  
16 and see how much it really improves safety? Or what  
17 things you could drop because it doesn't?

18 MR. FINE: I don't see how Level 3,  
19 because we haven't really learned a lot about it yet.  
20 But I don't see how Level 3 is going to help with  
21 that. Level 3 could help with like e-plan or  
22 something like that, you know, risk informing that  
23 whole process.

24 What we do currently with Level 2 PRAs  
25 with external hazards gives much more information than

1 a Level 3 would give. So if we were --

2 MEMBER CORRADINI: So going back to that  
3 then, if that gives you more information, is there  
4 some example of where the industry or at least the  
5 owners group has looked into this and decided how  
6 these things all kind of are prioritized in terms of  
7 --

8 MR. FINE: I'm going to let Victoria  
9 answer.

10 MS. ANDERSON: So I believe this can be a  
11 start about the prioritization initiative, that both  
12 the NRC and the industry took on together. So I mean  
13 I think that's sort of --

14 CHAIR STETKAR: Yes, we have.

15 MS. ANDERSON: Probably more than you  
16 wanted to. But I think that's sort of where that kind  
17 of work would be going on, and I didn't work very  
18 closely with that. But I believe that didn't call for  
19 a Level 3 PRA. That was just using existing risk  
20 information, and people were, would -- they would be  
21 able to use that guidance to help prioritize  
22 activities.

23 MR. RISHEL: Bob Rishel from BWR Owners  
24 Group and Duke Energy. I would just add that the BWR  
25 Owners Group does have a plan on the books to go

1 forward with both Level 2 and Level 3, to try and  
2 provide some tools of our members on how to do that.  
3 Just personally, you know, Duke Energy does use Level  
4 2 on the fringes, I would say.

5 But you know, when we start talking about  
6 Level 2, the uncertainty really starts to climb, much  
7 moreso than LER. So that is one issue that is sort of  
8 worth thinking about when we think about Level 2 and  
9 then subsequently Level 3. What the uncertainties in  
10 that are tend to get even larger.

11 CHAIR STETKAR: Victoria, just for the  
12 public record in this meeting, we not only have heard  
13 about the risk prioritization; we wrote a letter on it  
14 March 11th of this year. So we're -- ACRS is on the  
15 record on that issue.

16 MS. ANDERSON: Okay. I was fairly certain  
17 you had heard a lot about it.

18 CHAIR STETKAR: Yeah, we have. Yeah.

19 MR. RISHEL: So I'm Bob Rishel from Duke  
20 Energy and the BWR Owners Group, and I'm the chairman  
21 of the Informed -- Risk-Informed Regulation Committee.  
22 So we'll discuss where the BWR Owners Group with PRA  
23 and where we're going in the near term, and future  
24 applications that we would like to see the NRC pursue.

25 Mr. Giitter talked a lot about -- go back

1 -- about the technical adequacy. We'll talk about  
2 that and the peer reviews and then we'll talk about  
3 our Option 2s and 3s. So BWR Owners Group is --  
4 supports the continual evolution incremental approach.  
5 Licensees are continuing to develop new hazard models,  
6 and it's mostly driven by business need more than  
7 anything else.

8           You know, there's a need there, so or a  
9 concern. So currently like that of Fukushima, there's  
10 a flooding, external flooding PRA work; there's  
11 seismic PRA work going on, which will then also feed  
12 into all the applications. Then companies are making  
13 decisions about whether they need to -- even though  
14 they're not required by the order to do those things,  
15 whether they think those are beneficial for them for  
16 whatever risk applications they may be having.

17           I would -- I'd add that model maintenance  
18 is a continual process, and model upgrades have to be  
19 done as part of the evolution going on. Many of the  
20 plants, as a result of both the order and for other  
21 reasons, are making plant design changes. Some of  
22 them are relatively significant changes, added  
23 capabilities, be it diesel driven cooling pumps that  
24 are permanently installed and permanently installed  
25 additional diesels are the typical things that are

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1       being done.

2               But I would add that PRA model development  
3       and maintenance, the cost of this to our -- to an  
4       individual utility has grown quite a bit. 805 is  
5       another very large cost burden to maintain that model.

6               MEMBER SCHULTZ:     Bob, before you go  
7       forward, I want to get an appreciation for what you've  
8       said the owners group's activity is. Is it -- has the  
9       owners group taken on a common process that is being  
10      established for BWR licensees, that is effective in  
11      coordinating what individual licensees are doing and  
12      transferring knowledge from one licensee to the other  
13      in the applications?

14              MR. RISHEL: There's a lot of information-  
15      sharing between licensees.

16              MEMBER SCHULTZ: Is that done through the  
17      owners group or is it done through their own devices?

18              MR. RISHEL: It's both. The owners group  
19      is trying to facilitate it. We're developing  
20      databases on what -- so that everybody can look at  
21      each other's models and compare how do I stack up?  
22      Why is Limerick this way and I seem to be an outlier?  
23      Make sure I understand what the -- in many cases the  
24      design issues are that might be driving those, or is  
25      it go back to is there a methodology being used that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 I'm not using or I could learn from.

2 The other part is we took an effort on  
3 this past year, to try and see what we can do about  
4 fire PRAs, to try and cut down the effort on what's  
5 required, to try and get at the meat of what the fire  
6 PRA should tell them.

7 Now that's probably not good enough for a  
8 805 submittal, but it might be good enough for risk  
9 applications, and we're continuing that on with the  
10 seismic effort, to see if there's something that we  
11 can put out there as a template on how to get to it.

12 MEMBER SCHULTZ: The owners group is  
13 acting as a facilitator?

14 MR. RISHEL: Yes.

15 MEMBER SCHULTZ: As well as a librarian?

16 MR. RISHEL: As well as setting up a --  
17 correct.

18 MR. FINE: This is Ray Fine. Plus we work  
19 with EPRI and NEI. So if it's R&D that generic all,  
20 for example like high frequency relay testing, well  
21 then EPRI will take that as a lead, and then we'll  
22 feed off of that and then share amongst each other  
23 what we did.

24 So like on my seismic PRAs, I've done  
25 three and we're pretty much done. We're just wrapping

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 up, and the -- all of my notebooks, template. It is  
2 an industry template. I've shared it with everyone,  
3 including vendors, so that everybody has a template to  
4 work by, on how to do these seismic PRAs, because it  
5 is a very complex project.

6 And so as I progress through each of my  
7 plants, I developed this template and then I said okay  
8 guys, now follow this and you'll be at least 50  
9 percent there. So and then that also allows us to  
10 have better consistency in peer review; it allows us  
11 to have better consistency in the application and the  
12 submittal, because we all did it pretty much the same  
13 way.

14 Granted, I was a rock site, Vogtle was a  
15 soil site. They were doing the template with us. But  
16 as these sites change, they'll be uniqueness in them.  
17 But the general concept of what is there, where to  
18 find it, it's all going to be the same.

19 MEMBER SCHULTZ: Is the PWR Owners Group  
20 also have the focus for lessons learned in fire PRA,  
21 for example?

22 MR. FINE: Yes, yes. Very much so, and we  
23 worked with EPRI and NEI very closely, and the Risk  
24 Committee for that matter. Fire is hot topic, so  
25 everybody stays very tight on that. Yeah.

1 MR. RISHEL: No pun intended.

2 MEMBER SCHULTZ: I wish I had a snare  
3 drum.

4 MR. FINE: But even on seismic, yeah we --  
5 all these different new things that we're doing, even  
6 regarding FLEX and PRA, that now has both BWR and PWR.  
7 I'm on that committee and we have multiple people,  
8 plus EPRI is on the committee. All these people that  
9 need to be in the room are in the room, and we do it  
10 as a unified effort.

11 MR. RISHEL: I would be remiss. EPRI also  
12 has a very, and we've been pushing them, a robust  
13 effort on knowledge-sharing on a specific topic. HRA  
14 is probably the biggest one with uncertainty coming  
15 up, and just the generic, you know, how-to is also  
16 EPRI holds the workshops quite frequently across the  
17 country.

18 We've had two in Charlotte in the past two  
19 months, with various utilities coming in to Charlotte  
20 and getting essentially a week seminar on various  
21 actions or technical knowledge.

22 MEMBER SCHULTZ: One reason that I'm  
23 pursuing this is every time fire PRA is mentioned,  
24 there's a big groan in the room that comes forward.  
25 Again, unless we're learning those lessons and not

1       only learning them but figuring out ways to apply them  
2       to these additional initiatives going forward, we're  
3       going to be in the same place.

4               MR. FINE:   Oh absolutely, yes.   We were  
5       worried about that when we moved forward on seismic,  
6       because we're like well if seismic goes the way fire  
7       went, this is going to be a very bad day.   But luckily  
8       everybody's learned from that experience, and we're  
9       not doing that.   So seismic seems to be moving much  
10      smoother, with much more agreement than fire did.

11             MEMBER SCHULTZ:   Thank you.

12             MR. RISHEL:   So I mentioned fire.   So  
13      there it is.   Fire PRA, there are concerns with the  
14      over-conservatism and we also have similar concerns  
15      with seismic, especially in the fragility analysis  
16      area.   We are working with EPRI to try and improve  
17      those state of knowledge.   These conservatisms do  
18      impact our ability to use our PRAs in some sort of  
19      licensing action or a tech spec action.

20             MEMBER SCHULTZ:   Is that because the  
21      uncertainties are so large or we don't know how to  
22      handle the uncertainty in the analysis?

23             MR. RISHEL:   I think it's three things.  
24      One is the uncertainties are large, and we tend to  
25      default to the high for the uncertainty.

1                   MEMBER SCHULTZ:       The treatment of  
2       uncertainty.

3                   MR. RISHEL: The treatment, and we are --  
4       currently we're adding them up. So we're adding the  
5       uncertainty of seismic with uncertainty of fire and  
6       coming up with a number. Those are the two major  
7       drivers of the issue.

8                   VICE CHAIR BLEY: Why do you live with a  
9       plant estimate at the high end, when you have the  
10      uncertainty distribution? You don't know how to  
11      handle them?

12                  MR. RISHEL: Well, let's take fire, for  
13      example. So in fire, much of the uncertainty is in  
14      the fire itself. We can do the uncertainty  
15      distribution of the event trees, of the circuit  
16      failures.

17                  But when we start talking about non-  
18      suppression probabilities, detection time, fire  
19      growth, those are very uncertain. So there's two ways  
20      to handle that. One is to chop up the fire scenarios  
21      into small pieces and that can be done, and then you  
22      add it up.

23                  Of course a lot of it, a lot of the fire  
24      would drop off the table, as it doesn't leave the  
25      cabinet. It doesn't do any damage other than the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 component itself. But if I try and put that into a  
2 probability distribution, that gets very complicated  
3 very quickly. So our probability distribution for  
4 fire is somewhat limited by the ability to do that.

5 VICE CHAIR BLEY: I mean all those curves  
6 you're using were put together either from data or  
7 from expert groups that the industry and NRC  
8 participated in. It's not that they're artificial;  
9 it's that that's the best people could do. You have  
10 tools for --

11 MR. RISHEL: We do have tools --

12 VICE CHAIR BLEY: --for working with that.  
13 I mean it's not surprising if you just take the high  
14 ends of everything that you get an answer you don't  
15 like a whole lot.

16 MR. RISHEL: Correct, and part of it is in  
17 some cases, there is schedule pressure, you know,  
18 under fire, especially under 805. It was get done and  
19 okay, I don't like the answer. How can I improve my  
20 uncertainty, reduce my uncertainty?

21 CHAIR STETKAR: But Bob, modern computer  
22 codes, I can push a button a propagate uncertainties  
23 faster than you can tell me it takes too much time to  
24 do that.

25 MR. FINE: It's not that simple. This is

1 Ray Fine.

2 CHAIR STETKAR: It isn't?

3 MR. FINE: No. There isn't --

4 CHAIR STETKAR: No, it's not. But I've  
5 seen people do it.

6 MR. FINE: Well no. It's the fact that  
7 you have a combination of deterministic input and  
8 probabilistic input, and some of that is inherent in  
9 the actual model building. So when you put together,  
10 you know, I can give a different example taking the  
11 seismic route. If you look at how we calculate the  
12 fragility of a component, you start with the  
13 structure. Then you get to its particular location.  
14 You propagate into the component itself, and then you  
15 calculate a fragility.

16 All of those can be all based on  
17 probabilities, or you can actually do deterministic  
18 math. The thing is that whether you use separation of  
19 variables, which is the probabilistic method or CDFM,  
20 which is the deterministic method, you get about the  
21 same answer, okay. But all of them have inherent  
22 built-in conservatism.

23 For example, you know, when we do the  
24 fragility analysis on the structure, and we're looking  
25 at how the steel moves and the concrete moves, well

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 civil engineers built in a lot of safety factor in  
2 those numbers, okay, in some cases a factor of five or  
3 ten.

4 It's really difficult to back-calculate to  
5 what the median is, because they didn't actually give  
6 you the median number. They gave you a number that,  
7 with a fairly good certainty, it won't fail.

8 MEMBER CORRADINI: It met the code.

9 MR. FINE: Yes, because it met the code,  
10 right. So nobody knows what the actual failure of  
11 that beam is or where it's going to break. They built  
12 it to the code, okay.

13 So the -- and each time you take -- you  
14 know, first I view the building. Then I go to the  
15 frame that the structure is sitting on or the  
16 component is sitting on. Then I go to the component  
17 itself. Each one of those compounding conservatisms  
18 has that inherent deterministic bound in it, plus the  
19 probabilistic bound in it.

20 The only part we're really tracking is the  
21 probabilistic part. So we don't know how to undo and  
22 get to realism on the actual when does this thing  
23 fail, you know, and that's the hard part. It's  
24 bounded by at least a factor of five.

25 MEMBER CORRADINI: So you're saying

1       there's an inherent conservatism because if I follow  
2       code in all the building of the components, there's no  
3       way to unravel that as to what the actual failure,  
4       where the actual failure might be compared to where  
5       the code is satisfied?

6               MR. FINE: That's correct.

7               MEMBER RAY: Yes, but the conservatism is  
8       there for a purpose.

9               MR. FINE: Correct.

10              MEMBER CORRADINI: No, I understand that  
11       conservatism is there for a purpose, because you make  
12       darn sure it doesn't fail.

13              MR. FINE: But will it fail in real space  
14       is the question.

15              MEMBER RAY: You make darn sure it doesn't  
16       fail because of uncertainties in your design.

17              MEMBER CORRADINI: Well, but the moment --  
18       so I think Harold was going where I was going to ask.  
19       So the moment you start unraveling and say well the  
20       code is conservative, then you have to take care of  
21       all the uncertainties of the manufacturing of that  
22       component and all those uncertainties. Unless I'm off  
23       base, I don't think you really want to go there,  
24       because that's a rat's nest.

25              MR. FINE: Exactly, and that's what Bob's



1 saying, is that there comes a point where tracking the  
2 uncertainty becomes impossible.

3 MR. RISHEL: And I would -- I would just  
4 add, at least in fire, that you know, we're working on  
5 the uncertainty. So NUREG-2178 was out with heat  
6 release rates. So that gives us an opportunity to go  
7 back and revisit a lot of issues, and try and remove  
8 some more of that uncertainty.

9 VICE CHAIR BLEY: I'm glad you said that,  
10 because earlier, you're right. You were under time  
11 pressure to get things done and you had to take, get  
12 there. Over the next few years, you'll have time to  
13 do some of those things more carefully --

14 (Simultaneous speaking.)

15 VICE CHAIR BLEY: --and I think that's an  
16 important point.

17 MR. RISHEL: Many plants have either put  
18 a plan on the table to go start that or there's a few  
19 actually that have started using it.

20 VICE CHAIR BLEY: And that time pressure  
21 came from a lot of sources, some here, some out there.  
22 Eventually, it came to a head.

23 MR. RISHEL: Some were self-induced.

24 MR. FINE: Yeah. But that's the natural  
25 evolution of PRA, because our internal events PRA

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 started out fairly simplistic, with a lot of more  
2 uncertainty than they have today, and we over the last  
3 20 years have brought them into something that makes  
4 pretty good sense.

5 Fire's going to take about that long to  
6 make it make sense, and seismic and all them the same  
7 way. So --

8 MR. RISHEL: So the other point I wanted  
9 to make was development of new methods is slow, and  
10 hopefully the Risk-Informed Steering Committee will  
11 help streamline that process. If somebody comes up  
12 with a new method, we can get that through some  
13 process that has some -- a surety of outcome in some  
14 reasonable amount of time.

15 So the current plans are for the BWR  
16 Owners Group is, I'd say generically and there could  
17 be some outliers here or there, but is to continue  
18 with the current approach of essentially Option 1.

19 So plan submittals here in the near term,  
20 we've got some risk-informed surveillance frequency  
21 programs coming up being submitted, completion time  
22 for the 4b tech spec. A number of members have  
23 indicated they'll be submitting license applications,  
24 and of course the 15 year Appendix J will be submitted  
25 as the plants come up to essentially the need date.

1 When they need that application, they'll submit it.

2 So going forward, some areas we would sort  
3 of like to see; this sort of comes out a little bit  
4 maybe out of Option 2 is tech spec completion time for  
5 containment isolation valves, 50.69, which is  
6 available but really no BWR is in the pool yet, and  
7 use of PRA for SPAR. I think that's an area we would  
8 also like to see.

9 So on peer reviews, so we're trying to  
10 incorporate NRC feedback on peer reviews for technical  
11 adequacy.

12 VICE CHAIR BLEY: Bob, Bob?

13 MR. RISHEL: Yeah.

14 VICE CHAIR BLEY: Before you read that  
15 last line, that was passing kind of fast, there was  
16 some discussion about this. It seemed in the  
17 subcommittee it was a more complex issue. I mean  
18 there are some people who really like that idea of  
19 licensing PRA as a SPAR model. I think we heard there  
20 are others out in the industry who have reasons  
21 they're not so sure they like it. Can you provide the  
22 Committee a little more background on that?

23 MR. RISHEL: So you're correct. It's a  
24 split, and it's more in favor of than against. I give  
25 you that.

1 VICE CHAIR BLEY: At least for the BWRs.  
2 I don't know --

3 (Simultaneous speaking.)

4 MR. RISHEL: For the BWRs, right. I'm not  
5 speaking for the P's. You know, as I said at the  
6 Subcommittee meeting, we have provided the regulator  
7 all of our models, all of the notebooks, all of the  
8 fault trees, you know, and actually we just sent --

9 CHAIR STETKAR: Bob, just for the record,  
10 when you say "we," does that mean Duke?

11 MR. RISHEL: Duke Energy.

12 CHAIR STETKAR: Okay, thank you.

13 MR. RISHEL: I'm sorry. I mean yeah. For  
14 the record, Duke Energy has sent to the Region II, and  
15 we just provided an update to one of the plants that  
16 had an update provided to the -- and so far, the  
17 interchange has been -- has been beneficial for both  
18 sides, that they have that information available. I  
19 don't think they're running the models, you know,  
20 trying to solve it, some issue on this.

21 But they are using information to get  
22 insights into so what is it -- so what is it that's  
23 applicable to whatever issue is that we're missing,  
24 that they don't understand or has changed since the  
25 last time. And frankly there's been turnover in the

1 SRAs. That's another area that, you know, is -- and  
2 they need to understand the plants too. So that's  
3 another tool for them.

4 VICE CHAIR BLEY: Okay. I just wonder for  
5 the record. Ray, do you want to add anything to this  
6 discussion?

7 MR. FINE: Well, from the PWR perspective,  
8 we would do it on a plant by plant basis. They don't  
9 believe in wholesale sharing the models.

10 But I do know of my particular -- one of  
11 my plants I will have to share with the staff here  
12 soon, because of the number of changes we've made,  
13 that if we were to go into an STP following our spring  
14 outage, it would get really interesting, because our  
15 answers would be totally different.

16 So it's on a case-by-case basis, and right  
17 now we don't currently plan on sharing.

18 VICE CHAIR BLEY: Okay, thank you.

19 MS. ANDERSON: And NEI's actually leading  
20 a tabletop study on the potential to share licensee  
21 PRAs with the NRC, to eliminate the need for the SPAR  
22 models. That tabletop setting I think is starting at  
23 the beginning of next month, and we have some  
24 volunteer plants to work on that. So I think if we go  
25 through this tabletop study and then maybe eventually

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 a pilot, that might help alleviate some of the  
2 concerns that people have and that might help us move  
3 towards using licensee PRAs instead of the SPAR  
4 models.

5 MR. FINE: And we are involved with this.

6 VICE CHAIR BLEY: Okay, good. Thank you.

7 MEMBER SCHULTZ: I think that's very  
8 encouraging. It would be nice to go through the  
9 significance determination process in a way where the  
10 discussion is not about the modeling, but about the  
11 results associated with the inputs only, and not  
12 trying to determine whether -- whose model is correct  
13 or not.

14 It takes a lot of time and a lot of effort  
15 and it would be nice to eliminate that piece. So I'm  
16 glad it's moving forward with some demonstration  
17 projects as well.

18 MR. RISHEL: So back on the peer reviewed  
19 technical adequacy. So the BWR Owners Group is  
20 putting greater emphasis on the peer-review team  
21 leader being a leader, rather than being a super  
22 technical expert but leading a team. We introduced a  
23 training program for those folks, specifically on the  
24 standard, what does that requirement meet, what are  
25 some of the OEs that have been seen in the past, where

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 people have either defaulted, you know, too  
2 conservatively or too much towards you didn't do it  
3 the way I do it, so it's wrong, and much more emphasis  
4 on the consensus of the team rather than individual  
5 person and the rest of the team just acquiescing to  
6 whatever that person's view is.

7 Also, the licensee ownership of being  
8 ready. That's been an issue in the past sometimes,  
9 where the licensees, again under some pressure to have  
10 a peer review, probably should not have undergone a  
11 peer review at that point in time. So a lot more  
12 effort on pushback on being ready, meaning that their  
13 model has been churned enough, that they've looked at  
14 the uncertainties and issues enough that they've tried  
15 to remove some of the uncertainty in there.

16 As a matter of fact, we just had one  
17 ownership, owners group, excuse me, one plant that was  
18 supposed to have a peer review this week as a matter  
19 of fact, be pushed out into second quarter next year.

20 MEMBER SCHULTZ: Bob, in the process of  
21 trying to develop an approach where the review team  
22 works as a team rather than a group of individuals, do  
23 you do that by -- has that been done or accomplished  
24 by direction to the team, or have you developed some  
25 processes that make the team work as a team?

1 MR. RISHEL: Well we've -- the process,  
2 the closest we have to process is we put together a  
3 little training package for the team, on what the  
4 expectations are. It's not so much on technical, but  
5 the expectations of your team. Here's what we expect  
6 of you, and they hold that pretty early on, once the  
7 team is formed and before they start reviewing  
8 anything.

9 Then you know, we come back with the team  
10 leader and make sure he understands that, and going  
11 forward we're talking about what to do next, to try  
12 and circle back and see how this is working.

13 MEMBER SCHULTZ: What I was looking for  
14 was whether you had an issue resolution process  
15 associated with it at this point.

16 MR. RISHEL: Yeah. We do have --

17 MR. FINE: We do. It's actually Victoria  
18 runs an NEI task force for peer reviews and peer  
19 review leads. So both me and Bob are on it and quite  
20 a few other people are on it, including the vendors  
21 who could potentially be leads and so forth.

22 So it's a fairly large group of people.  
23 When we identify issues, we hash it out, work it out  
24 and say okay, well this is what we need to do to  
25 improve that. And we're kind of going through a sea



1 change, because we experienced what we did with NFPA-  
2 805.

3 Now that wasn't just modeling challenges.  
4 That was also peer review challenges, because a whole  
5 lot of models went through peer reviews very quickly,  
6 and it was getting the right people in the room at the  
7 right time, the right leads and you know. It was  
8 extremely challenging to have the right people there  
9 for some of these.

10 And so the, you know, and seismic will be  
11 no different, because the population of people who can  
12 do that is even smaller. So it's going to -- we're  
13 trying to get all of our programs such that, you know,  
14 we can adapt to these things and be ready for them and  
15 prepare for them, instead of just getting run over by  
16 them.

17 So you know, the requirements of 30 days  
18 prior to you will have, and the team will be assembled  
19 at least by this date and the lead will be a lead and  
20 not an actual reviewer of any particular supporting  
21 requirement or high level requirement, and all these  
22 little rules that we're putting in place.

23 These are all fairly recently, in the last  
24 year, okay, and we're feeling them out as we go,  
25 seeing if it works. So we've only had a couple of

1 peer reviews so far where the lead is truly an  
2 independent lead who's, you know, roving. But I've  
3 been in peer reviews where the lead did do that. A  
4 contractor led one of them is a utility guy and it  
5 worked really well. So we said why don't we try it on  
6 more?

7 So there's things like this that we're  
8 constantly evolving on. But we do it as an industry.  
9 It's not just the B's. Everybody does it together the  
10 same, because of the need to ensure consistency.

11 MR. RISHEL: I do have a slide, I think.

12 MEMBER BROWN: But before you --

13 MR. RISHEL: But we do have -- I'll cover  
14 it now because of the question. With NEI, there is a  
15 peer review task force, and issues come up and they're  
16 brought to the task force, and it is sort in its  
17 infancy now. But the task force is also going okay,  
18 so this is what good looks like. The licensee does  
19 something that looks like this; that's what the  
20 standard is looking for.

21 You can always do more, but this is the  
22 minimum of what the effort should be in that we've  
23 done, what, two of those.

24 MR. FINE: Well, all of my PRAs are on the  
25 new process.

1 MR. RISHEL: So far, but there's more to  
2 come. So we are bringing things forward. But it is  
3 a bit like herding cats, I'll say, on getting a  
4 consensus.

5 MEMBER BROWN: Yes sir. Your comment that  
6 greater emphasis on peer review team leader being a  
7 leader, and then I've listened to the rest of  
8 discussion. But I hope I don't get the flavor that  
9 when you say you want somebody who's "comes out, he's  
10 got this great management training and leadership  
11 skills because he's been through leadership training."

12 But if he doesn't have a fundamental  
13 understanding of PRA itself, while he may not be a  
14 reviewer -- I agree the leader shouldn't be -- I think  
15 that's a good idea, should not be a reviewer so he can  
16 overview everything. But he really does need a  
17 fundamental understanding.

18 MR. RISHEL: I'll say we're not using  
19 folks that don't know anything about PRA.

20 MEMBER BROWN: Thank you. That's all I  
21 wanted to make sure.

22 MS. ANDERSON: They still have the  
23 qualification requirements.

24 MR. RISHEL: They still have to be on the  
25 peer review team. They've still got to meet the PRA

1 reviewer quals.

2 MR. FINE: So this individual doesn't have  
3 to be per se the technical --

4 MEMBER BROWN: I'm not arguing with that.  
5 But if he can't talk across the board and understand  
6 what the team would bring to, you know, to the table,  
7 then it's difficult to meld those guys together and  
8 make sure you get a valid result.

9 MR. FINE: He has to speak the language.

10 MR. RISHEL: So exactly. So what we were  
11 finding was is that the team leads were typically the  
12 heaviest, as far as PRA knowledge goes, and they would  
13 be totally immersed in the technical and not paying  
14 attention to what everybody else is doing. So extract  
15 him from that, come in and provide some oversight on  
16 whatever, exactly what you're talking about.

17 And as far as new reviewers, we have  
18 instituted a working observer, where an individual  
19 that has been working in PRA for some number of years,  
20 but hasn't participated in a peer review before,  
21 rather than throw him into the fire right away, have  
22 him participate, do work but he's not -- he's not an  
23 official member, but is part of a training process so  
24 he understands what's going on.

25 MR. FINE: Right, and just to amplify on

1 that a little more, the working observer will be  
2 somewhat specific. So if you want to do peer review  
3 on a seismic PRA, then you're a working observer on a  
4 seismic PRA just like on a fire PRA, because I don't  
5 have the skill set for fire PRA. Even though I've  
6 managed the development of fire PRAs, I don't go on  
7 those, because they're very complex.

8 But I have guys that do that, okay. But  
9 I wouldn't send one of those guys on the seismic PRA  
10 review because he wouldn't know what he's looking at.  
11 So you're being trained to that type of model.

12 MR. RISHEL: Next slide, Ray. So for the  
13 BWR Owners Group, you know, one of the issues that  
14 staff brought up and we share is that a week on site  
15 is not much time. So part of that was the expectation  
16 that the peer review team look at at least 40 percent  
17 of it before they show up on site, and have a stack of  
18 questions or issues for the -- to provide the host on  
19 what's -- on something they discovered in part of  
20 their review.

21 We've also seen licensees follow up with  
22 a follow-up peer review, to try and see if they've  
23 resolved F&Os and get a sort of second view. Okay, I  
24 had a peer review. They had these F&Os. I think I  
25 did the work, bring in another team to pass judgment

1 on that work. That has picked up speed in the owners  
2 groups. Like I said, the industry task force looking  
3 for some technical resolution of one issue or other.  
4 We talked about it earlier.

5 So then with the gap on technical  
6 adequacy, so part of it is there is limited resources.  
7 These folks take a long time to train up and so it is  
8 a small group. In peer reviews, the objective  
9 criteria in trying to get consistency, you know.

10 The worse case is like I had two peer  
11 reviews, this is from Duke Energy. One was a strength  
12 and the other was a not met, and it was exactly the  
13 same approach in both cases. Two different peer  
14 reviewers. So that kind of, you know, makes us pull  
15 our hair out and circle back.

16 But it is an individual and then, you  
17 know, as the licensee we have to go back and resolve  
18 what the -- what we think the right answer is. So  
19 going forward for like using the PRA, one of the  
20 questions we have as the owners group is if the staff  
21 members start passing judgment on technical elements  
22 in, you know, that's something we would need to work  
23 out for reviews, is whose opinion counts so to speak.

24 Also going forward with Option 2 and 3 is,  
25 you know, the question about we have these -- the

1 projected benefits, but if we don't have a fixed time  
2 line on resolving all of the -- either the technical  
3 issues or the process issues, the time lines stretch  
4 out and we'll never achieve the benefit of an Option  
5 2 or 3.

6 MEMBER CORRADINI: Can I ask a question of  
7 both owners group representatives? So if you did a  
8 survey of your membership, how does the membership  
9 come down in terms of Option 2? In other words, is it  
10 95 percent of all the owner group members think that  
11 Option 2 just really is not appropriate, or is there  
12 a relatively large split that finds on a case-by-case  
13 basis there might be some benefit?

14 MR. RISHEL: So we're probably -- we're  
15 probably the 95 percent no and maybe a five percent,  
16 I would say, maybe. I wouldn't even say a yes.

17 VICE CHAIR BLEY: In concept, or in terms  
18 of the way it was presented in the SECY paper?

19 MR. RISHEL: In concept.

20 VICE CHAIR BLEY: In concept.

21 MR. RISHEL: You know, I guess kind of  
22 step back of where the fleets are at.

23 MEMBER CORRADINI: And this is -- it's  
24 based on resource or based on there's no safety  
25 benefit?

1 MR. RISHEL: It's based on --

2 MEMBER CORRADINI: Well I should say the  
3 opinion thereof.

4 MR. RISHEL: The opinion thereof of the  
5 cost to get there and two is a question about whether,  
6 what the benefit would be. Where is the payoff at the  
7 end?

8 MR. FINE: I would agree. The P's are  
9 pretty much at the same place. There was a lot of  
10 uncertainty programmatic wise in the bullets in Option  
11 2 and 3, and you don't really know where it's going to  
12 go. But you know, when you say something like oh, we  
13 would like to do certified PRAs.

14 Well, you're talking about completely  
15 redoing the entire process and we've got to start over  
16 again? Seriously. Yeah, that's not going to work,  
17 you know. But could we talk with a different way to  
18 do it? Probably, you know. I think it would be  
19 beneficial for all of us.

20 VICE CHAIR BLEY: That's kind of what I  
21 meant by hidden concept.

22 MR. FINE: Yeah. Not in the flavor that  
23 it was sold to us, you know. We would change it.

24 MR. RISHEL: I would hazard an opinion  
25 that fire, 805 fire is the elephant that sticks over

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 this.

2 VICE CHAIR BLEY: In terms of it gave  
3 everybody a bad taste or --

4 MR. RISHEL: It gave everybody a bad  
5 taste. The costs were astronomically much higher than  
6 anybody projected.

7 MR. FINE: It showed us how -- it showed  
8 us how, you know, when you don't have regulatory  
9 certainty moving forward, the cost will go  
10 exponential. Because we started out thinking five to  
11 ten million dollars to do a fire PRA. But then  
12 because of issues with methods and approvals and other  
13 things, we're at 50, 60 million per unit and counting,  
14 and we're not even implemented yet.

15 So that's why we're like no, we don't need  
16 any uncertainty at all right now. If you want us to  
17 keep moving forward and show safety benefit and  
18 improve the safety of the plants, we need some, you  
19 know, like when you want us to go after 4b tech specs  
20 or 50.69 because it will focus us better on the things  
21 that matter most, you know, and we agree. We want to  
22 go do that.

23 But if the staff or anybody starts  
24 changing those rules midstream, which we're discussing  
25 right now, yeah. A lot of people are going to stop,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 because it's just too uncertain, too much money. And  
2 so, you know, there's quite a few plants. You know,  
3 even though Bob gave you a list of plants that are  
4 moving forward, he has a similar list.

5 These are the plants that want to move  
6 forward and want to submit. But all of them are saying  
7 "but we want to see what happens in the current  
8 submittals before we decide we're going to go."

9 MR. RISHEL: Yeah. We're not spending  
10 that much on 805.

11 CHAIR STETKAR: It makes me sad that I'm  
12 not a contractor anymore.

13 MR. FINE: It made a lot of contractors  
14 very wealthy.

15 CHAIR STETKAR: You could buy a few extra  
16 shirts for that.

17 EE I can't say anything.

18 (Laughter.)

19 MR. RISHEL: So that's our concerns, those  
20 three bullets with Option 2 and 3, and that's pretty  
21 much why the BWR Owners Group wants to sort of back up  
22 the staff's position of keeping forward where we're  
23 going, keeping -- progressing forward. If there's  
24 areas where we can improve the technical adequacy and  
25 review process, you know, we would do those things.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 I know we got a recent letter with some  
2 issues and questions that provide feedback to the  
3 staff on peer reviews. So I already started my  
4 conclusion here, and again, the elephant in the room  
5 is fire PRA. It has become a large consumer of  
6 resources.

7 I would just say for Duke Energy, just not  
8 even revising the model, but just keeping up with the  
9 plant is 4 FTE for the Duke Energy fleet.

10 MEMBER CORRADINI: So let me ask the  
11 question differently, since this is how you've ended  
12 it. Are there lessons learned from the fire PRA that  
13 you don't want to ever do again on any risk-informed  
14 topic, and does the NRC staff agree with it? In other  
15 words, are there attributes that have come out of this  
16 behavior that you never want to see revisited, and  
17 have you talked it out with the staff?

18 MR. RISHEL: Yeah. So I don't know if the  
19 staff agrees, but I think we attempted to do a pilot,  
20 two pilots with fire and they weren't as good of a  
21 pilot. The problem, I think the problem was the rest  
22 of the industry was right behind them, and there  
23 wasn't enough time to really swallow what came out of  
24 that.

25 CHAIR STETKAR: Bob for the record, there

1 was an attempt to do a pilot back in 2005, and nobody  
2 -- the industry didn't support it. So when you say  
3 "pilots," there were the first on the record  
4 submittals of the process that had not been actually  
5 tested in a real world pilot application.

6 MR. RISHEL: Yeah, and so to get back to  
7 the question, correct, I think. So they really  
8 weren't pilots. So going forward, we do need to pilot  
9 things. So we just finished up a pilot of a low power  
10 shutdown for a BWR, and we have a laundry list of  
11 things that we think ought to be changed before  
12 anybody goes forward and uses that document.

13 MEMBER CORRADINI: Is part of it -- well  
14 I mean I don't really -- this is not my area of  
15 expertise. But is part of it lack of experience of  
16 the managers of the project that allowed too many  
17 details in when they didn't need to be there?

18 MR. FINE: I wouldn't say that. I would  
19 say that, you know, 68.50 in general had a lot of  
20 steps in it that weren't really well thought out, and  
21 when somebody actually started putting it all together  
22 and adding it all up and it started not making any  
23 sense, everybody was like well what do we do now, and  
24 that's when we got into this whole methodology. How  
25 do we make this make more sense, because we know what

1 we're getting right now doesn't make any sense.

2 And then we got -- but we're in a lesson  
3 learned kind of scenario, where the staff really  
4 hadn't been involved in methodology before then. Now  
5 they wanted to be involved in methodology. Then, you  
6 know -- before they just took what we did and now it  
7 doesn't go like that.

8 There's a whole lot of things that changed  
9 in and amongst just doing it, you know, and you know,  
10 so one of the things we did with seismic different  
11 than fire was when the pilots, which were my plants  
12 and Vogtle, got done, completely done, peer reviewed,  
13 everything, lessons learned, had lots of workshops,  
14 had a good year or so for people to digest and  
15 understand before the others started moving forward.

16 MS. ANDERSON: So I think the two major  
17 lessons learned we took from the fire PRA and 805  
18 experience, and the first was that we need to have  
19 some level of staff involvement and NRC staff  
20 understanding of the methods that are being used,  
21 because I think we didn't necessarily have that with  
22 fire PRA, and that held up the licensing applications.

23 The other major lesson learned is that we  
24 need to have a clear understanding of the level of  
25 realism of the PRAs that are supporting licensing

1 applications before the licensing applications go in.  
2 That was where we wound up with a lot of problems and  
3 time pressure and inability to solve the methods  
4 problems in 805, was that all these applications were  
5 due and the fire PRAs were not yet ready to support an  
6 application like that.

7 MR. FINE: We were committed to a date  
8 without the ability to truly make it right.

9 MR. RISHEL: I would agree with all that.

10 MEMBER CORRADINI: Thank you.

11 MR. RISHEL: So we'll continue to work on  
12 technical adequacy and work with the various owners  
13 groups to improve the peer review process, and I think  
14 we'd support continuing on with Option 1. So I don't  
15 have any other points to make.

16 CHAIR STETKAR: Anything more for Bob? If  
17 not, Victoria, you're up.

18 MS. ANDERSON: Victoria Anderson with NEI.  
19 I'm going to present on the industry comments on the  
20 draft SECY on the RMRP. Before I get into our  
21 specific presentation, I'm going to talk a little bit  
22 about sort of the vision that the RISC has, because  
23 the question came up and the question I think that was  
24 posed earlier was well, is the RISC really working to  
25 a larger vision, or are we just working on tools and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 maybe --

2 CHAIR STETKAR: Victoria, before -- for  
3 clarity for the members, we heard earlier about the  
4 NRC staff's RISC.

5 MS. ANDERSON: Right.

6 CHAIR STETKAR: You're going to talk about  
7 the industry's RISC.

8 MS. ANDERSON: The industry RISC.

9 CHAIR STETKAR: There are two RISCs.

10 MS. ANDERSON: Yep.

11 CHAIR STETKAR: Who talk to one another.

12 MS. ANDERSON: Yep, and we talk to each  
13 other and work together and so far have not had major  
14 disagreements on where we need to be moving forward.  
15 But I think the question that was posed was maybe the  
16 Risk Management Regulatory Framework would have been  
17 some sort of visionary change that maybe the RISC  
18 should have been looking for.

19 And I think, you know, right now we are  
20 doing a lot of work on sort of those tools. But we  
21 did spend some time on the overall vision back when we  
22 formed the two risk-informed steering committees. I  
23 just want to talk about that for a little bit.

24 I mean I think the overall vision and  
25 purpose of the Risk-Informed Steering Committees is to

1 maximize the use of risk information and regulation.  
2 Underpinning that, you know, other parts of that  
3 vision are that we'll have a deliberate approach to  
4 PRA development, maintenance and applications. So we  
5 don't go off developing models that will sit on a  
6 shelf or models that won't help us run the plants  
7 better; that we have a seamless risk-informed  
8 licensing process. That's a nicer way of saying we  
9 don't want to repeat NFPA-805.

10 I think, you know, outside of risk-  
11 informed licensing, we want to have an increased use  
12 of PRA in all regulatory activities, as well as a more  
13 predictable use of PRA in regulatory activities and  
14 plant operations. So these things like inspections,  
15 the significance determination process and just day-  
16 to-day decision-making at the plants.

17 So those are sort of the visions that  
18 we're looking at, and we say well, what's stopping us  
19 from getting to this vision? What's getting in our  
20 way, and we did actually -- you know, it was almost  
21 two years ago now. We said if we could rewrite the  
22 PRA policy statement, what would we make it say to  
23 make things better?

24 And when we looked at the policy  
25 statement, we said there's really nothing that's



1 missing there. There's no need for a new enabling  
2 rule. The things that are getting in our way are  
3 tools and culture. So that's why we've been focusing  
4 on those things. But I think they are supporting that  
5 larger vision.

6 So now I'll go ahead and start on the  
7 presentation. So what you're going to notice  
8 throughout the slides is that we do agree with the  
9 staff's recommendation throughout. The first  
10 recommendation, to maintain the current framework and  
11 continue to make improvements. Based on what I just  
12 said about the risk-informed steering committees and  
13 our vision and how we've been progressing, you know,  
14 we agree with that.

15 There are a lot of efforts underway to  
16 improve things, and we didn't think that any kind of  
17 large-scale policy statement change or rulemaking was  
18 really necessary to support improvement.

19 So the specific Option 2, the plant-  
20 specific regulatory framework, the staff agreed with  
21 our comments that the approach need not be pursued.  
22 We didn't really find any licensees that would want to  
23 implement it, as was described in the papers we had  
24 seen. So if no licensees are going to use it, given  
25 how much the staff has on their plate, it's really not

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1     worth it to go and develop something like that. So we  
2     agree with the staff recommendation in the draft SECY  
3     there.

4             I think we already talked about the design  
5     basis extension category and where the staff landed on  
6     that. We also agreed with the staff that there's no  
7     need for a design basis extension category.

8             With respect to defense indepth, we also  
9     agree that the right place is in Reg Guide 1.174. We  
10    don't think a policy statement is really necessary  
11    there. Reg Guide 1.174 has been sufficient. We can  
12    enhance the discussion in there to provide additional  
13    guidance, but we don't think a policy statement would  
14    really do much.

15            As far as an overarching policy statement  
16    on the risk management approach, we think the existing  
17    PRA policy statement does enough. So we agree with  
18    the staff recommendation to not work on an overarching  
19    agency-wide policy statement.

20            So our conclusion, if it hasn't been clear  
21    so far, we agree with the staff's recommendations in  
22    the SECY paper, and we are going to continue to work  
23    with the staff, both through the Risk-Informed  
24    Steering Committee and on specific initiatives, to  
25    make sure that the right methods and guidance are

1 available to support that vision that we have for  
2 maximizing the use of risk information and regulation.

3 MEMBER CORRADINI: So I have a question  
4 about non-currently operating plants like the SMRs.

5 MS. ANDERSON: Okay.

6 MEMBER CORRADINI: There's no need for any  
7 of this for the SMRs from your perspective?

8 MS. ANDERSON: So what we noted with the  
9 SMRs is that there's nothing -- there isn't a need for  
10 an enabling rule or a change to the policy statement  
11 to pursue the use of risk information in the design  
12 and construction of the SMRs. There isn't anything  
13 that really needs to be changed at a policy level to  
14 support that.

15 I do know the SMR designers are doing a  
16 lot of integrated PRA development in design, where  
17 they're doing sort of an iterative process and using  
18 the risk information throughout. There's absolutely  
19 nothing in the current regulatory framework that stops  
20 them from doing that.

21 MEMBER CORRADINI: So if they have to take  
22 on a particular topic and risk-inform it, they can do  
23 it on a case-by-case basis and there's no need for any  
24 of the Option 2 activities?

25 MS. ANDERSON: Right. That's what we

1 noticed here. For example, they're doing -- they're  
2 using some risk information to support changes to  
3 emergency planning. It's not really a traditional  
4 risk-informed application, but that's something that  
5 they're doing just under normal processes.

6 MEMBER CORRADINI: Okay.

7 MR. FINE: So there's even nothing under  
8 the current process that would prevent me from doing  
9 for 50.69, 5b and 4b all in one submittal, you know,  
10 or going after one of those but saying in my submittal  
11 I want to be my PRA reviewed for all. They can do  
12 that too.

13 MEMBER CORRADINI: I guess where I was  
14 going with this was if you don't want to relive the  
15 fire PRA activity, you think that you can handle it by  
16 these steering committees on individual issues or  
17 general attributes, without having to do some of the  
18 activities under Option 2?

19 MS. ANDERSON: Right. I don't think that  
20 Option 2 is really necessary. I mean I think if you  
21 look at the current policy statement and the current  
22 regulatory guidance, it says we should use PRAs that  
23 are realistic, you know, and that was one of the major  
24 sticking points with fire PRAs.

25 So I think it's a matter of getting back

1 to the overarching policy statement and the vision  
2 that we have, and making sure that we're really  
3 following it.

4 MEMBER CORRADINI: Okay. So now if I move  
5 on to non-light water reactors and NEI now has a  
6 working group in that area, is that not correct?

7 MS. ANDERSON: Yes, we do.

8 MEMBER CORRADINI: So what's the view  
9 there?

10 MS. ANDERSON: They had some interest in  
11 the concept of a risk managed regulatory framework.  
12 But again when we talked to them, they also agreed,  
13 you know, well it doesn't seem like there's really  
14 anything in the current rules or the current policy  
15 statements that's prohibiting us from doing what we  
16 want to do.

17 MEMBER CORRADINI: So but okay. So you're  
18 telling me I could do it on a case-by-case basis  
19 there, because I've done it in the past and at least  
20 until I approach it and nothing looks like it's  
21 broken, that I can't use the current --

22 MS. ANDERSON: Right.

23 MEMBER CORRADINI: Right. But I guess I  
24 hear different things from different parts of the  
25 industry. Are we back to resource issue, which is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 current plant shouldn't pay for it, or that it really,  
2 from a technical standpoint, that it makes no sense to  
3 take Option 2 attributes or activities for advanced  
4 reactors?

5 MS. ANDERSON: I think the advanced  
6 reactors, I think the design isn't that really far  
7 enough along in what they're planning with their  
8 regulatory strategies, to say for sure that they would  
9 use an Option 2 type framework either way.

10 MEMBER CORRADINI: Okay. So let me  
11 pushback. So we just went through NGNP, and when all  
12 is said and done, we were in this room and staff came  
13 in and said we don't know enough. We'll invent a  
14 maximum credible accident that may not be physical,  
15 but it's definitely maximum credible, and the DOE, who  
16 was representing the industry group said well, we  
17 don't necessarily agree with that.

18 But and we have our risk analysis or their  
19 -- I'll call it their mini-PRA. I can't even call it  
20 a PRA. We'll call it a mini-PRA and historical stuff,  
21 and there was a rift. It seems to me that's almost  
22 like a lesson learned, that if I go down the path of  
23 pick your favorite peanut butter reactor, chunky,  
24 creamy, and you go down this path, you're going to --  
25 we're going to stumble over the same path again unless

1 we address it now.

2 You think there's enough there without  
3 doing Option 2 attributes, that we could just go down  
4 that path again?

5 MS. ANDERSON: I mean I think -- well,  
6 avoid going down the same path, but I think we can do  
7 that without pursuing something like Option 2, and  
8 that is what it sounded like the advanced reactors  
9 agreed with.

10 MEMBER CORRADINI: Okay, all right.

11 MEMBER REMPE: During the subcommittee  
12 meeting, I guess actually Michael was the presenter  
13 rather than you.

14 MS. ANDERSON: Yes.

15 MEMBER REMPE: But my notes indicated that  
16 there was a discussion about any plants being  
17 interested in Option 2, and my notes indicated that  
18 they said absolutely no at this time. They needed  
19 some nearer term wins and in fact the staff had said  
20 they weren't going to be pursuing defining more  
21 details, you just won't have that regulatory  
22 certainty.

23 I kind of got that a little bit from the  
24 BWR presentation, but I didn't see that today. Is  
25 that still the message?

1 MS. ANDERSON: Yep, that's still the case,  
2 yes.

3 MEMBER REMPE: Okay, thanks.

4 MS. ANDERSON: I think we'd just say 95  
5 percent of the plants say no, because we're PRA people  
6 and we never want to say it's absolutely 100 percent  
7 for sure.

8 (Laughter.)

9 CHAIR STETKAR: Any other questions for  
10 the industry?

11 MEMBER CORRADINI: Yeah, I guess I'm still  
12 bugged by all this, because I went through the  
13 advanced reactor stuff with DOE helping industry and  
14 it went nowhere after ten years. So I'm still  
15 bothered. So is it resources or is it safety benefit?  
16 I'm struggling with don't go down an Option 2 path  
17 with current reactors. I understand the logic.

18 So now if I switched the target to an SMR,  
19 I switched the target to a non-LWR, is it still the  
20 same thing? There's no safety benefit and not enough  
21 resources, or if we had the resources, there actually  
22 would be some safety benefit?

23 MS. ANDERSON: I think the concept is more  
24 that the resources could be used to reach the same  
25 safety -- you could get the same safety benefit for

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 less of a resource investment under the current  
2 regulatory framework, under the current approaches  
3 that are available. I think that's the perception.

4 MEMBER CORRADINI: Okay.

5 MEMBER RAY: Well Mike there's -- you  
6 posed two choices there. There's a third choice that  
7 has to be evaluated which is not a safety benefit, but  
8 an economic benefit.

9 MEMBER CORRADINI: Well okay.

10 MEMBER RAY: All right, and whether  
11 there's an economic benefit or not is also part of the  
12 calculus that any new reactor vendor has to engage in.  
13 In order to do that, you have to know well in the  
14 absence of PRA, what am I going to be faced with?  
15 That's where you get into the do loop.

16 In other words, you don't want to commit  
17 as a vendor to doing an analysis that doesn't provide  
18 any obvious safety benefit, unless it also provides  
19 you an economic outcome benefit.

20 MEMBER CORRADINI: Right.

21 MEMBER RAY: And that's where I think the  
22 hangup exists, more than whether it's a safety benefit  
23 or not.

24 MEMBER CORRADINI: So maybe we're -- the  
25 Chairman will tell us to be quiet, but since we're in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 discussion mode, it just strikes me that after --  
2 since I attended all these meetings and it was  
3 frustrating with the NGNP, nobody looks at that as a  
4 lessons learned and say okay, how could we have done  
5 that better, whether it be for safety or for economics  
6 and for what I'll call certainty in the process, that  
7 we could learn better because we're going to get  
8 another one of these, because it seems that a lot of  
9 venture capitalists, whether they're on some sort of  
10 Kool-Aid trip or in reality want to do it.

11 So again, the staff is going to get beaten  
12 up about not being precise. Industry is going to  
13 proceed with some of these things and there could be  
14 a lot of money wasted and going nowhere again. It  
15 just strikes me that at least the NGNP is something  
16 that can be looked at as a way to essentially improve  
17 on it. But I think you're right. It could be  
18 economic as well as safety.

19 MEMBER RAY: Well, it's going to be  
20 economic in my judgment. Again, the question that the  
21 proponent of a new design is going ask themselves is  
22 what if I don't do it? Or what's the consequence of  
23 not engaging in full scope PRA as opposed to the  
24 benefit, economic benefit that I would obtain from  
25 doing it?

1 I don't think the driver is I'm going to  
2 improve safety by doing it, from a vendor's  
3 perspective, because the vendor's already presumably  
4 comfortable with the idea that this concept has got  
5 advantages that warrant moving forward.

6 The thing that they don't know is well,  
7 where is it going to prove to me -- prove to be an  
8 advantage by doing the analysis, and I would use NGNP  
9 as an example of that. You just -- how is this going  
10 to benefit me? Well, I don't know, because I don't  
11 know what I have to do in the absence of it, from the  
12 standpoint of EPZ or whatever you're talking about.

13 MR. FINE: Plus in this particular case,  
14 you have no owner involved yet. It's all just vendor.  
15 The owner's still going to come in and --

16 MEMBER RAY: That's another debate that we  
17 have over dinner often.

18 (Simultaneous speaking.)

19 MEMBER RAY: But you're right, yes.  
20 Getting an owner engaged makes a big difference as  
21 well, but right now, he and I are just talking with --

22 MEMBER CORRADINI: I mean under the  
23 assumption there's a vendor and there's a potential  
24 owner, because there is that other stumbling block.

25 MEMBER REMPE: And you seem to not want to

1 mention the Cheyenne example, where they --

2 MEMBER CORRADINI: But Cheyenne is good  
3 nuclear. Cheyenne is not bad nuclear.

4 MEMBER REMPE: Yeah. Well again, they  
5 went through a different process with inadequate  
6 detail, and they are moving forward.

7 CHAIR STETKAR: Remember, that's just a  
8 construction permit, so they don't have to have the  
9 same --

10 MEMBER REMPE: I know, but maybe that's  
11 not bad --

12 CHAIR STETKAR: --they don't face the same  
13 issues.

14 MEMBER REMPE: But then that's not a bad  
15 way to go when you don't have the detail.

16 MEMBER CORRADINI: Well, I mean again  
17 we're debating.

18 MEMBER REMPE: Hypotheticals.

19 MEMBER CORRADINI: --off topic a bit, but  
20 it is not a commercial reactor. It's not a power  
21 reactor. It's essentially being treated as a research  
22 reactor in terms of licensing. It's a different  
23 beast. The only reason I'm going to NGNP --

24 MEMBER REMPE: Then what would be a  
25 different beast?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   MEMBER CORRADINI: The only reason I'm  
2 going back to the NGNP, there was a lot of industry  
3 activity on now good it was because of this and that.  
4 There were actually risk numbers advanced as to why  
5 it's safer or could be more economic. When all came  
6 to past, there was this chasm between staff and DOE,  
7 and I just see -- or and DOE and the industry  
8 consortium, and all I see is this is going to happen  
9 again unless some parts of Option 2 aren't addressed.

10                  MS. ANDERSON: I mean I'm not sure if that  
11 chasm existed because there wasn't some sort of  
12 enabling rule or framework out there, or if it was  
13 because there was a cultural difference and maybe some  
14 sort of miscommunication on how risk could be used to  
15 improve the process.

16                  MEMBER CORRADINI: So without a framework,  
17 there will still remain a culture difference, wouldn't  
18 there?

19                  MS. ANDERSON: Or we could try to fix the  
20 cultural differences, which is one of the things that  
21 the Risk-Informed Steering Committee is trying to do,  
22 is try to address the cultural differences and the  
23 lack of tools.

24                  MEMBER CORRADINI: Yeah. Well, there's  
25 enough cultural differences in the world. Eventually

1       you come to a peace agreement with rules.

2               MS. ANDERSON: Right.

3               MEMBER CORRADINI: That you have to  
4 follow. Otherwise, the cultural difference remains.

5               MR. RISHEL: You know what -- this is Bob  
6 Rishel. I would just, you know, maybe that would be  
7 the value of Option 2, would be it would bridge -- it  
8 would force the culture to change.

9               MEMBER CORRADINI: Well, I would be  
10 totally honest on the record, that it strikes me it's  
11 a resource issue. If industry didn't have to dive  
12 into their essentially revenues for it, but actually  
13 was looking forward on some sort of advanced reactor  
14 and on simultaneously on the NRC side it wasn't a fee-  
15 based approach.

16               It strikes me with those resources, there  
17 might be some benefit to do this. But I sense that  
18 there's a resource underpinning here. On a level of  
19 where I want to spend my resources, this is low on the  
20 totem pole.

21               CHAIR STETKAR: I'm going to have to  
22 interject here, because we do have a schedule and --

23               MEMBER CORRADINI: Well, you didn't stop  
24 me before.

25               CHAIR STETKAR: No, I know. I need to let

1 the discussion play out until we start repeating too  
2 many things. So anything else for the industry?

3 (No response.)

4 CHAIR STETKAR: Okay. If not, we do have  
5 Mary Drouin on the line, and I want to make sure we  
6 get the line opened up, because she has been patiently  
7 waiting out there. She wants to make a statement.  
8 While we're getting the line opened up, for the record  
9 we do have written material from Mary.

10 It will be entered into the record of the  
11 meeting, so that it will be on the meeting record,  
12 discussing her non-concurrence on the staff's SECY  
13 paper. But with that background, Mary would like to  
14 have the opportunity to give us a little bit of oral  
15 background and perspectives on her non-concurrence.

16 But I'm hearing popping and crackling.  
17 Mary, if they're out there, could you just let us know  
18 that you're there?

19 (No response.)

20 CHAIR STETKAR: And we're not hearing  
21 that. So we're going to wait and get the actual line  
22 open.

23 (Pause.)

24 CHAIR STETKAR: I'm told the line is open.  
25 Mary, are you there?

1 (Pause.)

2 CHAIR STETKAR: Hmm. So --

3 MR. SNODDERLY: John, this is Mike  
4 Snodderly, ACRS staff. What I'd like to suggest is  
5 that, as you said, we're going to have this document  
6 that was emailed to us by Mary entered into the  
7 record.

8 It will be part of the transcript and put  
9 into ADAMS. If someone from the public would like a  
10 copy of the email, please you can either phone me at  
11 301-415-2241 or at mrs1@nrc.gov, and I'll forward you  
12 the email. But eventually it will be put into ADAMS  
13 this week and will be referenced in our --

14 CHAIR STETKAR: Okay. Thanks Mike. I  
15 appreciate that. While we're -- we're going to see if  
16 we can perhaps contact Mary on the side, to see if  
17 she's available. While we're doing that, let me take  
18 the opportunity to ask is there anyone, members of the  
19 public in the room who would like to make a statement?  
20 If so, come up to the mic and do so.

21 (No response.)

22 CHAIR STETKAR: And since we have, I  
23 think, the bridge line open, if there are members of  
24 the public on the bridge line, could you just someone  
25 say hello to confirm that indeed the line is open?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 (No response.)

2 CHAIR STETKAR: Okay. Silence is always  
3 questionable.

4 MR. SNODDERLY: It's open.

5 CHAIR STETKAR: I've been told the bridge  
6 line is open, so I'm assuming there is no one out  
7 there.

8 MR. SNODDERLY: She's not available for  
9 about five minutes.

10 (Pause.)

11 CHAIR STETKAR: Okay. Mary is temporarily  
12 unavailable. So as Mike Snodderly said, we certainly  
13 will enter her written comments into the record.  
14 They're rather complete. I've scanned through them.  
15 So they will be on the meeting record and, as Mike  
16 said, available to the public.

17 With that, I'd like to ask if there are  
18 any other member comments?

19 VICE CHAIR BLEY: I have a question. Was  
20 there any -- has there been any resolution to --

21 CHAIR STETKAR: I don't know. I think  
22 we'll have to -- I don't believe so. But for the non-  
23 concurrence, I don't believe so.

24 VICE CHAIR BLEY: Any resolution at all to  
25 the non-concurrence, or it's just standing by itself?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. DUDLEY: It was just received at seven  
2 o'clock this morning.

3 VICE CHAIR BLEY: Oh, this morning. Okay.

4 CHAIR STETKAR: Yeah. It's very recent.

5 VICE CHAIR BLEY: I didn't know.

6 MR. DUDLEY: It's been partially read.

7 VICE CHAIR BLEY: Okay, fair enough.

8 CHAIR STETKAR: Any other comments or  
9 questions for the staff or the industry? If not, we  
10 are recessed until one o'clock this afternoon.

11 (Whereupon, the above-entitled matter went  
12 off the record at 10:54 a.m. and then resumed.)

13 CHAIRMAN STETKAR: We are back in session.  
14 The topic for this afternoon is the Davis-Besse  
15 Nuclear Power Station license renewal, and Harold Ray  
16 will lead us through this session. Harold?

17 MEMBER RAY: Thank you, John. In  
18 reviewing the application for license renewal at  
19 Davis-Besse we'll be hearing obviously from the  
20 applicant and also from our Division of License  
21 Renewal.

22 There is a bridge line, as we just heard,  
23 in service. It's going to remain in a listen-in mode  
24 until we end the meeting today when it will be open  
25 for any comments from members of the public. Also,

1 we've received a request to address the Committee by  
2 someone present in the audience. He and anyone else  
3 who wishes to do so may make comments on the record at  
4 the end.

5 As we will seen in timelines that are to  
6 be presented, the Davis-Besse license renewal  
7 application was submitted in 2010 and the License  
8 Renewal Subcommittee first met to review the SER with  
9 open items two years later in 2012. We met again in  
10 September of this year to review the final SER and  
11 Supplement 1 to that SER which had been issued a month  
12 prior in August of this year.

13 The discussion at our first Subcommittee  
14 meeting including questions concerning the potential  
15 for groundwater on the exterior of the containment  
16 pressure vessel and refueling canal leakage on the  
17 interior to cause corrosion of the steel pressure  
18 vessel. This was addressed at our second Subcommittee  
19 meeting and now by the Aging Management Program and it  
20 will be addressed later here today.

21 Following our second Subcommittee meeting  
22 the applicant provided on the LRA docket for our  
23 review the calculations and analyses which had been  
24 performed concerning the effect of concrete cracking  
25 on the strength of the shield building. We needed to

1 perform this review in order to evaluate the adequacy  
2 of the Shield Building Aging Management Program. The  
3 applicant also provided on the docket a letter further  
4 describing the margin between the cracking, which is  
5 expected to exist at the start of the period of  
6 extended operation and that which has been  
7 conservatively assumed in the calculation of its  
8 effects. We appreciate the clarification provided  
9 since the assessment of any Aging Management Program  
10 needs to understand the margins which do exist.

11 Also following our second Subcommittee  
12 meeting the applicant submitted an amendment to the  
13 LRA which elaborates on the use of nondestructive  
14 testing to monitor the extent of the concrete  
15 cracking. Again, this is important relative to  
16 assuring that margin is maintained between the  
17 cracking which exists and that which has been assumed  
18 in the analyses.

19 Finally, the staff and we, including our  
20 consultant Dr. Shack, have separately reviewed the  
21 analysis used by the applicant to demonstrate the  
22 effect of the concrete cracking on the ability of the  
23 shield building to perform its intended functions and  
24 the applicant will submit an amendment to include this  
25 analysis in the current license.

1                   We will now proceed and I call on Jane  
2 Marshall to begin.

3                   MS. MARSHALL: Okay. Thank you, Mr. Ray.  
4 As stated, I'm Jane Marshall. I'm the Deputy Director  
5 for the Division of License Renewal and members of my  
6 Management Team with me here today at the table are  
7 Yaira Diaz-Sanabria. She is Branch Chief of Project  
8 Branch 1. In the audience we have additional branch  
9 chiefs Dennis Morey, Brian Wittick, James Danna and  
10 Steve Bloom. Also in the audience joining us today  
11 from Region III is Jim Neurauter. He is the lead  
12 inspector from Region III who led the shield building  
13 laminar cracking inspections.

14                  The staff's presentation on the Davis-  
15 Besse Safety Evaluation Report will be given by the  
16 safety project manager, Rick Plasse, who will be  
17 joined at the presentation table by another one of our  
18 safety project managers, Phyllis Clark. We also have  
19 in the audience with us today a number of staff  
20 members from NRC, and those who add comments or answer  
21 questions during the presentations will introduce  
22 themselves at that time.

23                  As you know, the last time we met with the  
24 ACRS Subcommittee was on September 23rd of 2015 when  
25 we discussed the resolutions for the open items that

1 were documented in the final SER that was issued in  
2 September of 2013 and in Supplement 1 to that SER  
3 which was issued in August of 2015.

4 Rick Plasse will provide an overview and  
5 background of the staff's safety review on the Davis-  
6 Besse license renewal application and will go into  
7 more details on the resolution of the open items  
8 during his presentation.

9 At this time I'd like to turn the  
10 presentation over to FirstEnergy and the site vice  
11 president Brian Boles to introduce his team and give  
12 their presentation.

13 MR. BOLES: Thank you. Good afternoon.  
14 My name is Brian Boles. I'm the site vice president  
15 at Davis-Besse. We have an agenda that we will run  
16 through today. I'll provide the introductions, we'll  
17 cover some of the background -- sorry. Should I start  
18 over?

19 My name is Brian Boles. I'm the site vice  
20 president at Davis-Besse. Today I'll provide some  
21 introductions, we'll cover some of the background  
22 information of Davis-Besse, we'll cover our license  
23 renewal application description, closure of the  
24 previously mentioned open items, we'll talk about our  
25 containment vessel inspections and then we'll have a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 summary and closing remarks at the end.

2 I'd like to introduce the team that we  
3 have here today. Along with myself, to my left is Ken  
4 Byrd. He's the director of site engineering. And to  
5 Ken's left is Cliff Custer. He is the fleet project  
6 manager for our license renewal effort and Steve Dort  
7 is our Davis-Besse site project coordinator. We also  
8 have a number of our License Renewal Core Team members  
9 seated in the room here over to my right, and a fairly  
10 large contingent of our Aging Management Program  
11 owners and subject matter experts are also seated in  
12 the room.

13 With that, what I'd like to do is turn our  
14 presentation material over to Ken who will cover most  
15 of this material, and then we'll also be introducing  
16 another member of our team that will cover some of the  
17 details. Ken?

18 MR. BYRD: Okay. If you could go to the  
19 next slide.

20 CHAIRMAN STETKAR: Yes, just remember turn  
21 your mics on when you speak; turn them off when you  
22 don't. It helps our transcript.

23 MR. BYRD: Okay. So first of all, I'll  
24 provide a little background on Davis-Besse, our site  
25 and location.

1           So, we're on the southwestern shore of  
2     Lake Erie. We're in Ottawa County. It's in Ohio.  
3     We're about between 20 to 30 miles east of Toledo, and  
4     Toledo is the nearest metropolitan area to the site.  
5     The site is a 954-acre site, and of that site 733  
6     acres are wildlife refuge and marshland and that's  
7     leased to the U.S. Government.

8           Could you go to the next slide, please?  
9     Okay. We're a pressurized water reactor. Davis-Besse  
10    is a Babcock & Wilcox designed nuclear steam supply  
11    system. The one unique feature, or one of our unique  
12    features, we're a raised-loop design. The raised loop  
13    design is unique and it provides improved natural  
14    circulation over the previous designs. Bechtel was  
15    our construction management. And our operating  
16    license expires on April 22 of 2017.

17           So I'll talk very briefly here about some  
18    of our recent improvements. And there's many things  
19    we've done. I just selected a few of the really high-  
20    level ones for this slide. But just to cover a few  
21    other things we've done just within the last year, in  
22    our last outage we put in digital electrohydraulic  
23    control. Eliminates single point vulnerabilities.  
24    Provides us with improved monitoring capability.

25           We replaced our turbine plant cooling



1 water heat exchangers and turbine plant cooling water  
2 valves. It improves our thermal performance, gives us  
3 better isolation.

4 We modified a major project over an  
5 extended period of time. We modified our switchyard.  
6 Added in three new breakers, added in a new offsite  
7 line. That significantly improves our operational  
8 flexibility and our reliability for loss of offsite  
9 power.

10 We replaced our reactor coolant pump seal  
11 vent piping with flexible hoses for all four of our  
12 reactor coolant pumps. This reduces our  
13 susceptibility to high-cycle fatigue in the socket  
14 welds in that piping. On our last outage we replaced  
15 about 1,000 feet of service water piping, and that's  
16 part of a multi-outage project we have to replace all  
17 of our small service water piping. That would be  
18 piping under six inches. And that will improve our  
19 capability of that piping.

20 And as we speak right now, we're in the  
21 process of replacing the second of our two station air  
22 compressors. So we're just improving the reliability  
23 of those components.

24 Moving on to the more larger items, which  
25 I put on the slide here, we did in our -- in 2011 we

1 replaced our reactor head. Our new head has got alloy  
2 690 control rod drive mechanism tubes making it less  
3 susceptible to primary water stress corrosion  
4 cracking. Picture in the center there is our new head  
5 going through the shield building.

6 In our outage we conducted in the spring  
7 of 2014 -- we replaced both of our once through steam  
8 generators. We also replaced a portion of our reactor  
9 coolant system hot legs. Again, this eliminated the  
10 alloy 600. Our new tubes are alloy 690 making us less  
11 susceptible to stress corrosion cracking.

12 And then finally, the picture I have on  
13 the right there, that's a picture of our new emergency  
14 feedwater facility under construction. That  
15 construction is going on right now. And that's a  
16 project that we initiated in response to two programs.  
17 One is the National Fire Protection Association 805  
18 and the other is our FLEX. This provides us with our  
19 Phase 1, the initial response in FLEX. It also  
20 significantly improves our fire core damage frequency  
21 and that assists us in our NFPA 805.

22 What we're going to have here is a  
23 290,000-gallon tank. We'll have a diesel-driven  
24 feedwater pump which would be equivalent to our  
25 current auxiliary feedwater pump. Similar head and

1 similar flow. And when we get this completed that  
2 will be an automatic start. This provides us with a  
3 lot of benefits. Of course this will all be seismic.  
4 It will be missile-protected. Benefits we'll get.  
5 We'll get a significant improvement in our core damage  
6 frequency for fire, about two orders of magnitude.  
7 And it will also provide us with a pretty good benefit  
8 to our online core damage frequency.

9 So that's a very brief kind of outline of  
10 some of the things that we have going on for long-term  
11 site improvements at Davis-Besse.

12 At this point now I'll turn it over to  
13 Cliff to talk about some of the details of our license  
14 renewal application.

15 MR. CUSTER: Thank you, Ken. My name is  
16 Cliff Custer. I'm the fleet project manager for  
17 license renewal.

18 So the application was developed to GALL  
19 Rev 1, but was reviewed to GALL Rev 2 due to the  
20 changes in the initiation of GALL Rev 2. It was  
21 developed by a core team of AREVA and the FENOC Core  
22 Team. Site review and concurrence were involved in  
23 the documents that went into the application and we  
24 had industry peer review prior to submittal. There  
25 are 44 Aging Management Programs, 13 of which are new

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 and 31 of which are existing programs. We ended up  
2 with 55 license renewal commitments.

3 Next slide, please. So this is a timeline  
4 of the application evolution. We began the project in  
5 2008. We submitted in August of 2010. Our  
6 sufficiency review was in October of 2010. And to a  
7 large degree our audits occurred in 2011. You'll  
8 notice on the bottom of the slide we had an event  
9 occur which we'll talk about later. The shield  
10 building crack was observed in October of 2011. But  
11 moving forward we had a draft safety evaluation report  
12 that was issued in 2012. Our first Subcommittee  
13 meeting was in September of 2012 and the final SER  
14 occurred in 2013. Our Supplemental SER was originated  
15 in August of this year, and of course our second  
16 Subcommittee meeting was September of this year.

17 Next slide, please. So in the earlier  
18 safety evaluation we had four open items. They were  
19 addressed and closed in the September 2013 safety  
20 evaluation. They were related to operating  
21 experience, reactor vessel neutron embrittlement,  
22 pressure-temperature limits, and of course the shield  
23 building.

24 So different individuals will now talk to  
25 that issue. Next slide, please, Steve. So I'll have

1 Trent Henline speak to the operating experience and  
2 how we've closed that open item.

3 MR. HENLINE: Trent Henline, license  
4 renewal implementation project manager.

5 So, in December of 2012 we updated both  
6 our Corrective Action Program and our Operating  
7 Experience Program to allow for an aging management  
8 evaluation check box. What we do with this is we  
9 allow the normal course of evolution evaluation for  
10 those two processes to take place. And independently  
11 we evaluate these particular instances in accordance  
12 with the Aging Management Program to determine if we  
13 are appropriately addressing the items that may have  
14 been identified independently.

15 So we use this as an opportunity to review  
16 external operating experience, internal operating  
17 experience, NRC guidance, including revisions to the  
18 GALL, or the generic aging lessons learned, as well as  
19 vendor technical information that we may get through  
20 our normal processes. This process has proven to be  
21 effective. We have identified over 500 items that  
22 have been considered for aging management evaluation  
23 and we're confident that this process will be  
24 successful through the period of extended operation.

25 MR. CUSTER: To discuss the next two open

1 items I'll ask Dennis Blakely, subject matter expert,  
2 to discuss how we closed the reactor vessel neutron  
3 embrittlement and pressure-temperature limits open  
4 item.

5 Please go ahead, Dennis.

6 MR. BLAKELY: Good afternoon. My name is  
7 Dennis Blakely and I'm the reactor engineering  
8 supervisor at Davis-Besse and also the reactor vessel  
9 Aging Management Program owner.

10 We had two open items related to the  
11 reactor vessel as a result of our license renewal  
12 application. The first had to do with the upper shelf  
13 energy evaluations done for the vessel. Initially we  
14 used a generic value of 70 foot-pounds for that upper  
15 shelf energy evaluation. That would be the initial  
16 upper shelf energy. That was based on a mean value  
17 for similar type weld materials because we do not have  
18 material data for all the welds in the reactor vessel.  
19 That was considered statistically non-conservative  
20 since half of the values lie below the mean for that  
21 material data.

22 We evaluated the consequences of utilizing  
23 initial upper shelf energy that would bound the lowest  
24 data available and found that that would result in  
25 values less than 50 foot-pounds. 10 CFR 50 Appendix

1 G requires the final upper shelf energy to remain  
2 above 50 foot-pounds or requires the licensee to  
3 provide equivalent margins analysis to demonstrate  
4 that there's still adequate margins against fracture  
5 if the value is determined to be below 50 foot-pounds.

6 FirstEnergy conservatively decided to  
7 perform evaluations for all the reactor vessel welds  
8 utilizing equivalent margins analysis to ensure that  
9 we do have adequate margin to safety for the vessel.  
10 The results of those analyses demonstrated that we do  
11 retain adequate margin and the information was  
12 provided to the NRC staff. They reviewed it and  
13 closed the open item based on those analyses.

14 Next slide, please? The other issue with  
15 the reactor vessel aging had to do with the  
16 methodology utilized to develop the pressure-  
17 temperature limit curves at the plant and also sought  
18 assurance that we had considered all the reactor  
19 vessel materials as well as the ferritic materials  
20 that constitute the reactor coolant system when  
21 developing those pressure-temperature limits.

22 We do utilize 10 CFR 50 Appendix G and  
23 Regulatory Guide 1.99 Revision 2 methodologies in  
24 developing our pressure-temperature limit curves. We  
25 also use the methodologies described in the topical

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 report BAW-10046, which has been approved by the NRC.  
2 That topical report details how the other ferritic  
3 materials in the reactor coolant system and the  
4 reactor vessel are considered within the development  
5 of the pressure-temperature limit curves. With the  
6 amount of fluents that the reactor vessel has received  
7 and will receive during the period of extended  
8 operation the reactor vessel beltline material is  
9 controlling for the plant at this point in time.

10 Any questions, please?

11 (No audible response)

12 MR. BLAKELY: Thank you.

13 MR. CUSTER: Moving on, I'd like to turn  
14 the discussion of the shield building now over to Ken  
15 and follow through with that discussion.

16 MR. BYRD: Thanks, Cliff. So for our  
17 discussion of the shield building I'm going to have  
18 our design engineering manager Jon Hook come up to the  
19 front table here. And just to introduce Jon, Jon is  
20 our design engineering manager. He is a civil  
21 engineer with over 40 years of experience in  
22 engineering design, also a member of the EPRI Concrete  
23 Technical Oversight Committee. So we are very  
24 fortunate to have Jon as our lead for the shield  
25 building activity over the last four years.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 I also wanted to introduce a couple other  
2 people who are here and are going to be supporting us  
3 in our discussion of the shield building. Over on the  
4 side table we have Dr. Chong Chiu. Dr. Chiu is the  
5 founder of Performance Improvement International. PII  
6 is internationally recognized for their root cause  
7 analysis and investigations.

8 We did engage Dr. Chiu and his  
9 organization immediately back in November of 2011 when  
10 he first identified this condition. They did perform  
11 the initial root cause that we had conducted on the  
12 shield building. Later when we identified additional  
13 cracking, as Jon will describe as we walk through the  
14 events that occurred, we reengaged Dr. Chiu's  
15 organization. They conducted the second root cause as  
16 well on the propagation of cracking. And then finally  
17 we engaged Dr. Chiu to investigate the condition of  
18 the shield building with regards to relative humidity  
19 and our expectations with regards to how that  
20 condition would develop. So Dr. Chiu was involved in  
21 many of the different aspects of our investigations.

22 The other individual I want to introduce  
23 is Dr. Javeed Munshi. Dr. Munshi is a senior  
24 principal engineer and Bechtel Fellow. He has over 25  
25 years experience in design and construction of

1 concrete structures. Dr. Munshi is chair of the ASME  
2 Code Committee for Concrete Containment. He's also a  
3 member of the American Concrete Institute Code  
4 Committee for Nuclear Concrete Structures. He's a  
5 fellow of the American Concrete Institute, fellow of  
6 the American Society of Civil Engineers and fellow of  
7 the Structural Engineering Institute.

8 We brought Dr. Munshi in as part of our  
9 initial team back in October of 2011 when we first  
10 identified we had laminar cracking. He was involved  
11 in the initial investigations and assisted us in  
12 performing the analysis that was required to determine  
13 we had the functionality of the shield building prior  
14 to restarting. Dr. Munshi was also involved in the  
15 formulation of our testing program we did at Kansas  
16 and Purdue University as well as in the evaluation of  
17 those test results. And then finally, Dr. Munshi and  
18 his organization were involved or actually performed  
19 the design basis analysis which we are using to move  
20 forward based on the Purdue and Kansas analyses.

21 So what we're going to talk about here,  
22 really our intent here is to describe the Aging  
23 Management Program that we have to ensure that the  
24 shield building maintains its functions throughout our  
25 period of extended operation, recognizing this is a

1 complicated topic. We've been at this for four years  
2 and had a lot of activity. So in order to make sure  
3 that we can coherently describe this, first we're  
4 going to describe the initial condition, where we are  
5 in the shield building.

6 Mr. Hook here is going to walk through a  
7 timeline and attempt to in a brief period of time  
8 bring us all up to speed with the various activities  
9 that we've performed with regards to the shield  
10 building. Then we'll get into a more detailed  
11 description of our monitoring program and our basis  
12 for concluding the shield building conditions  
13 acceptable.

14 So at this point I'll turn it over to Jon  
15 Hook.

16 MR. HOOK: Thank you, Ken. As Ken  
17 indicated, my name is Jon Hook. I am the design  
18 engineering manager at Davis-Besse.

19 Next slide, please. So I'd like to start  
20 off with some basic information on our shield building  
21 to get everyone familiar with the structure. The  
22 shield building is a reinforced concrete structure.  
23 It's independent of our containment vessel and there's  
24 a four-and-a-half-foot annular between the two.  
25 Although the shield building and containment are

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 independent, they do share the same foundation. The  
2 shield building design function is to provide  
3 biological shielding, provide protection of the  
4 containment vessel and it provides an extra barrier  
5 for defense-in-depth against a release during an  
6 accident.

7 Next slide. Our shield building has what  
8 we call shoulders. So if you look at the upper left-  
9 hand part there, you'll see 16 projections sticking  
10 out of the cross-section of our shoulder. Those are  
11 shoulder areas. They serve no structural purposes and  
12 are only there for architectural reasons. Now if you  
13 look at the upper right, that is a picture of one of  
14 our shoulders and you'll notice that it terminates  
15 right above the aux building roof. The lower left is  
16 a section of our shoulder area where were first  
17 identified laminar crack. A laminar crack was located  
18 along the outer matte rebar shown here in red. And  
19 the picture on the lower right is a picture of one of  
20 the cracks inside our core bore. That crack has a  
21 crack width of 5,000th an inch, about the size or  
22 thickness of a single sheet of paper, and the cracks  
23 are very tight.

24 Next slide, please. Now I'd like to go  
25 over the major activities associated with the shield

1 building. In October of 2011 --

2 VICE CHAIR BLEY: Jon?

3 MR. HOOK: Yes?

4 VICE CHAIR BLEY: Just from that last  
5 picture the cracks that you found are all in the  
6 shoulder area?

7 MR. HOOK: No, that was the initial  
8 condition just in the shoulder areas.

9 VICE CHAIR BLEY: Okay.

10 MR. HOOK: But we did find cracking at two  
11 other areas, the top 20 feet and then around the main  
12 steam line penetration areas. And I'll get into that.

13 VICE CHAIR BLEY: Okay. Thanks.

14 MR. HOOK: Okay. So a laminar crack was  
15 first identified when we provided an opening in the  
16 shield building to replace our reactor head. We  
17 formed a team of experts that Ken mentioned, Bechtel  
18 Power and Performance Improvement International  
19 engineers, and we did perform impulse response mapping  
20 and we did core bores to confirm the results and also  
21 to locate the crack. If you're not familiar with  
22 impulse response, that is a nondestructive examination  
23 technique very similar to ground penetrating radar  
24 where you take a calibrated mallet and you strike the  
25 building and then you record the amount of energy

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 brought back. Based on this investigation laminar  
2 cracking is located along the outer matte of the main  
3 reinforcing steel. It's assumed to occur in all our  
4 shoulders, the top 20 feet of the shield building and  
5 near the two main steam line penetrations.

6 In November of 2011, prior to starting the  
7 plant up, we performed two analyses to show that the  
8 shield building meets its designed function. We took  
9 no credit for the rebar lap splice in the areas of  
10 laminar cracking. These calculations were reviewed by  
11 the NRC prior to restart. We also did a seismic two-  
12 over-one analysis to address the effect of the  
13 shoulder separating from the shield building during a  
14 seismic event. These analyses show that we have a  
15 very high margin of safety, well over four times  
16 required by the code.

17 In May of 2012 we --

18 MEMBER RAY: Jon, just to make sure  
19 everybody understands what you just said, you're,  
20 really if understood you, talking about the potential  
21 for spalling when you're talking about the shoulder  
22 areas.

23 MR. HOOK: Well, it's more than just  
24 spalling. It's the whole shoulder falling off, yes.

25 MEMBER RAY: Well, all right. The

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 shoulder coming off.

2 MR. HOOK: Right.

3 MEMBER RAY: That's what I call spalling.

4 MR. HOOK: All right.

5 MEMBER RAY: But in any event -- and  
6 that's what you meant by the margin you just referred  
7 to?

8 MR. HOOK: That is correct.

9 MEMBER RAY: Because there are other  
10 margins in here and we have to sort of keep track as  
11 we go along. Okay. Thanks.

12 MR. HOOK: Correct. No, right, the four  
13 times margin was associated with the shoulders --

14 MEMBER RAY: Yes.

15 MR. HOOK: -- separating.

16 MEMBER RAY: Shoulders separating. We'll  
17 use that term. Okay.

18 MR. HOOK: Okay. Thank you.

19 In May of 2012 we completed our root  
20 cause. This was led by Performance Improvement  
21 International. Through extensive investigation,  
22 testing and analysis the root cause was determined to  
23 be wind-driven rain that saturated the concrete  
24 followed by a sudden drop to near-zero temperatures.  
25 This resulting in freezing the water and cracking the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 concrete. Contributing causes were the reinforcing  
2 steel configuration in the shoulder areas, stress  
3 concentrations associated with the shoulder areas and  
4 high density of rebar spacing in the top 20 feet and  
5 near the main steam line penetration areas. This root  
6 cause --

7 MEMBER RAY: Jon, let me interrupt you  
8 again, because you used a phrase there that triggers  
9 the point I want to make.

10 We've seen this attributed to a particular  
11 event in 1978. You didn't do that. Was it your  
12 intent to say this could have happened over a longer  
13 period than that one event?

14 MR. HOOK: This was a singular event --

15 MEMBER RAY: Okay.

16 MR. HOOK: -- as a result of the blizzard  
17 of 1978.

18 MEMBER RAY: Because it was 33 years until  
19 you discovered it, it's that gap that I'm wanting to  
20 make sure you intend to refer to. Okay.

21 MR. HOOK: Right. Right. Correct. This  
22 happened much earlier on in the life of the plant.

23 MEMBER RAY: Okay.

24 MR. HOOK: Thank you.

25 MEMBER SKILLMAN: Jon, how do you know

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1       that it was that single event that began this course  
2       of events?

3               MR. HOOK:   Okay.   What I'd like to do is  
4       refer to Dr. Chiu who did the evaluation.

5               MEMBER SKILLMAN:   Please.   Yes, sir.  
6       Please.

7               MR. HOOK:   Dr. Chiu?

8               DR. CHIU:   Yes, this is Chong Chiu.   As  
9       indicated, we did an analysis, a root cause analysis.  
10      What we did is we started with 45 failure modes  
11      including everything we know about concrete failures.  
12      So by process of elimination -- we first of course --  
13      through thermal cycling we find out that stress is  
14      very low.   And then through other mechanisms we do a  
15      core bore and analyze what's the data?   We find out  
16      there's only one mechanism can occur with that large  
17      stress.   Was a single shock, because all the crack has  
18      no I call the ridges.   No sign of propagation.   All  
19      the fractured surface is very smooth.   It's like one  
20      force, very big force.

21              So with that we start looking at all the  
22      -- I call it weather or climate events through the  
23      construction, through the operation of the plant.   So  
24      we identify only two events that can have that  
25      problem, can cause that issue, or this force.   Is '77

1 and '78. So analyze the two events. We find out '77,  
2 the water is not enough. That's just so -- the rain  
3 is not as heavy as '78 and therefore not enough water  
4 are impregnated into the concrete. Therefore, upon  
5 freezing the stress is so low, low enough not to cause  
6 the one single shock can cause the crack. So only by  
7 process of elimination we only have '78 as only  
8 possibility can cause that event.

9 MEMBER SKILLMAN: Okay. Thank you.

10 MR. HOOK: And this root cause was --

11 MEMBER RICCARDELLA: Excuse me.

12 MR. HOOK: Okay. Sure.

13 MEMBER RICCARDELLA: Can we go back to the  
14 previous slide?

15 Given the root cause I guess I'm somewhat  
16 surprised at the location of the crack as it  
17 approaches the shoulder. Why would it be in the  
18 second rebar layer as opposed to the first one that's  
19 closer to the surface?

20 MR. HOOK: So there is stress  
21 concentrations in there as a result of the shoulder  
22 configuration. So there's some locked in additional  
23 stresses that are there.

24 PARTICIPANT: Dr. Chiu's analysis. Do you  
25 want to have him describe that?

1 MR. HOOK: Yes. And, okay, Dr. Chiu,  
2 that's consistent with your analysis that you did on  
3 your modeling that you did?

4 DR. CHIU: Yes, exactly. That location is  
5 very unique because it's have two edges. We have  
6 water impregnated into the concrete from two sides.  
7 Then you freeze up and cause the expansion. You can  
8 generate a very large stress in the second point.  
9 That's why it start cracking at that point.

10 MEMBER RICCARDELLA: The other edge you're  
11 referring to is the flute?

12 DR. CHIU: Yes, flute. Two edge. You see  
13 that --

14 MEMBER RICCARDELLA: Yes.

15 DR. CHIU: -- corner? Yes.

16 MEMBER RICCARDELLA: Yes.

17 MEMBER RAY: The stress explanation I  
18 think also applies to the upper region where it's in  
19 between the shoulders.

20 DR. CHIU: I miss your point, sir.

21 MEMBER RAY: I believe the explanation  
22 having to do with the high stress area applies also to  
23 the upper region where it goes across the barrel  
24 section between the shoulders.

25 DR. CHIU: Yes, I think.

1 MEMBER RAY: Speak up.

2 DR. CHIU: Yes, sir.

3 MEMBER RAY: All right. I'm just trying  
4 to get a consistent explanation on the table here.  
5 And if I'm mistaken, please tell me, but that's what  
6 I understood to be the case.

7 MR. HOOK: Right, so in addition to the  
8 stresses that are up there, the top 20 feet is unique  
9 in the fact that we have a high density of rebar. We  
10 have No. 11 rebar spaced at six inches on center. So  
11 that's unique to that area. And that's the same  
12 configuration that's around the main steam line  
13 penetration area, too. So there's a little different  
14 rebar configuration there compared to what's in the  
15 shoulder area. But it has to do with stresses as  
16 well.

17 Okay. So the first root cause was  
18 reviewed by the NRC in a special inspection.

19 Going on to July 2012, we did complete our  
20 rebar test at Purdue University and the University of  
21 Kansas. These independent tests show that near design  
22 capacity is achieved for cracks that are significantly  
23 wider than we see on our shield building, and portions  
24 of these tests were witnessed by both FirstEnergy and  
25 the NRC individuals.

1 In August of 2012 we completed our first  
2 annual inspections with no identified issues. Also,  
3 in October of 2012 we completed the coating of the  
4 shield building exterior. The root cause identified  
5 high winds and driving rain with near-zero  
6 temperatures that caused the crack. The only  
7 practical item that we could control would be the  
8 ability to coat the shield building to prevent water  
9 from penetrating the concrete.

10 In August of 2013 we established the  
11 design-based calculation that addresses the current  
12 condition of the shield building. This calculation  
13 also incorporated the rebar test results from Purdue  
14 and Kansas University, and this calculation was also  
15 the subject to a special NRC inspection.

16 Also in August of 2013 we completed our  
17 second monitoring campaign. It was during this  
18 campaign when we first identified crack propagation.  
19 As a result, we inspected all 80 core bores and  
20 performed impulse response testing to establish the  
21 condition of laminar crack.

22 Yes?

23 CHAIRMAN STETKAR: Let me interrupt you.  
24 If anybody has your microphones on, if you're not  
25 speaking, please turn them off. We have some folks on

1 the bridge line who are complaining that they can't  
2 hear because of rustling of papers and whatnot.

3 MR. HOOK: Okay.

4 PARTICIPANT: Can people on the phone mute  
5 their phones?

6 CHAIRMAN STETKAR: I don't know what that  
7 means, Glen.

8 PARTICIPANT: No, ask the people on the  
9 phones to --

10 CHAIRMAN STETKAR: People on the phones  
11 out there, also if you're listening in, please mute  
12 your phones so that we don't get cross-talk among  
13 people who are connected through the bridge line. If  
14 you could do that so all of you can hear.

15 Now, Dennis?

16 VICE CHAIR BLEY: Jon --

17 MR. HOOK: Okay. Continuing with --

18 VICE CHAIR BLEY: Jon, I had a question  
19 before he --

20 MR. HOOK: All right.

21 VICE CHAIR BLEY: -- shut me up. What  
22 kind of coatings did you use? And on concrete how  
23 long do these hold up? Do you have to do this  
24 routinely in the future?

25 MR. HOOK: So, what we applied was the

1 primer coat and then two top coats. And it was done  
2 by Sherwin-Williams, but I forget the actual number.  
3 But it's designed for high wind penetrating water, so  
4 it is a very good seal. It's part of our Aging  
5 Management Program. We perform this inspection every  
6 five years to make sure the coating system is intact,  
7 and also we will re-coat the shield building in 15.  
8 It has a 20-year life. We'll re-coat it in 15 years.

9 VICE CHAIR BLEY: Thank you.

10 MR. HOOK: Okay. So as a result of  
11 identifying crack propagation we inspected all 80 core  
12 bores and performed impulse response testing to  
13 establish the condition of the crack. We established  
14 a Root Cause Team. This again was led by Performance  
15 Improvement International. And based on their  
16 investigation of the crack surface and analysis ice  
17 wedging was determined to be the cause.

18 Three things are needed for ice wedging.  
19 You need an existing crack, high concrete humidity and  
20 freezing temperature that would result in collection  
21 of water in the cracked area, freeze and then expand  
22 to propagate the crack. This root cause was also  
23 subject to a special NRC inspection.

24 MEMBER SKILLMAN: Jon, let me ask this,  
25 and this is primarily for the record: You had a root

1 cause in 2012.

2 MR. HOOK: Correct.

3 MEMBER SKILLMAN: Then we got to do  
4 another root cause.

5 MR. HOOK: Correct.

6 MEMBER SKILLMAN: So for those of us who  
7 came out of Corrective Action Programs and how strong  
8 are your corrective actions and how strong are your  
9 root causes and have you really gotten to the bottom  
10 of the issue? Why was a second root cause needed,  
11 please?

12 MR. HOOK: So there are two separate  
13 phenomena that occurred, and I'll let Dr. Chiu go into  
14 detail on those.

15 MEMBER SKILLMAN: Thank you.

16 DR. CHIU: Yes, This is Chong Chiu. The  
17 second root cause was initiated because the crack  
18 propagation at the bottom. What result of that  
19 analysis has shown, one of the contributing factor  
20 which didn't exist before is the paint. When you  
21 paint the concrete, you change the temperature profile  
22 such that the water will be driven from inside of the  
23 containment or shield building toward the outside.  
24 And also at the bottom the water through gravity will  
25 accumulate at the bottom. So as the paint solve the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 problem of a blizzard but do cause the water  
2 redistributed inside the containment, which was a  
3 phenomenon, was not in existence before. So  
4 therefore, the second root cause has to be initiated.

5 MEMBER SKILLMAN: Thank you.

6 MR. HOOK: Also, just to add on what Dr.  
7 Chiu was saying, that we did do a core bore in the  
8 area of a new crack propagation and its cracked  
9 surface is significantly different than all the other  
10 core bores that we had. All the other core bores were  
11 very smooth. This one was step cracked towards -- is  
12 a different phenomenon, and there's evidence of that.

13 MEMBER SKILLMAN: Okay. Thank you, Jon.

14 MR. HOOK: In May of 2015 we performed a  
15 series of analyses to establish the limit of crack  
16 propagation. These analyses show that we have  
17 significant margin over 20 years at the current crack  
18 growth rate before we reach a limit where additional  
19 analysis may be required.

20 And in August of 2015 performance  
21 improvement completed a series of evaluations and  
22 tests to show that the shield building relative  
23 humidity trend is declining and that the shield  
24 building will dry out to an acceptable level within  
25 two to eight years. And then just --

1                   MEMBER RAY:     Jon, I just want to  
2 underscore something you said.     You said it  
3 accurately. I said it earlier also. But to be sure  
4 everyone understands. The margin we are referring to  
5 is the margin to the conservative assumptions in the  
6 calculations that have been done --

7                   MR. HOOK:   That's right.

8                   MEMBER RAY:     -- to demonstrate  
9 functionality. It's not the margin to building  
10 failure, but --

11                  MR. HOOK:   Oh, no, not by any means.  
12 There's more steps to follow that we could do.

13                  MEMBER RAY:   But you made a conservative  
14 assumption, you've done calculations and it's the  
15 margin to those assumptions that we're talking about.

16                  MR. HOOK:   That is correct.

17                  MEMBER RAY:   All right.

18                  MEMBER RICCARDELLA: Excuse me. Would you  
19 mind if we went ahead a couple of slides? I always  
20 believe a picture is worth 1,000 words. Could we go  
21 to page 19, slide 19 where you have the results of the  
22 IR mapping?

23                  Yes, just so I can understand, the pink in  
24 this region, is that the 2011 cracking or the 2013  
25 cracking profile?

1 MR. HOOK: The pink area that you're  
2 seeing, that is the 2011-12 composite.

3 MEMBER RICCARDELLA: Okay.

4 MR. HOOK: So that is the baseline of the  
5 shield building.

6 MEMBER RICCARDELLA: Okay. But could we  
7 get kind of just an estimate of how much the  
8 incremental growth was in 2013 on this picture? I  
9 mean, is it just the thickness of the line or  
10 something?

11 MR. BYRD: I think on slide 60 we can  
12 demonstrate that in a specific area. There we go.

13 MR. HOOK: So what you see on this slide  
14 is the -- we did an IR map, impulse response, on the  
15 left. That was done in 2012. And then you can see it  
16 again in 2013 and then 2015. For your point of  
17 reference the green line is the same point in each of  
18 those three slides.

19 MEMBER RICCARDELLA: Okay.

20 MR. HOOK: So you can see at the bottom  
21 there's a little bulge where we're getting crack  
22 propagation. It's not the whole area that's cracking.  
23 It's just a few areas that are there.

24 MEMBER RICCARDELLA: Okay. So if you  
25 tried to draw that on this page 19, it would hardly

1 even show up. Is that what you're --

2 MR. HOOK: That's is correct.

3 MEMBER RICCARDELLA: Okay.

4 MR. HOOK: That is correct.

5 MEMBER RICCARDELLA: Thank you.

6 MR. HOOK: Okay.

7 MR. DORT: Ken, what number were we on?

8 The timeline?

9 MR. HOOK: We're on the timeline slide,  
10 which is --

11 MR. DORT: What number?

12 MR. HOOK: -- 16.

13 MR. DORT: Thank you.

14 MR. HOOK: Okay. August of 2015 is  
15 Performance Improvement -- we talked about the drying  
16 out rate. Then October of 2015, just last month, we  
17 revised our Aging Monitoring Plan to address several  
18 issues. We will increase our sample size to 28 core  
19 bores that will bound the leading edges that we have  
20 identified. Our impulse response testing is now a  
21 requirement whenever we find crack propagation in lieu  
22 of it being an option. And we'll perform selected  
23 impulse response testing in 2016 and in 2018 in areas  
24 not adjacent to core bores.

25 VICE CHAIR BLEY: So just so I understand,

1 see if what I understand is correct, in response to  
2 the propagation and the moisture issue you're not  
3 doing any particular AMP other than monitoring and  
4 seeing that it continues to dry out?

5 MR. HOOK: That is correct at this time.

6 VICE CHAIR BLEY: And not propagate --

7 MR. HOOK: It's based on the significant  
8 margin that we have in the --

9 (Simultaneous speaking)

10 VICE CHAIR BLEY: Okay. That's what I  
11 thought I heard. Thank you.

12 MR. HOOK: Okay. Slide 17, please? Our  
13 Shield Building Monitoring Program consists of 28 core  
14 bores. Fourteen of these core bores are located  
15 approximately two feet from the existing crack areas  
16 that we are monitoring for crack propagation. We are  
17 monitoring areas of known cracking in the top 20 feet  
18 of the shield building, in our shoulder areas and the  
19 main steam line penetration areas. Specifically 6 of  
20 the 14 are located in shoulders where we have not seen  
21 crack propagation. Four of the fourteen are located  
22 in shoulders where we have seen and we are monitoring  
23 for crack propagation. Three of the fourteen are  
24 located in the top 20 feet of the shield building, and  
25 one of these we are monitoring for crack propagation.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 And one is also in a main steam line penetration. And  
2 in a couple slides I'll go over and show you exactly  
3 where these core bores are located.

4 Next slide, please. We're also monitoring  
5 14 crack locations to assess any changes in crack  
6 characteristics. Specifically, three are on the top  
7 20 feet of the shield building, nine are in the  
8 shoulder areas and one is in the main steam line  
9 penetration area.

10 Our frequency for inspection is yearly  
11 inspections as long as we note changes. If there are  
12 no changes noted, then we'll increase our frequency to  
13 every other year. And the location of laminar  
14 cracking is well understood based on the impulse  
15 response map, which we address all the entire  
16 building.

17 Next slide. So this is the impulse  
18 response map for the entire exterior surface of the  
19 shield building all laid out on a flat piece of paper  
20 here. A couple things I want to point out. At the  
21 bottom, the two red circles, the zero azimuth, that's  
22 north and the 180 that's due south. The red circles  
23 on top, those are the flute areas. Each flute has 2  
24 shoulders, so a total of 16. Over 60,000 individual  
25 impulse response readings were taken to make this map.

1           The magenta areas are portions of the  
2 shield building where high mobility is located which  
3 would indicate areas of laminar cracking. This map  
4 also shows the location of the auxiliary building. We  
5 also took impulse response mapping in that area as  
6 well. This map shows all 28 core bore locations that  
7 we are monitoring. Fourteen of these core bores are  
8 located immediately adjacent to areas of known cracks.  
9 Specifically, they are nine black dots. If you see  
10 those, the nine black circles there. They are  
11 immediately adjacent to existing cracks where we are  
12 not seeing crack propagation. We have five black  
13 triangles. Those are immediately adjacent to areas  
14 where we have seen and we are monitoring for crack  
15 propagation.

16           MEMBER RAY: Jon, I don't think you have  
17 done this. Describe the core bore a little more  
18 descriptively. How big is it? How deep is it?  
19 There's 80 of them. You've picked these 28.

20           MR. HOOK: The core bores range from two  
21 inches in diameter to four inches in diameter,  
22 depending upon if we were just going to inspections or  
23 we wanted to extract a sample for concrete testing.  
24 And the core bores go into the building past the  
25 outside matte rebar so we can locate the area of

1 laminar cracking. Does that answer your question?

2 MEMBER RAY: Yes, I think so.

3 MR. HOOK: Okay. Thank you.

4 And then we have 14 green dots on there.

5 The green dots have little X marks in front of those  
6 as well. Those are the 14 areas where we are  
7 monitoring for changes in crack characteristics. We  
8 are monitoring all 12 shoulders as well as the top of  
9 the shield building and the main steam line  
10 penetration areas.

11 Next slide, please. We have revised our  
12 Shield Building Monitoring Program to address the  
13 Subcommittee's comment on using impulse response as a  
14 requirement versus an option. We are now required to  
15 perform impulse response mapping whenever crack  
16 propagation is noted. This will also help us  
17 characterize the crack. We also revised the program  
18 to perform selected impulse responses in 2016 and in  
19 2018. We will perform impulse response mapping at two  
20 locations in the areas known for cracking, but not in  
21 the near vicinity of core bores. We will monitor  
22 those for any changes in the area of leading edges.  
23 We are also performing impulse response mapping on two  
24 locations in areas currently not containing laminar  
25 cracking and away from core bores to establish

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 cracking has not expanded into these areas as well.

2 Next slide, please. Our Shield Building  
3 Monitoring Program consists of 28 core bores which  
4 represent areas of cracking: the top 20 feet of the  
5 shield building, in the shoulder areas and main steam  
6 line penetration areas. The extent of cracking is  
7 well understood based on the impulse response map. In  
8 the examination of 80 core bores that represents the  
9 entire surface.

10 Laboratory tests and evaluations suggest  
11 that crack propagation will decrease as the shield  
12 building dries out. The shield building is a heavily  
13 reinforced concrete structure with significant margin  
14 in both the structural calculation and in the percent  
15 of allowable cracking. This margin provides ample  
16 time before any limits are met. Our monitoring  
17 program scope and frequency is appropriate for the  
18 identified condition.

19 With that, that's the conclusion I have on  
20 the shield building pending any questions.

21 MEMBER RAY: Jon, I don't think you've  
22 talked about what is the importance of a crack  
23 relative to strength, the issue of overlap, shear load  
24 transfer and so on. Can you make some comments about  
25 that, why the testing at the university is applicable

1 and --

2 MR. HOOK: What I'd like to do is defer  
3 that one to Dr. Javeed who's been involved with both  
4 the testing and the analysis.

5 MEMBER RAY: That's fine.

6 MR. HOOK: Dr. Javeed?

7 DR. MUNSHI: Thank you, Jon. My name is  
8 Javeed Munshi. I have been involved with the shield  
9 building evaluation since 2011.

10 VICE CHAIR BLEY: Could you speak a little  
11 closer to the mic, please?

12 DR. MUNSHI: Sure.

13 VICE CHAIR BLEY: Thanks.

14 DR. MUNSHI: My name is Javeed Munshi. I  
15 have been involved with the evaluation of the Davis-  
16 Besse shield building since 2011. Very early on when  
17 we got involved with the cracking we recognized it's  
18 a unique type of cracking that has not been seen in  
19 the industry before, and in fact no information  
20 existed at that time to really address it as to what  
21 it means to the structural integrity. So we started  
22 a very elaborate investigation program, hired two of  
23 the main experts in the industry; namely Dr. Sozen at  
24 Purdue and Dr. Darwin, who is right now the leading  
25 expert in bond and transfer of force from rebar to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 concrete.

2           So with the help of those two experts we  
3 recognized that the only issue we have is where the  
4 rebar -- that this is what the rebar looks like in the  
5 shield building. It's a No. 11 bar. It's a very  
6 heavy bar and it has these lugs. If you see them  
7 here. These lugs, the way it works is that when this  
8 bar goes into tension -- that's the primary function  
9 of the bar. When it goes to tension these lugs bear  
10 against the concrete.

11           So the only question that actually the  
12 professors and we came to is that what we have is  
13 wherever we have the lap, wherever the bars lap is  
14 where we have the weak points in the shield building.  
15 So we went into that process of investigating through  
16 testing as to what does this mean to the building,  
17 because there was no prior information on this issue.

18           So we tested at two different places, 12  
19 samples in one place, 6 samples in another place,  
20 independent processes. So we came to the conclusion  
21 that because of the fact which we sort of intuitively  
22 knew from structural engineering basics is that if you  
23 look at the lug, the lug is about seven times the size  
24 of the crack width that we actually saw. So if you  
25 think about a crack width that is one-sixth of the lug

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 size, you expect that this bar will continue to  
2 develop the force and transfer the force from rebar to  
3 concrete and vice-versa.

4 So that's what we found in the test. We  
5 actually found that even after we have a crack that  
6 size, it's not really going to affect much in terms of  
7 structural integrity or serviceability of the  
8 structure. So that's the phenomena we came to  
9 understand. And it has been recognized now that -- we  
10 have actually done two different places with two  
11 experts and they feel very comfortable, as we do, me  
12 personally with the experience I have with concrete  
13 structures, that this building has the structural  
14 capacity to withstand its designed function.

15 Did I answer your question, sir?

16 MEMBER RAY: Yes, that was a good  
17 explanation. I guess one other thing, at least my  
18 understanding, is though, notwithstanding that  
19 explanation, the crack width present anyway is limited  
20 to 0.13 inches. If it exceeds that amount, then you  
21 have to reestablish what's acceptable. Is that  
22 correct?

23 MR. HOOK: The 13 thousandths that we're  
24 talking about, that is in our Aging Management  
25 Program, and that was based upon the original value

1 that we identified. And that's the threshold where we  
2 identified in the condition report -- if we see  
3 anything greater than 0.13, we identify it in the  
4 condition report and we evaluate it. Since then  
5 though the professors have come back and given us a  
6 significantly larger value.

7 And, Javeed, Dr. Munshi, you want to talk  
8 about that?

9 DR. MUNSHI: Right. So --

10 MEMBER RAY: Yes, because I think now  
11 we're going beyond anything I've seen so far in terms  
12 of -- this would be how you disposition, if I  
13 understand you correctly, something that exceeded 13  
14 thousandths of an inch?

15 MR. HOOK: Correct.

16 MEMBER RAY: All right. Go ahead.

17 DR. MUNSHI: So when we did the two test  
18 programs, the two different universities, we were not  
19 looking for exactly the crack widths per se. What we  
20 were looking for is if you have laminar crack in the  
21 plane of the bar would the rebar be able to do its  
22 intended function? And the answer was yes, it would.

23 Then when we started looking at the  
24 readings as to what was the crack width before we  
25 actually recycled the force back to develop the full

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 force in the -- in essence what we did is we pre-  
2 cracked the beam to a particular laminar crack and  
3 then we reloaded it. And we proved that even after  
4 you have a crack you can reload it back to its full  
5 capacity. Then we started looking at the numbers as  
6 to what were the numbers that we actually saw before  
7 we reloaded it? In fact, the numbers were quite high,  
8 sometimes 0.06 to even sometimes larger numbers.

9 But, so from a testing point of view there  
10 is no limit that says it has to be 0.013. In fact,  
11 the crack width limit can be much higher than what it  
12 is -- what's being observed at the current state.

13 MEMBER RAY: Okay. Well, we just want to  
14 understand how you would respond to identification of  
15 a larger crack width. Is there anything more you want  
16 to say about that?

17 MR. HOOK: No, we keep track of that in  
18 our calculations. We have a calculation process that  
19 we identify that. And the value right now in the calc  
20 is 0.02, or 20 thousandths of an inch. That's the  
21 value that's in our calc. That's what we've got from  
22 both professors. They were very comfortable in giving  
23 that conservative upper limit. And as Dr. Munshi has  
24 indicated, test results show significantly wider  
25 cracks, but for conservatism right now our threshold

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 is 20 thousandths.

2 MEMBER RAY: Thank you.

3 MEMBER RICCARDELLA: Could I ask a  
4 question of Dr. Munshi, please?

5 My understanding is that the testing was  
6 done predominantly monotonic loading up to some max  
7 load. Would you comment on the applicability of that  
8 type of testing to some of the service loads like  
9 seismic, which are dynamic loads?

10 DR. MUNSHI: Sure. So when we design the  
11 building, the building is typically designed for a  
12 code like ACI 318 in this case or 307, the chimney  
13 code, for example, in this case. So the inherent  
14 requirement in those two codes is that it's based on  
15 the requirement that the --

16 CHAIRMAN STETKAR: Dr. Munshi, make sure  
17 you speak into the microphone --

18 DR. MUNSHI: Yes, sir.

19 CHAIRMAN STETKAR: -- so that we pick you  
20 up on the transcript.

21 DR. MUNSHI: Okay. So the requirement in  
22 those two, or the expectation in those two codes is  
23 based on monotonic testing. And since this is not in  
24 a high seismic region like for example in California  
25 where you would have to look at cyclic behavior of the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 building, in this case it's really not a big issue in  
2 terms of what we expect. So in essence the monotonic  
3 testing is the fundamental testing that is done on any  
4 rebar. It's only when we go into expecting inelastic  
5 excursions into any system. In this case we don't  
6 expect any inelastic excursions because the seismic  
7 force is relatively low. If it was a building in  
8 California, for example, then, yes, you get into those  
9 cycles and then -- but they have required detailing in  
10 those codes for those buildings. But in this case  
11 it's not applicable, I think.

12 MEMBER RICCARDELLA: Thank you.

13 VICE CHAIR BLEY: I had a question from  
14 Dr. Chiu's explanation of the high stresses in the  
15 shoulder region where the first cracks were found. My  
16 first thought was, gee, if we didn't have this  
17 architectural fancy work, you wouldn't have had the  
18 problem. But you also said you found it in other  
19 areas as well. So is that first idea true or is it  
20 that it could have happened anywhere?

21 MR. HOOK: It we didn't have the  
22 shoulders, then we wouldn't have laminar cracking  
23 behind the shoulder areas. That is --

24 (Simultaneous speaking)

25 VICE CHAIR BLEY: But you also found it

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1       somewhere else?

2               MR. HOOK: We also found it up at the top  
3       20 feet and outside the shoulder areas. And as a  
4       result of that it's -- is high density of rebar.  
5       Again, we had a No. 11 bar, which is like almost one-  
6       and-a-half inches in diameter spaced six inches apart.

7               VICE CHAIR BLEY: Wow. Okay.

8               MR. HOOK: So it's a very highly congested  
9       area.

10              VICE CHAIR BLEY: Thank you.

11              MR. HOOK: Okay. Ken, I think -- any  
12       other questions on the shield building?

13              (No audible response)

14              MR. HOOK: Okay.

15              MR. BYRD: Okay. If there's no further  
16       questions on the shield building, we'll move forward  
17       to containment vessel inspections. And for this part  
18       of the discussion I'm going to call again on Mr. Hook  
19       to lead the discussion through this.

20              MR. HOOK: Okay. Thank you. So the other  
21       item I would like to talk about is the results of our  
22       containment vessel inspections. During our earlier  
23       ACRS Subcommittee meeting in 2012 several questions  
24       were asked about the containment vessel sand pocket  
25       area in the bottom of the containment vessel,

1 specifically groundwater seeping into the sand pocket  
2 area and how this would affect the exterior surface of  
3 the containment vessel. And the other item was  
4 borated water storage, or borated water from the  
5 refueling canal would migrate through the concrete and  
6 be entrapped on the inside of the containment vessel.

7 We addressed both of these issues in our  
8 18th refueling outage last year. This slide shows a  
9 general orientation of the shield building and the  
10 containment vessel with respect to these two issues.  
11 The red circles on the left and right is the location  
12 of the sand pocket area, and the lower red circle  
13 represents the bottom inside surface of the  
14 containment vessel.

15 Next slide, please. This is a sketch of  
16 the cross-section of the sand pocket which is  
17 identified by the upper red circle there. That's  
18 pointing to the sand pocket. The sand pocket is a  
19 tapered notch in the foundation approximately 4½ feet  
20 deep, 15 inches wide at the top. The sand pocket  
21 surface is sloped away from the containment vessel.  
22 Right there, yes, at the containment vessel. And it  
23 drains to two drains in the area. This will prevent  
24 any standing water from being in contact with the  
25 containment vessel.

1           To address the effects of groundwater on  
2           the containment vessel we inspected five separate  
3           areas at the bottom of the sand pocket. Each of these  
4           had nine individual readings for a total of 45  
5           readings. All UT readings at and below the ground  
6           surface were greater than the specified mill tolerance  
7           of 1.49 inches. The nominal thickness of the  
8           containment vessel is 1.5.

9           Next slide, please.

10           CHAIRMAN STETKAR: Now, that inspection  
11           tells you that at least in the accessible area of the  
12           sand pocket you haven't seen any degradation. What  
13           about the inaccessible area?

14           MR. HOOK: I'll address that in a minute.

15           CHAIRMAN STETKAR: Okay.

16           MR. HOOK: The very, very next slide as  
17           well.

18           CHAIRMAN STETKAR: Okay.

19           MR. HOOK: Okay. The other concern was  
20           associated with the borated water leaking from the  
21           refueling canal, migrating through the concrete and  
22           resting at the bottom of the containment vessel  
23           interior. A core bore was located as close to the  
24           containment centerline as possible using ALARA  
25           practices. We performed a visual inspection in this

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 area and we also took a UT reading of the containment  
2 vessel thickness. The inspection results showed no  
3 presence of water on the inside surface of the  
4 containment vessel and the UT readings were above the  
5 1.5 nominal thickness value. So these inspections not  
6 only confirmed that there are no effects of the  
7 containment vessel from the borated water for the  
8 refueling canal, but this UT test also shows there is  
9 no effect on the containment vessel from the  
10 groundwater under -- from the outside.

11 So the answer to your question, we took  
12 another UT reading at the very, very bottom, and  
13 that's inaccessible. And it also showed we got full  
14 nominal thickness there.

15 CHAIRMAN STETKAR: Okay. And that's  
16 -- it's hard to see on this, but that location is well  
17 below the average groundwater water.

18 MR. HOOK: Yes. Yes.

19 CHAIRMAN STETKAR: So if the exterior is  
20 constantly wetted, you'd see any evidence of  
21 corrosion?

22 MR. HOOK: Oh, correct. The sand pocket  
23 area is about like seven feet below the groundwater  
24 table. The dead center bottom of the containment  
25 vessel is maybe 15-20 feet.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: Okay. Good. Thank  
2 you.

3 MEMBER RAY: Is there a provision in the  
4 Aging Management Program to repeat this at any point?

5 MR. HOOK: No, there's not. This was a  
6 one-time inspection to prove we don't have a concern.  
7 Correct me if I'm wrong.

8 MR. DORT: This is Steve Dort, the site  
9 project coordinator. We had a commitment that had two  
10 parts. The first part was to perform an inspection  
11 prior to the period of extended operation. The second  
12 one is conditional. If we find that we have continued  
13 leakage from the spent fuel pool, we will perform  
14 another core bore and examination of the inner surface  
15 in --

16 MEMBER RAY: Okay. I thought there was  
17 something out there.

18 MR. DORT: -- 2020.

19 MEMBER RAY: Yes, all right. So it's  
20 directed toward continued leakage on the interior  
21 surface resulting in wetting of the interior?

22 MR. DORT: Correct. But it also tell us  
23 whether we're seeing degradation from the external.

24 MEMBER RAY: Yes, understood, but in the  
25 absence of any continued leakage, then we're not going

1 to find out anything further about the outside. Just  
2 to be clear.

3 CHAIRMAN STETKAR: Steve or Jon, do you  
4 monitor the drains from the sand pocket area?

5 MR. HOOK: Every outage we monitor the  
6 drain.

7 CHAIRMAN STETKAR: When you say "monitor"  
8 you --

9 MR. HOOK: Sorry. The access to the  
10 annulus is only during an outage, so when we go in  
11 there and do our inspection, that's one of the things  
12 we look at is making sure the drains are free-flowing.

13 CHAIRMAN STETKAR: Are free-flowing?

14 MR. HOOK: Yes.

15 CHAIRMAN STETKAR: Okay. When I said  
16 "monitor," I meant verify somehow that they're indeed  
17 free-flowing.

18 MR. HOOK: Correct.

19 MEMBER RICCARDELLA: And has there been  
20 prior leakage in the refueling canal, or is that just  
21 a hypothetical consideration?

22 MR. HOOK: I'd like to turn that one over  
23 to Trent Henline. He's the project manager for that  
24 project.

25 MR. HENLINE: Trent Henline, license

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 renewal implementation manager. If you could go to  
2 backup slides 32 and 33, Steve?

3 So we have a history or we had a history  
4 of refueling canal leakage this past outage in the  
5 spring of 2014. We mitigated everything that  
6 penetrated our liner in the entire refueling canal.  
7 That was over 75 penetrations. If you look at the  
8 picture here, in the upper left-hand corner is a  
9 picture of our upender support plates. You can see  
10 the shims below the plate as well as the bolting that  
11 goes down through the liner. On the bottom right hand  
12 is post-mitigation. We used new technology, silicone  
13 technology that utilizes a two-part silicone with  
14 stainless steel plates to protect the particular  
15 areas.

16 So what we did after we mitigated and  
17 filled the refueling canal to reload the fuel, we had  
18 live monitoring in three particular areas where we  
19 noted leakage. Of those areas we did not see any  
20 leakage with one exception. With one exception we saw  
21 a brief amount of water that came through a cold joint  
22 in the concrete, formed about one cup of puddle, dried  
23 up and disappeared despite the refueling canal  
24 continuing to be filled.

25 So what we are fairly confident happened

1 was the water that was put into the refueling canal  
2 during the filling stage was trapped between the liner  
3 and the concrete. When we filled the pool back up, it  
4 pushed that water out that was trapped after  
5 mitigation. And we have a scheduled follow-up  
6 inspection this upcoming outage to confirm that we did  
7 100 percent mitigate the refueling canal leakage.

8 MEMBER RICCARDELLA: Thank you.

9 MR. HOOK: With that, I would like to then  
10 turn it over back to Mr. Ken Byrd.

11 MR. BYRD: Okay. Unless there's any  
12 further questions, we will continue with our closing  
13 remarks. So I'll turn it over to Brian Boles.

14 MR. BOLES: Okay. Well, appreciate the  
15 opportunity to be before the Committee today. As you  
16 heard today, we had a large number of improvements  
17 that we've made to our station. We did briefly  
18 discuss the closure of our four open items based on  
19 operating experience, the reactor vessel neutron  
20 embrittlement issue, pressure-temperature limits and  
21 our shield building. We also provided an update on  
22 the containment vessel inspections. That was at the  
23 request of a previous Committee meeting.

24 And, Mr. Chairman, that's all we have from  
25 a presentation perspective today.



1                   MEMBER RAY: Yes, I just want to confirm  
2                   you still, as you said at the Subcommittee, are  
3                   intending at some point to submit an amendment to the  
4                   license to include the analyses that were used.

5                   MR. BYRD: That's correct. We will be  
6                   submitting a license amendment for our shield  
7                   building.

8                   MEMBER RAY: A shield building analysis  
9                   methodology. That's right.

10                  Okay. Anything else from members?

11                  MEMBER REMPE: Where is the coating as a  
12                  commitment? The second re-coating after 15 years, is  
13                  that part of the license amendment or is that part of  
14                  the aging management?

15                  MR. HOOK: That is included in our Shield  
16                  Building Aging Management Program.

17                  MEMBER REMPE: Thank you.

18                  MEMBER RAY: If there's nothing else from  
19                  members, we will give the staff a chance.

20                  John, when do you want to take a break?  
21                  It's your --

22                  CHAIRMAN STETKAR: You're in charge.

23                  MEMBER RAY: Well, we've been one hour  
24                  into this. We'll see how far the staff goes. We may  
25                  take a break during the staff presentation, depending

1 on how long it takes. But one hour is too soon, I  
2 think, having come back from lunch.

3 Okay, Rick. The floor is yours.

4 MR. PLASSE: Okay. Good afternoon,  
5 Chairman Stetkar, Mr. Ray, and members of the ACRS.  
6 My name is Rick Plasse. I'm the license renewal  
7 project manager for the Davis-Besse license renewal  
8 safety review. We are here today to discuss the  
9 review of the Davis-Besse license renewal application  
10 as documented in the SER which was issued September  
11 2013 and the Supplemental SER which was issued in  
12 August of 2015.

13 Joining me here at the table is Phyllis  
14 Clark, DLR Safety Project Manager, who'll be running  
15 the slides, Mr. Jim Neurauter from Region III. The  
16 senior reactor inspector is with us today in the  
17 audience. And seated in the audience are the members  
18 of the tech staff who participated in the review of  
19 the license renewal application and conducted the  
20 onsite audits.

21 Next slide. This slide I'll skip over.  
22 The applicant pretty much covered this in detail. And  
23 I'll go to the next slide on safety review results.

24 The SER with open items was issued in July  
25 of 2012 and the first Subcommittee was held on

1 September 19th of 2012. There were four open items,  
2 which we've discussed earlier, that we will also  
3 discuss on operating experience, pressure-temperature  
4 limits, upper shelf energy and the shield building  
5 laminar cracking. There were no other open items or  
6 confirmatory items. The final SER was issued in  
7 September 2013 and a supplement to the SER was issued,  
8 as I stated, in August 2015, which closed the four  
9 items. A second License Renewal Subcommittee was held  
10 September 23rd of 2015.

11 Next slide. The operating experience open  
12 item, B.1.4-1. During the review of Davis-Besse's  
13 Operating Experience Program the staff issued ISG-  
14 2011-05, titled "Ongoing Review of Operating  
15 Experience." The open item was identified to  
16 determine how Davis-Besse addressed the recommended  
17 framework for operating experience review activities  
18 in the ISG. To address the ISG and the open item the  
19 applicant provided additional information to describe  
20 how it will enhance its current AMPs or develop new  
21 AMPs based on plant-specific and industry operating  
22 experience when necessary to ensure that age-related  
23 degradation is managed during the term of the renewed  
24 operating license.

25 A couple examples of those program

1 attributes were that Davis-Besse would screen all  
2 incoming OE for age-related degradation, they included  
3 an aging flag in both the Corrective Action Program  
4 and the OE Programs, and the Corrective Action Program  
5 be used to revised or develop new AMPs based on  
6 applicable OE evaluations.

7 Any questions on that slide?

8 (No audible response)

9 MR. PLASSE: Next slide.

10 MEMBER POWERS: I don't understand how  
11 operating experience -- say something happens and they  
12 find it, when do they decide they need a new AMP  
13 versus putting an additional piece of paper into an  
14 existing AMP?

15 MR. PLASSE: I would let them speak to  
16 their program, if someone wants to speak to that.  
17 They'd use their Corrective Action Program to identify  
18 the issue. And then go ahead and explain what you  
19 would do.

20 MR. HENLINE: Trent Henline,  
21 implementation manager. So historically the  
22 Corrective Action Program would address the issue  
23 specifically. So if we found a piece of pipe that was  
24 rusted, essentially depending on the safety  
25 significance of the pipe we would fix it and close the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 evaluation. The difference here is that we would  
2 check the aging management evaluation box which would  
3 kick off a separate evaluation in or program. So we  
4 would continue the condition report evaluation that  
5 addresses the immediate issue and how we're going to  
6 resolve that particular condition.

7 Then a separate evaluation is provided by  
8 the Aging Management Program to determine if the  
9 inspection frequency, the inspection type is adequate  
10 and the Aging Management Program continues to address  
11 whatever particular conditioning or aging mechanisms  
12 that we're trying to manage is adequate. We have had  
13 examples where we have revised Aging Management  
14 Programs as a result of this process, so we believe  
15 that it continues to be effective.

16 MEMBER POWERS: So the baseline response  
17 is to augment existing AMPs and it takes something  
18 very special to cause you to create a new AMP?

19 MR. HENLINE: Yes, that's correct.

20 MEMBER POWERS: How special is special?

21 MR. HENLINE: So for example, our Small  
22 Bore Piping Program was intended to be a one-time  
23 inspection program. We did the full scope of that  
24 one-time inspection program and during the destructive  
25 analysis we did identify cracking in socket welds,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 small bore socket welds. So as a result of our aging  
2 management evaluation we looked at that and determined  
3 that a one-time program was not adequate, so we are in  
4 the process of developing an ongoing program that will  
5 last through the extended period of operation.

6 MEMBER POWERS: Excellent example. Thank  
7 you.

8 MR. HENLINE: You're welcome.

9 MR. PLASSE: Any other questions on the  
10 Operating Experience Program?

11 (No audible response)

12 MR. PLASSE: Next slide. Okay. Open Item  
13 4.2-1 concerning reactor vessel neutron embrittlement.  
14 For Davis-Besse the applicant performed updated 60-  
15 year upper shelf energy calculations for the reactor  
16 vessel shell, nozzle and weld components in the  
17 beltline region of the vessel. The staff determined  
18 that the applicant did not have sufficient plant-  
19 specific un-irradiated upper shelf data for those  
20 reactor vessel beltline welds that were fabricated  
21 using Linde 8 weld flux materials. Under this open  
22 item the staff required the applicant to submit an  
23 equivalent margins analysis basis for accepting the  
24 upper shelf energy values for these reactor vessel  
25 weld materials.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           To close the open item the applicant  
2           sufficiently demonstrated that the equivalent margins  
3           analysis basis is given in specific NRC-approved  
4           Babcock & Wilcox reports. The EMA basis was reviewed  
5           by the staff and found to be a valid basis for  
6           accepting the Davis-Besse upper shelf energy TLA under  
7           the requirements of 54.21(c)(1)(ii) and for the  
8           extended period of extended operation. This Open Item  
9           4.2-1 has been closed by the tech staff.

10           MEMBER RAY: Ron, you had a chance to look  
11           at this I believe. Did you?

12           MEMBER BALLINGER: Yes, I did a couple  
13           times. It's consistent.

14           MR. PLASSE: Okay. Next slide considers  
15           Open Item 4.2.4-1, pressure-temperature, P-T, limits.  
16           The open item is associated with a potential issue  
17           that the methods in the B&W report 10046, Rev 2 for  
18           generating P-T limits may not be conservative if  
19           stresses for reactor vessel non-beltline near  
20           geometric discontinuities would cause those components  
21           to be the limiting components for P-T limit  
22           calculations.

23           The applicant resolved and closed the open  
24           item by demonstrating that the methodology in Babcock  
25           & Wilcox Topical Report 10046A, Rev 2 appropriately

1 accounts for impacts of stress and tensities for non-  
2 beltline components including those near geometric  
3 discontinuities. Thus, the applicant was able to  
4 demonstrate that the approved methodology in BAW-10046  
5 remains valid for generating P-T limits that will be  
6 needed for the period of extended operation and this  
7 forms an acceptable basis for accepting the P-T limits  
8 TLA in accordance with 10 CFR 54.21(c)(1)(iii) and  
9 demonstrating that the P-T limit update basis is valid  
10 to manage by analysis loss of fracture toughness in  
11 the reactor vessel.

12 Do you have any questions for the staff on  
13 the TLAs and these open items?

14 (No audible response)

15 MR. PLASSE: Okay. Go to the next slide.  
16 This slide gives the safety review results. Following  
17 the closure of all the open items, the final SER was  
18 issued in September 2013. In total, there's 44 Aging  
19 Management Programs which were reviewed. This  
20 includes 43 programs which were reviewed by the staff  
21 during the initial safety review of the license  
22 renewal application. After the final SER was issued,  
23 one additional new plant-specific program to manage  
24 service level III coatings and linings was submitted  
25 for review to address recent industry operating

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 experience. The table here summarizes the final staff  
2 disposition of the 44 Aging Management Programs.

3 Any questions?

4 MEMBER RAY: Let me say Charlie wasn't  
5 able to attend the Subcommittee meeting, but he did  
6 review in his area, which the members are well  
7 acquainted with and found them satisfactory.

8 MR. PLASSE: Okay. Thank you. Go to the  
9 next slide. This slide here is what's the framework  
10 of the supplement that was issued in August of 2015.  
11 The first sub-bullet in this list, the applicant  
12 updated its Reactor Vessels Internals AMP and  
13 submitted the Reactor Vessel Internal Inspection Plan  
14 for NRC approval in late April of 2015.

15 The staff found the Reactor Internals AMP  
16 and the Reactor Vessels Internal Inspection Program to  
17 be acceptable because: (A) for internals conforming to  
18 the generic design in MRP-227-A the applicant will be  
19 implementing the approved protocols in MRP-227-A; and  
20 (B) for components deviating from the generic design  
21 the applicant appropriately adjusted the AMP in the  
22 Reactor Vessel Internal Inspection Program in a manner  
23 that was found to be acceptable to the staff. Thus,  
24 the prior commitment for this AMP in the final FSER  
25 was closed in the supplement.

1 Other noted items. For the steam  
2 generator replacement the design modification results  
3 in some changes to the list of analyses that conform  
4 to the definition of TLA for 10 CFR 54.3(a). This  
5 resulted in changes to a number of metal fatigue or  
6 cyclical flaw evaluation TLAs for specific steam  
7 generator components or auxiliary feedwater system  
8 components. The staff found the TLA's changes to be  
9 acceptable based on the new steam generator design,  
10 the updated evaluations of the TLAs were appropriately  
11 accounted for and the updates of Section 4.3 and  
12 Section 4.7 subsections in the Supplemental SER.

13 Does the Committee have any further  
14 questions for the staff on any of these updates and  
15 TLAs in the supplement?

16 (No audible response)

17 MR. PLASSE: Okay. With that, we'll move  
18 to the last open item. Our slides are focused on the  
19 actual aging program for the shield building. On the  
20 first slide, as the applicant noted, hairline laminar  
21 cracking was discovered in the fall of 2011 in  
22 multiple locations adjacent to the outer horizontal  
23 reinforcement of the cylindrical shell primarily in  
24 the flute shoulder regions with some cracking outside  
25 the flute shoulder in the top 20 feet and around the

1 main steam penetrations. The applicant determined and  
2 characterized the extent of condition by ND testing  
3 using an impulse response technique and core boring.  
4 Although the root cause determined the initial  
5 cracking was an event driven by extreme environmental  
6 conditions during the Blizzard of '78, the NRC staff  
7 was concerned that the degradation could grow and  
8 potentially affect the safety function, the primarily  
9 structural concerning being effects on the rebar bond  
10 capacity adjacent to the cracks.

11 To address this the applicant submitted a  
12 plant-specific AMP, the Shield Building Monitoring  
13 Program, to monitor and manage aging effects of the  
14 laminar cracking through the period of extended  
15 operation. Also, the applicant applied an exterior  
16 protective coating in October 2012 as a preventive  
17 corrective action to reduce future moisture ingress.

18 The Shield Building Monitoring Program was  
19 updated by letter October 6th of 2015 following the  
20 second ACRS Subcommittee meeting as a plant-specific  
21 prevention and condition monitoring program to manage  
22 aging effects. Example: propagation on the shield  
23 building laminar cracking. The program supplements  
24 the structure's monitoring program. The preventive  
25 aspect is the application of the coating.

1           The scope of the program includes the  
2 concrete and reinforcing steel of the shield  
3 building's cylindrical wall and exterior concrete  
4 coatings on the shield building.

5           The program uses periodic visual  
6 inspections using a borescope of the interior surfaces  
7 of a representative sample of core bore holes,  
8 currently a minimum of 28 selected from the 80  
9 existing core bore holes, to monitor the shield  
10 building for changes in existing laminar cracks and/or  
11 new indications of laminar cracks.

12           Visual inspections using borescope are  
13 appropriate because it can measure crack width and  
14 depth from the surface. The detection of laminar  
15 crack propagation during baseline inspections in the  
16 fall of 2013 and 2015 provides evidence that visual  
17 inspections are effective. The AMP will supplement  
18 visual inspections with ND techniques; i.e., the  
19 impulse response testing, noting that impulse response  
20 testing can detect the presence of cracking but cannot  
21 measure crack width or depth.

22           The updated AMP by letter dated October  
23 6th will use IR for updating extent of condition in  
24 areas where propagation is indicated in leading edge  
25 core bores for a minimum of 100 square feet around the

1 bores of observed propagation. Additionally, IR will  
2 be performed in four randomly selected 100-square-foot  
3 grids each during 2016 and 2018 inspections, two grids  
4 in areas of known cracking leading edge bores to  
5 confirm extent of crack propagation and two grids in  
6 areas with no previously known cracking away from the  
7 core bores to detect new or expanded cracking.

8 The program also conducts opportunistic  
9 visual inspections or rebar near laminar cracks for  
10 corrosion indications when exposed for some reason.

11 The coatings are visually inspected for  
12 loss of effective at an interval of five years and the  
13 coatings will be reapplied every 15 years.

14 Inspections under the program are  
15 conducted and the results are evaluated by personnel  
16 meeting quantification requirements of ACI Report  
17 349.3R Chapter 7.

18 Any questions on the program?

19 MEMBER SKILLMAN: Rick, yes, Dick  
20 Skillman. My question to you is this: Did you  
21 witness the coating of the building a couple years  
22 ago?

23 MR. PLASSE: I was not on this project a  
24 couple years ago. We do have the region. The  
25 question is did someone in the NRC inspect the

1 application of the coatings on the building?

2 CHAIRMAN STETKAR: You have to come up to  
3 the microphone. Identify yourself, please.

4 MR. NEURAUTER: Hi, I'm Jim Neurauter,  
5 Region III inspector. The region has resident  
6 inspectors on site and they oversaw the application of  
7 the coating to the shield building. That was one of  
8 the follow-up items that we were monitoring.

9 MR. PLASSE: Thank you.

10 CHAIRMAN STETKAR: Thank you.

11 MR. PLASSE: Any questions on the program?

12 (No audible response)

13 MR. PLASSE: Okay. We'll go to the  
14 operating experience of crack propagation slide. The  
15 operating experience program element includes  
16 provisions to evaluate and incorporate future plant-  
17 specific operation experience such as inspection  
18 findings, and industry operating experience is  
19 applicable and necessary.

20 During baseline inspections of core bores  
21 conducted during August and September of 2013 the  
22 applicant discovered indications of limited laminar  
23 crack propagation in 8 of the total of 80 core holes  
24 inspected. The applicant's apparent cause evaluation  
25 characterized this 2013 plant-specific operating

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 experience to be the result of an ice wedging  
2 mechanism which is the freezing and expansion of  
3 trapped water at the tip of preexisting laminar  
4 cracks. Crack propagation was also detected in the  
5 recent 2015 inspection.

6 The applicant increased the representative  
7 core hole sample size for future inspections from the  
8 previous 20 to 23 following the 2013 inspection and to  
9 28 following the 2015 inspection, which now includes  
10 5 leading edge monitoring bores to identify changes in  
11 the limits of cracking in areas of observed crack  
12 propagation. The adequacy of the sample size and  
13 location of the inspection core bores will be  
14 discussed in the next slide.

15 The applicant also increased the  
16 inspection frequency since the observed propagation is  
17 not considered passive. The inspection interval will  
18 be annual for the years 2015 through 2018, then  
19 increase to two years 2018 through 2026, and four  
20 years thereafter, which is acceptable because the  
21 inspection interval is progressively increased only if  
22 no aging effects; i.e., indications of new cracking  
23 and/or propagation of existing laminar cracks are  
24 identified. Changes to the inspection schedule,  
25 sample size and the locations and parameters monitored

1 will be evaluated if aging effects are identified.

2 The annual inspection frequency for the  
3 initial years is acceptable because it will include a  
4 complete winter between inspections, which is the  
5 likely time of propagation. And the AMP also conducts  
6 additional impulse response testing around core bores  
7 observed crack propagation to confirm and update the  
8 extent of propagation.

9 Any questions on the operating experience  
10 of crack propagation?

11 (No audible response)

12 MR. PLASSE: Next slide. Adequacy of  
13 sample size and distribution. The minimum  
14 representative sample size of 28 core holes to be  
15 inspected in different regions of the shield building  
16 and their distribution is acceptable because they  
17 include 14 crack core holes that cover 9 of 10 flute  
18 shoulders with highest prevalence of cracking, the  
19 upper 20 feet of the shield building and at main steam  
20 penetrations, which are areas with cracking outside  
21 shoulders in a range of observed crack widths  
22 including maximum observed crack widths.

23 They include 14 un-cracked core holes, but  
24 located near areas of known cracking providing ability  
25 to monitor crack propagation which include 5 bores



1 that define the leading edge of recent observed crack  
2 propagation. And the program includes provisions for  
3 expansion of sample, consideration of past evidence of  
4 crack propagation and choosing inspection locations  
5 and for addition of new core holes for inspection if  
6 needed to bound crack propagation limits. Further,  
7 each representative core bore in the sample provides  
8 information regarding crack characteristics with depth  
9 and planar limit which help monitor maximum crack  
10 width and/or planar propagation.

11 The staff notes that the sample consists  
12 of core holes that define maximum observed crack  
13 widths as well as planar propagation limits.  
14 Therefore, the program includes appropriate monitoring  
15 and trending of the limiting crack width parameter as  
16 well as planar limit to effectively detect aging  
17 effects of potential crack propagation on the bond  
18 capacity of the adjacent rebar, which is the primary  
19 structural concern related to laminar cracking.

20 MEMBER RAY: Rick, at this point let me  
21 stop you and say you heard the dialogue, I presume,  
22 that we had about, well, what is the limit? It's now  
23 13. Now 20 is the point at which further assessment  
24 is required. Staff's satisfied with the current setup  
25 on that? Because there isn't any particular limit

1 specified beyond which the cracks would be considered  
2 to render the rebar non-functional.

3 MR. THOMAS: Yes, this is George Thomas.  
4 And, Rick, if you move to the next slide --

5 MR. PLASSE: Okay.

6 MR. THOMAS: -- we have the acceptance  
7 criteria for the program.

8 MEMBER RAY: So I was anticipating the  
9 comment. But in any event, that's the question that  
10 I'm trying to get to is is there a limit to the crack  
11 width beyond which you don't count the rebar any  
12 longer, or is that to be determined in the future?

13 MR. PLASSE: Let me go through the slide.  
14 Okay. The governing acceptance criteria for the core  
15 hole inspection results against which need for  
16 corrective actions is evaluated in a Corrective Action  
17 Program -- I'm on the right slide, right?

18 MR. THOMAS: Yes.

19 MR. PLASSE: Okay. In the qualitative  
20 criteria that the crack remains passive; that is, no  
21 discernible changes in existing laminar cracking and  
22 no new crack indications. However, quantitative  
23 criteria with defined limits for crack width and  
24 planar limits are also included. Note that the  
25 qualitative criteria controls because it bounds the

1 quantitative criteria. The quantitative criteria was  
2 included in an RAI response January 28th of 2015 to  
3 provide an indication of the crack width and planar  
4 limit conditions that can be considered bounded by the  
5 calculation of record, calculation CSS 99.20-63.

6 The applicant completed inspections and  
7 analysis of the currently observed laminar cracking  
8 and propagation in the shield building in accordance  
9 with guidance in Section 5.3, Conditions Requiring  
10 Further Evaluation, of ACI 349.3R, which included  
11 large-scale beam testing at Purdue University and the  
12 University of Kansas on the impact of observed laminar  
13 cracking on rebar lap splice capacity and new analysis  
14 and design calculations based on which the applicant  
15 concluded that the as-found condition is acceptable  
16 after evaluation.

17 However, such is the condition is not  
18 passive, the laminar crack will be subject to  
19 increased frequency monitoring until determined to be  
20 passive and continued ongoing monitoring during the  
21 PEO by the Shield Building Monitoring Program. Thus,  
22 if the acceptance criteria is not met, the condition  
23 will be evaluated in the FENOC Corrective Action  
24 Program pursuant to 10 CFR 50 Appendix B using the  
25 evaluation criteria hierarchy in Chapter 5 of ACI

1 Report 349.3R. And the next slide shows the hierarch.

2 MEMBER RAY: Well, wait a minute. Let's  
3 just --

4 MR. PLASSE: Okay.

5 MEMBER RAY: -- stay since it's got 13  
6 thousandths there and --

7 MR. PLASSE: Okay.

8 MEMBER RAY: -- we heard it's not 20.

9 MR. THOMAS: Right. The numbers, the  
10 quantitative numbers given here were provided in  
11 response to an RAI in January of 2018. And since  
12 then --

13 MEMBER RAY: January of when?

14 MR. THOMAS: January of 2015. I'm sorry.  
15 Since then the applicant has further refined their  
16 calculations and my understanding is that limit could  
17 be 0.02 inches.

18 MEMBER RAY: Well --

19 CHAIRMAN STETKAR: Well, but --

20 MEMBER RAY: Go ahead, John.

21 CHAIRMAN STETKAR: Now I'm confused. We  
22 have a slide in front of us here in writing that says  
23 0.013. So what's the staff's evaluation based on?

24 MR. THOMAS: Well, as I said, the  
25 qualitative criteria, if it exceeds 0.013, or any

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 discernable change in the crack characteristics, that  
2 will be entered in the Corrective Action Program and  
3 evaluated and necessary actions taken in that.

4 CHAIRMAN STETKAR: Okay, I guess.

5 MEMBER RAY: Well, yes --

6 CHAIRMAN STETKAR: I hear what you're  
7 saying.

8 MEMBER RAY: I think what we need to do at  
9 this point -- it's 2:30. This is not a very good way  
10 to leave this point. And so we're going to take a  
11 break and when we come back I would like you to be  
12 prepared to give a more clear statement as to what  
13 your evaluation is based on. Is it a value of crack  
14 width which is to be determined as acceptable by the  
15 applicant under their Appendix B Corrective Action  
16 Program, but we don't know what that -- it's not a  
17 fixed value, or is it, as I had read previously and as  
18 the slide suggests, a number not to be exceeded?  
19 Which is it? And rather than answer me right now, I'd  
20 like you to think about your answer and then we'll  
21 resume after taking a break. Okay?

22 MR. THOMAS: Okay.

23 MEMBER RAY: So we'll recess for 15  
24 minutes, come back at a quarter to 3:00. Is that all  
25 right?

1 (Whereupon, the above-entitled matter went  
2 off the record at 2:33 p.m. and resumed at 2:47 p.m.)

3 CHAIR STETKAR: Okay. We're back in  
4 session. Back to you, Harold.

5 MEMBER RAY: All right. Thank you very  
6 much.

7 I hope everybody had a break that they  
8 needed. And with that, we'll resume back to you,  
9 Rick.

10 MR. PLASSE: Yes. There's a correction on  
11 this slide.

12 Under "Quantitative," -- the first bullet,  
13 "Current Observed Maximum Width," that is the trigger  
14 point where they would use a corrective action program  
15 based on test results -- the .013.

16 In the 2015 inspection this summer, they  
17 did have a location that was .016 inch. And the way  
18 it's explained is the trigger point gets to anything  
19 exceeding that measurement of .013, it will go into  
20 the corrective action program and then will be  
21 evaluated.

22 And you are correct. The calculation of  
23 record is .02.

24 With that, I'll turn it over to George and  
25 he can talk about the various criteria here -- the

1 qualitative and quantitative.

2 MEMBER RAY: Okay.

3 Before George speaks though, will you  
4 revise this for the record -- this slide? Or how do  
5 you want to handle it?

6 Otherwise, I'd like you to be very precise  
7 about what the change is that you would make in it.  
8 You can either revise it, I believe, or you can say it  
9 should be changed in whatever way you want to change  
10 it.

11 MR. PLASSE: I can provide for the record  
12 a revised slide to strike what's in parentheses. And  
13 the correct width does not exceed .013 is the  
14 criteria.

15 MEMBER RAY: Don't you want to say is the  
16 criteria for something?

17 MEMBER BROWN: For subsequent re-  
18 evaluation or --

19 MEMBER RAY: I'm just trying to understand  
20 the slide at this point. And I think I'd ask you  
21 before we adjourn for the day to describe exactly how  
22 the slide should read so that then we can look back on  
23 it as a matter of record.

24 MR. PLASSE: Can I recommend that when I'm  
25 finishing up that you work with Sam and management?

1           MEMBER RAY: Okay. Whatever you want to  
2 do. Don't worry. We won't close the record until you  
3 can do that.

4           MR. PLASSE: I'll do a revised slide at  
5 the end of the meeting.

6           MEMBER RAY: This is something I want to  
7 be sure we understand staff position.

8           And I will ask the Applicant, since this  
9 was sort of a comment in passing earlier, to be  
10 precise. They've asked to have another minute for a  
11 different reason. I'll ask them to also say precisely  
12 what it was that they are intending so that we don't  
13 get into a situation in which we're not understanding  
14 each other.

15          MR. PLASSE: Yes. So as I stated earlier,  
16 in the upper bullets, any change to any existing crack  
17 width or planar size, they'll write up a corrective  
18 action report and evaluate any new indication of new  
19 cracking -- any crack width that is above the trigger  
20 point of .013. And that will start the corrective  
21 action review and the evaluation criteria of ACI  
22 349.3R.

23          And for the record, they did have an  
24 indication of .016 inch that they evaluated from the  
25 2015 review. But still, the trigger point going



1 forward is still .013 inch.

2 MEMBER RAY: All right. Well, I want to  
3 hear the same thing from the Applicant. But we'll do  
4 that later.

5 George, you wanted to make a comment?

6 MR. THOMAS: Yes. Just clarifying.

7 What you see on the slide is the criteria  
8 in the AMP. And if any of these conditions -- whether  
9 qualitative or quantitative -- is exceeded, that'll  
10 trigger a condition report in the Applicant's  
11 corrective action program. And it will be evaluated  
12 against the calculations of record and any other  
13 further evaluation that needs to be done.

14 MEMBER RAY: Well, all right. But perhaps  
15 it's best the Applicant then explain how larger crack  
16 widths would be expected to be dispositioned.

17 But we'll let them do that. Okay?

18 MR. PLASSE: Do you want to do that now?

19 MEMBER RAY: No.

20 MR. PLASSE: No? Okay.

21 Okay. The next slide shows the 349  
22 evaluation hierarchy -- the evaluation procedure from  
23 ACI 349.3R applied to the shield building.

24 Note that if there are indications of  
25 discernible changes in the cracking, the cracks are

1 observed not passive and the condition is considered  
2 exceeding the second tier criteria. And therefore,  
3 the condition is considered in need of further  
4 technical evaluation.

5 The further technical evaluation and the  
6 calculations of record -- CRRCR 99.20-63 and 69 --  
7 determined the condition was acceptable for structure  
8 adequacy. However, the condition of recently observed  
9 propagation in 2013 and 2015 is considered not  
10 passive. So they're still in the option at the bottom  
11 of the figure -- monitor increased frequency.

12 So it'd be --

13 MEMBER RAY: Well, that's one of the  
14 options at the bottom. Repair and replace is two  
15 other options.

16 MR. PLASSE: Well, right. But the one  
17 that they're using is the monitor increased frequency  
18 --

19 MR. THOMAS: At this time.

20 MR. PLASSE: -- at this time.

21 MR. THOMAS: At this time.

22 MEMBER RAY: George, did you want to say  
23 more?

24 MR. THOMAS: No. I just want to say that  
25 at this time of the three options, they determined

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 monitor increased frequency. That's the appropriate  
2 --

3 MEMBER RAY: And the staff has accepted  
4 that?

5 MR. THOMAS: Yes.

6 MR. PLASSE: Okay. And the next slide.

7 To summarize, the staff finds the shield  
8 building monitoring program AMP acceptable because  
9 laminar cracks are inspected at a one-year interval  
10 and this interval will not be progressively  
11 incremented to two to four years unless cracks become  
12 passive.

13 A representative sample of no less than 28  
14 core bores will be inspected at every inspection to  
15 effectively monitor crack width and planar limit. A  
16 total of 80 existing bores are available for  
17 inspection if samples need to be expanded.

18 The use of visual inspections and impulse  
19 response testing can effectively detect changes in  
20 laminar cracking, crack width, planar limit or new  
21 indications.

22 Inspection findings will be evaluated by  
23 qualified personnel using the evaluation procedure in  
24 ACI 349.3R, which is recommended by the GALL Report  
25 for evaluation of concrete structures.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   And the acceptance criteria of a crack  
2                   being not passive would trigger further evaluation  
3                   under the corrective action program if inspection  
4                   findings indicate discernible changes in the cracks.  
5                   Thus, the AMP will effectively collect and evaluate  
6                   laminar crack monitoring data periodically against  
7                   acceptance criteria that will lead to further  
8                   evaluation in the corrective action program to ensure  
9                   that intended functions of the shield building are  
10                  maintained.

11                  Next slide.

12                  Based on the AMP attributes discussed in  
13                  the previous slides, the staff concludes that through  
14                  implementation of the AMP, the Applicant will be able  
15                  to adequately monitor the cracks, perform structural  
16                  evaluations and take corrective actions as necessary  
17                  in a timely manner prior to loss of intended function.

18                  Based on the review, the staff concludes  
19                  that there is reasonable assurance that the shield  
20                  building monitoring program will adequately manage  
21                  aging effects of the laminar cracking such that  
22                  intended functions of the shield building will be  
23                  maintained consistent with the current licensing basis  
24                  during the period of extended operation.

25                  And the shield building item is closed.

1 The open item -- staff evaluation -- is documented  
2 both in the SER and the Supplemental SER Section  
3 3.0.3.3.9.

4 In conclusion, on the basis of its review,  
5 the staff concludes that the requirements of 10 CFR  
6 54.29(a) have been met for the renewal of Davis-Besse  
7 License.

8 This concludes our staff presentation, and  
9 now we'd be available for any further questions from  
10 the Committee.

11 MEMBER RAY: Okay. There were a couple of  
12 things mentioned -- one, at the Subcommittee meeting  
13 and one here today -- that I don't know that the staff  
14 has commented on or may not have any comment on.

15 One of them was the implications, if any,  
16 for crack growth of cyclic loading. And here, we'd be  
17 talking about seismic.

18 Has there been any evaluation by the staff  
19 of that? It was characterized as well in California.  
20 It would be different than it is in Ohio. And cyclic  
21 loading isn't expected to be such as to result in  
22 crack propagation.

23 Has the staff considered that, do you  
24 know, Rick? Or is there anybody who can speak to  
25 that?

1 MR. THOMAS: This is George Thomas.

2 The staff has not evaluated that because  
3 our scope of review has been limited to aging  
4 management. And a seismic SSC event is a one-time  
5 rare event that's --

6 MEMBER RAY: Well, it goes to the adequacy  
7 of margin. The margins here are substantial.

8 MR. THOMAS: Right.

9 MEMBER RAY: And if the margins were very  
10 small, one might say well, we need to be aware of that  
11 as part of the aging management program.

12 MR. THOMAS: Right.

13 MEMBER RAY: That's the implication for  
14 license renewal if there is any. I'm not saying there  
15 needs to be any. I'm just saying that it was a  
16 comment that was made earlier.

17 It's something that we thought about  
18 during the course of our review. And I just wondered  
19 if the staff had given it any consideration.

20 Jim?

21 MR. NEURAUTER: Yes. Jim Neurauter.

22 As you know, the licensee or the Applicant  
23 here needs to put in a license amendment for the  
24 shield building to re-establish to the design basis.  
25 And they have a structural calculation that they have

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 prepared that they believe adequately addresses the  
2 design basis.

3 They have not submitted this application  
4 at this point in time. So staff has not reviewed it  
5 with respect to margins. It really is a margin issue  
6 as to what staff will accept.

7 So until that review has taken place and  
8 staff has issued its SER with the appropriate margins  
9 that they feel are safe, it's premature.

10 MEMBER RAY: That's fine. I understand  
11 it, and that's fine.

12 Like I say, the comment has been made. It  
13 was a consideration. And I just wondered if you had  
14 anything to offer.

15 MR. NEURAUTER: Well, yes.

16 MEMBER RAY: And you've answered the  
17 question. Thanks.

18 MR. NEURAUTER: Okay. Thank you.

19 MEMBER RAY: The other issue that we also  
20 discussed was a spalling. The Applicant had addressed  
21 that very early on in the Subcommittee meeting and  
22 touched on it again today. But I don't recall seeing  
23 anything in the staff review and discussion, and I  
24 wondered if you had any comment on spalling, either in  
25 the shoulder area where there are large chunks -- and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 maybe you don't call it spalling but separation  
2 possible -- and also in the region of high up where  
3 there's laminar cracking in between the shoulder areas  
4 where the thinner sections might be subject to  
5 spalling failure.

6 Is that anything that the staff has  
7 discussed and I just missed it, or not?

8 Then, Rick, I guess you should be in  
9 charge here.

10 MR. PLASSE: I mean, the plant's operating  
11 today. It's operable. And a lot of these form the  
12 basis in 9118 space in the corrective action program.

13 And Jim, can you explain the items that  
14 you guys have looked at to consider?

15 MR. NEURAUTER: Well, we asked the  
16 question. Because it's the seal building is operable  
17 if nonconforming, why is it safe to operate your plant  
18 today? And right now, we have determined the licensee  
19 has reasonable assurance that the plant is safe.  
20 That's different than licensing basis.

21 Now, when staff looks at their evaluations  
22 as to why they believe this concrete won't fall off  
23 and there's adequacy of rebar to hold it in place,  
24 again, it's premature.

25 MEMBER RAY: Okay. Well, again, I was



1 exploring just not from the standpoint of whether  
2 there was anything that was of concern today. But if  
3 we're looking at the aging management program and  
4 changes in the current condition would lead to the  
5 possibility of a failure such as a spalling, the  
6 assessment that one might reach is that the rebar on  
7 the shoulders precludes a large failure and the  
8 tornado design for the areas in between the shoulders  
9 assures that there's not going to be any damage to  
10 safety-related structure systems and equipment if  
11 their failure is in between the shoulder areas.  
12 That's one way to consider it.

13 You guys haven't looked at it yet, and  
14 that's fine.

15 MR. NEURAUTER: If it was perfected round  
16 without shoulders on it, that's what they evaluated in  
17 their design basis -- that thickness of concrete --

18 MEMBER RAY: Right.

19 MR. NEURAUTER: -- for tornado missile.

20 So if just the shoulders --

21 MEMBER RAY: I'm talking about the  
22 spalling piece being smaller in size than a tornado-  
23 induced missile striking a piece of the adjacent  
24 structure systems and components. That was what I was  
25 --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. NEURAUTER: Again, right now, they  
2 believe the concrete is going to stay up on the shield  
3 building.

4 MEMBER RAY: Okay.

5 MR. NEURAUTER: And there hasn't been an  
6 evaluation of a chunk of concrete hitting the ops  
7 building.

8 MEMBER RAY: Okay.

9 MR. NEURAUTER: Okay?

10 MEMBER RAY: All right. Well, I just  
11 wanted to be sure because I hadn't seen anything  
12 discussed on either of those two items.

13 MR. NEURAUTER: And neither have I.

14 MEMBER RAY: Okay. Fine. Thank you.

15 Okay, Rick, anything more from you?

16 MR. PLASSE: Any other questions for the  
17 staff?

18 MEMBER RAY: All right. Well, then we'll  
19 ask if there are any questions from Members for the  
20 staff.

21 We will give the Applicant an opportunity  
22 to come back and address a couple of items that have  
23 come up since they left the front. And then we'll go  
24 to members of the public.

25 But do Members of the Committee have any

1 questions of the staff?

2 (No audible response.)

3 MEMBER RAY: Hearing none, thank you,  
4 Rick.

5 MEMBER RAY: Okay. The Applicant has  
6 informed me that they would like to clarify a point  
7 related to the -- what do you call it -- the sand?

8 MR. HENLINE: Sand pocket.

9 MEMBER RAY: Sand pocket. Thank you.

10 And the other question I would pose to you  
11 here is if you have anything to add to the dialogue  
12 that we had about the 13/1000s and what role does that  
13 play, and has it been superseded by 20/1000s now and  
14 that sort of thing. I'd like to get anything further  
15 that you want to say on that score on the record.

16 MR. HENLINE: Trent Henline,  
17 Implementation Manager.

18 I'm going to clarify the sand pocket  
19 question.

20 The question was asked were the  
21 inspections that we did in the spring of 2014 were the  
22 last inspections that we're going to do of the  
23 containment vessel in the sand pocket area. And the  
24 answer to that question is no, we have a commitment.  
25 It's Commitment Number 35 in the license renewal

1 application commitments to repeat the inspections that  
2 we completed in the spring of 2014 by December 31st of  
3 2025. So we will do that inspection again to confirm  
4 that there is no ongoing degradation.

5 But I just wanted to clarify that point.

6 MEMBER RAY: Thank you. It makes me feel  
7 so much better.

8 CHAIR STETKAR: That's inspection from the  
9 exterior in the accessible area of the sand pocket?

10 MR. HENLINE: That's correct.

11 CHAIR STETKAR: Okay.

12 MR. HENLINE: That's the five locations  
13 where we did the nine points at each location.

14 CHAIR STETKAR: Okay. Thank you.

15 MEMBER RAY: I thought there was something  
16 on that score, but then I thought I was mistaken.

17 Okay. I would ask the Applicant if  
18 there's anything they can offer to us further. And  
19 frankly, let me just be clear about what I think can  
20 benefit from clarification.

21 The 13/1000s, I think -- and this is a  
22 long history so it's understandable -- appeared as a  
23 limit on crack width. But it wasn't clear what was  
24 going to happen after that if it was exceeded.

25 We understand it has been exceeded, and we

1 understand further that perhaps it's now become a  
2 different number -- 20/1000s.

3 But we'd like to understand okay, what is  
4 the number and what happens afterward. Is there any  
5 limitation other than I suppose the university testing  
6 results would serve as a limitation on crack width?  
7 Or something. Just tell us how -- because crack width  
8 is very important. It's at least as important as the  
9 growth in the area of the laminar cracking. And we'd  
10 like to understand how you're going to manage that as  
11 part of the aging management program.

12 MR. HOOK: Okay. Again, I'm Jon Hook.

13 And you are correct. The crack width is  
14 an important parameter.

15 And so, originally it was .13, and now the  
16 current criteria is .020 -- 20/1000s.

17 MR. BYRD: You might direct them why we  
18 started with .13 just to get the history.

19 That was the widest crack we initially  
20 identified. And I think we can help you understand  
21 where we're at.

22 So why don't you start there?

23 MR. HOOK: Right.

24 Initially, when we first came up with or  
25 first identified laminar cracking, that was the widest

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 crack -- 13/1000s. So that was in our program. That  
2 would be a threshold which we would take action to  
3 make sure nothing exceeded that.

4 So since then, we wanted to increase  
5 margin in our crack width. So we went back to the  
6 professors. Both of them independently looked at  
7 their test results and the crack sizes that they saw.  
8 Again, they saw crack sizes over 30/1000s of an inch  
9 for stresses higher than what we see in our shield  
10 building in the rebar. So they are both very  
11 comfortable in establishing a conservative level of  
12 20/1000s of an inch. So that is right now in our  
13 calculation as an acceptance criteria.

14 Both professors have indicated we can go  
15 beyond that. But what they would like to do is do  
16 another series of tests to more specifically monitor  
17 that because that wasn't one of the conditions that  
18 they were looking for. They just happened to record  
19 all that information. So they believe in some cases  
20 significantly more.

21 So we're in the process of in the very  
22 early stages of communicating with both Purdue to do  
23 additional testing to expand even beyond 20/1000s.  
24 But right now, our design calculations have a limit of  
25 20/1000s.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   MEMBER RAY: Okay. And that seems to me,  
2                   if I understand it correctly, similar to the same  
3                   approach taken with regard to the aerial extent which  
4                   is there's conservatively established aerial extent.  
5                   There's margin to that presently.

6                   MR. HOOK: That's correct.

7                   MEMBER RAY: But that aerial extent could  
8                   then be subject to increasing based on whatever  
9                   analysis is appropriate at the time if you approached  
10                  it.

11                  MR. HOOK: That is a true statement. Yes.

12                  MEMBER RAY: All right.

13                  Pete, do you have anything you want to ask  
14                  about this width issue?

15                  MEMBER RICCARDELLA: No.

16                  MEMBER BALLINGER: Well, I do.

17                  MEMBER RAY: All right.

18                  MEMBER BALLINGER: If you see the largest  
19                  crack is .016?

20                  MR. BYRD: That's correct.

21                  MEMBER BALLINGER: If you see some later  
22                  on at .02, that implies crack propagation, does it  
23                  not?

24                  So presumably, you would see that as part  
25                  of the IR stuff -- other inspections. No?

1 MR. BYRD: Not IR.

2 MR. HOOK: We would see it as part of our  
3 -- we do core bore inspections. As part of our visual  
4 core bore inspections, we would be able to see that.

5 MEMBER RICCARDELLA: Just to clarify,  
6 impulse response won't give you a crack width.

7 MEMBER BALLINGER: It won't give you a  
8 crack width, but if you see crack widths that have  
9 increased by the way from .013 to .02, does that not  
10 imply that cracks have propagated?

11 MR. HOOK: That would be an indication  
12 that potentially the crack is widening -- or not  
13 widening, but extending.

14 MEMBER BALLINGER: Extent.

15 MR. HOOK: Correct.

16 MEMBER BALLINGER: And so that would be  
17 picked up by the IR -- yes, the extension which --

18 MEMBER RAY: But Ron, I don't think we can  
19 be certain of that. I know Pete wanted to make a  
20 point.

21 In other words, we can't be certain that  
22 increasing width necessarily means aerial propagation.

23 MEMBER RICCARDELLA: That's right. It's  
24 not even conceivable that the width could grow without  
25 the area increasing.



1 MR. BYRD: That is correct.

2 MEMBER BALLINGER: Okay. I'm just trying  
3 to think of a double way of seeing things.

4 MEMBER RAY: No, I understand. I think  
5 everybody would concede that it's likely that the  
6 aerial extent would grow at the same time the width  
7 increased. But I don't know that anybody can say it  
8 necessarily would.

9 MR. NEURAUTER: Jon, just for point of  
10 clarification, both you and the staff's presentation,  
11 your presentation to the staff's presentation had  
12 within it a description of what would happen at the  
13 other end of the spectrum -- that is if the cracks  
14 become passive. But it's not clear to me. What are  
15 the criteria there for assuring that the cracks are  
16 passive before the program is changed -- the  
17 inspection program interval is changed?

18 MR. HOOK: The program is if we see any  
19 change at all, then we'll continue to do yearly  
20 inspections. If we do our yearly inspections and we  
21 see no change at all -- none -- in either width or  
22 extent, then we would increase our inspection  
23 frequency to every other year.

24 MR. NEURAUTER: And that's if you see it  
25 in any given year?

1 MR. HOOK: Yes.

2 MR. NEURAUTER: Just one time and then you  
3 would increase to two years?

4 MR. HOOK: Right.

5 Then the next time if we saw a change,  
6 then we would go back to every year again.

7 MR. NEURAUTER: Okay. Thank you.

8 MEMBER RAY: Okay. That's very  
9 responsive. And I appreciate your clarifying the  
10 situation for us.

11 While you're still there, does anybody --  
12 any Member -- have a question for these two gentlemen?  
13 If not, thank you very much.

14 MEMBER SKILLMAN: Yes. Let me ask one.

15 In the write-up on the AMP on your choice  
16 of number of holes, you originally had 12. You added  
17 nine to 21. And then you went from 21 to 28.

18 Just in a nutshell, what drove the deltas?

19 MR. HOOK: Twelve was established because  
20 originally the root cause says the cracks are passive.  
21 And so 12 was just a sample size to validate it's  
22 prudent to make sure that what the assumption made in  
23 the root cause was appropriate.

24 So we didn't have as large a sample, but  
25 those samples were still representative of all the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 areas -- the top and the solars and the main steamline  
2 penetration.

3 But when we did find a laminar crack --  
4 and that's when we increased the sample size to 21.  
5 Since then, we've also increased it again because we  
6 get crack propagation. And sometimes we increase the  
7 sample size because we want to maintain that leading  
8 edge on a crack. So we'll add additional core bores  
9 because we know where the leading edge is and we're  
10 adding more core bores. And that's why this last time  
11 we moved it up to 28 because we're tracking those five  
12 median edges.

13 MR. BYRD: So we aren't eliminating any  
14 core bores. As it expands, we just keep adding.

15 So it will probably expand beyond 28 if  
16 propagation continues.

17 MEMBER SKILLMAN: Thank you, Jon. Ken,  
18 thank you.

19 MEMBER RICCARDELLA: But is it fair to say  
20 that the original sample of 12 did detect the  
21 propagation?

22 MR. HOOK: That's correct. That is  
23 correct. Yes. It's a true statement.

24 MEMBER RAY: Okay. Thank you so much.

25 Now stand by for anything further that we

1 might need you for. I'm sure you will.

2 The next step was we've been informed that  
3 there is I believe a member of the audience -- at  
4 least one -- who would wish to make a comment to the  
5 Committee at this time. And if that's correct, I see  
6 Kent has gone to seek the person who's asked to make  
7 a comment to us. We'll invite you to come forward to  
8 the microphone, please. We'll try and make sure that  
9 the microphone is working fully. Thank you.

10 Yes. Hi. Let's just take a second and  
11 see if the microphone is on and you're close enough to  
12 it.

13 Okay. If you'll just please introduce  
14 yourself and then proceed. Thank you.

15 MR. KAMPS: Thank you, Subcommittee  
16 Chairman and Chairman and Members for this opportunity  
17 to speak.

18 My name is Kevin Kamps with Beyond Nuclear  
19 where I serve as Radioactive Waste Watchdog. And I'm  
20 also on the Board of Directors for Don't Waste  
21 Michigan which is the state-wide watchdog  
22 organization.

23 Both groups -- in addition, there are  
24 others -- are official intervenors against the 20-year  
25 license extension at Davis-Besse. And we have been

1 since December 27th of 2010. That's when we filed our  
2 intervention.

3 But as was stated today, the cracking did  
4 not come to light until October 10th of 2011. And we  
5 then began to file a series of cracking contentions in  
6 the Atomic Safety and Licensing Board proceeding. Our  
7 first one was filed on January 10th of 2012.

8 So I only got the materials some hours  
9 ago. So it's difficult to try to wrap your head  
10 around all this and present a cogent response. But  
11 some of the concerns that come to mind just kind of  
12 follow along with that chronology I already laid out.

13 We protested the confirmatory action  
14 letter of December 2, 2011, which NRC staff issued  
15 allowing this reactor to re-start just a few days  
16 later. And it was some six months later after the NRC  
17 regional administrator refused to provide documents.  
18 In early January of 2012, there was a large public  
19 meeting held at Camp Perry just down the road from  
20 Davis-Besse. Some 300 people attended.

21 Documents were not available to the  
22 public. We had to FOIA those documents. It took six  
23 months and a threat of a law suit against the NRC FOIA  
24 staff to finally get those documents in hand. That  
25 was in June of 2012.

1           And it was then that we began to realize  
2           how rushed the re-start decision had been, how many  
3           unanswered questions there were. And even on the  
4           public face of the documents, the confirmatory action  
5           letter, Davis-Besse was allowed to operate until  
6           February 28th of 2012 without a root cause analysis in  
7           place, without an extent of condition for the  
8           cracking, without a corrective action plan.

9           Then there was what we called the snow job  
10          of 2012. That was the blizzard of 1978 route cause  
11          report that came out on February 28th of 2012.

12          Obviously, it was far from good enough.  
13          The NRC staff issued a large number of requests for  
14          additional information which led to a second revised  
15          root cause report that came out in May of 2012. And  
16          I think this was all included in our various filings  
17          to the Atomic Safety and Licensing Board which were  
18          ignored, in short.

19          There were 27 potential root causes that  
20          the NRC requests for additional information  
21          identified. And I listed some off the top of my head  
22          that I recalled. One was a top down water flow  
23          mechanism due to cracking that existed at the dome as  
24          far back as August of 1976. Pre-operational.

25          Another area of potential root cause was

1 the fact that the shield building construction began  
2 in the early 1970s was not completed until the mid- to  
3 late 1970s. There were a number of years where there  
4 was no dome on the shield building. It was open to  
5 the elements. There were no number of additional  
6 years where the side of the shield building had the  
7 initial construction opening -- a very large-scale  
8 opening.

9 So all of these were potential water  
10 infiltration pathways. Multiple winters where the  
11 inside face of the shield building was exposed to the  
12 elements, not just the outside face. As was mentioned  
13 by Dr. Chiu -- if I have his name correct -- from PII,  
14 the blizzard of 1977 was another potential root cause,  
15 not just the blizzard of 1978. The list was 27 long  
16 for potential root causes.

17 We raised the issue synergisms between  
18 various potential root causes. Again ignored by NRC  
19 staff which opposed us at every time in our license  
20 intervention. Certainly ignored by the company.  
21 Ignored by the Atomic Safety and Licensing Board.

22 Lo and behold, August/September 2013, the  
23 cracking is growing. So we had been blocked in our  
24 intervention because our intervention contents had to  
25 be aging related. Up until that point -- we're now

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 talking the better part of two years -- for lack of  
2 aging relatedness.

3 Well, now it's aging-related. It was not  
4 until July of 2014 that the full apparent cause  
5 evaluation was published by First Energy. So there was  
6 no explanation. Now this is root cause number three  
7 for the cracking. What could not possibly have  
8 happened, this all took place over a three-day period  
9 in 1978. There will be no cracking growth. That's  
10 not possible. Get lost.

11 Well, July of 2014, a full apparent cause  
12 evaluation root cause number three, ice-wedging crack  
13 propagation. Where did that come from? Well, it came  
14 from what we called the whitewash of 2012 -- the  
15 August to October application of a weather sealant 40  
16 years too late on the exterior face of the shield  
17 building.

18 As Congressman Kucinich said in late 2011,  
19 everyone in Northern Ohio knows you have to paint your  
20 porch. Well, apparently Bechtel, First Energy's  
21 predecessor companies, back in the late 1960s decided  
22 that a weather sealant was not needed on the exterior  
23 of this building, which was odd because weather  
24 sealant was applied to other buildings on site.

25 When asked about that disconnect, First



1 Energy's only response was the other buildings  
2 appeared splotchy. It was an aesthetic reason that  
3 they did weather sealant on those buildings. So one  
4 of the single most safety significant buildings at the  
5 Davis-Besse site was not weather sealed for decades.

6 Well, in various exchanges with the NRC  
7 and with the company back in 2012, especially leading  
8 up to the white wash of August to October, warnings  
9 were issued by concerned members of the public. What  
10 are the unintended consequences of the weather sealant  
11 40 years too late?

12 And wouldn't you know there was a big one?  
13 It locked the water in the walls. And what was really  
14 objectionable -- and I guess a part of this gets to  
15 the character of this company -- was that from early  
16 2012 until July of 2014, First Energy knew full well  
17 that they had water locked in the walls. After the  
18 weather sealant was applied -- they knew they had  
19 water in the walls before that in early 2012 -- after  
20 the weather sealant was applied in August to October,  
21 they had now locked that water in the walls preventing  
22 its evaporation out. And hence, the ice wedging crack  
23 propagation which warnings had been issued that there  
24 could be unintended consequences to this white wash.

25 So this ad hoc response to this very

1 significant safety concern at Davis-Besse obviously  
2 thus far for the past four or five years has not gone  
3 very well. The NRC staff seems willing to sign off on  
4 First Energy's position at any turn to allow not only  
5 current operations but extended operations.

6 Based on the September 23rd Subcommittee  
7 meeting -- I mean, the importance of impulse response  
8 testing, which is something we've raised since January  
9 of 2012 -- to get an idea of where things are at -- I  
10 mean, referring to the old impulse response mapping  
11 from years ago now, that is obsolete. And new impulse  
12 response mapping of a comprehensive nature -- not just  
13 random selections of the shield building -- should be  
14 required. It should not be an option. It should be  
15 required.

16 Another example today of kind of making it  
17 up as you go along is this .013 versus .016 versus  
18 .020 versus .030, it seems like the road is being  
19 constructed as you go.

20 Another major issue that I've not heard  
21 addressed is corrosion of the rebar itself. Obviously  
22 you've got severe and worsening cracking. And I think  
23 that the figure for how bad the cracking is, each  
24 freeze-thaw free cycle should be mentioned on the  
25 record. According to the full apparent cause

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 evaluation of July 2014, it's a 0.4 to 0.7 growth of  
2 cracking with every single freeze at this site which  
3 is quite disturbing.

4 At the Subcommittee meeting in September  
5 as well, it was very disconcerting to hear the  
6 extended discussion which I've not heard today thus  
7 far about the potential for spalling -- as it's been  
8 referred to -- exterior chunks of shield building  
9 concrete falling off most significantly onto safety-  
10 significant systems, structures and components.

11 The auxiliary building was mentioned by  
12 First Energy itself in September. The borated water  
13 storage tank -- there are other safety-related  
14 systems, structures and components down below.

15 And this is for 20 more years. So that's  
16 the big concern.

17 Another big concern we have is the loss of  
18 current licensing basis and design basis. And I  
19 mentioned the FOIA response that we didn't get for six  
20 months despite the ongoing licensing proceeding we  
21 were engaged in. That was a major conundrum for NRC  
22 staff at the time in October and November of 2011.  
23 How can this reactor be allowed to operate without a  
24 design basis or current licensing basis in place?

25 In August of 2012, there was a public

1 meeting held at Oak Harbor High School where the  
2 company -- and again, back at Camp Perry in January of  
3 2012 -- we were promised that current licensing basis  
4 and design basis would be re-established. It became  
5 very clear from the FOIA response how significant that  
6 loss was in NRC decision making, although the reactor  
7 was operating from December on.

8 And then at the meeting in August of 2012,  
9 we were promised a plan to re-establish current  
10 licensing basis and design basis by December of 2012.  
11 Here we are it's November of 2015 and the plan seems  
12 to be a license amendment to re-establish this.

13 So what's really hard for the public to  
14 understand is how this reactor has been allowed to  
15 operate this whole time, how this license extension  
16 proceeding has been allowed to get to this point where  
17 if you look at the schedule, there's this meeting,  
18 there's the Director of NRR's sign off and then  
19 there's the Commission sign off. There are three  
20 check boxes left before a 20-year license extension is  
21 approved by this Agency despite this issue of cracking  
22 and other issues. This isn't the only issue.

23 And so, there have been broken promises --  
24 very serious ones. Our members who live downwind and  
25 downstream, not only Ohio but in Michigan and also in

1 Ontario and beyond, are most concerned about this  
2 issue.

3 As I mentioned in September, our  
4 organizations are also appealing the NRC's Nuclear  
5 Waste Confidence policy at the second-highest court in  
6 the land -- the D.C. Circuit Court of Appeals. So  
7 this challenge against the license extension  
8 continues.

9 And we continue to assert that this reactor  
10 should be retired as planned on Earth Day 2017. There  
11 are way too many problems, way too many risks, way too  
12 many unanswered questions.

13 Thank you.

14 MEMBER RAY: Thank you, sir.

15 Is there anyone else in the audience who  
16 would wish to make a comment?

17 (No audible response.)

18 MEMBER RAY: Could we make sure the phone  
19 line is open, please, Kent?

20 While we're waiting for that to occur, the  
21 results of our meeting here today will be a letter at  
22 this session of the full committee, at least proposed  
23 for consideration.

24 The phone line appears now to be open.  
25 And I would ask for any comments from any member of

1 the public who's on the phone line.

2 Is there anyone who would like to make a  
3 comment?

4 (No audible response.)

5 MEMBER RAY: Is there anyone on the phone  
6 line that could at least identify that it's open as it  
7 sounds like it must be.

8 MR. HOFFMAN: I'd like to make a comment  
9 if you can hear me.

10 MEMBER RAY: I can hear you. We all can.  
11 Your name, please? And then proceed.

12 MR. HOFFMAN: Yes. Thank you.

13 My name is Ace Hoffman. And the comment  
14 is that I was first of all not able to hear a lot of  
15 it because there was cross talk on the phone line that  
16 might have driven a few people away.

17 But from material that I heard at the  
18 beginning, the utility went into great detail about  
19 various parts that they replaced. A new reactor's  
20 going to talk about \$20 billion. And I don't think  
21 they were talking about anything near that kind of  
22 money. Putting a replacement part can often cost a  
23 lot more than putting the same part into a new  
24 reactor. So I don't think the utility, based on what  
25 they were saying, is replacing more than five percent

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 or maybe ten percent of the reactor. So I don't think  
2 that emphasis was appropriate.

3 And also, we seem to be at the tail end of  
4 a lot of replacement projects that have gone on. I  
5 hope these should have been considered as not worth  
6 doing if they're going to retire the reactor in 2017  
7 or maybe even a little earlier because they would  
8 prefer to save money. This is the wrong way to do  
9 business to get yourself all set up for something and  
10 then you have all the inertia to get the NRC to  
11 approve it.

12 I understand there were 500 items that  
13 were adjusted. And that sounds like a lot, but I  
14 think it's only a small percentage.

15 And that's it. That's all of my comments  
16 for now. Thank you.

17 MEMBER RAY: Yes, sir. Thank you.

18 MR. LEWIS: My name --

19 MEMBER RAY: Marvin?

20 MR. LEWIS: Yes. Thank you.

21 MEMBER RAY: Go ahead.

22 MR. LEWIS: Marvin Lewis.

23 And look, my undergrad degree is in  
24 metallurgical engineering. And I've also been a bench  
25 chemist and I've also run a concrete lab. So between

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 a concrete lab and an undergraduate degree, I think I  
2 can talk on concrete and I can talk on rebar.

3 And one of the things I can talk on is  
4 they're quite different and they love to separate.  
5 And when you get a temperature change, the -- well, it  
6 can withstand a heck of a lot more than the concrete  
7 which means everyday you're getting a little closer to  
8 where a wall's going to fall in.

9 And the second thing is it makes me wonder  
10 about the telephones on site. If you can't get your  
11 telephones working right at the NRC, how the heck are  
12 you going to get the telephones right -- working right  
13 at the site.

14 CHAIR STETKAR: Mr. Lewis? Mr. Lewis,  
15 this is John Stetkar.

16 It's not a problem here. It's a problem  
17 with cross talk among people in the public who are  
18 talking on their phones on a common line. It is not  
19 a problem with our phone system here at NRC.

20 MR. LEWIS: Well, I'm listening to your  
21 phone system at the NRC on this phone here, and I was  
22 having a problem. I don't know how that separates one  
23 problem from another, but I'm sure you do and I'm sure  
24 you'll go down on site and make sure their phones are  
25 working.



1                   Thank you very much for allowing me to  
2                   make my comment.

3                   MEMBER RAY: Are there any other members  
4                   of the public on the phone line at present who would  
5                   like to make a comment?

6                   (No audible response.)

7                   MEMBER RAY: Hearing none then, let's go  
8                   ahead and close the line to end the popping and  
9                   cracking and I'll turn it back to you, John.

10                  CHAIR STETKAR: Thank you very much,  
11                  Harold.

12                  Any final comments by any of the members?

13                  (No audible response.)

14                  CHAIR STETKAR: If not, we re-scheduling  
15                  --

16                  MEMBER RAY: Excuse me a second. I just  
17                  saw that maybe Rick wanted to make a comment here. He  
18                  was walking toward the table.

19                  Pardon me. I'm sorry.

20                  CHAIR STETKAR: Okay.

21                  MR. PLASSE: Yes. If we could refer back  
22                  to slide 12.

23                  MEMBER RAY: We need your slide operator  
24                  there.

25                  MR. PLASSE: This slide was to show the

1 acceptance criteria for the program.

2 And the acceptance criteria is still crack  
3 width does not exceed .013 inches. The confusion was  
4 added with in parentheses, current observed maximum  
5 width which we're going to strike from the slide.

6 That was factual when we got the RAIs  
7 which we used to evaluate the program back in January  
8 of 2015. Subsequent to that, they have done a 2015  
9 inspection, and evidently they had an item of greater  
10 than that trigger point which they evaluated in the  
11 corrective action program which is where they are  
12 today.

13 So the correction will simply be to strike  
14 what's in parentheses on that slide. And I'll provide  
15 that slide to Kent.

16 MEMBER RAY: All right? We understand  
17 you've modified or corrected the slide accordingly.

18 Any questions for Rick?

19 (No audible response.)

20 MEMBER RAY: Once again, I'll turn it back  
21 to you, John.

22 CHAIR STETKAR: You're sure?

23 MEMBER RAY: No, I'm not. But I'll --  
24 we'll try it anyway.

25 CHAIR STETKAR: I'll try to leap in here

1 quickly then.

2 Thanks to everyone. Thanks to First  
3 Energy, the staff. Thanks to the public, by the way.

4 And thanks for bearing with us. Members  
5 of the public out there, I know that we had problems  
6 on the bridge line. I apologize for that. Things are  
7 beyond our control with cross talk out there.

8 With that, we are recessed until -- we'll  
9 be off the record until tomorrow morning.

10 (Whereupon, the above-entitled matter went  
11 off the record at 3:33 p.m.)

12

13

14

15

16

17

18

19

20

21

22

23

24

25

# **INDUSTRY COMMENTS ON DRAFT SECY “RECOMMENDATIONS ON ISSUES RELATED TO IMPLEMENTATION OF A RISK MANAGEMENT REGULATORY FRAMEWORK”**

Victoria Anderson  
Senior Project Manager, NEI

# I. Path Forward for enhancing risk management approach

- Staff Evaluation and Recommendation in draft SECY
  - Existing policy statements on safety goals and use of PRA along with guidance and experience have established most key aspects of RMRF for nuclear power reactor safety program area.
  - Staff recommendation: Maintain current framework and continue to make improvements on incremental basis.
  - Industry agrees with this recommendation.
    - Utilize Risk Informed Steering Committee (RISC) to expand the use of risk-informed decision making.

# I. Path Forward for enhancing risk management approach

- Consideration of Alternatives
  - Plant Specific regulatory framework
    - The Staff agrees with public commenters that this approach should not be implemented for currently operating reactors
    - Industry does not find this to be a viable option.
    - Industry agrees with Staff recommendation in draft SECY

## II. Re-evaluation of Improvement Activity 1 from Fukushima Near-Term Task Force Recommendation 1

- Improvement Activity 1: Establish Design-Basis Extension Category
  - Rulemaking guidance provides consistency in specifying necessary regulatory “attributes” (performance goals, treatment requirements, documentation requirements, change processes, and reporting requirements) whenever new regulations (both design-basis and beyond design-basis) are developed.
  - Staff recommends that a new category of events should not be established at this time.
  - Industry agrees with Staff recommendation in draft SECY.

## II. Re-evaluation of Improvement Activity 2 from Fukushima Near-Term Task Force Recommendation 1

- Improvement Activity 2: Establish Commission Expectations for Defense-in-Depth
  - Staff recommends that a defense-in-depth policy statement is not needed. This is consistent with the industry's comments.
  - Staff intends to complete a previous effort to modify the guidance on defense-in-depth in RG 1.174.
  - The industry agrees with the Staff recommendation that a defense-in-depth policy statement is not needed and supports the revision of guidance documents (e.g., RG 1.174) to ensure consistent application of defense-in-depth in regulatory decisions.



### III. Consideration of an overarching policy statement on using the Risk Management Approach

- NRC staff recommends not to develop an overarching agency-wide policy statement.
- Industry Comment:

Accomplishing this across the entire agency in a coordinated, consistent manner would appear to be an extremely challenging task for the NRC that will require a long period of time, inter-agency coordination, and perhaps a dilution of methodological approaches to satisfy all of the agency's desires.
- Industry agrees with the staff recommendation not to develop an overarching agency-wide policy statement.

# Conclusions

- The industry agrees with the staff's recommendations in the draft SECY paper.
- Will continue to work with the staff to ensure appropriate methods and guidance are available to develop, and implement risk-informed applications.

**November 3, 2015**

**Author: Mary Drouin**

**Subject: Staff SECY Paper Entitled “Recommendations On Issues Related To Implementation Of A Risk Management Regulatory Framework”**

**Basis for Non-Concurrence:**

The SECY on the Risk Management Regulatory Framework (RMRF) recommends that an Agency-wide Policy Statement on an RMRF should not be developed. This decision is inconsistent with establishing a sound agency-wide basis for increasing the use of risk insights into NRC’s regulatory decision-making. Existing Policy Statements provide some of the visionary guidance for the use of risk (i.e., the PRA Policy Statement and the Safety Goal Policy Statement), but fall short in providing a holistic framework under which NRC processes could be enhanced in the long-term to increase the use of risk insights in a consistent and predictable way. As such, I believe the decision should be changed to recommend that the staff develop an Agency-wide RMRF policy statement for Commission approval that provides a high level, visionary statement towards which all of the program offices could work towards as resources permit.

The SECY paper also states that the “staff believes that developing a policy statement on defense-in-depth for nuclear power reactor safety is unnecessary, and that further efforts to develop a definition of and criteria for determining adequacy of defense in depth should not be pursued at the present time.” This decision is inconsistent with the NRC’s strategic goals and NRC’s endeavor to have a predictable and stable regulatory process. As such, I believe the decision should be changed to recommend that the staff develop a single, formal definition for defense-in-depth and develop associated guidance for determining adequacy of defense-in-depth.

**Background**

In 2012, under Commissioner Apostolakis, the results from the Risk Management Task Force (RMTF) study (NUREG-2150) were published. On June 14, 2012, the NRC Chairman issued a tasking memorandum that directed the NRC staff to “... review NUREG-2150 and provide a paper to the Commission that would identify options and make recommendations, including the potential development of a Commission policy statement.”

I do not believe the staff paper to the Commission has been responsive to the tasking memorandum. My issues are discussed below.

As stated in the SECY paper regarding NUREG-2150, “The report [NUREG-2150] provides findings and recommendations in two categories. The first category addresses strategic, agency-wide issues, and recommends that “[t]he NRC should formally adopt the proposed Risk

Management Regulatory Framework through a Commission Policy Statement.’ The second category addresses what changes could be made in specific regulatory program areas (e.g., power reactors, nuclear materials) in the next several years to support implementation of the risk management regulatory framework.” Moreover, the goal of the RMRF study was to “develop a strategic vision and options for adopting a more comprehensive, holistic, risk-informed and performance-based regulatory approach for reactors....” The staff limited its evaluation to a reactor perspective rather than assessing the merits of the study from an agency-wide, holistic perspective. Because of this limitation, I believe that observations and insights provided in the study were not fully understood or appreciated.

The paper asserts that the Safety Goal and PRA policy statements with other regulatory guidance “have established most of the key aspects of an RMRF for the nuclear power reactor safety [emphasis added] program area.” First, the insights from the RMRF study were from an agency-wide, holistic perspective and not a reactor safety perspective. Consequently, the insights and benefits from the study were truly not considered. The paper does not address, as stated in NURE-2150, the patchwork of regulatory requirements that have been created as a result of addressing problems on a case-by-case basis for many years. Second, the paper, in a footnote, argues that the existing nuclear power reactor safety regulatory framework has similar elements that include a mission, objective, goal, and decision-making process. I believe this is a misleading statement. The NRC does have a formal mission as stated in the Atomic Energy Act, however, while the NRC does try and practice the stated objective and goal, it is not implemented through a formal program or policy. The Safety Goal policy statement has served the agency well, however, it is not equivalent to an agency-wide risk management policy statement. The PRA policy statement (which has also served the agency well) also is more of a sub-element of a risk management regulatory framework. The increased use of PRA in regulatory activities is not the same as risk management. Risk management is a higher level concept; the PRA policy statement is policy that addresses one element in how to implement a risk management framework. Managing risk uses insights from various risk analyses and not every program office activity is amenable to gaining insights from a PRA. There are other approaches to gain risk insights than just from a PRA.

I believe the characterization of the public comments is misleading. The staff did receive negative feedback, but it is important to read the bases for their comments. It is clear that the intent, purpose, etc. of a proposed policy statement provided to the public was not clear to stakeholders which I believe was a major reason for their negative reaction. At the public meetings, the intent, etc. were discussed. Given a clearer explanation of the intent of the policy statement and that stakeholder input would be solicited throughout the process, the staff received positive feedback. NRC policy statements are powerful tools. They communicate to the staff and to our stakeholder the Commission policy, “this is how we do business.” They serve as the catalyst and basis for many of our regulatory programs and decisions. The Safety Goal and PRA policy statement are not substitutes or equivalent to a risk management policy statement.

I disagree with the statement in the paper regarding defense-in-depth. The staff states that “the defense-in-depth philosophy is already well-established in the regulations and existing Commission policy statement.” Only the term and not the meaning of defense-in-depth is well established; there is not a solid, consistent understanding of defense-in-depth or how defense-in-depth is implemented. There is a long litany of examples to illustrate (which was demonstrated in the limited historical review and evaluation attached to SECY-13-132 as Enclosure 3). For example, there are several places in the NRC literature (e.g., Commission White paper, regulation, regulatory guide, NRC glossary) where defense-in-depth is defined, each different. The Commission should have a single formal definition, and it should not be left to individuals to pick and choose the definition. While it is true that the Commission has been able to make regulatory decisions without a formal definition or guidance, the staff has and continues to struggle with defense-in-depth. This struggle was very clearly articulated at the 2015 RIC conference in Dr. Uhle’s presentation on defense-in-depth. Defense-in-depth is a major issue recognized in the international community; there have been and continue to be major dialogue on this topic. It is an issue that other regulatory entities have and continue to struggle with. Defense-in-depth is key to ensure that the NRC is achieving its mission. Our decision-making would be much more efficient and effective if we had a solid, common understanding of defense-in-depth.

I do not agree that the staff would be unable to establish “predictable, objective criteria acceptable to the Commission.” There has been a tremendous amount of work in this area which does indicate that “predictable and objective criteria” in the form of guidance can be developed; it would not be “prescriptive,” nor would it need to be. There are also examples where such an argument was used to not move forward. For example, the Systematic Assessment of Licensee Performance (SALP) process was criticized because it was too judgmental and inconsistent from Region to Region. It was heavily argued that “predictable and objective criteria” could not be developed. However, the existing Reactor Oversight Process, while not perfect, is far more predictable, using objective criteria that is a vast improvement over SALP.

I believe that the resource evaluation is misleading. I do not believe it appropriately factors in the resource savings that will be realized by having a definition and guidance for determining defense-in-depth adequacy. The development of a definition and adequacy guidance should start at high level that cuts across the entire agency. With this high level guidance, each program office can then expand to suit their unique needs. In this manner, we have a consistent and holistic approach which reinforces our strategic goals and is in line with our principles of good regulation.



**Global Expertise • One Voice**

# Direction of Risk-Informed Regulatory Framework

K. Raymond Fine (FirstEnergy Nuclear Operating Co.)

Vice-Chair, Risk Management Committee

November 4, 2015

# Overview

- Current State
- Successful Applications
- Challenges
- Recommended Path Forward/Conclusions

# Current State

- Current NRC Policy Statements, combined with industry and NRC experience, have established a workable structure for risk-informed applications
  - RG 1.174
  - RG 1.175
  - RG 1.176
  - RG 1.177
  - RG 1.178
- RG 1.200 defines an acceptable way to assess PRA technical adequacy using the ASME/ANS PRA Standard
- PRA Peer Review process independently assesses PRA technical adequacy
  - NEI PRA Peer Review Task Force is addressing:
    - Enhancements for reviewer qualifications
    - PRA Peer Review consistency



# Successful Applications

- Industry and NRC have developed successful applications under the current regulatory framework
  - Surveillance Frequency Control Program (TSTF-425)
  - Risk-Informed Completion Times (TSTF-505)
  - 10 CFR 50.69 Special Treatment Rule
  - Maintenance Rule
  - Mitigating Systems Performance Index (MSPI)
  - Integrated Containment Leak Rate Testing

# Challenges

- Challenges being addressed by industry and NRC Risk-Informed Steering Committees (RISCs):
  - PRA Technical Adequacy
    - Acceptance of new methods
    - Closure of Peer Review findings
    - PRA Peer Reviewer qualifications
  - Treatment of Uncertainty
    - Training for decision-makers
    - NUREG-1855 update
  - Incorporation of FLEX in risk-informed decision-making
    - Maximize safety benefits
    - Quantitative and qualitative assessments
    - Avoid unintended consequences
    - Enhanced guidance and pilots
  - Risk Metric Aggregation
    - PWROG pilot of EPRI 3002003116 (*Risk Aggregation for Risk-Informed Decision-Making*) in 2016

# Recommended Path Forward

- The PWROG agrees with the NRC staff to continue to pursue incremental improvements in current regulatory framework
  - A clear case has not been made that a new regulatory framework would be cost beneficial
  - Significant effort has been expended by both the industry and NRC
  - The current framework is well understood and has been used successfully
  - Leverage existing lessons-learned to improved the efficiency of the NRC risk-informed application review process
  - Improve consistency in licensee submittals and NRC reviews
  - Finalize 10 CFR 50.46a (Risk-Informed Emergency Core Cooling System)

# Conclusions

- The PWROG endorses the staff's recommendations in the draft SECY paper:
  - Maintain the NRC's current regulatory framework
  - NTTF Recommendation 1 Improvement Activities
    - A new category of events should be not established
    - A defense-in-depth policy statement is not needed
  - Development of an over-arching agency-wide policy statement is not needed
- The PWROG will continue to work with the staff to ensure appropriate methods are available to develop, implement, and regulate risk-informed applications and risk-informed regulations



**Global Expertise • One Voice**  
**[www.pwrog.com](http://www.pwrog.com)**



# Staff Recommendations Regarding a Risk Management Regulatory Framework

ACRS Meeting

November 4, 2015

# Outline of NRC Staff Presentation on Risk Management Regulatory Framework (RMRF)

- Background and Next Steps
- RMRF SECY paper
  - I. RMRF implementation options for power reactors
  - II. Re-evaluation of Improvement Activities 1 and 2
  - III. Agency-wide risk management policy statement
    - Changes made to paper during office concurrence
  - IV. Interrelationships between risk-informed activities
- Discussion of Risk-Informed Steering Committee oversight activities

# Background and Next Steps

- Significant level of public interaction on NUREG-2150 RMRF activities
  - 4 public meetings
  - 5 meetings with ACRS subcommittee
  - 3 written public comment periods
- White papers released in November 2013 and May 2015
- Met with Reliability and PRA subcommittee to discuss draft RMRF SECY paper on October 19, 2015
  - Staff positions were supported by industry stakeholders
- Full committee meeting today
- ACRS letter mid-November
- Staff response to ACRS letter mid-December
- RMRF SECY due to Commission by December 18, 2015



# Section I. RMRF Implementation Options for Power Reactors

Staff Considered 3 options:

1. Maintain current regulatory framework
2. Voluntary alternative risk-informed plant-specific licensing basis
3. NUREG-2150 recommended approach

# Power Reactor Option 1 – Maintain Current Framework

- No extensive revision of NRC's regulatory framework
- The current power reactor regulatory framework meets the RMRF criteria in NUREG-2150
  1. Mission – Public health and safety; common defense and security; protect the environment
  2. Objective – Manage the risks via current regulations, guidance, and oversight (including defense-in-depth, safety margins, single failure criterion, fail-safe design, reactor oversight program, etc.)
  3. Goal – Provide sufficient risk-informed and performance-based protections to ensure risks are acceptably low (utilizing Commission's Safety Goal Policy Statement and subsidiary risk metrics)
  4. Decisionmaking Process that includes monitoring and feedback (e.g., LIC-504, "Integrated Risk-Informed Decision-Making Process for Emergent Issues;" Regulatory Guide 1.174, "An Approach for Using Probabilistic Risk Assessment in Risk-Informed Decisions on Plant-Specific Changes to the Licensing Basis;" Generic Issues Program; Operating Experience Program; Accident Sequence Precursor Program; Industry Trends Program, etc.)

# Power Reactor Option 2 – Risk-Informed Alternative Licensing Basis

- Maintain existing generic regulatory structure
- Issue rule allowing licensees who upgrade PRAs to apply for approval of a risk-informed alternative licensing basis
  - Licensees allowed to select a plant-specific set of design changes/compliance issues of low risk-significance that would deviate from current deterministic requirements **and** must mitigate all known plant-specific risk vulnerabilities meeting NRC-specified criteria
  - Mandatory monitoring and feedback (as described in RG 1.174) to ensure changes in risk remain acceptable throughout the lifetime of the facility
- Staff has not developed implementation details for this approach -- implementation uncertainties:
  - Review all power reactor regulations and develop list of rules amenable to risk-informing under Option 2
  - Minimum scope/technical accuracy of “suitable” PRA for entry into the alternative approach
  - Certification/review of PRA
  - Selection and scope of permissible design changes
  - Process for staff review of design changes
  - Reporting and documentation requirements
  - Ensure transparency (NRC and public) of process

# Public Meeting on RMRF Option 2

## July 29, 2015

- Staff presentation
  - Additional details on Option 2
  - Thoughts/approach for “suitable” PRA
- Industry stakeholders still concerned about the lack of implementation details on Option 2
  - Industry stakeholders said that without explicit details of how the Option 2 process would work, it is very difficult to assess safety benefits and costs
  - Industry would not support the approach without more details

# Power Reactor Option 3 – Plant-Specific RMRF from NUREG-2150

- Issue regulation requiring PRAs and plant-specific licensing basis based on:
  - Plant-specific risk profiles
  - NRC-specified risk management objective
  - Enhanced criteria for determining adequacy of non-risk factors (defense-in-depth, safety margins, etc.)
- Based on the risk profile, licensees would implement the plant-specific licensing basis by:
  - Determining how the risk objective is met
  - Ensuring that the necessary protections are in place to meet the risk management goal
  - Demonstrating the adequacy of non-risk factors (defense-in-depth, safety margins, etc.)
  - Establishing the risk-informed decision-making process
  - Establishing the monitoring/feedback and reporting process

# Written Public Comments on RMRF Options for Power Reactors

## Option 1 - Maintain Current Regulatory Framework

- Four commenters addressed Option 1. All four recommended maintaining the current regulatory framework.

## Option 2 – Voluntary Alternative Risk-Informed Licensing Basis

- Three commenters addressed Option 2. All three expressed some level of interest but said the NRC had not developed sufficient implementation details to enable commenters to analyze potential costs and benefits.

## Option 3 – NUREG-2150 recommended approach

- Two commenters addressed Option 3. Neither supported Option 3 for currently operating reactors.
  - Approach was not viable
  - Although insufficient implementation details had been provided to evaluate its safety and cost benefits, Option 3 is unlikely to be justifiable for the current fleet of operating reactors

# Section I. RMRF Implementation Options for Power Reactors - Staff Recommendation

## Staff Conclusion:

- Do not pursue Option 2 at present time because industry and staff do not have resources to develop/support
- Do not pursue Option 3 for operating reactor fleet because modest potential safety benefits are unlikely to justify substantial implementation costs
- **Staff recommends Option 1** -- maintain current framework
  - Not a “do nothing” approach
  - All ongoing and planned risk-informed initiatives would continue
  - Staff will continue to make incremental risk-informed regulatory improvements whenever appropriate

## Section II. Staff Re-evaluation of NTTF

### Recommendation 1 Improvement Activities 1 and 2

#### Activity 1 – New design-basis extension category:

- Staff determined that creating new design-basis extension category is not necessary.
- Instead, staff will develop clear internal rulemaking guidance to ensure that new regulations properly specify all regulatory attributes necessary for requirements that exceed the existing design basis.

#### Activity 2 – Criteria for adequacy of defense in depth:

- While this effort could potentially succeed in establishing predictable, objective criteria for determining the adequacy of defense in depth for power reactor safety, the estimated resource requirements (6.3 FTE over a period of 3 to 4 years) are significant.
- It is possible that after spending these resources, the staff would be unable to establish predictable, objective criteria acceptable to the Commission.
- Based on current resource limitations, the staff recommends that the NRC should not undertake this activity at the present time.
- Staff will update defense-in-depth guidance in RG 1.174 as directed by Commission in SECY-11-0014 on Containment Accident Pressure



# Section III. Agency-wide Risk Management Policy Statement

- An agency-wide risk management policy statement could potentially improve and make more consistent the regulatory framework used for all program areas
- NRC requested public comments on two draft example policy statements (November 2013 and May 2015)
- Public comments were generally not supportive
  - On May 2015 draft, 1 of 10 commenters supported an agency-wide risk management policy statement
    - NRC programs can be appropriately risk-informed under the current policy and guidance
    - Use of NRC and licensee resources

## Staff Evaluation:

- Staff agrees with public commenters that NRC programs can be appropriately risk-informed without an agency-wide risk management policy statement
- Staff believes that it would not be appropriate to divert NRC and licensee resources away from more safety-significant activities
- Staff recommends **against** developing an agency-wide policy statement

# Office Concurrence Changes to RMRF SECY Paper

## SUMMARY OF RECOMMENDATIONS:

The NRC staff recommends that the Commission direct the staff to:

1. Maintain the existing regulatory framework for the nuclear power reactor safety program area. The NRC will continue its long-held commitment to the defense-in-depth concept; to the regulation of nuclear reactor issues beyond the traditional design-basis events, where appropriate; and to the inclusion of the defense-in-depth concept as an essential component of risk-informed regulation. All ongoing and planned risk-informed initiatives to enhance the existing regulatory framework would continue.
2. Refrain from developing an overarching, agencywide risk management policy statement. Ongoing staff activities to implement risk-informed approaches within NRC program areas will continue to move forward and are not impacted by the staff's recommendation against developing an overarching, agencywide risk management policy statement.

## Section IV. Interrelationships Between Ongoing Risk-Informed Initiatives

- In its SRM on SECY-13-0132 on Near-Term Task Force Recommendation 1, the Commission directed the staff to provide a “description of any interrelationships of ongoing risk-informed initiatives”
- Section IV of the SECY explains the interrelationships between ongoing risk-informed power reactor safety initiatives

# Risk-Informed Steering Committee Oversight

- **RISC Charter:**

- Provide **strategic** direction to the NRC staff to advance the use of risk-informed decision-making in licensing, oversight, rulemaking and other regulatory areas ....”

- **RISC Membership:**


- Chair, Director NRR
- Members: Deputy Office Directors from RES, NMSS, NSIR, NRO and RI RA

- **RISC Focus (to date):**

- PRA Technical Adequacy
- Treatment of Uncertainty in Decision Making
- PRA Credit for Mitigating Strategies
- RMRF

# Backup Slides

# Inter-relationships Between Ongoing Risk-informed Activities



\*NTTF Recommendation 1 was closed by SRM-SECY-13-0132; which directed staff to re-evaluate the objectives of Improvement Activities 1 (new category of events) and 2 (definition and criteria for defense-in-depth (DID)) as part of RMRF-related implementation activities.

# Section I. RMRF Implementation Options for Power Reactors - Staff Recommendation

## Generation IV reactor designs:

- The staff believes that the adoption of a risk-informed regulatory framework, similar in concept to an RMRF, would provide the greatest benefit for new reactor designs that employ non-traditional technologies (e.g., Generation IV designs). The staff will continue to engage stakeholders interested in pursuing such a risk-informed framework.

# Agency-wide Risk Management Policy Statement

- Organization of Agreement States provided comments:
  - Policy statement would be a useful way to provide the Commission's expectations for a Risk Management Regulatory Framework
  - "We cannot state or endorse the concept that there is a general understanding [in the radioactive materials program] of the terms *risk-informed* and *defense-in-depth*."
  - "[A] risk management approach is already being performed with our current regulatory system and IMPEP [Integrated Materials Performance Evaluation Program] process" to ensure adequate protection of public health and safety
  - Policy statement should say to "review current [risks and practices] and provide recommendations for enhancement."



# NUREG-2150 Hierarchy and Structured Decision-making Process





Figure ES-1 A Proposed Risk Management Regulatory Framework

# Improvement Activity 1- Establish Design-Basis Extension Category



# BWROG IRIR

## Future of PRA and Risk Management Regulatory Framework

November 4th, 2015

BWROG IRIR Chair

Robert Rishel (Duke Energy)-  
Director, Nuclear Engineering PRA



*BWR Expertise – Proven Solutions*

# Topics – BWROG Integrated Risk Informed Regulation (IRIR)



- BWROG near term vision of PRA
- BWROG Planned submittals 2016-2017
- BWROG IRIR Future PRA Applications
- BWROG PRA Technical Adequacy Peer Reviews
- PRA Technical Adequacy Question
- BWROG Concerns With Option 2 or 3
- Conclusions

# BWROG Near Term Vision of PRA



- PRA development is a continuing evolution
  - Incremental approach
  - Licensees continue develop new PRA hazard models
  - Dependent upon business need
- PRA model maintenance is a continuous process
  - Model upgrades as needed
  - Update PRA model consistent with plant design and operational changes
- PRA model development and maintenance costs have significantly increased

# BWROG Near Term Vision of PRA



- Concerns with over conservatism
  - Fire PRA
  - Concern with similar impact of Seismic PRA results
  - Impact ability to use risk informed applications
- Development and acceptance of new methods is slow and hinders PRA hazard model development

Current plans are to continue with current approach (Option 1)

# BWROG IRIR Planned Submittals 2016-2017



- Continue with Licensee Controlled Tech Spec Surveillance Frequency (Risk Informed Initiative 5b)
  - Approximately 6 BWR Licensees expect to submit 2015-2017
- Submit for Risk Informed Technical Specification Completion Time (Risk Informed Initiative 4b)
  - Approximately 8 BWR Licensees expect to submit 2015-2018
- Containment Extended ILRTs Appendix J
  - Expect most will apply as need dates approach

# BWROG IRIR Potential Future PRA Applications



- Extended Tech Spec Completion time for containment isolation valves
- Risk Informed SSC categorization
  - 10 CFR 50.69
- Use of Licensee PRA as a SPAR replacement



# BWROG PRA Technical Adequacy Peer Reviews



## Improvements made

- Incorporated NRC feedback on Peer Review process
- Greater emphasis on Peer Review Team Leader being a leader
- Training of peer review team leaders is occurring
- Improved licensee ownership of “being ready”
- Continue to ensure peer reviewers are technically knowledgeable
- Use of “working observers” as part of the training process.

# BWROG PRA Technical Adequacy Peer Reviews



## Improvements made

- Peer Review team expectations
  - Review 40% of the Supporting Requirements before site visit
- Use of licensee follow-up Peer Reviews has increased
  - Determine if F&Os resolved in some specific areas of weaknesses
- Industry Peer Review Task Force has provided some guidance on “what is technically acceptable” for limited number of Supporting Requirements

# PRA Technical Adequacy Question



Understanding the “Gap” between current PRA Peer Review and what would be needed for Option 2 or 3

- Limited resource issue
  - Same small group of individuals
- Use of objective criteria has same consistency issue
  - Individuals make determination of acceptability
- Concern with NRC staff members making individual judgments beyond ANS/ASME PRA Standard - R.G. 1.200 requirement
- Current process relies heavily upon “consensus” of Peer Review results

# BWROG Concerns With Option 2 or 3



- Projected benefits are not realized or achievement timeline stretches out
- Concerns with costs to achieve a PRA model that NRC staff determines is adequate
- NRC and Licensee interactions on specific technical elements PRA elements

# Conclusions



- Current Licensee staffing support the continued incremental increase in PRA
- Fire PRA has become a large consumer of resources limiting other work
- Continued concerns with conservatism in Fire PRA and the efforts required to remove the conservatism
- Licensee are continuously improving the technical adequacy of their PRAs models
- BWROG will continue to work with the industry (NEI/PWROG/EPRI/ANS-ASME) and NRC to make improvements in the PRA Peer Review process
- BWROG agree with NRC Staff on use of Option 1



# QUESTIONS



# **Advisory Committee on Reactor Safeguards Full Committee**

## **Davis-Besse Nuclear Power Station Final & Supplemental Safety Evaluation Report**

November 4, 2015

Rick Plasse, Project Manager  
Office of Nuclear Reactor Regulation

# Overview

- LRA Submitted by letter dated August 27, 2010
- Pressurized Water Reactor (PWR), Babcock & Wilcox nuclear steam supply system
- Operating license for NPF-3 expires April 22, 2017
- Located approximately 20 miles east of Toledo, OH



# Safety Review Results

- Safety Evaluation Report (SER) with Open Items was issued July 2012
- ACRS License Renewal Subcommittee Meeting held September 19, 2012
- Final SER was issued September 2013
- Supplement to SER was issued August 2015
- ACRS 2<sup>nd</sup> License Renewal Subcommittee Meeting held September 23, 2015

# Open Item B.1.4-1: Closed

## OI B.1.4-1 Operating Experience

- **Issue:** During review, LR-ISG-2011-05, “Ongoing Review of Operating Experience,” was issued
- **Basis for closure:** Applicant provided additional information that addressed the guidance in LR-ISG-2011-05

Applicant will enhance AMPs or develop new AMPs when necessary to ensure effects of aging are adequately managed

# Open Item 4.2-1: Closed

## OI 4.2-1 Reactor Vessel Neutron Embrittlement (SER Section 4.2.2):

- **Issue:** Reactor vessel welds with unknown initial upper shelf energies (USE) require an equivalent margins analysis (EMA), per §Part 50, App G, requirements
- **Basis for closure:** EMA submitted and approved to demonstrate that the welds will have adequate margins of safety on USE, as required by §Part 50, App. G
- EMA provides an acceptable basis to accept the USE TLAA under §54.21(c)(1)(ii).

## Open Item 4.2.4-1: Closed

### OI 4.2.4-1 Pressure-Temperature (P-T) Limits:

- **Issue**: Methodology (Report BAW-10046-A, Rev. 2) invoked by Tech. Spec. 5.6.4 for calculating P-T limits may not assess potentially limiting reactor vessel non-beltline locations
- **Basis for closure**: Applicant demonstrated Report BAW-10046, Rev. 2, appropriately accounts for potentially limiting reactor vessel non-beltline locations near geometric discontinuities.
- TS basis remains valid to accept under §54.21(c)(1)(iii).

# Safety Review Results

- Final SER issued September 2013 (all open items were closed): 44 AMPs total

Staff Disposition of Program	Existing AMPs	New AMPs
Consistent with the GALL Report	9	5
Consistent with enhancements	11	2
Consistent with exceptions	2	-
Consistent with both enhancements and exceptions	5	-
Plant specific	4	6
Subtotals:	31	13

# SER Supplement 1

- Supplement 1 to SER issued August 10, 2015
  - Reactor Vessel Internals Inspection Plan and Program
  - Annual Updates in 2013, 2014, and 2015
  - Updated information and commitments in response to recent industry operating experience
  - New plant specific program Service Level III Coating and Linings Monitoring Program
  - Steam Generator Replacement (Spring 2014)
  - Shield Building Laminar Cracking Propagation
- Conclusion is unchanged
- List of Commitments in Appendix A
  - Several commitments completed and reviewed by NRC staff



# **Shield Building Monitoring Program (OI 3.0.3.2.15-1)**

- **Shield Building Monitoring Program to manage aging effects on laminar cracks; preventive protective coating applied. Plant-specific prevention & condition monitoring AMP, supplements Structures Monitoring Program**
- **Scope includes SB Wall Concrete & Reinforcing Steel; SB exterior concrete coatings**
- **Periodic visual inspections of representative sample of core holes; Visual inspections will be supplemented with NDE (i.e., Impulse Response (IR) Mapping)**
- **Opportunistic visual inspections of rebar near laminar cracking**
- **Periodic visual inspections of exterior coating every 5 years & coating reapplied every 15 years**
- **Personnel qualifications per ACI Report 349.3R Ch. 7**

# Shield Building Monitoring Program (contd...)

## Operating experience of crack propagation:

- AMP considers and incorporates future operating experience, as necessary
- Accordingly, the applicant revised AMP to incorporate plant-specific OpE of laminar crack propagation discovered in 2013 & 2015, attributed to “ice-wedging” phenomenon
- Revised AMP increased inspection sample size of core holes, increased inspection frequency, and conducts IR to confirm extent of crack propagation



# Shield Building Monitoring Program (contd...)

## Adequacy of sample size and distribution:

- Representative sample for inspection consists of a minimum of 28 core hole locations, with provisions for consideration of past evidence of propagation and expanding inspection sample.
- 14 are cracked covering the spectrum of locations with highest prevalence of cracking and a range of observed crack widths; includes the 3 maximum observed crack widths, to monitor crack width & planar limit of propagation.
- 14 are uncracked but generally located near areas of known cracking providing ability to monitor propagation including 5 leading edge bores to monitor limits of recent planar propagation.

# Shield Building Monitoring Program (contd...)

## Acceptance Criteria for Core Bore Inspection Findings:

- Need for corrective action evaluated in Corrective Action Program using evaluation hierarchy in Figure 5.1 of ACI 349.3R, if any of below criteria not met.

**Qualitative:** *Cracking remains passive*

- No discernible change in existing cracks (width, planar size)
- No Indication of new cracking in bores or from IR mapping

**Quantitative:** *Bounded by qualitative criteria; and bounded by SB calculations-of-record*

- Crack width does not exceed 0.013 inch
- Extent of circumferential planar crack limit does not exceed that in SER Table 3.0.3.3.9-2.

# ACI 349.3R Evaluation Hierarchy




Fig. 5.1—Evaluation criteria hierarchy.

# Shield Building Monitoring Program – Conclusion

☐ **In summary, the staff finds the SBMP AMP acceptable because:**

- Laminar cracks are inspected at a 1 year interval and this interval will not be progressively incremented to 2/4 years unless cracks become passive
- A representative sample of no less than 28 core bores will be inspected at every inspection to effectively monitor crack width and planar limit
- The use of visual inspections and Impulse response testing can effectively detect changes in laminar cracking
- Inspection findings will be evaluated by qualified personnel using the evaluation procedure in ACI Report 349.3R
- The acceptance criteria of crack being “not passive” would trigger further evaluation under the corrective action program if inspection findings indicate discernable change in the cracks

## **Shield Building Monitoring Program – Conclusion (contd..)**


- ☐ Based on the AMP attributes discussed in the previous slides, staff concludes that through implementation of the AMP, the applicant will be able to adequately monitor the cracks, perform structural evaluations, and take timely corrective actions, if necessary, prior to loss of function
- ☐ Staff thus concludes that there is reasonable assurance that aging effects on the shield building laminar cracking will be adequately managed by the Shield Building Monitoring Program, such that intended functions will be maintained during the period of extended operation.
- ☐ OI 3.0.3.2.15-1 is closed and staff evaluation is documented in SER/SSER Section 3.0.3.3.9.

# Conclusion

On the basis of its review, the staff determines that the requirements of 10 CFR 54.29(a) have been met for the license renewal of Davis-Besse Nuclear Power Station

# Davis-Besse Nuclear Power Station License Renewal Application

**Advisory Committee on Reactor Safeguards  
Full Committee Meeting  
November 4, 2015**



# AGENDA

- **Introductions & Opening Remarks**
- **Background**
- **License Renewal Application Description**
- **Closure of Open Items**
- **Containment Vessel Inspections**
- **Summary & Closing Remarks**



# Introductions

- **Brian Boles – Site Vice President**
- **Ken Byrd – Director, Site Engineering**
- **Cliff Custer – Fleet Project Manager**
- **Steve Dort – Site Project Coordinator**
- **License Renewal Core Team Members**
- **Aging Management Program Owners and Subject Matter Experts**

# Background – Site



## Davis-Besse Site

- Southwestern shore of Lake Erie in Ottawa County, Ohio
- ~20 miles East of Toledo, Ohio
- 954 Acre Site
  - 733 acres leased to US Government as wildlife refuge
  - 221 acres for Plant structures & equipment

# Background – Plant

## ■ Design

- Pressurized Water Reactor
- Babcock & Wilcox nuclear steam supply system with raised-loop design
  - 2817 Megawatts thermal / 908 Megawatts electrical rating
- Bechtel Engineering construction management
- Facility Operating License expires April 22, 2017

# Background – Upgrades

## ■ Equipment Improvements


- Replaced Steam Generators, related Feedwater piping & Reactor Coolant System hot legs
- Replaced Reactor Head
- Installing Emergency Feedwater System



# License Renewal Application (LRA) – Details

- **Developed to NUREG-1801 Rev 1, reviewed to Rev 2**
  - AREVA; FENOC core team
  - Site review and concurrence
  - Industry peer review prior to submittal
- **44 Aging Management Programs (AMPs)**
  - 13 New
  - 31 Existing
- **55 License Renewal commitments**

# LRA – Review Timeline



# LRA – Closure of Open Items

- **4 Open Items were addressed and closed in the Safety Evaluation Report (Sept 2013) [Section 1.5]**
  - Operating Experience
    - Developed a process to align with LR-ISG-2011-05, “Ongoing Review of Operating Experience”
  - Reactor Vessel Neutron Embrittlement
    - Provided Equivalent Margins Analyses for the RV shell region weld materials
  - Pressure-Temperature (P-T) Limits
    - P-T limit curves are and will be developed for all ferritic materials of the reactor coolant pressure boundary
  - Shield Building
    - Developed a plant-specific Shield Building Monitoring Program



## OI B.1.4-1: Operating Experience (OE)

- **Systematic review of plant-specific and industry OE concerning age-related degradation and aging management**
  - Aging Management Evaluation (AME) checkbox added to Corrective Action Program and OE Program to flag age-related degradation
  - Evaluate material-environment combinations and AMPs
  - Will enhance AMPs or develop new AMPs based on AME results
- **Process will ensure the continued effectiveness of the license renewal aging management programs**



# OI 4.2-1: RV Neutron Embrittlement

## ■ **RV Beltline Upper-shelf Energy (USE) Evaluation**

- Analysis using generic mean value of 70 ft-lb to project 52 EFPY USEs considered not statistically conservative
- Selection of lowest value resulted in 52 EFPY USE of < 50 ft-lb
- 10 CFR 50 Appendix G requires end-of license USE to be no less than 50 ft-lb, or demonstrate that lower values of USE will provide margins of safety against fracture, as determined by equivalent margins analysis (EMA)

## ■ **FENOC Response**

- In accordance with 10 CFR 50 Appendix G, FENOC elected to qualify welds by EMA
- EMA demonstrated adequate margin of safety against fracture for all beltline welds

# OI 4.2.4-1: P-T Limits

## ■ RAI 4.2.4-1 Request

- Describe how P-T limit curves to be developed for use in the period of extended operation, and methodology used to develop these curves, considered all Reactor Vessel materials (beltline and non-beltline) and lowest service temperature of all ferritic reactor coolant pressure boundary materials

## ■ RAI 4.2.4-1 Response

- Davis-Besse P-T Limits generated in accordance with 10 CFR 50 Appendix G and R.G. 1.99 Rev. 2 using methods described in approved topical report BAW-10046A
- BAW-10046A considered all ferritic materials (beltline & non-beltline material)

# OI 3.0.3.2.15-1: Shield Building


## ■ Request

- Develop an AMP to monitor crack changes so that the safety function of the Shield Building is not affected during the period of extended operation



## ■ Discussion

- Describe the Shield Building Initial Condition
- Provide a timeline of Shield Building activities
- Provide description of monitoring program
- Provide basis for conclusion that Shield Building condition is acceptable with continued monitoring


# Shield Building



# Shield Building



**Left boundary of RVCH opening**



# Shield Building Timeline

**October 2011** - Laminar cracking discovered in Shield Building access opening

**November, 2011** - Analysis completed to establish operability of Shield Building

**May, 2012** – Root Cause completed

**July, 2012** – Rebar testing completed to establish capacity in regions of laminar cracking

**August, 2012** – First inspection of shield Building completed with no issues identified

**October, 2012** – Completed exterior coating of Shield Building

**August, 2013** - Design Calculation for Shield Building approved

**August, 2013** - Condition monitoring identified crack propagation

**June, 2014** - Completed Root Cause for crack propagation (ice-wedging)

**May, 2015** – Calculation to define crack propagation limits approved

**August, 2015** - Completed evaluation for concrete humidity

**October, 2015** -AMP Rev. #5 (Impulse Response addition)



# Shield Building Monitoring Program


- **28 Core bores will monitor both cracked and uncracked areas**
- **Fourteen areas of potential crack propagation**
  - Six core bores located in areas adjacent to known cracks to monitor crack propagation (Shoulders 4, 8, 9, 10, 11, and 12)
  - Four core bores monitoring leading edge where crack propagation has been identified (Shoulders 5, 7, 13, and 15)
  - Three core bores in areas greater than 780 feet
    - One core bore monitoring leading edge
  - One core bore in Main Steam Line penetration areas

# Shield Building Monitoring Program

- **Fourteen core bores in various areas of laminar cracking to monitor changes in crack characteristics**
- **Frequency of Inspection**
  - Yearly inspections if changes are noted
  - If yearly inspections result in no changes, then inspection intervals increase to every other year
- **Extent of cracking is well understood and matches the Monitoring Program**



# Shield Building Monitoring Program



# Impulse Response (IR) Mapping


- **Shield Building Monitoring Program modified to require IR mapping**
  - Where crack propagation is identified, IR mapping (minimum 100 sq ft) will be used to help characterize extent of crack propagation
- **Additional IR mapping as follows:**
  - Two IR locations (10 ft x 10 ft) in known crack areas and away from existing core bores to monitor any changes in leading edges
  - Two IR locations (10 ft x 10 ft) not currently known to contain laminar cracking and away from existing core bores to establish cracking has not expanded into these areas
  - To be performed in 2016 and 2018

# Shield Building Monitoring Conclusions

- **Test results & evaluations suggest crack propagation from ice wedging will decrease as the Shield Building dries out**
- **Margin in the structural calculation is sufficient to allow continued monitoring during the time building is drying**
- **Margin in the structural calculation provides sufficient time to develop additional actions if required**
- **Monitoring scope and frequency is appropriate for the identified condition**

# Containment Vessel Inspections

## Shield Building / Containment Vessel Foundation



# Containment Vessel Inspections

## ■ Ground Water Intrusion in Sand Pocket

- Containment Vessel 1.5" carbon steel plate
- 5 representative locations were investigated
- 45 total ultrasonic test (UT) readings
- All UT readings at or below the grout interface were above required mill tolerance thickness

## ■ Therefore, sand pocket seepage has negligible effect on the Containment Vessel






Figure 1. Sand Pocket Area



# Containment Vessel Inspections

## Refueling Canal Leakage – Effects on Containment Vessel



### Conclusions

- ✓ No signs of water
- ✓ UT reading > 1.5"

# Closing Remarks

- **Application has received a thorough staff review**
- **Current with Interim Staff Guidance expectations**
- **Implementation efforts are in progress**

# Questions?







# Backup Information

# Davis-Besse Site 50-mile Radius



# Containment Vessel Examination (exterior)





# Containment Vessel Examination (exterior)



# Containment Vessel Examination (interior)






# Refuel Canal Leakage Mitigation




# Refuel Canal Leakage Mitigation

## Repair Options



# Davis-Besse Groundwater Monitoring Wells






# Intake Canal Slope Repair

## ■ License Renewal Commitment #48

- Existing slope protection rock removed
- Soil re-graded to 2:1 slope
- Slope protection rock added at 4:1 slope



# Service Water System Supports



# Service Water System Supports



# Service Water System Supports

## ■ **Surface rust / discoloration was noted**



- Condition was evaluated in a Condition Report
  - Condensation from Service Water pipes dripped on support, creating surface rust
  - Structural integrity of support not challenged
  - Support deemed acceptable for continued service
- Evaluated per ASME Section XI, IWF-3410(b)(5)
  - “Roughness or general corrosion which does not reduce the load bearing capacity of the support...” [non-relevant condition]
- InService Inspection (ISI) program
  - 10-year Interval
  - Next examination of this component scheduled in 19RFO

# Small Bore Piping Inspection Results

Weld	Orientation	Defect Location (Circumferential)	Percent Through Wall	Defect Notes
SG-2-CHD-29 *	Vertical	180 *	1-5 % *	In weld. Near socket interface. *
SG-1-HLV-3C	Horizontal	180	1-5 %	In weld near triple point.
SG-2-CHD-23	Horizontal	0	40-50 %	In weld and socket base material near triple point.
SG-1-CHD-8	Vertical	270	40-50 %	In weld and socket base material near triple point.
		270	55-65 %	In weld and pipe base material near triple point.
SG-2-CHD-24	Horizontal	180	40-50 %	In weld and pipe base material near triple point.
		270	55-65 %	In weld near triple point.
* NOTE * - Examination of this weld noted OD indications. This was evaluated to be a fabrication flaw.				



# Small Bore Piping Inspection Results



Dimensioned Image of Defect in Section 24-B2


# Small Bore Piping Inspection Results

Zoomed in Dimensioned Image of Defect  
in Section 24-B2

Tortuous and branched cracked  
paths indicative of SCC.


200  $\mu\text{m}$

# Switchyard Breaker Arrangement (current)






# Switchyard Breaker Arrangement (original)





# Switchyard Foundations

- Degradation noted in the form of concrete cracking and spalling
- FENOC Order 200652044 written for rework of foundations
- FENOC walkdown completed 9/1/15
- Order start date 9/14/15



# Access Openings in the Shield Building



# Shield Building Analysis and Margin

## ■ **Evaluation of Shield Building with Observed Cracking**

- Provided reasonable assurance the Shield Building will perform design functions
- Considered reinforcement ineffective in regions of laminar cracking
- Calculations were reviewed by the NRC prior to restart

## ■ Seismic II/I Evaluation of Flute Shoulder

- 
- SHOULDER
- FLUTE
- 3/4" CHAMFER (TYP.)
- 2' 10 1/2"
- 2' 2 1/2"
- 8' 12"
- 17' 11"
- 8' 12"
- 3" CHAMFER (MIN.)
- 3" CHAMFER (MIN.)
- POINT OF TANGENCY
- 3" CL. (MIN.)

# Spalling outside the Shoulder Areas

## ■ **Spalling of large sections**

- 11 of 13 core bore indicate the crack is within or behind the horizontal or vertical rebar
- Concrete is firmly attached to the reinforcing steel
- Reinforcing steel mat capacity is sufficient to restrain large sections of concrete from falling

## ■ **Localized spalling**

- Safety related structures are design for a tornado missile impact
- Equivalent impact energy would equal a 6 ft. X 6 ft. X 3 inch section of concrete
- Tornado missile would bound any localized spalled area

# Root Cause Overview

## ■ Performance Improvement (PII)

- Established independent team of experts
- Established a comprehensive Failure Modes Analysis
- Investigated the design, materials, construction methods, and present day operational conditions
- Performed concrete tests
- Performed analyses
- Identified root cause

# Investigation


- **Impulse Response (IR) testing methodology used to investigate extent of crack**





# Investigation (cont.)


- Core bores validated IR testing results to determine crack depth and to determine crack width
- Cracks are very tight



# Shield Building Concrete Tests

## ■ 16 samples were tested for carbonation

- Average depth of carbonation is 8.57 mm (0.337 inches)
- Maximum average 11.7 mm ( 0.46 inches)
- Typical for concrete 40 years old



# Shield Building Root Cause

## ■ Performance Improvement International (PII)

- 36 concrete cores tested - Concrete is sound
- Normal building stress are very low
- Correlation between crack location and the physical layout of the reinforcing steel
- Ontario Ministry of the environment Study address similar condition on their above ground water tanks in Ontario
- Extreme environment event has the condition to create stresses beyond normal design
- Validated by complete computer modeling

# Moisture Intrusion and Low Temperatures

## ■ January 25-27, 1978, was the worst in terms of:

- Moisture
- Winds
- Temperature
- Duration
- Pressure



# Shield Building Root Cause

- **Blizzard of 1978 had the conditions to create cracking**
  - High winds and driving rain for three days
  - Sudden drop in temperatures to near zero degrees
- **Root Cause:**
  - Lack of water sealant on the concrete exterior
- **Contributing Causes:**
  - Shoulder reinforcing details (discontinuity and no radial rebar)
  - High density of rebar spacing
  - High moisture, severe wind, and low temperature conditions



# Rebar Splice Capacity Tests

- Tests were developed and conducted at two nationally recognized universities
- Professors are industry experts and are American Concrete Institute (ACI) Committee members




# Rebar Splice Capacity Tests

## ■ Conservative Test set Up

- Two different test methods
- Lap splices side by side, spaced 6 inches apart


## ■ Purdue Tests Results

- All bars achieved yield



## ■ Kansas Tests Results

- Achieved near design capacity



# Rebar Splice Capacity Tests

- **Based on the Test Results and conservative nature of the test**
- **Design capacity can be used for the Shield Building analysis**
- **Prudent to reduce reinforcing steel capacity by 8%**
- **Applied this reduction factor to the structural calculation**




# Shield Building Calculations

## ■ Shield Building Design Calculation

- Design Calculation for Shield Building for existing condition
- Analysis performed with a three dimensional finite element analysis using ANSYS
- Capacity of Lap Splices based on test results included
- Seismic loads from original design used based on evaluation of no adverse effects of laminar cracks on seismic analysis results
- Results showed Interaction of 0.76 for rebar and 0.81 for concrete

# Long Term Monitoring

- Monitoring in 2013 identified changes in eight of eighty core bores inspected
- IR also confirmed changes in condition




# Crack Propagation Cause Investigation

- Core bore extracted from an area of crack propagation
- Cracked surface is different from all the previous samples.
  - Noticeable ridges – stepped fracture planes



Original crack surface (2011)




Crack propagation surface 2013

# Crack Propagation Cause Investigation

- **Cause determined to be Ice-Wedging**
- **Ice-Wedging requires three conditions**
  1. Pre-existing crack
    - 2011 identified condition
  2. Freezing Temperatures
    - In-situ bore measurements determine that freezing temperatures have occurred.
    - Freeze damage evident in extracted samples
  3. Water accumulation at the crack location
    - Increase in relative humidity of the conc

# Crack Propagation Cause Investigation

- **Relative Humidity accumulation increase in the near surface and crack locations between samples collected in 2011, and 2015**
- **Building was coated in summer of 2012**






# Crack Propagation Cause Investigation

## ■ Ice-Wedging – Laboratory Simulation

- Used existing core from the Shield Building
- Replicates failure surface & crack growth
- Identifies crack growth at approximately ½ inch / freeze cycle



# Relative Humidity of the Shield Building


- **Core bore samples tested for relative humidity in 2011, 2013 and 2015**
- **Relative Humidity (RH) near external surface is high**
- **RH gradient drives moisture toward the inner surface**
  - If internal surface of a test sample is exposed to dry environment the drying out process can take place quickly
- **Higher inner surface (annulus) temperature drives moisture toward coating of the building**
  - Moisture can not freely evaporate at external surface
  - Moisture accumulates under the coating

# Shield Building Moisture Evaluation

## ■ Method



- Determined moisture diffusivity of concrete using samples from Shield Building
- Determined temperature distribution in the wall using plant and meteorological data
- Evaluated concrete RH considering temperature and moisture diffusivity

## ■ Results





# Driving Forces for Moisture Transfer in Concrete




# Shield Building Calculations

## ■ Shield Building Crack Propagation Calculation


- Determined an approximate extent of cracking for which the seismic loads from the original design remain valid
- Additional margin is available, but not quantified at this time

# Shield Building Margin



# Shield Building Margin

- Region 2 analyzed for 100% of the area as cracked
- Region 3 analyzed for 50% of the area cracked (actual cracked area from IR map approximately 12%)
- Therefore margin can be established as  $50\% - 12\% = 38\%$




Region	Elevation	% of areas cracked from IR Map	% of areas cracked from calculation C-CSS-099.20-069	% of Margin
1	801-812.75	N/A (Dome)	N/A (Dome)	N/A
2	774.5-801	38	100	62
3	643-774.5	12	50	38
4	565 - 643	1	20	19






# Shield Building Margin




- n **Margin can be established as follows:**
  - Region 3 = Consist of 59,438 ft<sup>2</sup>
  - 38% margin equates to 22,586 ft<sup>2</sup>
  - Region 3 has approximately 1300 linear ft. where cracks can propagate
  - Crack propagation rate is approximately 0.75 ft. per year
  - One year crack growth equals to:  
1300 linear ft. x 0.75 ft. = 975 ft<sup>2</sup> per year
  - Margin = 22,586 ft<sup>2</sup> / 975 ft<sup>2</sup> per year
  - Margin = approximately 23 years
- n **Conservative number because:**
  - Not all areas are cracking
  - Concrete is expected to dry out in 2-8 years

# 80 Core Bores Locations




# Shoulder Area Reinforcing Details



- n Shoulder areas were evaluated for design loads
- n Shoulders consist of #8 rebar (area = 0.79 in<sup>2</sup>) spaced 12" vertically
- n Required area of reinforcing steel = 0.089 in<sup>2</sup> << 0.79 in<sup>2</sup> (Area provided )
- n Margin of Safety is 4.5




# Crack Depth in the Shield Building Barrel






# Shield Building by Regions



# Crack Growth Rate



- **2011-2013 Crack Growth**

$$1.5 \text{ ft} / 2 \text{ years} = 0.75 \text{ ft./yr.}$$

- **2013-2015 Crack Growth**

$$1.5 \text{ ft} / 2 \text{ years} = 0.75 \text{ ft./yr.}$$

# Structural Margin

- **The controlling load combinations using the Allowable Working Stress are:**
  - Circumferential reinforcement – outside face: 0.76
  - Meridional reinforcement – outside face: 0.75
  - Circumferential reinforcement – inside face: 0.83
  - Meridian reinforcement – inside face: 0.88
  - Concrete: 0.81 of design allowable

# License Amendment Request

- **ACI Code provides no guidance on laminar cracking**
- **ACI Code does provide guidance on evaluating conditions not addressed in the Code**
  - Rigorous analysis, sound engineering principles, and specific testing as examples
- **Design Calculation documents Shield Building will perform its design function**
- **NRC Inspection 2014-008-01 resulted in 10CFR50 violation**
  - Change in methodology using ANSYS software
- **To Resolve the NRC violation**
  - Licensee is revising 50.59 Evaluation and will submit LAR after its spring outage (mid 2016)

# Root Cause – Exhibit 61 – Page 12




Figure 9 – Radial Stress (psi) during the Blizzard of 1978; Deformation Scale Factor 500X




Figure 10 – Hoop Stress (psi) during the Blizzard of 1978; Deformation Scale Factor 500X

- n **550 psi is the maximum radial stress**
  - No radial rebar to resist the load
  - **ACI Modulus of Rapture is  $7.5\sqrt{f_c'}$  or  $7.5\sqrt{5000 \text{ psi}} = 535 \text{ psi}$**
- n **1200 psi is the maximum hoop stress**
  - Hoop reinforcing bars  
**#11 bars (1.4 sq in) every 12 inches**

# Shield Building Monitoring Program

## ■ Exterior Coating

- Shield Building Wall, Dome, and Emergency Air Lock Enclosure walls inspected visually
- Acceptance criteria is ability of coating to continue to be effective
- Five year inspection interval
- Recoat the exterior surfaces in 15 years

## ■ Rebar

- Visually inspect when exposed
- Acceptance criteria is no loose flaky rust or reinforcement section loss



# Fracking-induced Earthquakes in Ohio

- Most horizontal fracking is near the Pennsylvania and West Virginia state lines in the Marcellus shale region
- Davis-Besse is over 125 miles from the Marcellus shale region
- Northwest Ohio does not have a shale formation conducive to horizontal fracking
- Fracking-induced earthquakes are not a concern at Davis-Besse



Potential Marcellus in Ohio      Potential Utica in Ohio

No higher resolution available.

[OhioShaleMap.jpg](#) (305 × 337 pixels, file size: 21 KB,

# Annulus Water Analysis

- **Water samples from annulus in sand pocket area**
- **2005-2014 Groundwater Chemical Analysis Average**
  - pH 10.32
  - Sulfate 1881.7 (mg/L) > 1700 max
  - Chloride 1665.3 (mg/L) < 2870 max