



Entergy Nuclear Northeast
Entergy Nuclear Operations, Inc.

James A. FitzPatrick NPP
P.O. Box 110
Lycoming, NY 13093
Tel 315-349-6024 Fax 315-349-6480

Brian R. Sullivan
Site Vice President – JAF

JAFP-15-0135
November 23, 2015

United States Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D.C. 20555-0001

Subject: LER: 2015-006-00, Secondary Containment Differential Pressure
Excursion

James A. FitzPatrick Nuclear Power Plant
Docket No. 50-333
License No. DPR-59

Dear Sir or Madam:

This report is submitted in accordance with 10 CFR 50.73(a)(2)(v)(C).

There are no commitments contained in this report.

Questions concerning this report may be addressed to Mr. Chris M. Adner, Regulatory Assurance Manager, at (315) 349-6766.

Sincerely,

A handwritten signature in black ink, appearing to read "BRS", with a horizontal line extending to the right.

Brian R. Sullivan
Site Vice President

BRS/CMA/ds

Enclosure(s): JAF LER: 2015-006-00, Secondary Containment Differential Pressure Excursion

cc: USNRC, Region 1
USNRC, Project Directorate
USNRC, Resident Inspector



LICENSEE EVENT REPORT (LER)

Estimated burden per response to comply with this mandatory collection request: 80 hours. Reported lessons learned are incorporated into the licensing process and fed back to industry. Send comments regarding burden estimate to the FOIA, Privacy and Information Collections Branch (T-5 F53), U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, or by internet e-mail to Infocollects.Resource@nrc.gov, and to the Desk Officer, Office of Information and Regulatory Affairs, NEOB-10202, (3150-0104), Office of Management and Budget, Washington, DC 20503. If a means used to impose an information collection does not display a currently valid OMB control number, the NRC may not conduct or sponsor, and a person is not required to respond to, the information collection.

1. FACILITY NAME James A. FitzPatrick Nuclear Power Plant	2. DOCKET NUMBER 05000333	3. PAGE 1 OF 3
---	-------------------------------------	--------------------------

4. TITLE
Secondary Containment Differential Pressure Excursion

5. EVENT DATE			6. LER NUMBER			7. REPORT DATE			8. OTHER FACILITIES INVOLVED	
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REV NO.	MONTH	DAY	YEAR	FACILITY NAME	DOCKET NUMBER
09	22	2015	2015	006	00	11	23	2015	N/A	N/A
									FACILITY NAME	DOCKET NUMBER
									N/A	N/A

9. OPERATING MODE	11. THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR §: (Check all that apply)			
1	<input type="checkbox"/> 20.2201(b)	<input type="checkbox"/> 20.2203(a)(3)(i)	<input type="checkbox"/> 50.73(a)(2)(i)(C)	<input type="checkbox"/> 50.73(a)(2)(vii)
	<input type="checkbox"/> 20.2201(d)	<input type="checkbox"/> 20.2203(a)(3)(ii)	<input type="checkbox"/> 50.73(a)(2)(ii)(A)	<input type="checkbox"/> 50.73(a)(2)(viii)(A)
	<input type="checkbox"/> 20.2203(a)(1)	<input type="checkbox"/> 20.2203(a)(4)	<input type="checkbox"/> 50.73(a)(2)(ii)(B)	<input type="checkbox"/> 50.73(a)(2)(viii)(B)
	<input type="checkbox"/> 20.2203(a)(2)(i)	<input type="checkbox"/> 50.36(c)(1)(i)(A)	<input type="checkbox"/> 50.73(a)(2)(iii)	<input type="checkbox"/> 50.73(a)(2)(ix)(A)
10. POWER LEVEL	<input type="checkbox"/> 20.2203(a)(2)(ii)	<input type="checkbox"/> 50.36(c)(1)(ii)(A)	<input type="checkbox"/> 50.73(a)(2)(iv)(A)	<input type="checkbox"/> 50.73(a)(2)(x)
	<input type="checkbox"/> 20.2203(a)(2)(iii)	<input type="checkbox"/> 50.36(c)(2)	<input type="checkbox"/> 50.73(a)(2)(v)(A)	<input type="checkbox"/> 73.71(a)(4)
	<input type="checkbox"/> 20.2203(a)(2)(iv)	<input type="checkbox"/> 50.46(a)(3)(ii)	<input type="checkbox"/> 50.73(a)(2)(v)(B)	<input type="checkbox"/> 73.71(a)(5)
	<input type="checkbox"/> 20.2203(a)(2)(v)	<input type="checkbox"/> 50.73(a)(2)(i)(A)	<input checked="" type="checkbox"/> 50.73(a)(2)(v)(C)	<input type="checkbox"/> OTHER
	<input type="checkbox"/> 20.2203(a)(2)(vi)	<input type="checkbox"/> 50.73(a)(2)(i)(B)	<input type="checkbox"/> 50.73(a)(2)(v)(D)	Specify in Abstract below or in NRC Form 366A

12. LICENSEE CONTACT FOR THIS LER

LICENSEE CONTACT Mr. Chris M. Adner, Regulatory Assurance Manager	TELEPHONE NUMBER (Include Area Code) 315-349-6766
--	--

13. COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT

CAUSE	SYSTEM	COMPONENT	MANU-FACTURER	REPORTABLE TO EPIX	CAUSE	SYSTEM	COMPONENT	MANU-FACTURER	REPORTABLE TO EPIX

14. SUPPLEMENTAL REPORT EXPECTED	15. EXPECTED SUBMISSION DATE	MONTH	DAY	YEAR
<input checked="" type="checkbox"/> YES (If yes, complete 15. EXPECTED SUBMISSION DATE) <input type="checkbox"/> NO		01	29	2016

ABSTRACT (Limit to 1400 spaces, i.e., approximately 15 single-spaced typewritten lines)

On September 22, 2015 at 17:03, with James A. FitzPatrick Nuclear Power Plant operating at 100 percent power, the Emergency and Plant Information Computer (EPIC) indicated a spike in Secondary Containment (SC) differential pressure (d/P) during performance of a surveillance test associated with automatic isolation of SC and initiation of the Standby Gas Treatment System. Per the plant data systems SC d/P exceeded the Technical Specification (TS) allowed value, and then immediately trended negative following auto-start of one of the trains of Standby Gas Treatment.

The time period that SC d/P was greater than the TS allowed value is reportable pursuant to 10 CFR 50.72(b)(3)(v)(C) and 10 CFR 50.73(a)(2)(v)(C), as an event or condition that could have prevented fulfillment of a safety function. SC was operable following reestablishment of greater than or equal to 0.25 inches of water vacuum, and remains operable.

Similar events that are potentially reportable were identified during preparation of this report. A comprehensive listing of the reportable events, causal information, and corrective actions will be provided in the supplemental report.



**LICENSEE EVENT REPORT (LER)
CONTINUATION SHEET**

Estimated burden per response to comply with this mandatory collection request: 80 hours. Reported lessons learned are incorporated into the licensing process and fed back to industry. Send comments regarding burden estimate to the FOIA, Privacy and Information Collections Branch (T-5 F53), U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, or by internet e-mail to Infocollects.Resource@nrc.gov, and to the Desk Officer, Office of Information and Regulatory Affairs, NEOB-10202, (3150-0104), Office of Management and Budget, Washington, DC 20503. If a means used to impose an information collection does not display a currently valid OMB control number, the NRC may not conduct or sponsor, and a person is not required to respond to, the information collection.

1. FACILITY NAME	2. DOCKET	6. LER NUMBER			3. PAGE
James A. FitzPatrick Nuclear Power Plant	05000333	YEAR	SEQUENTIAL NUMBER	REV NO.	2 of 3
		2015	- 006	- 00	

NARRATIVE

Background

The Secondary Containment (SC) [EIIIS identifier: NG] boundary surrounds the primary containment and refueling equipment. The boundary forms a control volume to contain, dilute, and hold up fission products. The SC consists of four systems which include the Reactor Building, the Reactor Building Isolation and Control System, the Standby Gas Treatment (SBGT) System [BH], and the Main Stack. Secondary Containment is designed to provide containment for postulated design basis accident scenarios: loss-of-coolant accident and refueling (fuel handling) accident. Since pressure may increase in Secondary Containment relative to the environmental pressure, support systems are required to maintain a differential pressure vacuum such that external atmosphere would leak into containment rather than fission products leak out.

The systems which maintain a differential pressure vacuum inside Secondary Containment include the normal Reactor Building Ventilation and Cooling (RBV) System [VA] (during normal plant operations) and the safety-related Standby Gas Treatment System for post-accident conditions.

Technical Specification (TS) Surveillance Requirement (SR) 3.6.4.1.1 requires the SC differential pressure to be maintained more negative than 0.25 inches of water vacuum relative to the atmosphere. Failure to meet this SR, except for momentary transients due to gusty wind conditions (TS Bases 3.6.4.1.1), results in the Secondary Containment Limiting Condition for Operation (LCO) not being met, and requires the Secondary Containment to be declared Inoperable.

Event Description

On September 22, 2015 at 17:03, with James A. FitzPatrick Nuclear Power Plant operating at 100 percent power, the Emergency and Plant Information Computer (EPIC) EPIC A-3348 indicated a spike in SC differential pressure during performance of a surveillance test associated with automatic isolation of SC and initiation of the SBGT. An operator was subsequently dispatched to the ventilation control panel. In general, the control room indications (i.e. the ventilation control panel) are used for operability determinations. They verified that Secondary Containment differential pressure was more negative than the Technical Specification allowed value; therefore, the SC was determined to remain Operable.

On September 29, 2015, as part of the investigation into RB differential pressure response during the process of isolating the reactor building, Operations determined that EPIC does correspond with plant status.

An NRC notification was made via ENS 51512 on 11/3/2015. This Licensee Event Report (LER) is being submitted per 10 CFR 50.73(a)(2)(v)(C) as an event or condition that could have prevented the fulfillment of a safety function to control the release of radioactive material.

Event Analysis

Preliminary investigations have found that the Secondary Containment differential pressure has a tendency to move towards a slight positive, when the RBV is switched from normal to an isolation mode. This is also observed from the readings obtained in the control room for the SC pressure during the transition phase. The probable cause for the positive pressure is the difference in closure time for the supply and exhaust isolation valves. The supply and exhaust isolation valves are designed to close in 15 and 5 seconds respectively. After the exhaust valves are closed (within the first 5 seconds), the operating supply fans keep bringing outside air in for the remaining 10 seconds of the supply valves closure, causing RB pressure to rise.



**LICENSEE EVENT REPORT (LER)
CONTINUATION SHEET**

Estimated burden per response to comply with this mandatory collection request: 80 hours. Reported lessons learned are incorporated into the licensing process and fed back to industry. Send comments regarding burden estimate to the FOIA, Privacy and Information Collections Branch (T-5 F53), U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, or by internet e-mail to Infocollects.Resource@nrc.gov, and to the Desk Officer, Office of Information and Regulatory Affairs, NEOB-10202, (3150-0104), Office of Management and Budget, Washington, DC 20503. If a means used to impose an information collection does not display a currently valid OMB control number, the NRC may not conduct or sponsor, and a person is not required to respond to, the information collection.

1. FACILITY NAME	2. DOCKET	6. LER NUMBER			3. PAGE
James A. FitzPatrick Nuclear Power Plant	05000333	YEAR	SEQUENTIAL NUMBER	REV NO.	3 of 3
		2015	- 006	- 00	

Cause

Information relative to the cause of this condition will be provided in the supplemental report.

Similar Events

Internal Events

Similar historical events that are potentially reportable were identified during preparation of this report. A more detail list will be provided in the supplemental report.

External events:

Susquehanna Steam Electric Station; Unit 1: LER 2015-005, Loss of Secondary Containment Differential Pressure During Ventilation Damper Testing.

Columbia Generating Station; LER 2013-007-01, Secondary Containment Pressure Exceeded During Severe Weather Conditions.

Corrective Actions

Corrective actions associated with this event will be tracked in the JAF CAP; additional information in this regard will be provided in the supplemental report.

Safety Consequence

There were no actual consequences caused by this event. SC provides a control volume to contain fission products that leak from primary containment, or are released directly to the secondary containment as a result of a Loss of Coolant Accident (LOCA) or Refueling Accident (RA).

The Design Basis (DB) LOCA event results in a rapid primary containment pressure increase and reactor water level decrease. Drywell High Pressure or Low Reactor Water Level signals directly isolate the RBV, and start SBGT. Fuel damage caused by a DB LOCA is not expected until a rise in fuel cladding temperature after coolant is lost. The SC differential pressure was positive for approximately 10 seconds during the RBV isolation reported in this LER. Therefore, it would have occurred early in the DB LOCA event. RBV isolation and initiation of SBGT would have been completed prior to fuel failure and release of radiological materials.

The DB RA event results in a release of radioactive material by a dropped fuel assembly during refuel operations. Radiation detectors would detect the release and initiate SC isolation. The pressure change reported in this LER would have caused some exfiltration before the isolation was complete; however, the amount of exfiltration, consequentially the offsite and control room doses, would remain below regulatory limits.

References

- Condition Report: CR-JAF-2015-04198, September 22, 2015, Secondary Containment Differential Pressure Excursion
- Condition Report: CR-JAF-2015-04893, Failure to Immediately Report the Condition Documented in CR-JAF-2015-04198
- Nuclear Safety Evaluation: JAF-SE-96-071, Revision 2