



Entergy Operations, Inc.
17265 River Road
Killona, LA 70057-3093
Tel 504 739 6685
Fax 504 739 6698
jjarrel@entergy.com

John P. Jarrell III
Manager – Regulatory Assurance
Waterford 3

W3F1-2015-0088

November 18, 2015

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555-0001

Subject: Core Operating Limits Report – Cycle 21 Revision 0
Waterford Steam Electric Station, Unit 3
Docket No. 50-382
License No. NPF-38

Dear Sir or Madam:

Waterford 3 Technical Specification 6.9.1.11.3 requires submittal of the Core Operating Limits Report for each reload cycle including any mid-cycle revisions or supplements thereto. Attached is the Waterford 3 Core Operating Limits Report for reload Cycle 21.

If you have any questions concerning this submittal, please contact John P. Jarrell, Regulatory Assurance Manager, at (504) 739-6685.

There are no new commitments contained in this submittal.

Sincerely,

A handwritten signature in blue ink, appearing to read "JPJ/LEM".

JPJ/LEM

Attachment: Waterford 3 Core Operating Limits Report Cycle 21 Revision 0

cc: Mr. Marc L. Dapas
Regional Administrator
U. S. Nuclear Regulatory Commission
Region IV
RidsRgn4MailCenter@nrc.gov

NRC Senior Resident Inspector
Waterford Steam Electric Station Unit 3
Frances.Ramirez@nrc.gov
Chris.Speer@nrc.gov

NRC/NRR Project Manager for Waterford 3
April.Pulvirenti@nrc.gov
Michael.Orenak@nrc.gov

Attachment to

W3F1-2015-0088

Waterford 3 Core Operating Limits Report
Cycle 21 Revision 0

(Attachment contains 46 pages)



ENTERGY NUCLEAR
Engineering Report Cover Sheet

Engineering Report Title:

WSES-3 Cycle 21 Core Operating Limits Report

Engineering Report Type:

New Revision Cancelled Superseded
Superseded by: _____

Applicable Site(s)

IP1 IP2 IP3 JAF PNPS VY WPO
ANO1 ANO2 ECH GGNS RBS WF3 PLP

EC No. 54054

Report Origin: Entergy
Vendor _____ Vendor Document No.: _____

Quality-Related: Yes No

Prepared by: C. G. Eastus / See EC 54054 Date: See EC 54054
Responsible Engineer (Print Name/Sign)

Design Verified: R. E Griffith / See EC 54054 Date: See EC 54054
Design Verifier (if required) (Print Name/Sign)

Reviewed by: N/A Date: N/A
Reviewer (Print Name/Sign)

Approved by: F. H. Smith / See EC 54054 Date: See EC 54054
Supervisor / Manager (Print Name/Sign)

Revision Summary

Revision 0 Initial issue of the report

Table of Contents

	Revision Summary.....	2
1.0	Scope and Objectives	4
2.0	Input Documents.....	4
3.0	Assumptions	4
4.0	Detailed Discussion.....	4
5.0	Operating Experience	4
6.0	Summary of Results.....	4
7.0	Conclusions and Recommendations	4
8.0	References	4
9.0	Attachments.....	5

1.0 Scope and Objectives

This report describes the development of the Waterford-3 Cycle 21 (W3C21) Core Operating Limits Report (COLR). The report is developed by updating the previous cycle COLR (Input Document (ID) 2.1) with information from the W3C21 Reload Analysis Report (ID 2.2) and the W3C21 Setpoints Document (ID 2.3).

2.0 Input Documents

The input documents used to develop the W3C21 COLR include the following:

- 2.1. "Entergy Operations Waterford-3 Core Operating Limits Report for Cycle 21 Revision 1," July 1, 2014
- 2.2. Letter, A. L. Miller to C. G. Eastus, "Waterford-3 Cycle 21 Final Reload Analysis Report, Revision 1," NF-WTFD-15-24 Rev. 1, September 22, 2015.
- 2.3. Letter, A. L. Miller to C. G. Eastus, "Startup Test and Setpoints Transmittal (STST) for Waterford-3 Cycle 21,"NF-WTFD-15-37, October 30, 2015.

3.0 Assumptions

None

4.0 Detailed Discussion

ID 2.2 contains the non-setpoints related information necessary to update the COLR. The document has sections specifically addressing the information necessary to update the COLR based upon the cycle specific analysis performed by the fuel vendor (Westinghouse). Setpoints related changes are provided in ID 2.3. The received information was applied to ID2.1. The resulting W3C21 COLR is found in Attachment 9.1.

5.0 Operating Experience

A PCRS search was performed looking for issues related to the development of a COLR as described here. None were found.

6.0 Summary of Results

Using vendor provided information; the W3C19 Rev. 2 COLR was updated to reflect Cycle 21 information.

7.0 Conclusions and Recommendations

The W3C21 Revision 0 COLR has been developed and is acceptable to use.

8.0 References

None

9.0 **Attachments**

9.1 W3C21 Revision 0 COLR (using formatting and numbering appropriate for the COLR).

Attachment 9.1

Waterford-3 Cycle 21 COLR Revision 0

ENERGY OPERATIONS

WATERFORD 3

CORE OPERATING LIMITS REPORT

FOR CYCLE 21

REVISION 0

WATERFORD 3
CORE OPERATING LIMITS REPORT
CYCLE 21, REVISION 0

<u>INDEX</u>		<u>PAGE</u>
I.	INTRODUCTION	5
II.	AFFECTED TECHNICAL SPECIFICATIONS	6
3.1.1.1	Shutdown Margin - Any CEA Withdrawn	COLR 3/4 1-1
3.1.1.2	Shutdown Margin - All CEAs Fully Inserted	COLR 3/4 1-3
3.1.1.3	Moderator Temperature Coefficient	COLR 3/4 1-4
3.1.2.9	Boron Dilution	COLR 3/4 1-15
3.1.3.1	Movable Control Assemblies - CEA Position	COLR 3/4 1-18
3.1.3.6	Regulating and Group P CEA Insertion Limits	COLR 3/4 1-25
3.2.1	Linear Heat Rate	COLR 3/4 2-1
3.2.3	Azimuthal Power Tilt - T_q	COLR 3/4 2-4
3.2.4	DNBR Margin	COLR 3/4 2-6
3.2.7	Axial Shape Index	COLR 3/4 2-12
3.9.1	Boron Concentration	COLR 3/4 9-1
III.	METHODOLOGIES	38

LIST OF EFFECTIVE PAGES	
Revision 0	Pages 1-6, COLR 3/4 1-1, 1-3, 1-4, 1-15, 1-18, 1-25, 2-1, 2-4, 2-6, 2-12, 9-1, and Pages 38 – 40

LIST OF FIGURESPAGE

COLR Figure 1	Shutdown Margin Versus Cold Leg Temperature	COLR 3/4 1-3A
COLR Figure 2	Moderator Temperature Coefficient Versus % of Rated Thermal Power	COLR 3/4 1-4A
COLR Figure 3	Required Power Reduction After Single CEA Deviation	COLR 3/4 1-18A
COLR Figure 4	Regulating CEA Group Insertion Limits Versus Thermal Power	COLR 3/4 1-25A
COLR Figure 5	Group P CEA Group Insertion Limits Versus Thermal Power	COLR 3/4 1-25B
COLR Figure 6	Not Used	COLR 3/4 2-1A
COLR Figure 7	Not Used	COLR 3/4 2-1B
COLR Figure 8	Allowable DNBR with Any CEAC Operable (COLSS Out of Service)	COLR 3/4 2-6A
COLR Figure 8A	Subset of Allowable DNBR with Any CEAC Operable (COLSS Out of Service)	COLR 3/4 2-6B
COLR Figure 8.1	Not Used	COLR 3/4 2-6C
COLR Figure 8.1A	Not Used	COLR 3/4 2-6D
COLR Figure 9	Allowable DNBR with No CEAC(s) Operable (COLSS Out of Service)	COLR 3/4 2-6E
COLR Figure 9A	Subset of Allowable DNBR with No CEAC(s) Operable (COLSS Out of Service)	COLR 3/4 2-6F
COLR Figure 9.1	Not Used	COLR 3/4 2-6G
COLR Figure 9.1A	Not Used	COLR 3/4 2-6H

LIST OF EFFECTIVE FIGURE PAGES	
Revision 0	COLR 3/4 1-3A, 1-4A, 1-18A, 1-25A, 1-25B, 2-1A, 2-1B, 2-6A, 2-6B, 2-6C, 2-6D, 2-6E, 2-6F, 2-6G, 2-6H

LIST OF TABLES

PAGE

COLR Table 1 Required Monitoring Frequencies for Backup Boron Dilution Detection as a Function of Operating Charging Pumps and Plant Operational Modes for K_{eff} Greater Than 0.98.	COLR 3/4 1-15A
COLR Table 2 Required Monitoring Frequencies for Backup Boron Dilution Detection as a Function of Operating Charging Pumps and Plant Operational Modes for K_{eff} Greater Than 0.97 and Less Than or Equal to 0.98.	COLR 3/4 1-15B
COLR Table 3 Required Monitoring Frequencies for Backup Boron Dilution Detection as a Function of Operating Charging Pumps and Plant Operational Modes for K_{eff} Greater Than 0.96 and Less Than or Equal to 0.97.	COLR 3/4 1-15C
COLR Table 4 Required Monitoring Frequencies for Backup Boron Dilution Detection as a Function of Operating Charging Pumps and Plant Operational Modes for K_{eff} Greater Than 0.95 and Less Than or Equal to 0.96.	COLR 3/4 1-15D
COLR Table 5 Required Monitoring Frequencies for Backup Boron Dilution Detection as a Function of Operating Charging Pumps and Plant Operational Modes for K_{eff} Greater Than or Equal to 0.95.	COLR 3/4 1-15E

LIST OF EFFECTIVE TABLE PAGES	
Revision 0	COLR 3/4 1-15A through COLR 3/4 1-15E

WATERFORD 3

CORE OPERATING LIMITS REPORT CYCLE 21, REVISION 0

I. INTRODUCTION

This CORE OPERATING LIMITS REPORT (COLR) has been prepared in accordance with the requirements of Waterford 3 Technical Specification 6.9.1.11 for Waterford 3 Cycle 21. The core operating limits have been developed using the NRC approved methodologies specified in Section III. This is Revision 0 of the Cycle 21 COLR.

The major changes between the Cycle 21, Revision 0, COLR and the Cycle 20, Revision 1, COLR are listed below:

Section 3.2.3 was revised to change the Azimuthal Power Tilt limit from 0.05 to 0.03.

II. AFFECTED TECHNICAL SPECIFICATIONS

CORE OPERATING LIMITS REPORT

SHUTDOWN MARGIN - ANY CEA WITHDRAWN


- 3.1.1.1 The SHUTDOWN MARGIN shall be greater than or equal to 5.15% $\Delta k/k$ when T_{avg} is greater than 200 °F or 2.0% $\Delta k/k$ when T_{avg} is less than or equal to 200 °F.

CORE OPERATING LIMITS REPORT

SHUTDOWN MARGIN - ALL CEAs FULLY INSERTED

3.1.1.2 The SHUTDOWN MARGIN shall be maintained within the region of acceptable operation of COLR Figure 1.

**Shutdown Margin Versus Cold Leg Temperature
(All CEAs Fully Inserted)**




COLR Figure 1

CORE OPERATING LIMITS REPORT
MODERATOR TEMPERATURE COEFFICIENT

3.1.1.3 The Moderator Temperature Coefficient (MTC) shall be maintained within the region of acceptable operation of COLR Figure 2.

Moderator Temperature Coefficient Versus % of Rated Thermal Power



CORE OPERATING LIMITS REPORT

BORON DILUTION

3.1.2.9 See COLR Tables 1 through 5 for required RCS boron concentration monitoring frequencies and Charging Pump operation limits.

SURVEILLANCE REQUIREMENTS

Each required boron dilution alarm shall be adjusted to less than or equal to 1.75 times (1.75x) the existing neutron flux (cps) at the following frequencies:

- a. No sooner than one half hour after shutdown and no later than 1 hour after shutdown.
- b. At least once per one-half (1/2) hour if the reactor has been shut down ≥ 0.5 hour but < 2 hours
- c. At least once per hour if the reactor has been shutdown ≥ 2 hours but < 10 hours.
- d. At least once per 5 hours if the reactor has been shut down ≥ 10 hours but < 25 hours.
- e. At least once per 24 hours if the reactor has been shut down ≥ 25 hours but < 21 days.
- f. At least once per 7 days, if the reactor has been shutdown ≥ 21 days.

COLR TABLE 1

REQUIRED MONITORING FREQUENCIES FOR BACKUP BORON
DILUTION DETECTION AS A FUNCTION OF OPERATING
CHARGING PUMPS AND PLANT OPERATIONAL MODES FOR
 K_{eff} GREATER THAN 0.98

$K_{eff} > 0.98$

OPERATIONAL MODE	<u>Number of Operating Charging Pumps</u> [*]			
	0	1	2	3
3	12 hours	0.75 hours	Operation not allowed **	
4	12 hours	Operation not allowed **		
5 RCS filled	8 hours	Operation not allowed **		
5 RCS partially drained	8 hours	Operation not allowed **		
6	Operation not allowed **			

* Charging pump OPERABILITY for any period of time shall constitute OPERABILITY for the entire monitoring frequency.

** The precluded number of charging pumps shall be verified to be inoperable by racking out their motor circuit breakers.

COLR TABLE 2

REQUIRED MONITORING FREQUENCIES FOR BACKUP BORON
DILUTION DETECTION AS A FUNCTION OF OPERATING
CHARGING PUMPS AND PLANT OPERATIONAL MODES FOR
 K_{eff} GREATER THAN 0.97 AND LESS THAN OR EQUAL TO 0.98

$$0.98 \geq K_{eff} > 0.97$$

OPERATIONAL MODE	<u>Number of Operating Charging Pumps</u> [*]			
	0	1	2	3
3	12 hours	2.0 hours	0.5 hours	Operation not allowed ^{**}
4	12 hours	0.75 hours	Operation not allowed ^{**}	
5 RCS filled	8 hours	0.75 hours	Operation not allowed ^{**}	
5 RCS partially drained	8 hours	0.5 hours	Operation not allowed ^{**}	
6	Operation not allowed ^{**}			

^{*} Charging pump OPERABILITY for any period of time shall constitute OPERABILITY for the entire monitoring frequency.

^{**} The precluded number of charging pumps shall be verified to be inoperable by racking out their motor circuit breakers.

COLR TABLE 3

REQUIRED MONITORING FREQUENCIES FOR BACKUP BORON DILUTION DETECTION AS A FUNCTION OF OPERATING CHARGING PUMPS AND PLANT OPERATIONAL MODES FOR K_{eff} GREATER THAN 0.96 AND LESS THAN OR EQUAL TO 0.97

$$0.97 \geq K_{eff} > 0.96$$

OPERATIONAL MODE	Number of Operating Charging Pumps [*]			
	0	1	2	3
3	12 hours	3.0 hours	1.25 hours	0.5 hours
4	12 hours	1.5 hours	Operation not allowed ^{**}	
5 RCS filled	8 hours	1.5 hours	Operation not allowed ^{**}	
5 RCS partially drained	8 hours	0.75 hours	Operation not allowed ^{**}	
6	Operation not allowed ^{**}			

* Charging pump OPERABILITY for any period of time shall constitute OPERABILITY for the entire monitoring frequency.

** The precluded number of charging pumps shall be verified to be inoperable by racking out their motor circuit breakers.

COLR TABLE 4

REQUIRED MONITORING FREQUENCIES FOR BACKUP BORON
DILUTION DETECTION AS A FUNCTION OF OPERATING
CHARGING PUMPS AND PLANT OPERATIONAL MODES FOR
 K_{eff} GREATER THAN 0.95 AND LESS THAN OR EQUAL TO 0.96

$$0.96 \geq K_{eff} > 0.95$$

OPERATIONAL MODE	<u>Number of Operating Charging Pumps*</u>			
	0	1	2	3
3	12 hours	4.0 hours	2.0 hours	1.0 hours
4	12 hours	2.25 hours	0.75 hours	Operation not allowed**
5 RCS filled	8 hours	2.0 hours	0.75 hours	Operation not allowed**
5 RCS partially drained	8 hours	2.0 hours	0.5 hours	Operation not allowed**
6	Operation not allowed**			

* Charging pump OPERABILITY for any period of time shall constitute OPERABILITY for the entire monitoring frequency.

** The precluded number of charging pumps shall be verified to be inoperable by racking out their motor circuit breakers.

COLR TABLE 5

REQUIRED MONITORING FREQUENCIES FOR BACKUP BORON
DILUTION DETECTION AS A FUNCTION OF OPERATING
CHARGING PUMPS AND PLANT OPERATIONAL MODES FOR
 K_{eff} LESS THAN OR EQUAL TO 0.95

$$K_{eff} \leq 0.95$$

OPERATIONAL MODE	<u>Number of Operating Charging Pumps*</u>			
	0	1	2	3
3	12 hours	5.0 hours	2.0 hours	1.0 hours
4	12 hours	2.75 hours	1.0 hours	Operation not allowed**
5 RCS filled	8 hours	3.0 hours	1.0 hours	0.5 hours
5 RCS partially drained	8 hours	2.5 hours	0.75 hours	Operation not allowed**
6	24 hours	2.25 hours	0.5 hours	Operation not allowed**

* Charging pump OPERABILITY for any period of time shall constitute OPERABILITY for the entire monitoring frequency.

** The precluded number of charging pumps shall be verified to be inoperable by racking out their motor circuit breakers.


CORE OPERATING LIMITS REPORT

MOVABLE CONTROL ASSEMBLIES - CEA POSITION

- 3.1.3.1.a With one CEA trippable but misaligned from any other CEA in its group by more than 19 inches, operation in MODES 1 and 2 may continue, provided that core power is reduced in accordance with COLR Figure 3.
- 3.1.3.1.b With one or more CEAs trippable but misaligned from any other CEAs in its group by more than 7 inches but less than or equal to 19 inches, operation in MODES 1 and 2 may continue, provided that core power is reduced in accordance with COLR Figure 3.

NOTES

1. Item 3.1.3.1.a corresponds with ACTION "c" of Technical Specification 3.1.3.1.
2. Item 3.1.3.1.b corresponds with ACTION "d" of Technical Specification 3.1.3.1.




COLR Figure 3

* When thermal power is reduced to 60% of rated thermal power per this limit curve, further reduction is not required by this Technical Specification.

CORE OPERATING LIMITS REPORT
REGULATING AND GROUP P CEA INSERTION LIMITS


3.1.3.6 The regulating CEA groups and Group P CEAs shall be limited to the withdrawal sequence and to the insertion limits shown on COLR Figure 4 (regulating groups) and Figure 5 (Group P).

Regulating CEA Group Insertion Limits Versus Thermal Power



COLR Figure 4

Group P CEA Group Insertion Limits Versus Thermal Power



COLR Figure 5

CORE OPERATING LIMITS REPORT

LINEAR HEAT RATE

3.2.1 The linear heat rate shall be maintained:

a. ≤ 12.9 kW/ft when COLSS is in service

b. ≤ 13.2 kW/ft when COLSS is out of service

In accordance with Technical Specification 3.6.1.5 Action a, with the minimum containment average air temperature less than 95°F but greater than or equal to 90°F, the linear heat rate shall be maintained:

a. ≤ 12.7 kW/ft when COLSS is in service

b. ≤ 13.0 kW/ft when COLSS is out of service

COLR Figure 6

(Not Used)

COLR Figure 7

(Not Used)

CORE OPERATING LIMITS REPORT
AZIMUTHAL POWER TILT- T_q

3.2.3 The measured AZIMUTHAL POWER TILT shall be maintained ≤ 0.03 . |

CORE OPERATING LIMITS REPORT

DNBR MARGIN


3.2.4 The DNBR margin shall be maintained by one of the following methods:

- a) When COLSS is in service and neither CEAC is operable: maintain COLSS calculated core power less than or equal to COLSS calculated core power operating limit based on DNBR decreased by 13% RATED THERMAL POWER.
- b) When COLSS is out of service and at least one CEAC is operable: operate within the region of acceptable operation shown on COLR Figure 8 (or 8A as appropriate), using any operable CPC channel.
- c) When COLSS is out of service and neither CEAC is operable: operate within the region of acceptable operation shown on COLR Figure 9 (or 9A as appropriate), using any operable CPC channel.


NOTES

1. The various DNBR limit lines shown between the vertical ASI limit lines at ± 0.12 and ± 0.22 on Figures 8, 8A, 9, and 9A represent the minimum CPC-calculated DNBR value required for operation in the power range displayed in the area above each line. Operation at lower power levels requires that a larger DNBR value be maintained. For example, with ASI equal to -0.12 and a core power of 85%, CPC calculated DNBR must be a minimum of 2.62 with any CEAC Operable. At 79% power and the same ASI value with any CEAC Operable, the calculated DNBR must be at least 3.12. At 65% power and the same ASI value, DNBR must be a minimum of 4.28. At 90% power and an ASI value of $+0.08$, DNBR must be no less than 2.37.
2. The vertical ASI limit lines shown at ± 0.12 and ± 0.22 on Figures 8, 8A, 9, and 9A may be considered as extending beyond the maximum DNBR value on the Y-axis of the charts. Therefore, when monitoring DNBR with these figures, compliance is achieved at all power levels shown on a given figure when DNBR is greater than the largest DNBR value on the vertical scale.
3. Figure 8A is provided to offer better resolution for the four power ranges in the lower portion of Figure 8. Figure 9A is provided to offer better resolution for the four power ranges in the lower portion of Figure 9.
4. Equations are provided on Figures 8, 8A, 9, and 9A to assist in determining DNBR limits in the sloped portions of the plots.

Allowable DNBR with Any CEAC Operable (COLSS Out of Service)



**Subset of Allowable DNBR with Any CEAC Operable
(COLSS Out of Service)**




COLR Figure 8.1

(Not Used)


COLR Figure 8.1A

(Not Used)

Allowable DNBR with No CEAC(s) Operable (COLSS Out of Service)



**Subset of Allowable DNBR with No CEAC(s) Operable
(COLSS Out of Service)**



COLR Figure 9.1

(Not Used)

COLR Figure 9.1A

(Not Used)

CORE OPERATING LIMITS REPORT
AXIAL SHAPE INDEX

3.2.7 The AXIAL SHAPE INDEX (ASI) shall be maintained within the following limits:

COLSS Operable

$$-0.16 \leq \text{ASI} \leq +0.16$$

for THERMAL POWERS \geq 50% of
RATED THERMAL POWER

$$-0.26 \leq \text{ASI} \leq +0.26$$

for THERMAL POWERS from 20% to <50%
of RATED THERMAL POWER

COLSS Out of Service

$$-0.12 \leq \text{ASI} \leq +0.12$$

for THERMAL POWERS \geq 50% of
RATED THERMAL POWER

$$-0.22 \leq \text{ASI} \leq +0.22$$

for THERMAL POWERS from 20% to <50%
of RATED THERMAL POWER

CORE OPERATING LIMITS REPORT
BORON CONCENTRATION

- 3.9.1 While in Mode 6, the RCS boron concentration shall be maintained sufficiently to ensure that the more restrictive of the following reactivity conditions is met:
- a. Either K_{eff} of 0.95 or less, or
 - b. A boron concentration of greater than or equal to 2050 ppm.

III. METHODOLOGIES

The analytical methods used to determine the core operating limits listed above are those previously reviewed and approved by the NRC in:

1. "Qualification of the PHOENIX-P/ANC Nuclear Design System for Pressurized Water Reactor Cores," WCAP-11596-P-A, June 1988; "ANC: A Westinghouse Advanced Nodal Computer Code," WCAP-10965-P-A, September 1986; and "ANC: A Westinghouse Advanced Nodal Computer Code: Enhancements to ANC Rod Power Recovery," WCAP-10965-P-A Addendum 1, April 1989. (Methodology for Specifications 3.1.1.1 and 3.1.1.2 for Shutdown Margins, 3.1.1.3 for MTC, 3.1.3.6 for Regulating and Group P CEA Insertion Limits, 3.1.2.9 Boron Dilution (Calculation of CBC and IBW), and 3.9.1 Boron Concentration).
2. "C-E Method for Control Element Assembly Ejection Analysis," CENPD-190-A, Revision 0, January 1976. (Methodology for Specification 3.1.3.6 for Regulating and Group P CEA Insertion Limits and 3.2.3 for Azimuthal Power Tilt.)
3. "Modified Statistical Combination of Uncertainties" CEN-356(V)-P-A, Revision 1-P-A, May 1988. (Methodology for Specification 3.2.4.c and 3.2.4.d for DNBR Margin and 3.2.7 for ASI.)
4. "Calculative Methods for the CE Large Break LOCA Evaluation Model For the Analysis of C-E and W Designed NSSS," CENPD-132, Supplement 3-P-A, June 1985. (Methodology for Specification 3.1.1.3 for MTC, 3.2.1 for Linear Heat Rate, 3.2.3 for Azimuthal Power Tilt and 3.2.7 for ASI.)
5. "Calculative Methods for the ABB CE Small Break LOCA Evaluation Model," CENPD-137-P, August 1974; Supplement 2-P-A, April 1998. (Methodology for Specification 3.1.1.3 for MTC, 3.2.1 for Linear Heat Rate, 3.2.3 for Azimuthal Power Tilt and 3.2.7 for ASI.)
6. "Technical Description Manual for the CENTS Code," WCAP-15996-P-A, Revision 1, March 2005. (Methodology for Specification 3.1.1.1 and 3.1.1.2 for Shutdown Margins, 3.1.1.3 for MTC, 3.1.3.1 for Movable Control Assemblies – CEA Position, 3.1.3.6 for Regulating and Group P CEA Insertion Limits, and 3.2.4.b for DNBR Margin)

7. "Implementation of ZIRLO Material Cladding in CE Nuclear Power Fuel Assembly Designs," CENPD-404-P-A, November 2001. (Methodology for Specification 3.1.1.3 for MTC, 3.2.1 for Linear Heat Rate, 3.2.3 for Azimuthal Power Tilt, and 3.2.7 for ASI).
8. "Qualification of the Two-Dimensional Transport Code PARAGON," WCAP-16045-P-A, August 2004. (Methodology for Specifications 3.1.1.1 and 3.1.1.2 for Shutdown Margins, 3.1.1.3 for MTC, 3.1.3.6 for Regulating and Group P CEA Insertion Limits, 3.1.2.9 Boron Dilution (Calculation of CBC & IBW), 3.2.4.b for DNBR Margin and 3.9.1 Boron Concentration).
9. "Implementation of Zirconium Diboride Burnable Absorber Coatings in CE Nuclear Power Fuel Assembly Designs," WCAP-16072-P-A, Revision 0, August 2004 (Methodology for Specification 3.1.1.3 for MTC, 3.2.1 for Linear Heat Rate, 3.2.3 for Azimuthal Power Tilt, and 3.2.7 for ASI).
10. "CE 16 x 16 Next Generation Fuel Core Reference Report," WCAP-16500-P and Final Safety Evaluation for Westinghouse Electric Company (Westinghouse) Topical Report (TR) WCAP-16500-P, Revision 0, "CE [Combustion Engineering] 16x16 Next Generation Fuel [(NGF)] Core Reference Report," (Methodology for Specification 3.1.1.3 for MTC, 3.2.1 for Linear Heat Rate, 3.2.3 for Azimuthal Power Tilt, 3.2.4.b, 3.2.4.c, and 3.2.4.d for DNBR Margin, and 3.2.7 for ASI).
11. "Optimized ZIRLO™," WCAP-12610-P-A and CENPD-404-P-A Addendum 1-A, July 2006. (Methodology for Specification 3.1.1.3 for MTC, 3.2.1 for Linear Heat Rate, 3.2.3 for Azimuthal Power Tilt, and 3.2.7 for ASI.)
12. "Westinghouse Correlations WSSV and WSSV-T for Predicting Critical Heat Flux in Rod Bundles with Side-Supported Mixing Vanes," WCAP-16523-P-A Revision 0, August 2007; and Final Safety Evaluation for Westinghouse Electric Company (Westinghouse) Topical Report (TR), WCAP-16523-P, "Westinghouse Correlations WSSV and WSSV-T for Predicting Critical Heat Flux in Rod Bundles with Side-Supported Mixing Vanes," (Methodology for Specification 3.2.4.b, 3.2.4.c, and 3.2.4.d for DNBR Margin.)
13. "ABB Critical Heat Flux Correlations for PWR Fuel," CENPD-387-P-A Revision 0, May 2000. (Methodology for Specification 3.2.4.b, 3.2.4.c, and 3.2.4.d for DNBR Margin and 3.2.7 for ASI.)

14. "Calculative Methods for the CE Nuclear Power Large Break LOCA Evaluation Model -Improvement to 1999 Large Break LOCA EM Steam Cooling Model for Less Than 1 in/sec Core Reflood" CENPD-132, Supplement 4-P-A, Addendum 1-P and Final Safety Evaluation for Westinghouse Electric Company (Westinghouse) Topical Report (TR) CENPD-132 Supplement 4-P-A, Addendum 1-P, "Calculative Methods for the CE [Combustion Engineering] Nuclear Power Large Break LOCA Evaluation Model - Improvement to 1999 Large Break LOCA EM Steam Cooling Model for Less Than 1 in/sec Core Reflood," (Methodology for Specification 3.1.1.3 for MTC, 3.2.1 for Linear Heat Rate, 3.2.3 for Azimuthal Power Tilt, and 3.2.7 for ASI).
15. "Application of CE Setpoint Methodology for CE 16x16 Next Generation Fuel (NGF)," WCAP 16500 P-A, Supplement 1, Revision 1, December 2010. (Methodology for Specification 3.2.4.b, 3.2.4.c, and 3.2.4.d for DNBR Margin.)