


| | |
|-------------------------------------------------------------------------------------------------------|-------------------------------|
| In the Matter of: Entergy Nuclear Operations, Inc. (Indian Point Nuclear Generating Units 2 and 3) | |
|  | ASLBP #: 07-858-03-LR-BD01 |
| | Docket #: 05000247 05000286 |
| | Exhibit #: NYS000455-00-BD01 |
| | Admitted: 11/5/2015 |
| | Rejected: Other: |
| Identified: 11/5/2015 | |
| Withdrawn: | |
| Stricken: | |

**Comparison of GALL Rev. 1 with GALL Rev. 2
On Tube to Tube Sheet Welds**

| V ENGINEERED SAFETY FEATURES | | | | | | | |
|----------------------------------------|------|----------------------------|----------|-------------|------------------------|--------------------------------|--------------------|
| D1 Emergency Core Cooling System (PWR) | | | | | | | |
| Item | Link | Structure and/or Component | Material | Environment | Aging Effect/Mechanism | Aging Management Program (AMP) | Further Evaluation |
| | | | | | | | |

GALL Rev. 1, p. IV D1-2 to IV D1-8, September 2005

| IV REACTOR VESSEL, INTERNALS, AND REACTOR COOLANT SYSTEM | | | | | | | |
|----------------------------------------------------------|------|----------------------------|--------------|-----------------|---------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------|
| D1 Steam Generator (Recirculating) | | | | | | | |
| Item | Link | Structure and/or Component | Material | Environment | Aging Effect/Mechanism | Aging Management Program (AMP) | Further Evaluation |
| IV.D1.RP-385 | | Tube-to-tube sheet welds | Nickel alloy | Reactor coolant | Cracking due to primary water stress corrosion cracking | Chapter XI.M2, "Water Chemistry" A plant-specific program is to be evaluated; the effectiveness of the water chemistry program should be verified to ensure cracking is not occurring. | Yes, plant-specific. |

GALL Rev. 2, p. IV D1-8, December 2010

Note: GALL Chapter IV D1 concerns recirculating-type steam generators found in Westinghouse and Combustion Engineering pressurized water reactors (PWRs).
See GALL Rev. 1, p. IV D1-1; GALL Rev. 2, p. IV D1-1.