COMMITMENT CLOSURE VERIFICATION FORM Sheet 1 of 2							
	IP3- A- 10377						
LO-LAR-2011-0174 CA	58 (IP2)	LRC #	41				
	59 (IP3)						

Commitment Summary Restate or paraphrase the commitment

IPEC will inspect steam generators for both units to assess the condition of the divider plate assembly. The examination technique used will be capable of detecting PWSCC in the steam generator divider plate assembly. The IP2 steam generator divider plate inspections will be completed within the first ten years of the period of extended operation (PEO). The IP3 steam generator divider plate inspections will be completed within the first refueling outage following the beginning of the PEO.

United States Nuclear Regulatory Commission Official Hearing Exhibit						
In the Matter of:	Entergy Nuclear Operations, Inc. (Indian Point Nuclear Generating Units 2 and 3)					
REE GOOMMISSOON	Docket #:	07-858-03-LR-BD01 05000247 05000286 NYS000535-00-BD01 11/5/2015	Identified: 11/5/2015 Withdrawn: Stricken:			

Extent of Closure	Full		Partial	
-------------------	------	--	---------	--

Means of Closure List the closure documents (e.g., letter, procedure, etc.) from which objective evidence of commitment closure can be obtained.¹

LO-LAR-2011-00174 CA 58 for IP2 is being used to track commitment 41 LO-LAR-2011-00174 CA 59 for IP3 is being used to track commitment 41

Note 1: Objective evidence from the listed closure documentation must be attached or reference provided regarding where the documentation may be retrieved.

EN-LI-110-Att-9.2, Rev. 5

Sheet 2 of 2 Robert J. Dolansky Site Program Owner Date 4/24/13 Date 4/25/17 Site License Renewal Project Manager Date

COMMITMENT CLOSURE VERIFICATION FORM

Site Licensing

The objective evidence supports the <u>Extent of Closure</u> indicated above AND the commitment tracking system has been updated.

CLOSURE DATE PO	1820	9/28/2023	
CLOSURE DATE TO	~ 1832	4/15/2017	4/25/13
Site Licensing Signature		The I Many	Date