

In the Matter of: Entergy Nuclear Operations, Inc.
(Indian Point Nuclear Generating Units 2 and 3)



ASLBP #: 07-858-03-LR-BD01
 Docket #: 05000247 | 05000286
 Exhibit #: NYS000548-00-BD01
 Admitted: 11/5/2015
 Rejected:
 Other:
 Identified: 11/5/2015
 Withdrawn:
 Stricken:

Power Reactor	Event Number: 51046
Facility: INDIAN POINT Region: 1 State: NY Unit: [] [3] [] RX Type: [2] W-4-LP,[3] W-4-LP NRC Notified By: FRANCISCO MERCADO HQ OPS Officer: CHARLES TEAL	Notification Date: 05/07/2015 Notification Time: 07:11 [ET] Event Date: 05/07/2015 Event Time: 07:00 [EDT] Last Update Date: 05/07/2015
Emergency Class: NON EMERGENCY 10 CFR Section: 50.72(b)(2)(xi) - OFFSITE NOTIFICATION	Person (Organization): DAN SCHROEDER (R1DO)

Unit	SCRAM Code	RX CRIT	Initial PWR	Initial RX Mode	Current PWR	Current RX Mode
3	N	Y	100	Power Operation	98	Power Operation

Event Text

OFFSITE NOTIFICATION DUE TO SHUTDOWN FOR AN UNISOLABLE STEAM LEAK

"At 0700 on 5/7/15, Indian Point Unit 3 commenced a shutdown due to the inability to isolate a steam leak on a feedwater instrument line.

"Offsite power is available.

"Indian Point Unit 2 is unaffected and remains in Mode 1 at 100% power.

"The NRC Resident Inspector, the NYISO (New York Independent System Operator), and NY Public State Commission have been notified."