

PRELIMINARY NOTIFICATION - REGION III

December 3, 2015

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE - PNO-III-15-010A

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. Some of the information may not yet be fully verified or evaluated by the Region III staff.

Facility

Monticello Nuclear Generating Plant
Northern States Power Co.
Monticello, MN
Docket: 50-263
License: DPR-22

Licensee Emergency Classification

Notification of Unusual Event
 Alert
 Site Area Emergency
 General Emergency
 Not Applicable

SUBJECT: UPDATE: MONTICELLO AUTOMATIC SCRAM DUE TO REACTOR PROTECTION SYSTEM SIGNAL

DESCRIPTION:

On November 30, 2015, the Monticello Nuclear Generating Plant was restarted following an automatic reactor shutdown occurring on November 23, 2015. Specifically, on November 23, there was an unexpected lockout of the 11 recirculation pump; this pump is used to circulate and control the flow of water through the reactor core. Shortly after the lockout, the Reactor Protection System detected an invalid indicated high steam flow in the main steam lines, prompting an automatic reactor shutdown.

The cause of the recirculation pump lockout was determined to be a loose wire connection on the pump control circuitry. The cause of the indicated high steam flow was a pressure transient caused by foreign material partially blocking the pressure sensing line. Both issues were corrected as part of the licensee's investigation and troubleshooting efforts.

The NRC senior resident inspector was on site to observe the shutdown, portions of the licensee's troubleshooting efforts, and portions of the startup.

This preliminary notification is issued for information only and no further action by the staff is anticipated.

Region III received initial notification of this occurrence via the Resident Inspector at 10:42 am (CST) on November 23, 2015. The information presented herein has been discussed with the licensee, and is current as of 3:00 p.m. (CST), on December 3, 2015.

ADAMS Accession Number ML15337A504.

CONTACT: Kenneth Riemer
630/829-9628
Kenneth.Riemer@nrc.gov