

**ENCLOSURE 6**

**GEH Technical Report**

**WG3-U97-DRD-S-0001 Revision 0**

**Fuel Building Structural Design Report**



**STRUCTURAL DESIGN REPORT**

**REVISION STATUS SHEET**

**Document Title:** Fuel Building Structural Design Report

**Revision #:** 0 **Type:** Engineering Report – Design

**Safety Related Classification Code:** N/A **MPL No.:** U97-5010

“|” Vertical Sidebar Denotes Change

Rev #	DOORS BL	Change Number	MM/DD/YYYY	Preparing Organization	Issue / Release Status	Verification Status
0	N/A	ECO-0015278	11/10/2015	GEH	Issued for Use-Design	Verified

MADE BY	APPROVALS	AUTH. DATE
Gary Ehler GEH	Tanya B. Kirby GEH	11/10/2015

**Public Information Notice**

This is a public version of WG3-U97-ERD-S-0001, Rev 0, from which the security-related information has been removed. Portions of the document that have been removed are indicated by white space within single brackets as shown here { }. The footer of each page where security-related information is withheld carries the notation “{{{Security-Related Information - Withheld Under 10 CFR 2.390}}}.”

**IMPORTANT NOTICE REGARDING CONTENTS OF THIS REPORT**  
**Please Read Carefully**

The design, engineering, and other information contained in this document are furnished for the purpose(s) stated in the “Development Agreement between Virginia Electric and Power Company and the consortium of GE-Hitachi Nuclear Energy Americas LLC and Fluor Enterprises, Inc.” dated April 5, 2013 as amended. The use of this information by anyone other than Virginia Electric and Power Company, or for any purpose other than that for which it is furnished by GEH is not authorized; and with respect to any unauthorized use, GEH makes no representation or warranty, express or implied, and assumes no liability as to the completeness, accuracy, or usefulness of the information contained in this document, or that its use may not infringe privately owned rights.

**Copyright 2015, GE-Hitachi Nuclear Energy Americas LLC, All Rights Reserved**





**HITACHI**

WG3-U97-ERD-S-0001 SH NO. 3  
REV. 0 of 151

**RECORD OF REVISION**

Rev #	Description
0	Initial issue



**TABLE OF CONTENTS**

- 1. SCOPE .....9
- 2. APPLICABLE DOCUMENTS .....9
  - 2.1 Supporting and Supplemental Documents ..... 9
    - 2.1.1 Supporting Documents..... 9
    - 2.1.2 Supplemental Documents ..... 9
  - 2.2 Industry Codes and Standards ..... 11
  - 2.3 Regulation and Regulatory Requirements..... 11
  - 2.4 References ..... 11
- 3. STRUCTURAL DESCRIPTION AND GEOMETRY .....11
  - 3.1 Structural Geometry and Dimensions ..... 11
  - 3.2 Key Structural Elements and Descriptions..... 12
  - 3.3 Floor Layout and Elevations ..... 12
  - 3.4 Conditions of Vicinity and Support..... 12
  - 3.5 Special Structural Features ..... 13
- 4. STRUCTURAL MATERIAL REQUIREMENTS .....13
  - 4.1 Concrete..... 13
  - 4.2 Reinforcement ..... 13
  - 4.3 Structural Steel ..... 13
    - 4.3.1 Carbon Steel Plate and Shapes..... 13
    - 4.3.2 Stainless Steel Plate ..... 13
    - 4.3.3 Steel Decking ..... 14
- 5. STRUCTURAL LOADS .....14
  - 5.1 Live Loads and Dead Loads..... 14
    - 5.1.1 Dead Loads ..... 14
    - 5.1.2 Live Loads ..... 14
  - 5.2 Transient Loads ..... 14
    - 5.2.1 Pressure Loads ..... 14
    - 5.2.2 Thermal Loads ..... 15
    - 5.2.3 Hydrodynamic Loads..... 16
    - 5.2.4 RPV Reactions due to Hydrodynamic Loads ..... 16
  - 5.3 Environmental Loads ..... 16
    - 5.3.1 Wind Loads..... 16
    - 5.3.2 Tornado Loads ..... 16
    - 5.3.3 Seismic Loads ..... 17
- 6. STRUCTURAL ANALYSIS AND DESIGN .....17
  - 6.1 General Description..... 17
  - 6.2 Stress Analysis ..... 18
    - 6.2.1 Analysis Program..... 18
    - 6.2.2 Analysis Model ..... 18
    - 6.2.3 Method of Applying Loads..... 18
    - 6.2.4 Analysis Results..... 19
  - 6.3 Load Combinations ..... 19



6.3.1	Code Requirements .....	19
6.3.2	Selection of Design Load Combinations .....	19
6.3.3	Result of Load Combination .....	21
6.4	Section Design Principles .....	21
6.4.1	Section Design of Reinforced Concrete Structures .....	21
6.4.1.1	Walls and Slabs .....	21
6.4.1.2	Columns and Girders .....	25
6.4.2	Section Design of Steel Structures .....	28
6.4.2.1	Section Design for Axial Compression and Bending .....	28
6.4.2.2	Section Design for Axial Tension and Bending .....	30
6.4.2.3	Section Design for Transverse Shear .....	30
6.4.2.4	Allowable Stresses .....	30
7.	SUMMARY OF RESULTS .....	32
7.1	Required Section .....	32
7.2	Provided Section .....	32
7.3	Tabulation of Allowable Stresses versus Calculated Stresses .....	33
7.3.1	Reinforced Concrete Structure .....	33
7.3.1.1	Walls and Slabs .....	33
7.3.1.2	Columns and Beams .....	34
7.3.2	Steel Structure .....	35
8.	CONCLUSIONS .....	35
Appendix A	COMPARISON WITH DCD DATA .....	127
Appendix B	IN-PLANE SHEAR CHECK FOR FB ACCORDING TO ACI349-01 .....	142
Appendix C	COMPRESSION LIMIT CHECK FOR FB ACCORDING TO ACI349-01 ...	148



**LIST OF TABLES**

Table 3.1-1 Key Dimensions of RB and FB .....37

Table 5.1.1-1 Dead Loads of Equipment in FB .....38

Table 5.1.1-2 Miscellaneous Structures, Piping, and Commodities on the Slabs .....39

Table 5.1.2-1 Floor Live Loads .....40

Table 5.1.2-2 Design Lateral Soil Pressure at-Rest .....40

Table 5.2.2-1 Steady State Temperature Conditions .....41

Table 5.2.2-2 Thermal Loads for Shell Elements Normal Operation: Summer .....42

Table 5.2.2-3 Thermal Loads for Shell Elements Normal Operation: Winter.....42

Table 5.2.2-4 Design Basis Accident Temperatures in Spent Fuel Pool .....43

Table 5.2.2-5 Thermal Loads for Shell Elements around Spent Fuel Pool: 72 hr. after DBA:  
Summer .....44

Table 5.2.2-6 Thermal Loads for Shell Elements around Spent Fuel Pool: 72 hr. after DBA:  
Winter .....44

Table 5.3.1-1 Design Wind Pressure Loads by Floor Level.....45

Table 5.3.2-1 Design Pressure of Tornado Wind Load .....45

Table 5.3.3-1 Design Seismic Loads for Horizontal SSE (RB and FB Walls).....46

Table 5.3.3-2 Maximum Vertical Accelerations (RB and FB Walls and Floor Slab).....47

Table 5.3.3-3 Enveloping Maximum Vertical Acceleration: RBFB Flexible Slab Oscillators...48

Table 5.3.3-4 Soil Pressure Due to an Earthquake .....50

Table 5.3.3-5 Sloshing Loads in the Spent Fuel Pool.....50

Table 5.3.3-6 Enveloping Maximum Horizontal Acceleration: RBFB Wall Out-of-plane  
Oscillators .....51

Table 6.2.2-1 Material Constants Used in Stress Analysis.....52

Table 6.2.4-1 Results of NASTRAN Analysis, Dead Load .....53

Table 6.2.4-2 Results of NASTRAN Analysis, Temperature Load (LOCA after 72 hours:  
Winter) .....54

Table 6.2.4-3 Results of NASTRAN Analysis, Seismic Load (Horizontal: North to South  
Direction) .....55

Table 6.2.4-4 Results of NASTRAN Analysis, Seismic Load (Horizontal: East to West  
Direction) .....56

Table 6.2.4-5 Results of NASTRAN Analysis, Seismic Load (Vertical: Upward Direction).....57

Table 6.3.1-1 Load Combinations and Acceptance Criteria for Safety-related Reinforced  
Concrete Structures .....58

Table 6.3.1-2 Load Combinations and Acceptance Criteria for Safety-Related Steel Structures 59

Table 6.3.1-3 Load Combinations, Load Factors and Acceptance Criteria for Reinforced  
Concrete Containment .....60

Table 6.3.2-1 Detail Load Combinations for Reinforced Concrete Structures.....61

Table 6.3.2-2 Detail Load Combinations for Steel Structures.....65

Table 6.3.3-1 Combined Forces and Moments: 1.05D + 1.3L +1.3To + 1.3W: Winter: Load ID  
= 4021 (Selected Load Combination FB-4).....68

Table 6.3.3-2 Combined Forces and Moments: LOCA (1.5Pa): Winter: Load ID = 6441  
(Selected Load Combination FB-8) .....69



Table 6.3.3-3 Combined Forces and Moments: LOCA + SSE: Winter: Load ID = 7441 (Selected Load Combination FB-9).....	71
Table 6.4.1.1-1 Material Constants for Stress Calculations.....	73
Table 6.4.1.1-2 Allowable Stress of Concrete for Membrane Plus Bending.....	73
Table 6.4.1.1-3 Allowable Stress of Reinforcement for Membrane Plus Bending .....	73
Table 6.4.1.1-4 Allowable Stress of Concrete for Membrane Compressive Forces.....	74
Table 7.3.1.1.1-1 Sectional Thicknesses and Rebar Ratios of FB Used in the Evaluation .....	75
Table 7.3.1.1.1-2 Rebar and Concrete Stresses of FB: 1.05D+1.3L+1.3To+1.3W: Winter: Load ID = 4021 (Selected Load Combination FB-4) .....	77
Table 7.3.1.1.1-3 Rebar and Concrete Stresses of FB: LOCA (1.5Pa): Winter: Load ID = 6441 (Selected Load Combination FB-8).....	78
Table 7.3.1.1.1-4 Rebar and Concrete Stresses of FB: LOCA + SSE: Winter: Load ID = 7441 (Selected Load Combination FB-9).....	79
Table 7.3.1.1.1-5 Maximum Stress Ratios for Flexure and Membrane Forces .....	80
Table 7.3.1.1.2-1 Membrane Compressive Forces of FB .....	81
Table 7.3.1.1.3-1 Transverse Shear of FB .....	82
Table 7.3.1.1.3-2 Transverse Shear of FB for DCD Load Combinations .....	83
Table 7.3.1.2-1 Maximum Stress Ratio of FB Reinforced Concrete Column.....	84
Table 7.3.1.2-2 Maximum Stress Ratio of FB Reinforced Concrete Girder .....	86
Table 7.3.2-1 Maximum Stress Ratio of FB Steel Girder.....	88



**LIST OF FIGURES**

Figure 1-1 RB/FB Global FE Analysis Model .....89

Figure 3.1-1 RB and FB Concrete Outline Plan at EL -11500 .....90

Figure 3.1-2 RB and FB Concrete Outline Plan at EL 4650 .....91

Figure 3.1-3 RB and FB Concrete Outline Plan at EL 17500 .....92

Figure 3.1-4 RB and FB Concrete Outline Plan at EL 27000 .....93

Figure 3.1-5 RB Concrete Outline Plan at EL 34000 .....94

Figure 3.1-6 RB and FB Concrete Outline N-S Section.....95

Figure 3.1-7 RB and FB Concrete Outline E-W Section.....96

Figure 5.1.2-1 Snow Load Considered Drift Load .....97

Figure 5.2.2-1 Application of Thermal Load on the External Wall (RA) .....98

Figure 5.2.2-2 Application of Thermal Load on the External Wall (RG FF).....99

Figure 5.2.2-3 Application of Thermal Load on the External Wall (R7/F1).....100

Figure 5.2.2-4 Application of Thermal Load on the External Wall (F3).....101

Figure 5.2.2-5 Application of Thermal Load on the Basemat .....102

Figure 5.2.2-6 Application of Thermal Load on the Spent Fuel Pool Wall-1 .....103

Figure 5.2.2-7 Application of Thermal Load on the Spent Fuel Pool Wall-2 .....104

Figure 5.2.2-8 Application of Thermal Load on the Spent Fuel Pool Wall-3 .....105

Figure 5.3.3-1 Dynamic Analysis Model.....106

Figure 6.2.4-1 Elements Selected for Tabulation (External Wall F3) .....107

Figure 6.2.4-2 Elements Selected for Tabulation (External Wall RA FA).....108

Figure 6.2.4-3 Elements Selected for Tabulation (Basemat).....109

Figure 6.2.4-4 Elements Selected for Tabulation (Slab at EL4,650).....110

Figure 6.2.4-5 Elements Selected for Tabulation (Spent Fuel Pool Wall) .....111

Figure 6.2.4-6 Force and Moment in Shell Element.....112

Figure 6.4.1-1 Design Flow Chart of Reinforced Concrete Structures.....113

Figure 6.4.1.1-1 Calculation of Shear Strength Provided by Concrete .....114

Figure 6.4.1.2-1 Stress-Strain Relationship Assumed for Strength Check.....115

Figure 6.4.1.2-2 Calculation Method of Strength Ratios.....116

Figure 6.4.2-1 Allowable Stress of W-shaped Members (Strong Axis Bending) .....117

Figure 6.4.2-2 Allowable Stress of W-shaped Members (Weak Axis Bending).....118

Figure 6.4.2-3 Allowable Bending Stress of Box Members .....119

Figure 7.1-1 Reinforcing Steel of Spent Fuel Pool Walls .....120

Figure 7.1-2 List of FB Wall and Slab Reinforcement.....121

Figure 7.1-3 FB Reinforced Concrete Column Reinforcing Schedule .....122

Figure 7.1-4 FB Reinforced Concrete Girder Reinforcing Schedule .....123

Figure 7.1-5 FB Steel Girder Member .....124

Figure 7.3.1.1-1 Moment Capacity Check according to ACI349-01 for Element 72004 with New Arrangement of Reinforcement .....125

Figure 7.3.1.2-1 Elements Selected for Tabulation - FB Frame -.....126



## 1. SCOPE

This report describes the section design calculation results of the Fuel Building (FB) for North Anna Unit 3 (NA3) site-specific seismic load demands that exceed the seismic loads used for the standard design of the FB. The scope of the evaluation is the analysis and stress checks of the structure for site-specific seismic loads in combination with other design loads in critical seismic load combinations. The analysis is performed using the same NASTRAN models used for the standard design of the FB, which are further described in Section 6.2.2.1 of Reference 2.1.2-p. The design loads applied to the models are the same as those considered in the standard design, except for the Safe Shutdown Earthquake (SSE) loads that are obtained from Reference 2.1.2-o. The NA3 site-specific SSE loads are combined with non-seismic standard plant loads following the same standard design analysis methodology and acceptance criteria.

The FB is integrated with the Reactor Building (RB), including the Reinforced Concrete Containment Vessel (RCCV), sharing a large common foundation mat. In the structural design of the FB, RB, and RCCV, stresses are evaluated using one Finite Element (FE) analysis model (RB/FB global model), which is shown in Figure 1-1. As described later in Chapter 6, the details of the FE analysis methods, such as analysis model and load application methods, are included in the Reactor Building Structural Design Report, Reference 2.1.2-p). Therefore, this report describes mainly the results of FE analyses and section design calculations of the FB.

## 2. APPLICABLE DOCUMENTS

### 2.1 Supporting and Supplemental Documents

The following documents form a part of this documents:

#### 2.1.1 Supporting Documents

Supporting documents are those documents that complete the requirements of this document and are referred to herein.

- |  | <u>Designation</u> |
|--|--------------------|
| a. 105E4059, Fuel Building Concrete Drawings, Revision 3   | U97-2010           |
| b. eDRF Section 0000-0102-0965, "Deliverable to Structural Group for Steady State Heat Transfer and Stress Analysis", Revision 0 |                    |

#### 2.1.2 Supplemental Documents

Supplemental documents are those documents that are to be used in conjunction with this document.

Designation



- a. SR3-1-A11-TRD-5201, Standard Review Plans and Regulatory Guides Design Specification, Revision 4 A11-5201
- b. 105E3908, "ESBWR Nuclear Island General Arrangement Drawing", Revision 5
- c. 26A6642AL, "ESBWR Design Control Document Tier 2 Chapter 3 Appendices 3A – 3F", Revision 10
- d. 26A6642AN, "ESBWR Design Control Document Tier 2 Chapter 3 Appendices 3G – 3L", Revision 10
- e. DE-ES-0083, "Seismic Load Data for North Anna 3 from HGNE Analysis", Revision 0
- f. 26A6650, "ESBWR RCCV Structural Design Report", Revision 5
- g. 26A6651, "ESBWR Reactor Building Structural Design Report", Revision 5
- h. 26A6655, "ESBWR Fuel Building Structural Design Report", Revision 5
- i. 26A6605, "Design Specification for Concrete Containment", Revision 4
- j. 26A6606, "Design Specification for Reactor Building", Revision 2
- k. WG3-U71-ERD-S-0001, "North Anna 3 Reactor/Fuel Building Complex Seismic Analysis Report", Revision 3
- l. WG3-U71-ERD-S-0003, "North Anna 3 Reactor/Fuel Building Complex Stability Analysis Report", Revision 1
- m. SER-DMN-011, "Benchmarking of SASSI2010 MSM Results from NA3 Site-Specific SSI Analysis", Revision 1
- n. TODI WG3-A25-TDI-S-0004, "North Anna 3 RB/FB, CB & FWSC SSI Analyses EPRI 2013 GMPE Based Inputs", Revision 0
- o. SER-DMN-019 "RB/FB Seismic Analyses Bounding Results and In-Structure Response Spectra" , Revision 0
- p. WG3-U71-ERD-S-0004, "North Anna 3 Reactor Building Structural Design Report", Revision 0
- q. WG3-T11-DRD-S-0001, "North Anna 3 RCCV Structural Design Report", Revision 0
- r. SR3-1-A11-TRD-5202, Industry Codes and Standards Design Specification, Revision 0 A11-5202
- s. 26A6558, General Civil Design Criteria, Revision 4 A40-4010
- t. 26A6649, Reactor/Fuel Building Complex Heat Transfer Analysis Report, Revision 3 U71-5060
- u. 26A6608, Design Specification for Fuel Building, Revision 2 U97-4010



## 2.2 Industry Codes and Standards

The following industry codes and standards shall form a part of this document to the extent specified herein. Unless otherwise specified, the applicable revision of the industry codes and standards as indicated in the Industry Codes and Standards Design Specification (Reference 2.1.2-r) shall be used.

- a. ACI 349-01: "Code Requirements for Nuclear Safety Related Concrete Structures (ACI 349-01) and Commentary (ACI 349R-01)"
- b. ASME-2004: Boiler and Pressure Vessel Code, Section III, Rules for Construction of Nuclear Power Plant Components, Division 2, Subsection CC, "Code for Concrete Reactor Vessels and Containments"
- c. AISC N690-1994: "Specification for the Design, Fabrication, and Erection of Steel Safety-Related Structures for Nuclear Facilities," with the Supplements No.1 (2002) and No.2 (2004)
- d. ASCE 7-02: "Minimum Design Loads for Buildings and Other Structures"
- e. ASCE 4-98: "Seismic Analysis of Safety-Related Nuclear Structures"

## 2.3 Regulation and Regulatory Requirements

The following regulations and regulatory requirements shall form a part of this document to the extent specified herein. Unless otherwise specified, the applicable revision of the Standard Review Plans (SRP) and Regulatory Guides (RG) as indicated in the Standard Review Plans and Regulatory Guides Design Specification (Reference 2.1.2-a) shall be used.

- a. NUREG-0800, "USNRC Standard Review Plan for Review of Safety Analysis Reports for Nuclear Power Plants-Light Water Reactor Edition" Revision 4

## 2.4 References

- a. A Review of Procedures for the Analysis and Design of Concrete Structures to Resist Missile Impact Effects, R.P. Kennedy, Holmes and Narver, Inc. (Nuclear Engineering and Design article Vol. 37 1976, pages 183-203)
- b. Topical Report, Design of Structures for Missile Impact, Bechtel Power Corp., BC-TOP-9A Revision 2, September 1974

## 3. STRUCTURAL DESCRIPTION AND GEOMETRY

### 3.1 Structural Geometry and Dimensions

The FB is integrated with the RB, sharing a common wall between the RB and the FB and a large common foundation mat. The FB houses the spent fuel pool (SFP) facilities and their supporting system, and HVAC equipment. The FB is a Seismic Category I structure except



for the penthouse that houses HVAC equipment. The penthouse is a Seismic Category II structure, and the design of the penthouse is not included in this report.

The FB is a rigid box shape building, and its key dimensions are summarized in Table 3.1-1. Table 3.1-1 includes the key dimensions of the RB for reference. Floor plans and sections of the FB and RB are shown in Figures 3.1-1 through 3.1-7.

The NA3 site-specific seismic demands for sliding stability can be solved without shear key as shown in the NA3 RB/FB Stability Analysis Report, Reference 2.1.2-1. Therefore, shear key design is not contained in this report. The same shear keys as described in Reference 2.1.2-g are provided under the basemat for NA3.

### **3.2 Key Structural Elements and Descriptions**

The FB is a reinforced concrete shear wall structure consisting of walls and slabs and is supported by a foundation mat. Concrete framing is composite with concrete slab and used to support the slabs for vertical loads. As for the floor slab at EL 22,500, it is supported by steel girders.

The FB is a shear wall structure designed to accommodate all seismic loads with its walls and the connected floors. Therefore, frame members such as beams or columns are designed to accommodate deformations of the walls in case of earthquake conditions.

The SFP is composed with thick walls and bottom slab to satisfy the requirements of radiation shielding and to bear pressure loads of the contained water. The bottom slab of the SFP is a part of the FB basemat. The thickness of the basemat is increased to 5.5 m, whereas it is 4.0 m in other regions. The steel liner plates are installed at the inside surfaces of the SFP to prevent leakage, but the design of the steel liners is out of scope of this report.

### **3.3 Floor Layout and Elevations**

Floor layouts and sections of the FB are shown in Figures 3.1-1 through 3.1-7. The FB is a four-story (excluding the penthouse) building with rectangular shape floor plans. The FB structure is partially embedded with the top of basemat 16.0 meters below the finished ground level grade.

### **3.4 Conditions of Vicinity and Support**

In the ESBWR NA3 site-specific design, the buildings including the RB are designed under the condition that they are supported by the foundation soil that has the following properties corresponding to the Soft Site conditions described in WG3-U71-ERD-S-0004 “North Anna 3 Reactor Building Structural Design Report”, Reference 2.1.2-p. The soft site conditions are conservative for NA3 rock site because softer soils lead to larger structural deformations.

- Shear wave velocity: 300 m/s
- Unit weight: 0.0196 MN/m<sup>3</sup> (2.00 t/m<sup>3</sup>)



- Shear modulus:  $180 \text{ MN/m}^2$  ( $1.835 \times 10^4 \text{ t/m}^2$ )
- Poisson's Ratio: 0.478

### 3.5 Special Structural Features

The FB has the following structural feature.

- Steel girders supporting the slabs at EL 22,500 are connected with pinned joints at their both ends.

## 4. STRUCTURAL MATERIAL REQUIREMENTS

### 4.1 Concrete

The specified compressive strengths,  $f'_c$ , of the concrete at 28 days, or earlier, are as follows.

- basemat: 27.6 MPa (4,000 psi)
- others: 34.5 MPa (5,000 psi)

### 4.2 Reinforcement

Reinforcing steel is deformed billet steel conforming to ASTM A-615 grade 60. Minimum yield strength,  $F_y$ , is 413.6 MPa (60,000 psi).

### 4.3 Structural Steel

#### 4.3.1 Carbon Steel Plate and Shapes

Structural steel and fasteners of the FB conform to the following:

- Structural Steel: A572 Gr.50 (for girders)
- High strength bolts: ASTM A325 or A490
- Anchor bolts (rods): ASTM A36 or A307
- Steel floor decking: ASTM A446 with minimum  $f_y = 228 \text{ MPa}$  (33 ksi)
- Studs: ASTM A 108
- Pipe material: ASTM A-333 Gr. 1 or 6, and A312 tp 304L or 316L
- Forgings: ASTM A 350 Gr. LF1 or LF2, and A182 Type F304L/316L

#### 4.3.2 Stainless Steel Plate

N/A.



### 4.3.3 *Steel Decking*

Steel floor and roof decks conform to ASTM A446, Grade A, galvanized.

## 5. **STRUCTURAL LOADS**

The structural loads considered in the design are described in detail in the Reactor Building Structural Design Report, Reference 2.1.2-p. They are summarized below.

### 5.1 **Live Loads and Dead Loads**

#### 5.1.1 *Dead Loads*

Dead loads under normal operation condition are considered in the design. The following loads are included in the dead loads.

- Structural weight:
- Equipment weights: Refer to Table 5.1.1-1.
- Weight of miscellaneous structures, piping, and commodities: Refer to Table 5.1.1-2.
- Pool water hydrostatic loads  
Hydrostatic pressure loads due to the SPF pool water of 14.35 m deep is considered in the design.

#### 5.1.2 *Live Loads*

The following live loads are considered.

- Floor live loads: Refer to Table 5.1.2-1. Floor live loads for roofs are enveloping snow load.
- Snow loads: Refer to Figure 5.1.2-1.
- Static soil pressure: Refer to Table 5.1.2-2

The at-rest lateral pressures are for generic sites considered in the standard design and they are larger than the NA3 site-specific static lateral pressures and conservatively used for NA3.

### 5.2 **Transient Loads**

#### 5.2.1 *Pressure Loads*

Pressure loads includes the following loads.

- Containment pressure loads
- High Energy Line Break (HELB) loads

These loads are not applied to the FB structures directly. However, because the FB is integrated with the RB and RCCV, the loads applied to the RCCV are transferred to the FB



through the RB floor slabs. Therefore, the containment pressure load at the following event is considered in the FB design among the pressure loads considered in the RCCV and RB design.

1. Normal operation
2. LOCA – 5 seconds after Design Basis Accident (DBA)
3. LOCA – 6 minutes after DBA
4. LOCA – 10 hours after DBA
5. LOCA – 72 hours after DBA

Details of pressure loads are described in the RCCV Structural Design Report, Reference 2.1.2-q and the Reactor Building Structural Design Report, Reference 2.1.2-p.

### **5.2.2 Thermal Loads**

Thermal loads during normal operation, LOCA and DBA in the spent fuel pool due to loss of Fuel and Auxiliary Pools Cooling System (FAPCS) cooling function are considered. Both of summer and winter conditions are included in each phenomenon.

Table 5.2.2-1 and 5.2.2-4 show the temperature conditions during normal operation and DBA in the FB, respectively. LOCA thermal loads at the following event are considered in the FB design with the same reason as pressure loads.

1. Normal operation, Summer and Winter
2. LOCA – 5 seconds after DBA, Summer and Winter
3. LOCA – 6 minutes after DBA, Summer and Winter
4. LOCA – 10 hours after DBA, Summer and Winter
5. LOCA – 72 hours after DBA, summer and winter

The thermal loads in the spent fuel pool are considered for the following cases in combination with No.1 and No.5 of the above RCCV conditions.

1. Normal operation
2. DBA – 72hours after DBA due to loss of Fuel and Auxiliary Pools Cooling System (FAPCS) cooling function

Tables 5.2.2-2 and 5.2.2-3 based on Reference 2.1.2-t show the average temperature,  $T_d$ , and the surface temperature difference,  $T_g$ , at the normal operation in the FB regions that are shown in Figures 5.2.2-1 through 5.2.2-8. The thermal loads at the 72 hours after DBA in the spent fuel pool are shown in Tables 5.2.2-5 and 5.2.2-6.

The stress-free design temperature used in the stress analyses is 15.5 °C.

**5.2.3 Hydrodynamic Loads**

Hydrodynamic loads are not applied to the FB structures directly. However, because the FB is integrated with the RB and RCCV, the loads applied to the RCCV are transferred to the FB through the RB floor slabs. Therefore, the following hydrodynamic loads are considered in the FB design among the hydrodynamic loads considered in the RCCV and RB design.

1. Safety-Relief Valve (SRV) Loads
2. Chugging (CH) Load
3. Condensation Oscillation (CO) Load
4. Pool Swell

Details of hydrodynamic loads are described in the RCCV Structural Design Report , Reference 2.1.2-q and the Reactor Building Structural Design Report, Reference 2.1.2-p.

**5.2.4 RPV Reactions due to Hydrodynamic Loads**

RPV reactions due to hydrodynamic loads considered for the FB design are described in the Reactor Building Structural Design Report, Reference 2.1.2-p.

**5.3 Environmental Loads****5.3.1 Wind Loads**

Design conditions for calculating the basic wind load are as follows.

Basic wind speed (50 year recurrence interval), m/s (mph)	62.6 (140)
Importance Factors (Safety-related structures)	1.15
Exposure Category	Exposure D

Wind load values at each floor level are shown in Table 5.3.1-1. The evaluation of design wind loads is described in Reference 2.1.2-g.

**5.3.2 Tornado Loads**

Design conditions for calculating the tornado wind load are as follows.

Maximum Tornado wind speed, m/s (mi/hr)	147.5 (330)
Maximum Rotational Speed, m/s (mi/hr)	116.2 (260)
Maximum Translational Speed, m/s (mi/hr)	31.3 (70)
Radius, m (ft)	45.7 (150)
Maximum Pressure Drop, kPa (psi)	16.6 (2.4)



Maximum Rate of Pressure Drop, kPa/s (psi/s)	11.7 (1.7)
--	------------

Tornado load values at each floor level are shown in Table 5.3.2-1. The evaluation of design tornado loads is described in Reference 2.1.2-g.

### 5.3.3 Seismic Loads

The seismic loads considered in the FB design are those generated by the site-specific Safe Shutdown Earthquake (SSE).

The design seismic loads are determined from the site-specific soil-structure interaction (SSI) analysis results, which are described in the site-specific seismic analysis of the Reactor/Fuel Building Complex (Reference 2.1.2-k). Four components - two horizontal, one vertical, and one torsional - of the seismic loads are evaluated following the methodology used for the standard design of the FB in Reference 2.1.2-h. The out-of-plane loads due to horizontal SSE acceleration are considered as one of the horizontal components at walls, whose out-of-plane natural frequency is less than 50 Hz.

The design loads applied to the FB are shown in the following tables. Node numbers in the tables are described in Figure 5.3.3-1.

- Horizontal seismic loads and torsion: Table 5.3.3-1.
- Vertical seismic loads: Tables 5.3.3-2 and 5.3.3-3
- Out-of-plane accelerations at walls: Table 5.3.3-6

The equivalent out-of-plane acceleration loads on slabs and walls are based on Tables 4.5-1 and 4.5-2 of Reference 2.1.2-o. The details of calculation of the equivalent out-of-plane acceleration loads on slabs and walls are shown in Appendix D of Reference 2.1.2-k.

The following loads are also regarded as seismic loads, which are described in the Reactor Building Structural Design Report (Reference 2.1.2-p), and are considered in the FB design:

- Soil pressure due to an earthquake: Refer to Table 5.3.3-4.
- Sloshing loads in pools  
Hydrodynamic loads in the SFP due to SSE are shown in Table 5.3.3-5.

## 6. STRUCTURAL ANALYSIS AND DESIGN

### 6.1 General Description

The structural analysis and design of the FB are performed according to the following procedure.

1. Prepare a finite element (FE) model for stress analyses considering structural characteristics and materials.  
As stated in Section 3.1, the RB including RCCV and the FB are integrated into one



building in the ESBWR plant. Therefore, the FE model includes the RCCV, RB, and FB (RB/FB global FE model).

2. Perform stress analyses for the design loads described in Chapter 5, and calculate the section forces.
3. Select the basic and critical load combinations as the selected design load combinations for the FB design.
4. Combine the section forces according to the selected design load combinations mentioned in Step 3 above, which are described later in Section 6.3.
5. Perform structural design calculations using the section forces for the selected design load combinations.

The design/evaluation is essentially performed using ASME, Section III, Division 2. The details of the design/evaluations and the exceptions to the use of ASME, Section III, Division 2 are described in Section 6.4.1.1.

The design of steel structures in the FB is performed in accordance with AISC N690-1994.

## **6.2 Stress Analysis**

An outline of the RB/FB global FE model analysis is summarized below since it is described in detail in the Reactor Building Structural Design Report, Reference 2.1.2-p.

### **6.2.1 Analysis Program**

The computer program used for the stress analysis calculations is NASTRAN Version 2013.0.0. It is a general-purpose stress analysis program, which is technically based on the finite element method. Analysis calculations are executed on Red Hat Enterprise Linux Server release 5.7 OS.

### **6.2.2 Analysis Model**

Figure 1-1 shows the global FE model, which consists of SHELL elements for plane members such as the basemat, the RCCV, walls, and slabs and BAR elements for linear members such as beams and columns.

Table 6.2.2-1 shows the material constants for the concrete and steel used in the analysis.

The Young's modulus for concrete used in the thermal load analysis is reduced depending on the average temperature of each element, as described in Note 2 of Table 6.2.2-1. Young's modulus for the RCCV steel liners is set to a small value, 1/10000 of the normal value, in analysis calculations for non-thermal loads so that they do not bear any stresses.

### **6.2.3 Method of Applying Loads**

Refer to the Reactor Building Structural Design Report, Reference 2.1.2-p.



**6.2.4 Analysis Results**

Tables 6.2.4-1 through 6.2.4-5 show the element forces and moments of the selected elements. The locations of the selected elements are illustrated in Figures 6.2.4-1 through 6.2.4-5. The elements for tabulation are selected, in principle, from the center and both ends of wall and slab, where it is reasonably expected that the critical stresses appear based on engineering experience and judgment. Element forces and moments listed in the tables are defined with relation to the element coordinate system shown in Figure 6.2.4-6.

**6.3 Load Combinations**

**6.3.1 Code Requirements**

**Reinforced concrete structures**

The load combinations and associated load factors and acceptance criteria for reinforced concrete structures outside the containment are summarized in Table 6.3.1-1, which is in compliance with ACI 349-01 and SRP 3.8.4.

For the design of any structures which are integrated with the RCCV structures, the load combinations and associated load factors and acceptance criteria for the RCCV design are also considered. Therefore, Table 6.3.1-3, which is the load combination table for the RCCV design, is considered to the FB structures in addition to Table 6.3.1-1. Table 6.3.1-3 complies with ASME-2004.

**Steel structures**

The load combinations and associated load factors and acceptance criteria for steel structures outside the containment are summarized in Table 6.3.1-2, which is in compliance with AISC N690-1994 Code and SRP 3.8.4.

**6.3.2 Selection of Design Load Combinations**

**Reinforced concrete structures**

The following load combinations given in Tables 6.3.1-1 and 6.3.1-3 need not be considered, because of the reasons described for each of the load combinations in common with the RB.

No.	Reason
FB-C5	Stresses in the basemat and pool due to wind loads W are negligibly small, and the combination FB-C3 covers these combinations.
FB-C6 FB-C8	These combinations are almost identical to CV-5, CV-7, respectively.
FB-C9	This combination is almost identical to CV-11.
CV-2	Stresses in the basemat and pool due to wind loads W are negligibly small, and the combination CV-3 covers CV-2.



CV-4, 6	Stresses in the basemat and pool due to wind loads W or tornado loads Wt are negligibly small, and these combinations are not critical for their design.
CV-5	This combination is covered by CV-11.
CV-8, 9	These combinations are covered by CV-7.
CV-10	Stresses in the basemat and pool due to wind loads W are negligibly small, and the combination CV-7 covers CV-10.

Finally, the following load combinations are selected for reinforced concrete structures.

- FB-C1, FB-C2, FB-C3, FB-C4, FB-C7, CV-1, CV-3, CV-7, CV-11

Detailed design load combinations are determined in terms of load patterns for the selected load combinations. Load patterns include time of year for temperature loads, time after an accident for LOCA pressure/temperature loads, and load application patterns for hydrodynamic loads. The determined detail design combinations are shown in Table 6.3.2-1. The acceptance criteria for the selected combinations are also included in the tables. In addition, the load combinations selected as critical combinations in Appendix 3G of the ESBWR Design Control Document (DCD) are identified in the table.

**Steel structures**

Among the load combinations listed in Table 6.3.1-2, the following combination is negligible.

No.	Reason
FB-S1	This combination is covered by FB-S3.
FB-S2	This combination is covered by FB-S4.

The detail design combinations for the steel structures are shown in Table 6.3.2-2 together with acceptance criteria.

Some remarks concerning the determination of the detailed load combinations are mentioned below.

- Two kinds of temperature loads, summer and winter, are considered. Because of the uncertainties in the temperature loads, two combinations which are almost same but different in including the temperature load or not are always considered in the detailed load combinations.
- Seismic loads include the following.
  - Sloshing load of the spent fuel pool water
  - Dynamic increment of soil pressure



- Dynamic load, i.e. seismic loads and hydrodynamic loads are combined according to the SRSS method, as specified in Section 6.3.2 of RCCV Structural Design Report, Reference 2.1.2-p.
- For the tornado loads, the following combinations are considered in accordance with SRP 3.3.2.

$$W_t = W_w$$

$$W_t = W_p$$

$$W_t = W_w + 0.5W_p$$

where,

$W_w$ : Tornado wind load

$W_p$ : Tornado differential pressure load

### 6.3.3 Result of Load Combination

Tables 6.3.3-1 through 6.3.3-3 show the resultant combined forces and moments for the selected elements shown in Figures 6.2.4-1 through 6.2.4-5, which are calculated for several typical design load combinations selected from the combinations in Table 6.3.2-1.

Section forces due to the following loads are shown independently in the tables.

- OTHR: Loads other than temperature and seismic loads
- TEMP: Temperature loads
- SEIS: Seismic loads
- HYDR: Hydrodynamic loads

Element forces and moments listed in the tables are defined with relation to the element coordinate system shown in Figure 6.2.4-6.

## 6.4 Section Design Principles

### 6.4.1 Section Design of Reinforced Concrete Structures

The design/evaluation is essentially performed using ASME, Section III, Division 2. The details of the design/evaluations and the exceptions to the use of ASME, Section III, Division 2 are described in the following Sections. The design flow chart is shown in Figure 6.4.1-1.

#### 6.4.1.1 Walls and Slabs

Section design calculations for reinforced concrete walls and slabs are carried out for the following section forces and it is confirmed that the results satisfy code requirements.

- Flexure and Membrane Forces



- Membrane Axial Forces
- Transverse Shear
- In-plane Shear Force

The evaluation method for each of the section forces is described in the following subsections.

#### **6.4.1.1.1 Section Design for Flexure and Membrane Forces**

Stress conditions of the FB structure sections are actually very complicated since the various forces, such as axial forces, in-plane shear, bending moments, and torsional moments, are applied simultaneously. It is difficult to estimate the section strength of the section under such a complicated stress condition by the equations which are normally used in the design calculation.

Therefore, stress calculations for flexure and membrane forces are performed by a computer program SSDP-2D. The program has the following characteristics.

- It calculates concrete and rebar stresses under two dimensional equilibrium conditions for six components of the section forces in a shell element – two axial forces, two bending moments, in-plane shear, and torsional moment.
- It takes concrete cracks into account in the stress calculation. Cracked concrete is assumed not to bear tensile forces.
- It assumes concrete and rebars to be perfectly elastic.
- It considers the reduction of thermal stresses due to the decreased stiffness of a cracked concrete section.
- Transverse shear is generated in an element but is not considered in the equilibrium conditions. Stresses of shear ties are not calculated with SSDP-2D. The design method for transverse shear is described in Section 6.4.1.1.3.

In calculations with SSDP-2D, section forces including in-plane shear force, axial forces and bending moments are considered simultaneously. In SSDP-2D, the compressive stress distribution of concrete is based on the linear distribution which is proportional to the strain distribution at the section. Moment capacity based on this condition is more conservative than the moment capacity specified in ACI 349-01 which is based on the stress block for the compressive stress distribution of concrete. Therefore, the wall design with SSDP-2D is considered to be more conservative than the design specified in ACI 349-01. This is further demonstrated in Appendices B and C for separate ACI 349-01 check for in-plane shear and axial compression, respectively.

As for the thermal effects, section forces due to thermal loads, which are evaluated by NASTRAN analyses using uncracked concrete stiffness, are reduced considering the depth and direction of cracking in calculations with SSDP-2D. The cracked section properties are



used in the calculation only for the cracked sections. Furthermore, compatibility between strain distribution in a section and internal forces including reduced thermal stress is examined under an assumed crack condition in calculations with SSDP-2D. The calculations are continued until the compatibility of strain and internal forces are satisfied. During the iterative calculations, redistribution of internal forces and strains are considered adequately.

Table 6.4.1.1-1 shows the material properties used for the stress calculation. Allowable stresses specified in CC-3420 of ASME-2004 are used in the design, since they are not defined in ACI 349-01. Tables 6.4.1.1-2 and 6.4.1.1-3 show the allowable stresses of concrete and rebar.

As specified in the Design Specification for Fuel Building (Reference 2.1.2-u), strengths of concrete and rebars are reduced taking effects of elevated temperatures into consideration.

Reduction of concrete strength due to high temperature, which is based on averaged temperature,  $T_d$ , obtained from the heat transfer analysis, is determined based upon the average value of the following upper bound and lower bound equations.

- Lower bound reduction factor
  - $\phi = 1.0 - 0.0030 (T-21.1)$                        $21.1^{\circ}\text{C} (70^{\circ}\text{F}) \leq T \leq 121.1^{\circ}\text{C} (250^{\circ}\text{F})$
  - $\phi = 0.70 - 0.00083 (T-121.1)$                        $121.1^{\circ}\text{C} (250^{\circ}\text{F}) \leq T$
- Upper bound reduction factor
  - $\phi = 1.0$      $T \leq 260.0^{\circ}\text{C} (500^{\circ}\text{F})$
  - $\phi = 1.0 - 0.00081 (T-260.0)$                        $260.0^{\circ}\text{C} (500^{\circ}\text{F}) \leq T$

Reduction of reinforcing steel strength is based upon the following equation.

- Reduction Factor
  - $\phi = 1.0 - 0.000873 (T-21.1)$                        $21.1^{\circ}\text{C} (70^{\circ}\text{F}) \leq T \leq 204.4^{\circ}\text{C} (400^{\circ}\text{F})$

Allowable stresses listed in Tables 6.4.1.1-2 and 6.4.1.1-3 are reduced using these factors in calculations for load combinations including thermal loads.

**6.4.1.1.2 Section Design for Membrane Compressive Forces**

ASME-2004 specifies the allowable concrete stresses for membrane forces. It is necessary to confirm that the compressive stresses of the concrete due to membrane forces do not exceed the allowable stresses specified in CC-3420 of ASME-2004. Examinations for membrane compressive forces are also performed in the FB design in addition to examinations for flexure and membrane forces.

The principal membrane compressive stress  $\sigma_c$ , which is calculated by the following equation, is used for the evaluation.



$$\sigma_c = \frac{\sigma_x + \sigma_y}{2} - \sqrt{\left(\frac{\sigma_x - \sigma_y}{2}\right)^2 + \tau_{xy}^2} \quad (- \text{ for compression, } + \text{ for tension})$$

$$\sigma_x = \frac{N_x}{h}$$

$$\sigma_y = \frac{N_y}{h}$$

$$\tau_{xy} = \frac{N_{xy}}{h}$$

where  $N_x$ : x-direction axial force per unit length (Tension is positive.)

$N_y$ : y-direction axial force per unit length (Tension is positive.)

$N_{xy}$ : in-plane shear force per unit length

$h$ : element thickness

Table 6.4.1.1-4 shows the allowable membrane compressive stress of concrete. Reductions due to elevated temperatures described in Subsection 6.4.1.1.1 are applicable to these allowables.

#### 6.4.1.1.3 Section Design for Transverse Shear

Section design calculations for transverse shear are performed according to ACI 349-01, Chapter 11. It requires that the shear force at a section and section strength satisfy the following equation.

$$V_u \leq \phi(V_c + V_s)$$

where  $V_u$ : factored shear force at section per unit length

$V_c$ : nominal shear strength provided by concrete per unit length

$V_s$ : nominal shear strength provided by shear reinforcement per unit length

$\phi$ : strength reduction factor (=0.85)

The nominal shear strength provided by concrete,  $V_c$ , is calculated in accordance with Section 11.3.2 of ACI 349-01. The calculation method is shown in Figure 6.4.1.1-1. The nominal shear strength provided by shear reinforcement,  $V_s$ , is calculated by the following equation.

$$V_s = \rho_v f_y d, \quad V_s \leq 8\sqrt{f'_c} d \quad (\text{in English units})$$



where  $\rho_v$ : shear reinforcement ratio  
 $f_y$ : specified yield strength of rebar  
 $d$ : distance from extreme compression fiber to centroid of tension reinforcement  
 $f'_c$ : specified compressive strength of concrete

The transverse shear stress is evaluated in the direction of the maximum shear force, and the section forces for evaluation are calculated by the following equations.

$$V_u = \sqrt{Q_x^2 + Q_y^2}$$
$$M_u = M_x \sin^2 \theta + M_y \cos^2 \theta + 2M_{xy} \sin \theta \cos \theta$$
$$N_u = N_x \sin^2 \theta + N_y \cos^2 \theta + 2N_{xy} \sin \theta \cos \theta$$
$$\theta = \tan^{-1}(Q_x/Q_y)$$

In NASTRAN analyses, the transverse shear forces, i.e.,  $Q_x$  and  $Q_y$ , are calculated independently in X and Y directions, respectively. The resultant transverse shear forces, i.e. the maximum transverse shear force ( $V_u$ ), is calculated with SRSS method in order to consider transverse shear forces in two directions simultaneously. The value,  $\theta$  means the direction of the maximum shear force. The values  $N_u$  and  $M_u$  are also evaluated in the direction of the maximum shear force.

#### 6.4.1.2 Columns and Girders

Structural design of reinforced concrete columns and girders is performed according to the following principles.

- Section design is performed by confirming strength ratios are less than 1.0 for each component of section forces, i.e., axial force, bending moment and shear force. Strength ratios are calculated by dividing section forces by corresponding section strengths including strength reduction factors defined in ACI 349-01.
- Rebar arrangements are determined based on the results of section design calculations and according to structural specifications on rebar arrangements described in ACI 349-01.
- Section forces due to thermal loads are reduced considering concrete cracking.
- Section forces are evaluated at both ends of bar elements, which are used to model frame members in the FE stress analyses.
- Columns are designed in two principal directions. Bending moments and shear forces are assumed to act in each independent direction. Effects of the bi-axial bending are neglected in the design because the effects are required to be considered only for slender columns in the ACI code.



- Girders with slabs are designed only in the out-of-plane direction with regard to the slabs, since in-plane deformations are restricted. For the in-plane direction (weak-axis direction), skin rebars are arranged according to ACI standards, but section strengths are, in principle, not examined.

#### 6.4.1.2.1 Strength Reduction Factor

Strength reduction factor  $\phi$  is defined in ACI 349-01 as follows.

- Axial force with bending moment:

$$p\phi = \begin{cases} 0.90 & (p\phi \cdot P_n \leq 0) \\ 0.70 + 0.20 \left( 1 + \frac{p\phi \cdot P_n}{P_m} \right) & (0 < p\phi \cdot P_n < 0.1f_c' A_g) \\ 0.70 & (p\phi \cdot P_n \geq 0.1f_c' A_g) \end{cases}$$

$$P_m = \begin{cases} 0.1f_c' A_g & (f_y \leq 60,000 \text{ psi and } (h-d'-d_s)/h \geq 0.70) \\ \min(0.1f_c' A_g, p\phi \cdot P_b) & (\text{others}) \end{cases}$$

where:

$P_n$ : nominal strength for axial force at given eccentricity

$P_b$ : nominal axial load strength at balanced strain conditions

$f_c'$ : specified compressive strength of concrete

$A_g$ : gross area of section

$f_y$ : specified yield strength of reinforcement

$h$ : overall thickness of member

$d'$ : distance from extreme compression fiber to centroid of compression reinforcement

$d_s$ : distance from extreme tension fiber to centroid of tension reinforcement

- Shear force

$$v\phi = 0.85$$

#### 6.4.1.2.2 Section Design for Axial Forces and Bending Moments

Section strengths for axial forces and bending moments are calculated based on the following assumptions, which conform to ACI 349-01, and on equilibrium conditions of section forces and conformity conditions of strains.

- Tensile strength and stiffness of concrete are ignored.



- Stress-strain relationship of concrete is perfectly elasto-plastic, in which design compressive strength is  $0.85 f'_c$  (See Figure 6.4.1.2-1).
- Section forces due to thermal loads are reduced considering concrete cracks. The reduction method is in accordance with SSDP-2D, which is described in the Subsection 6.4.1.1.1.
- Design section strengths are obtained from section strengths and strength reduction factor  $\phi$ . Strength ratios are calculated, as illustrated in Figure 6.4.1.2-2, by dividing design section forces by design section strengths. Section design for axial force and bending moment is completed by confirming that strength ratios are less than 1.0 as follows.

$$P_u / \phi P_n < 1.0 \text{ and } M_u / \phi M_n < 1.0$$

#### 6.4.1.2.3 Section Design for Shear Forces

It is confirmed that the following equation is satisfied in the section design for shear forces.

$$V_u \leq \phi (V_c + V_s)$$

where

$V_u$  : factored shear force at section

$V_c$  : nominal shear strength provided by concrete

$V_s$  : nominal shear strength provided by shear reinforcement

$\phi$  : strength reduction factor (=0.85)

Nominal shear strength provided by concrete,  $V_c$ , is evaluated as follows.

$N_u > 0$  (compression)

$$V_c = \min(V_{c1}, V_{c2})$$

$$V_{c1} = \left( 1.9 \sqrt{f'_c} + 2500 \rho_w \frac{V_u \cdot d}{M_m} \right) b_w d$$

$$V_{c2} = 3.5 \sqrt{f'_c} \cdot b_w d \sqrt{1 + \frac{N_u}{500 A_g}}$$

$$M_m = M_u - N_u \frac{(4h - d)}{8}$$

$$\text{if } M_m < 0, V_c = V_{c2}$$

$N_u < 0$  (tension)



$$V_c = 2 \left( 1 + \frac{N_u}{500A_g} \right) \sqrt{f'_c} \cdot b_w d$$

where:

$V_c$  : nominal shear strength provided by concrete

$f'_c$  : specified compressive strength of concrete

$M_u$  : factored moment at section

$N_u$  : factored axial load normal to cross section occurring simultaneously with  $V_u$

$V_u$  : factored shear force at section

$\rho_w$  : ratio of shear reinforcement

$b_w$  : width of section

$d$  : distance from extreme compression fiber to centroid of longitudinal tension rebar

$h$  : overall thickness of member

$A_g$  : gross area of section

Nominal shear strength provided by shear reinforcement,  $V_s$ , is evaluated as follows.

$$V_s = \rho_w r f_y \cdot b_w \cdot d \text{ and } V_s \leq 8 \sqrt{f'_c} \cdot b_w \cdot d$$

where:

$V_s$  : nominal shear strength provided by shear reinforcement

$\rho_w$  : ratio of shear reinforcement

$f_y$  : specified yield strength of shear reinforcement

$b_w$  : width of section

$d$  : distance from extreme compression fiber to centroid of longitudinal tension rebar

$f'_c$  : specified compressive strength of concrete

## 6.4.2 Section Design of Steel Structures

Section design of steel member is performed according to AISC N690-94. Steel members are examined by the evaluation method described in the following subsections.

The design flow of steel structures is almost same as the flow of reinforced concrete structures which is shown in Figure 6.4.1-1. However, reductions of thermal stresses are not considered for the steel design.

### 6.4.2.1 Section Design for Axial Compression and Bending

Steel members subjected to both axial compression and bending stresses shall be proportioned to satisfy the following requirements:



$$\frac{f_a}{F_a} + \frac{C_{mx} f_{bx}}{\left(1 - \frac{f_a}{F'_{ex}}\right) F_{bx}} + \frac{C_{my} f_{by}}{\left(1 - \frac{f_a}{F'_{ey}}\right) F_{by}} \leq 1.0 \quad (6.4.2-1)$$

$$\frac{f_a}{0.60 F_y} + \frac{f_{bx}}{F_{bx}} + \frac{f_{by}}{F_{by}} \leq 1.0 \quad (6.4.2-2)$$

When  $f_a/F_a \leq 0.15$ , Equation (6.4.2-3) is permitted in lieu of Equation (6.4.2-1) and (6.4.2-2):

$$\frac{f_a}{F_a} + \frac{f_{bx}}{F_{bx}} + \frac{f_{by}}{F_{by}} \leq 1.0 \quad (6.4.2-3)$$

In Equations (6.4.2-1), (6.4.2-2) and (6.4.2-3), the subscripts  $x$  and  $y$ , combined with subscripts  $b$ ,  $m$  and  $e$ , indicate the axis of bending about which a particular stress or design property applies, and

$F_a$  = Axial compressive stress that would be permitted if axial force alone existed, ksi

$F_b$  = Compressive bending stress that would be permitted if bending moment alone existed, ksi

$$F'_e = \frac{12\pi^2 E}{23(Kl_b / r_b)^2}$$

= Euler stress divided by a factor of safety, ksi (In the expression for  $F'_e$ ,  $l_b$  is the actual unbraced length in the plane of bending and  $r_b$  is the corresponding radius of gyration.  $K$  is the effective length factor in the plane of bending.)

$f_a$  = Computed axial stress, ksi

$f_b$  = Computed compressive bending stress at the point under consideration, ksi

$C_m$  = Coefficient whose value shall be taken as follows:

- a. For compression members in frames subject to joint translation (sidesway),  
 $C_m = 0.85$ .
- b. For rotationally restrained compression members in frames braced against joint translation and not subject to transverse loading between their supports in the plane of bending,

$$C_m = 0.6 - 0.4 (M_1/M_2).$$



where  $M_1/M_2$  is the ratio of the smaller to larger moments at the ends of that portion of the member unbraced in the plane of bending under consideration.  $M_1/M_2$  is positive when the member is bent in reverse curvature, negative when bent in single curvature.

- c. For compression members in frames braced against joint translation in the plane of loading and subjected to transverse loading between their supports, the value of  $C_m$  may be determined by an analysis. However, in lieu of such analysis, the following values are permitted:
  - i. For members whose ends are restrained against rotation in the plane of bending .....  $C_m = 0.85$
  - ii. For members whose ends are unrestrained against rotation in the plane of bending .....  $C_m = 1.0$

**6.4.2.2 Section Design for Axial Tension and Bending**

Steel members subjected to both axial tension and bending stresses shall be proportioned at all points along their length to satisfy the following requirement:

$$\frac{f_a}{F_t} + \frac{f_{bx}}{F_{bx}} + \frac{f_{by}}{F_{by}} \leq 1.0 \tag{6.4.2-4}$$

where  $f_b$  is the computed bending tensile stress,  $f_a$  is the computed axial tensile stress,  $F_b$  is the allowable bending stress and  $F_t$  is the governing allowable tensile stress.

**6.4.2.3 Section Design for Transverse Shear**

Steel members subjected to transverse shear stress shall be proportioned to satisfy the following requirement:

$$\frac{f_v}{F_v} \leq 1.0 \tag{6.4.2-5}$$

where  $f_v$  is the computed shear stress and  $F_v$  is the governing allowable shear stress.

**6.4.2.4 Allowable Stresses**

**6.4.2.4.1 Allowable Axial Tensile Stress**

On the gross section of axially loaded tension members, the allowable stress is:

$$F_t = 0.60F_y \tag{6.4.2-6}$$



where  $F_y$  is the specified minimum yield stress of the type of steel being used, ksi.

#### 6.4.2.4.2 Allowable Axial Compressive Stress

On the gross section of axially loaded compression members, when  $Kl/r$ , the largest effective slenderness ratio of any unbraced segment is less than  $C_c$ , the allowable stress is:

$$F_a = \frac{\left[ 1 - \frac{(Kl/r)^2}{2C_c^2} \right] F_y}{\frac{5}{3} + \frac{3(Kl/r)}{8C_c} - \frac{(Kl/r)^3}{8C_c^3}} \quad (6.4.2-7)$$

where

$$C_c = \sqrt{\frac{2\pi^2 E}{F_y}}$$

$E$  = Modulus of elasticity of steel, ksi

On the gross section of axially loaded compression members, when  $Kl/r$  exceeds  $C_c$ , the allowable stress is:

$$F_a = \frac{12\pi^2 E}{23(Kl/r)^2} \quad (6.4.2-8)$$

#### 6.4.2.4.3 Allowable Bending Stress of W-shaped Members (Strong Axis Bending)

The allowable stress for the strong axis bending of W-shaped members is given according to the procedure shown in Figure 6.4.2-1.

#### 6.4.2.4.4 Allowable Bending Stress of W-shaped Members (Weak Axis Bending)

The allowable stress for the weak axis bending of W-shaped members is given according to the procedure shown in Figure 6.4.2-2.

#### 6.4.2.4.5 Allowable Bending Stress of Box Members

The allowable bending stress of box members is given according to the procedure shown in Figure Figure 6.4.2-3.

#### 6.4.2.4.6 Allowable Shear Stress

For  $h/t_w \leq 380/\sqrt{F_y}$ , on the overall depth times the web thickness, the allowable shear stress is:



$$F_v = 0.40F_y \quad (6.4.2-9)$$

For  $h/t_w > 380/\sqrt{F_y}$ , the allowable shear stress on the clear distance between flanges times the web thickness is:

$$F_v = \frac{F_y}{2.89}(C_v) \leq 0.40F_y \quad (6.4.2-10)$$

where

$$C_v = \frac{45000k_v}{F_y(h/t_w)^2} \text{ when } C_v \text{ is less than } 0.8$$

$$= \frac{190}{h/t_w} \sqrt{\frac{k_v}{F_y}} \text{ when } C_v \text{ is more than } 0.8$$

$$k_v = 4.00 + \frac{5.34}{(a/h)^2} \text{ when } a/h \text{ is less than } 1.0$$

$$= 5.34 + \frac{4.00}{(a/h)^2} \text{ when } a/h \text{ is more than } 1.0$$

$t_w$  = thickness of web, in.

$a$  = clear distance between transverse stiffeners, in.

$h$  = clear distance between flanges at the section under investigation, in.

## 7. SUMMARY OF RESULTS

### 7.1 Required Section

Figures 7.1-1 through 7.1-4 shows typical sections of the FB concrete structures.

The steel members, i.e., steel girders at EL 22,500, are shown in Figure 7.1-5.

### 7.2 Provided Section

The sections of the FB structures that have been provided are identical to the required sections described in Section 7.1.



### 7.3 Tabulation of Allowable Stresses versus Calculated Stresses

#### 7.3.1 Reinforced Concrete Structure

##### 7.3.1.1 Walls and Slabs

###### 7.3.1.1.1 Calculations for Flexure and Membrane Forces

The stresses of the concrete and reinforcing steel are calculated for flexure and membrane forces. The calculations are performed for the selected design load combinations shown in Table 6.3.2-1, and it is confirmed that all values are less than their allowable stresses, except for the exterior wall at EL 4,650 to EL 6,600 with 3% exceedance. This exceedance is evaluated based on the moment capacity according to ASME-2004, conservatively. As shown in Figure 7.3.1.1-1, it is confirmed that the load demands are within the moment capacity of wall according to the specifications of ACI 349-01.

The calculation results for the selected elements shown in Figures 6.2.4-1 through 6.2.4-5 are given in this report. The thicknesses and the rebar arrangements of selected element are shown in Table 7.3.1.1.1-1. The arrangements of reinforcements and shear ties at the exterior wall on columns FA and FF at EL 4,650 to EL 6,600 are updated from standard design as shown in red in Table 7.3.1.1.1-1.

Calculated stresses and allowable stresses are compared in Tables 7.3.1.1.1-2 through 7.3.1.1.1-4 for several load combinations.

Table 7.3.1.1.1-5 shows a summary of the maximum stress ratios, which are ratios of the maximum stresses to the allowable stresses.

For shear walls and Spent Fuel Pool walls, the maximum stress of vertical rebar is found to be 257.3 MPa (37.30 ksi) at Section 2 due to the load combination FB-9 against the allowable stress of 372.2 MPa (53.97 ksi) as shown in Table 7.3.1.1.1-4. The maximum stress of horizontal rebar is found to be 333.3 MPa (48.33 ksi) at Section 2 for the combination FB-9 against the allowable stress of 372.2 MPa (53.97 ksi) as shown in Table 7.3.1.1.1-4. The maximum concrete stress is found to be -22.1 MPa (-3.20 ksi), which occurs at Section 3 due to load combination FB-9 against the allowable stress of -29.3 MPa (-4.25 ksi), as shown in Table 7.3.1.1.1-4.

For floor slabs, the maximum rebar stress of 133.5 MPa (19.36 ksi) is found due to the load combination FB-9 against the allowable stress of 372.2 MPa (53.97 ksi) as shown in Table 7.3.1.1.1-4. The maximum concrete stress is found to be -8.7 MPa (-1.26 ksi) due to load combination FB-9 against the allowable stress of -29.3 MPa (-4.25 ksi), as shown in Table 7.3.1.1.1-4.

For foundation mat, the maximum rebar stress is found to be 111.5 MPa (16.17 ksi) due to the load combination FB-9 against the allowable stress of 367.2 MPa (53.24 ksi) as shown in Table 7.3.1.1.1-4. The maximum concrete stress is found to be -7.0 MPa (-1.02 ksi) due to



load combination FB-9 against the allowable stress of -22.9 MPa (-3.32 ksi), as shown in Table 7.3.1.1.1-4.

#### **7.3.1.1.2 Calculations for Membrane Compressive Forces**

The compressive stress of concrete is calculated for membrane forces. The calculations are performed for the selected design load combinations shown in Table 6.3.2-1, and it is confirmed that the values are less than the allowable stress.

Table 7.3.1.1.2-1 gives a summary of the maximum compressive stresses for selected elements shown in Figures 6.2.4-1 through 6.2.4-5.

For shear walls and Spent Fuel Pool walls, the maximum compressive stress of -9.094 MPa (-1.319 ksi) is found at Section 1 against the allowable stress of -25.9 MPa (-3.756 ksi) as shown in Table 7.3.1.1.2-1.

For floor slabs, the maximum compressive stress of -3.689 MPa (-0.535 ksi) is found against the allowable stress of -25.9 MPa (-3.756 ksi) as shown in Table 7.3.1.1.2-1.

For foundation mat, the maximum compressive stress of -2.576 MPa (-0.374 ksi) is found against the allowable stress of -16.6 MPa (-2.407 ksi) as shown in Table 7.3.1.1.2-1.

#### **7.3.1.1.3 Calculations for Transverse Shear**

The transverse shear strength is calculated and compared with shear forces generated by design loads. The calculations are performed for the selected design load combinations shown in Table 6.3.2-1, and it is confirmed section forces are less than the shear strength of sections.

Table 7.3.1.1.3-1 gives a summary of the examinations for selected elements shown in Figures 6.2.4-1 through 6.2.4-5. Table 7.3.1.1.3-2 shows the calculation results for the load combinations selected for the DCD that are indicated in Table 6.3.2-1.

For shear walls and Spent Fuel Pool walls, the maximum transverse shear force is found to be 4.04 MN/m (23.1 kips/in) against the shear strength of 11.08 MN/m (63.25 kips/in) at Section 1, Exterior Wall and Pool Wall as shown in Table 7.3.1.1.3-2.

For floor slabs, the maximum transverse shear force is found to be 0.97 MN/m (5.54 kips/in) against the shear strength of 4.35 MN/m (24.8 kips/in) as shown in Table 7.3.1.1.3-2.

For foundation mat, the maximum transverse shear force is found to be 5.35 MN/m (30.54 kips/in) against the shear strength of 16.05 MN/m (91.62 kips/in) as shown in Table 7.3.1.1.3-2.

#### **7.3.1.2 Columns and Beams**

Design section strengths for axial forces, bending moments, and shear forces are calculated, and compared with section forces and moments generated by design loads. The calculations



are performed for the selected design load combinations shown in Table 6.3.2-1, and it is confirmed that all design section forces and moments are less than design section strengths.

The calculation results for the selected elements shown in Figure 7.3.1.2-1 are given in this report.

Tables 7.3.1.2-1 and 7.3.1.2-2 give a summary of the maximum strength ratios, which are defined in Subsection 6.4.1.2.

### 7.3.2 *Steel Structure*

The stresses of the steel members are combined in accordance with Table 6.3.2-2, and it is confirmed that all values are less than the allowable stresses.

Table 7.3.2-1 lists the calculation results of the selected sections included in Figure 7.3.1.2-1. The stress ratios of the design stresses against their allowable stresses shown in the tables are the maximum ratios among all the load combinations.

## 8. CONCLUSIONS

The site-specific stress check calculations for the FB structure are performed to evaluate the structural integrity of the FB at the NA3 site per the specifications of ACI 349-01, ASME-2004, and AISC N690-1994, following the same methodology as that used for the standard design. The stress checks are based on the results of the RB/FB global model analyses for the site-specific seismic loads combined together with the non-seismic load results according to site-specific seismic load combinations. The conclusions from the site-specific stress checks are summarized as follows:

- Reinforced concrete walls and slabs
  - The stresses of the concrete and rebar are less than the allowable stresses specified in the code, except for the exterior wall at EL 4,650 to EL 6,600 with 3% exceedance. This exceedance is evaluated based on the moment capacity according to ASME-2004, conservatively. As shown in Figure 7.3.1.1-1, it is confirmed that the load demands are within the moment capacity of wall according to the specifications of ACI 349-01. The arrangements of reinforcement at the exterior wall at EL 4,650 to EL 6,600 are updated from the standard design as shown in red in Table 7.3.1.1.1-1.
  - The sections have enough strength to bear transverse shear forces generated by design loads. The arrangements of shear ties at the exterior wall at EL 4,650 to EL 6,600 are updated from the standard design as shown in red in Table 7.3.1.1.1-1.
- Reinforced concrete columns and girders
  - The sections have enough strength to bear axial forces, bending moments, and shear forces generated by design loads.
- Steel structures



- The stresses of steel members are less than the allowable stresses specified in the code.

The comparison between NA3 and the standard design is shown in Appendix A.

In addition, the following structural evaluations are performed for the FB separately:

- The stability of the RB/FB at the NA3 site is demonstrated to resist the dynamic load demand without the shear keys that are part of the standard design of the RB/FB, as described in the "Reactor/Fuel Building Complex Stability Analysis Report," Reference 2.1.2-1.
- Tornado missile impact assessment is shown in Reference 2.1.2-g.

Therefore, it can be concluded that the FB structure is adequately designed to resist the NA3 site-specific SSE loads in combination with non-seismic standard plant loads.

**Table 3.1-1 Key Dimensions of RB and FB**

<b>Building</b>	<b>Dimension</b>		<b>Notes</b>
Reactor Building	Story	six stories (above grade) three stories (below grade)	The design plant grade is 16.15 m from the top of basemat
	Plan	49.0 m × 49.0 m (below EL 34.0 m) 49.0 m × 39.0 m (above EL 34.0 m)	
	Height	64.2 m	From the top of the basemat
Fuel Building	Story	one story (above grade) three stories (below grade)	(excluding the penthouse) The design plant grade is 16.15 m from the top of basemat
	Plan	21.0 m × 49.0 m	
	Height	34.0 m	From the top of the basemat (excluding the penthouse)
Common	Thickness of Basemat	4.0 m	The thickness is increased to 5.1 m inside of the RPV Pedestal and 5.5 m at the bottom of the Spent Fuel Pool.



**Table 5.1.1-1 Dead Loads of Equipment in FB**

Elevation (m)	Item No.*	Description	Weight				Area Load (kN/m <sup>2</sup> )
			unit (kN)	qt.	margin	Sum up (kN)	
-11.50	F-1	Skimmer Tank	353	1	0.2	424	
	F-2	Spent Fuel Racks	16,239	1	0.2	19487	
	F-3	Spent Fuel Cask					120
	F-4	Fuel and Auxiliary Pools Cooling Backwash Tank Room	353	1	0.2	424	
	F-5	Fuel and Auxiliary Pools Cooling Heat Exchange Room	236	1	0.2	284	
	F-6	Sump Room	95	1	0.2	114	
	F-7	Fuel and Auxiliary Pools Cooling Transfer Pump Room	17	2	0.2	41	
	F-8	Fuel and Auxiliary Pools Cooling Pump Room	112	1	0.2	134	
-6.40	F-11	Fuel and Auxiliary Pools Cooling Filter/Demineralizer Vault	142	2	0.2	341	
	F-12	FAPC Holding Pump Room	37	1	0.2	45	
	F-13	Control Rod Drive Maintenance Area	49	1	0.2	59	
	F-14	Control Rod Drive Maintenance Control Panel Room	38	1	0.2	46	
	F-15	Control Rod Drive Motor Test Room	98	1	0.2	118	
-1.00	F-21	New Fuel Prep Machine Pit	12	1	0.2	15	
4.65	CR-1	Fuel Handling Machine	343	1	0.2	412	
13.57	CR-2	Fuel Building Crane	1079	1	0.2	1295	
	CR-3	Lifted Load	1750	1	-	1750	
22.50	F-61a	HVAC Penthouse	112	2	0.2	269	
	F-61b	HVAC Penthouse	112	2	0.2	269	
	F-61c	HVAC Penthouse	174	2	0.2	416	
	F-61d	HVAC Penthouse	322	2	0.2	772	
	F-61e	HVAC Penthouse	292	2	0.2	701	

General Note: The values shown in this table are based on the following Design Specifications.

- 26A6605 Design Specification for Concrete Containment, Rev. 3
- 26A6606 Design Specification for Reactor Building, Rev. 2
- 26A6608 Design Specification for Fuel Building, Rev. 1

Note \*: Refer to Figures 5.1.1-1 through 5.1.1-9 of Reference 2.1.2-p.



**Table 5.1.1-2 Miscellaneous Structures, Piping, and Commodities on the Slabs**

<b>Elevation (m)</b>	<b>Piping Area Load (kN/m<sup>2</sup>)</b>	<b>Note</b>
27.50	0.0	FB roof slab of penthouse
22.50	2.4	
4.65	2.4	
-1.00	2.4	
-6.40	2.4	
-11.50	2.4	

**Table 5.1.2-1 Floor Live Loads**

Elevation (m)	Area Load (kN/m <sup>2</sup> )	Remarks
27.50	2.9	FB roof slab of penthouse
22.50	2.9	
4.65	4.8	
-1.00	4.8	
-6.40	4.8	
-11.50	4.8	

**Table 5.1.2-2 Design Lateral Soil Pressure at-Rest**

Elevation (m)	Soil Pressure (kN/m <sup>2</sup> )			Note
	RB on R1 column-row Wall	FB on FA column-row Wall	Other Walls	
4.65	11.0	175.4	11.0	Design plant grade
4.04	21.9	186.3	21.9	Water level
-1.00	127.7	292.1	127.7	
-4.20	194.9			Bottom level of basemat of TB
-4.20	457.9	359.3	194.9	
-6.40	504.1	405.5	241.0	
-11.50	611.1	512.5	348.1	
-15.50	695.1	596.5	432.0	Bottom level of basemat



**Table 5.2.2-1 Steady State Temperature Conditions**

Region	Temperature (°C)		Note
	Summer	Winter	
Rooms	40.0	10.0	
Spent Fuel Pool	48.9	48.9	
Air	46.1	-40.0	
Ground	15.5	15.5	



**Table 5.2.2-2 Thermal Loads for Shell Elements Normal Operation: Summer**

Location	Index	Boundary*		Thickness (mm)	Td (°C)	Tg (°C)	note
		1	2				
Basemat	BM1	RM	GR	4000	27.07	23.15	General
	BM6	FP	GR	5500	32.20	33.40	below Spent Fuel Pool
	BM7	FP	GR	4000	32.20	33.40	Skimmer Surge Tank
Spent Fuel Pool Wall	FP7	FP	RM	1500	45.05	7.70	
	FP8	FP	RM	1900	44.94	7.92	
	FP9	FP	RM	1750	44.97	7.85	around Skimmer Surge Tank
	FP10	FP	RM	2000	44.91	-7.96	
	FP11	FP	FP	1900	48.90	0.00	
	FP12	FP	FP	1750	48.90	0.00	between Skimmer Surge Tanks
Outer Wall	BW1	RM	GR	2000	26.47	21.94	below Grade General
	BW5	FP	GR	2000	32.19	33.39	below Grade Spent Fuel Pool
	BW6	FP	GR	3600	32.20	33.39	
	GW9	RM	AT	1000	43.49	-4.77	EL 27000 to Room
Inner Wall	IW1	RM	RM		40.00	0.00	General
Slab	SL1	RM	RM		40.00	0.00	General
	SL8	RM	AT	700	43.63	-4.36	FB Roof at EL 22500

\*: RM: Room                      FP: Spent Fuel Pool  
GR: Ground                      AT: Outside Air

**Table 5.2.2-3 Thermal Loads for Shell Elements Normal Operation: Winter**

Location	Index	Boundary*		Thickness (mm)	Td (°C)	Tg (°C)	note
		1	2				
Basemat	BM1	RM	GR	4000	12.90	-5.20	General
	BM6	FP	GR	5500	32.20	33.40	below Spent Fuel Pool
	BM7	FP	GR	4000	32.20	33.40	Skimmer Surge Tank
Spent Fuel Pool Wall	FP7	FP	RM	1500	32.07	33.63	
	FP8	FP	RM	1900	31.58	34.62	
	FP9	FP	RM	1750	31.74	34.30	around Skimmer Surge Tank
	FP10	FP	RM	2000	31.48	-34.82	
	FP11	FP	FP	1900	48.90	0.00	
	FP12	FP	FP	1750	48.90	0.00	between Skimmer Surge Tanks
Outer Wall	BW1	RM	GR	2000	13.04	-4.93	below Grade General
	BW5	FP	GR	2000	32.19	33.39	below Grade Spent Fuel Pool
	BW6	FP	GR	3600	32.20	33.39	
	GW9	RM	AT	1000	-18.80	39.27	EL 27000 to Room
Inner Wall	IW1	RM	RM		10.00	0.00	General
Slab	SL1	RM	RM		10.00	0.00	General
	SL8	RM	AT	700	-19.97	35.96	FB Roof at EL 22500

\*: RM: Room                      FP: Spent Fuel Pool  
GR: Ground                      AT: Outside Air

**Table 5.2.2-4 Design Basis Accident Temperatures in Spent Fuel Pool**

Time		Temperature (°C)
(hr.)	(sec)	
0.00	0	48.9
0.06	200	49.2
0.28	1000	50.5
0.50	1800	51.8
1.00	3600	54.7
5.00	18000	77.7
8.86	31900	100.0
10.00	36000	100.0
20.00	72000	100.0
72.00	259200	100.0

Note: DBA for the spent fuel pool is due to loss of Fuel and Auxiliary Pools Cooling System (FAPCS) cooling function.

The temperature after 8.86hrs. correspond to the spent fuel pool temperature at 100 °C (212 °F), which is slightly less than the 104 °C (219 °F) water boiling temperature. The slight 4% increase in the spent fuel pool temperature is negligible to the design of the spent fuel pool structure. This is because there are sufficient stress margins in accordance with Tables 7.3.1.1.1-5, 7.3.1.1.2-1, and 7.3.1.1.3-1, even if the total combined stresses were increased by 4%, which would be very conservative since stresses other than thermal in the load combination do not increase.



**Table 5.2.2-5 Thermal Loads for Shell Elements around Spent Fuel Pool:  
72 hr. after DBA: Summer**

Location	Index	Boundary*		Thickness (mm)	Td (°C)	Tg (°C)	note
		1	2				
Basemat	BM6	FP	GR	5500	36.74	56.83	below Spent Fuel Pool
	BM7	FP	GR	4000	38.45	63.68	Skimmer Surge Tank
Spent Fuel Pool Wall	FP7	FP	RM	1500	61.65	57.12	
	FP8	FP	RM	1900	58.10	54.97	
	FP9	FP	RM	1750	59.26	56.04	around Skimmer Surge Tank
	FP10	FP	RM	2000	57.42	-54.16	
	FP11	FP	FP	1900	75.29	0.00	
	FP12	FP	FP	1750	77.51	0.00	between Skimmer Surge Tanks
Outer Wall	BW5	FP	GR	2000	44.70	79.61	below Grade Spent Fuel Pool
	BW6	FP	GR	3600	39.14	66.16	

\*: RM: Room                      FP: Spent Fuel Pool  
GR: Ground                      AT: Outside Air

**Table 5.2.2-6 Thermal Loads for Shell Elements around Spent Fuel Pool:  
72 hr. after DBA: Winter**

Location	Index	Boundary*		Thickness (mm)	Td (°C)	Tg (°C)	note
		1	2				
Basemat	BM6	FP	GR	5500	36.74	56.83	below Spent Fuel Pool
	BM7	FP	GR	4000	38.45	63.68	Skimmer Surge Tank
Spent Fuel Pool Wall	FP7	FP	RM	1500	48.67	83.06	
	FP8	FP	RM	1900	44.74	81.67	
	FP9	FP	RM	1750	46.02	82.49	around Skimmer Surge Tank
	FP10	FP	RM	2000	43.99	-81.01	
	FP11	FP	FP	1900	75.29	0.00	
	FP12	FP	FP	1750	77.51	0.00	between Skimmer Surge Tanks
Outer Wall	BW5	FP	GR	2000	44.70	79.61	below Grade Spent Fuel Pool
	BW6	FP	GR	3600	39.14	66.16	

\*: RM: Room                      FP: Spent Fuel Pool  
GR: Ground                      AT: Outside Air



**Table 5.3.1-1 Design Wind Pressure Loads by Floor Level**

Height (m)		Design Wind Load (kN/m <sup>2</sup> )			
EL	Z	Windward Wall	Leeward Wall	Side Wall	Roof
52.40	47.75	3.13	-2.20	-2.82	-3.87
34.00	29.35	2.93	-2.20	-2.82	-3.87
27.00	22.35	2.82	-2.20	-2.82	
17.50	12.85	2.62	-2.20	-2.82	
13.57	8.92	2.50	-2.20	-2.82	
9.22	4.57	2.30	-2.20	-2.82	
9.06	4.41	2.30	-2.20	-2.82	
4.65	0.00	2.30	-2.20	-2.82	

zg 700 ft  
 α 11.5  
 Importance factor I 1.15  
 Basic wind speed V 62.59 m/s  
 Wind directionality factor Kd 0.85

Coef.	Wall			Roof
	Windward	Leeward	Side	
G	0.85			
Cp	0.8	-0.5	-0.7	-1.04
GCpi	-0.18	0.18	0.18	0.18

**Table 5.3.2-1 Design Pressure of Tornado Wind Load**

Wind Direction	Building	p (kN/m <sup>2</sup> )			
		Wall			Roof
		Windward	Leeward	Side	
All	RB/FB	5.6	-3.5	-4.9	-7.3
Differential		16.5	16.5	16.5	16.5



**Table 5.3.3-1 Design Seismic Loads for Horizontal SSE (RB and FB Walls)**

Elev. (m)	Elem No.	Node No.	Shear		Moment		Calculated Torsion (MN-m)	Accidental Torsion (MN-m)	Design Torsion (MN-m)
			X-Dir. (MN)	Y-Dir. (MN)	X-Dir. (MN-m)	Y-Dir. (MN-m)			
52.40*	1110	110	192.2	140.0	2724 5838	2143 4488	1284	471	1755
34.00	1109	109	173.2	113.9	8196 8719	5821 6389	1938	424	2362
27.00	1108	108	396.0	259.4	9400 9599	7162 7958	2799	1321	4120
22.50	1107	107	436.4	291.8	11216 11424	8328 9227	4678	1486	6164
17.50	1106	106	438.4	343.5	12105 12349	9408 10195	4023	1535	5557
13.57	1105	105	450.7	363.7	12839 13651	10255 11216	4211	1578	5788
9.06	1104	104	454.6	383.4	13904 15231	11338 12506	4694	1591	6285
4.65	1103	103	454.7	360.1	9392 10952	6302 7759	5248	1591	6839
-1.00	1102	102	240.0	226.6	6545 7303	4819 5358	2718	840	3558
-6.40	1101	101	237.7	200.4	4748	3351	2079	832	2910
-11.50		2							

Note: RB/FB Seismic Analyses Bounding Results and In-Structure Response Spectra. (Table 4.1-1 of Reference 2.1.2-o)

The node numbers in this table are described in Figure 5.3.3-1.

\* The difference between the modeled elevation 52.4 m and the actual elevation 52.7 m at the RB roof is negligibly small.



**Table 5.3.3-2 Maximum Vertical Accelerations (RB and FB Walls and Floor Slab)**

Elev. (m)	Node No.	Stick Model	Max. Vertical Acceleration (g)
52.4*	110	RBFB	1.56
34.00	109	RBFB	1.20
27.00	108	RBFB	1.02
22.50	107	RBFB	0.92
17.50	106	RBFB	0.80
13.57	105	RBFB	0.72
9.06	104	RBFB	0.62
4.65	103	RBFB	0.56
-1.00	102	RBFB	0.57
-6.40	101	RBFB	0.52
-11.50	2	RBFB	0.51
-15.50	1	RBFB	0.52

Note: RB/FB Seismic Analyses Bounding Results and In-Structure Response Spectra. (Table 4.2-1 of Reference 2.1.2-o)

The node numbers in this table are described in Figure 5.3.3-1.

\* The difference between the modeled elevation 52.4 m and the actual elevation 52.7 m at the RB roof is negligibly small.



**Table 5.3.3-3 Enveloping Maximum Vertical Acceleration: RBFB Flexible Slab Oscillators**

Elev. (m)	Node No.	Stick Model	Max. Vertical Acceleration (g)
52.4*	9101	Oscillator	0.33
	9102	Oscillator	1.33
	9103	Oscillator	6.27
	9104	Oscillator	2.62
	9105	Oscillator	2.42
	9106	Oscillator	3.74
	9107	Oscillator	3.22
	9108	Oscillator	2.50
	9109	Oscillator	1.53
34.00	9091	Oscillator	1.61
	9092	Oscillator	1.61
	9093	Oscillator	1.12
27.00	9081	Oscillator	1.64
	9082	Oscillator	1.52
	9083	Oscillator	1.30
	9084	Oscillator	1.67
	9085	Oscillator	1.46
	9086	Oscillator	1.12
	9087	Oscillator	1.03
22.50	9071	Oscillator	1.15
	9072	Oscillator	1.79
	9073	Oscillator	4.47
	9074	Oscillator	1.67
	9075	Oscillator	1.51
	9076	Oscillator	1.65
17.50	9061	Oscillator	3.65
	9062	Oscillator	2.62
	9063	Oscillator	1.17
	9064	Oscillator	2.56
	9065	Oscillator	1.28
	99064	Oscillator	0.99
	9066	Oscillator	1.09
	9067	Oscillator	0.91

Note: Bounding Equivalent Out-of-plane Acceleration Loads on Slabs are shown in RB/FB Seismic Analyses Bounding Results and In-Structure Response Spectra. (Table 4.2-1 of Reference 2.1.2-o)

\* The difference between the modeled elevation 52.4 m and the actual elevation 52.7 m at the RB roof is negligibly small.



Table 5.3.3-3 Enveloping Maximum Vertical Acceleration: RBF Flexible Slab Oscillators (Continued)

Elev. (m)	Node No.	Stick Model	Max. Vertical Acceleration (g)
13.57	9051	Oscillator	1.11
	9052	Oscillator	1.25
	9053	Oscillator	0.99
	9054	Oscillator	0.83
9.06	9041	Oscillator	1.02
	9042	Oscillator	1.26
	9043	Oscillator	0.93
	9044	Oscillator	0.80
4.65	9031	Oscillator	1.62
	9032	Oscillator	0.89
	9033	Oscillator	1.12
	9034	Oscillator	1.81
	9035	Oscillator	1.09
	9036	Oscillator	0.94
	9037	Oscillator	0.82
-1.00	9021	Oscillator	0.97
	9022	Oscillator	2.07
	9023	Oscillator	0.98
	9024	Oscillator	1.12
	9025	Oscillator	1.21
	9026	Oscillator	1.63
	9027	Oscillator	0.93
	9028	Oscillator	0.96
	9029	Oscillator	1.30
	9030	Oscillator	0.87
-6.40	9011	Oscillator	0.84
	9012	Oscillator	1.17
	9013	Oscillator	1.52
	9014	Oscillator	1.19
	9015	Oscillator	1.03

Note: Bounding Equivalent Out-of-plane Acceleration Loads on Slabs are shown in RB/FB Seismic Analyses Bounding Results and In-Structure Response Spectra. (Table 4.2-1 of Reference 2.1.2-o)



**Table 5.3.3-4 Soil Pressure Due to an Earthquake**

Elevation (m)	Soil Pressure (MPa)		Note
	F3 Wall	FA and FF Wall	
4.65			Grade
-1.00	0.56	0.45	
-6.40	0.28	0.29	
-11.50	0.24	0.22	
-15.50	0.94	0.76	

**Table 5.3.3-5 Sloshing Loads in the Spent Fuel Pool**

NS Motion				EW Motion				Vertical Motion		
Wall		Floor		Wall		Floor		Wall		Floor
Depth d/H	Pressure (kN/m <sup>2</sup> )	Distance x/(L/2)	Pressure (kN/m <sup>2</sup> )	Depth d/H	Pressure (kN/m <sup>2</sup> )	Distance x/(L/2)	Pressure (kN/m <sup>2</sup> )	Depth d/H	Pressure (kN/m <sup>2</sup> )	Pressure (kN/m <sup>2</sup> )
0.0	12.3	0.0	0.0	0.0	11.8	0.0	0.0	0.0	0.0	98.5  for all floor area
0.2	23.6	0.2	7.4	0.2	24.2	0.2	8.5	0.2	19.7	
0.4	37.8	0.4	15.2	0.4	40.0	0.4	17.5	0.4	39.4	
0.6	44.6	0.6	23.7	0.6	49.4	0.6	27.4	0.6	59.1	
0.8	45.2	0.8	33.6	0.8	52.2	0.8	38.7	0.8	78.8	
1.0	45.2	1.0	45.2	1.0	52.2	1.0	52.2	1.0	98.5	

- Note 1: "d" is a depth from the top of water. "H" is water height of the pool (14.35 m).  
 2: "x" is a distance from the center of the pool. "L" is width of the pool.  
 3: Floor pressure due to vertical motion is reference only. It is already included in vertical seismic loads for the floor.



**Table 5.3.3-6 Enveloping Maximum Horizontal Acceleration: RBFB Wall Out-of-plane Oscillators**

Elev. (m)	Node No.	Stick Model	Max. Horizontal Acceleration (g)	Portion
42.00 (X-dir)	99981	Oscillator	2.71	R1 and R7 walls
	99982	Oscillator	1.54	
	99986	Oscillator	0.89	
42.00 (Y-dir)	99983	Oscillator	1.86	RB and RF walls
	99984	Oscillator	1.02	
	99985	Oscillator	1.00	
	99987	Oscillator	0.59	
30.50 (X-dir)	99991	Oscillator	0.58	R1 and R7 walls
30.50 (Y-dir)	99992	Oscillator	0.56	RB and RF walls
13.57 (X-dir)	99971	Oscillator	2.11	F3 walls
	99972	Oscillator	2.29	
	99973	Oscillator	1.88	
	99974	Oscillator	1.13	
	99977	Oscillator	0.89	
13.57 (Y-dir)	99975	Oscillator	2.16	FA and FF walls
	99976	Oscillator	0.93	
	99978	Oscillator	0.97	

Note: Bounding Equivalent Out-of-plane Acceleration Loads on Walls are shown in RB/FB Seismic Analyses Bounding Results and In-Structure Response Spectra. (Table 4.5-2 of Reference 2.1.2-o)



**Table 6.2.2-1 Material Constants Used in Stress Analysis**

		Temperature (°C)	Reinforced Concrete		Steel			Note
			Basemat f'c=4000psi 27.6MPa	Others f'c=5000psi 34.5MPa	Carbon Steel Liner	Stainless Steel Liner	Structural Steel	
Young's Modulus (MPa)	Thermal Loads*2	<21	2.49E+04	2.78E+04	2.00E+05			Concrete: See Notes 1 & 2.
		93	1.81E+04	2.03E+04				
		204	1.62E+04	1.81E+04				
	Other Loads*1	2.49E+04	2.78E+04	2.00E+01	2.00E+05			
Poisson's Ratio			0.17		0.3			
Thermal Expansion (m/m°C)			9.90E-06		1.17E-05	1.52E-05	1.17E-05	
Weight Density (MN/m <sup>3</sup> )			0.0235		0.0770			

Note \*1: Young's modulus of concrete is calculated in accordance with ACI 349-01, Section 8.5.1.

$$E_c = 57,000\sqrt{f'_c}$$

\*2: Reduction factors of Young's modulus for concrete are determined based upon the average values of the following upper bound and lower bound equations. (See table and figure below.)

Lower bound:

$$\phi = 1.0 - 0.0038(T - 70) \quad 70^\circ F \leq T \leq 200^\circ F$$

$$= 0.50 - 0.0005(T - 200) \quad 200^\circ F \leq T$$

Upper bound:

$$\phi = 1.0 - 0.00031(T - 70) \quad 70^\circ F \leq T \leq 400^\circ F$$

$$= 0.90 - 0.00084(T - 400) \quad 400^\circ F \leq T$$

**Table 6.2.4-1 Results of NASTRAN Analysis, Dead Load**

Location	Element ID	Nx (MN/m)	Ny (MN/m)	Nxy (MN/m)	Mx (MNm/m)	My (MNm/m)	Mxy (MNm/m)	Qx (MN/m)	Qy (MN/m)
1 Exterior Wall and Pool Wall @ EL-11.50 ~-10.50m	60011	-0.483	-1.787	-0.532	-0.161	-1.151	-0.028	-0.097	-0.367
	60219	0.334	-1.569	-0.302	-0.653	-0.827	-0.170	0.032	0.289
	70201	0.298	-0.173	0.000	0.499	-0.014	0.116	-0.273	0.073
	70204	0.425	-1.009	0.028	-0.227	-0.053	0.122	-0.003	-0.358
	110718	0.325	-1.358	-0.067	-0.050	0.085	0.008	0.036	0.190
2 Exterior Wall @ EL4.65 ~-6.60m	62011	0.088	-1.040	0.070	0.043	0.145	0.010	0.010	0.056
	62019	0.125	-0.628	-0.192	-0.032	0.047	-0.031	-0.001	0.021
	72001	0.110	-0.170	0.106	0.106	0.020	-0.006	-0.015	-0.005
	72004	0.146	-0.452	0.196	-0.038	0.004	0.001	-0.016	0.014
3 Exterior Wall @ EL22.50 ~-24.60m	64011	0.093	-0.287	-0.091	-0.110	-0.533	-0.004	-0.005	0.075
	64019	-0.109	-0.369	-0.067	-0.061	-0.371	0.053	0.063	0.063
	74001	-0.016	-0.049	0.093	0.049	-0.045	-0.046	-0.020	-0.029
	74004	-0.054	-0.212	0.089	-0.078	-0.336	-0.061	0.019	-0.069
4 Spent Fuel Pool Wall @ EL-5.10 ~-3.30m	60819	0.603	-1.255	-0.494	-1.105	-0.819	-0.250	-0.006	-0.070
	70801	0.676	-0.155	0.010	1.075	0.074	-0.015	-0.548	0.031
	70804	0.581	-0.753	0.130	-0.561	-0.466	0.064	-0.097	0.045
	110748	0.225	-1.010	-0.442	-0.184	-0.081	-0.008	0.073	-0.025
5 Basemat	90306	-1.088	-0.435	0.523	0.940	-0.124	0.178	-0.539	1.189
	90310	-0.133	-0.122	-0.042	-0.153	-0.153	-0.696	0.169	-0.067
	90410	-0.454	-0.926	0.533	-0.714	0.165	1.501	1.398	-0.065
5 Basemat @ Spent Fuel Pool	90486	0.294	0.018	0.092	3.622	2.380	0.281	-0.180	0.125
	90490	0.429	0.186	0.284	1.433	1.263	0.508	1.201	0.262
	90526	0.518	0.486	0.013	1.991	2.124	0.124	-0.229	-0.799
6 Slab EL4.65m	93306	0.191	0.019	0.024	0.048	-0.004	0.005	0.031	-0.099
	93310	0.039	0.054	0.232	0.032	0.008	0.034	-0.024	0.006
	93410	0.313	0.318	-0.450	0.012	0.013	-0.069	0.002	-0.010



**Table 6.2.4-2 Results of NASTRAN Analysis, Temperature Load  
(LOCA after 72 hours: Winter)**

Location	Element ID	Nx (MN/m)	Ny (MN/m)	Nxy (MN/m)	Mx (MNm/m)	My (MNm/m)	Mxy (MNm/m)	Qx (MN/m)	Qy (MN/m)
1 Exterior Wall and Pool Wall @ EL-11.50 ~-10.50m	60011	-0.932	0.104	-0.283	1.040	0.845	0.081	-0.279	-0.151
	60219	1.775	-2.822	0.999	-12.784	-17.538	-0.622	0.026	-2.138
	70201	2.001	2.952	-0.673	-4.155	-4.561	0.310	-0.183	0.610
	70204	1.559	1.017	-0.470	-3.984	-4.709	0.285	0.069	0.073
	110718	-2.155	-3.145	-1.392	-1.934	-2.203	0.009	0.190	-0.234
2 Exterior Wall @ EL4.65 ~-6.60m	62011	5.880	1.937	0.541	-1.090	-1.228	0.001	-0.030	-0.062
	62019	7.722	0.133	-2.024	-1.201	-1.492	-0.050	0.033	-0.106
	72001	4.333	-1.692	2.655	-0.388	-0.891	0.038	-0.739	0.255
	72004	7.043	0.683	2.803	-1.318	-1.608	0.083	-0.056	0.166
3 Exterior Wall @ EL22.50 ~-24.60m	64011	4.710	0.187	0.313	-0.963	-0.391	-0.017	-0.003	-0.083
	64019	5.505	1.413	1.655	-1.023	-0.448	0.026	-0.009	-0.051
	74001	2.905	-0.810	-3.488	-0.742	-0.459	0.125	-0.302	0.092
	74004	4.031	0.191	-3.611	-0.936	-0.298	-0.021	0.021	0.087
4 Spent Fuel Pool Wall @ EL-5.10 ~-3.30m	60819	-2.067	-3.594	-0.353	-10.280	-9.932	-1.102	-0.058	-1.158
	70801	0.377	3.314	-0.183	-3.883	-4.019	0.017	-0.013	-0.017
	70804	-0.589	0.585	0.363	-3.927	-4.089	0.317	-0.051	0.144
	110748	-0.434	-2.821	-1.077	-1.340	-1.771	-0.097	0.369	-0.150
5 Basemat	90306	-0.842	-0.093	0.302	1.812	0.786	0.047	-0.013	0.259
	90310	0.134	0.271	0.321	1.221	1.339	0.612	0.152	-0.060
	90410	-0.192	-0.439	0.257	0.435	1.801	0.052	-0.016	-0.216
5 Basemat @ Spent Fuel Pool	90486	-3.327	-2.050	0.616	-18.282	-19.282	2.304	-0.005	0.385
	90490	-2.565	2.723	0.532	-22.985	-22.408	0.850	2.142	1.611
	90526	2.586	0.040	0.156	-19.469	-6.941	0.735	-0.998	1.464
6 Slab EL4.65m	93306	-0.789	-0.028	-1.656	-0.051	0.035	-0.014	0.080	-0.030
	93310	-2.219	-2.170	-3.223	-0.752	-0.783	-0.242	0.267	0.288
	93410	-0.686	-2.429	-0.064	-0.055	-0.015	0.020	-0.106	-0.032



**Table 6.2.4-3 Results of NASTRAN Analysis, Seismic Load (Horizontal: North to South Direction)**

Location	Element ID	Nx (MN/m)	Ny (MN/m)	Nxy (MN/m)	Mx (MNm/m)	My (MNm/m)	Mxy (MNm/m)	Qx (MN/m)	Qy (MN/m)
1 Exterior Wall and Pool Wall @ EL-11.50 ~-10.50m	60011	-2.527	-0.242	0.003	0.047	0.600	-0.044	0.182	0.250
	60219	-3.014	-0.410	-0.969	1.178	1.359	0.655	-0.168	0.104
	70201	0.104	-0.513	-2.050	-0.332	-0.161	-0.003	-0.008	-0.040
	70204	0.894	-0.953	-3.264	-0.222	-0.234	-0.136	0.010	0.024
	110718	0.541	0.223	0.570	0.024	0.004	-0.044	0.041	-0.064
2 Exterior Wall @ EL4.65 ~-6.60m	62011	0.623	-0.113	-0.372	0.013	0.227	0.003	-0.029	0.022
	62019	0.413	-0.851	-1.324	0.066	0.226	0.003	0.012	0.031
	72001	-0.541	-1.875	-3.594	-0.164	-0.068	0.013	0.015	0.044
	72004	-0.759	-1.467	-4.289	-0.040	-0.030	-0.001	0.024	0.004
3 Exterior Wall @ EL22.50 ~-24.60m	64011	2.978	-0.129	-0.106	-0.055	-0.191	0.022	0.012	0.035
	64019	2.526	0.030	-0.323	-0.057	-0.149	-0.058	-0.032	0.031
	74001	0.086	-0.118	-1.096	0.044	0.049	-0.051	0.031	-0.014
	74004	-1.294	-0.175	-1.774	0.030	0.027	-0.030	0.013	0.011
4 Spent Fuel Pool Wall @ EL-5.10 ~-3.30m	60819	-1.022	0.127	-1.375	1.221	0.842	0.921	0.121	0.038
	70801	-0.358	-0.817	-3.068	-0.657	-0.131	0.005	0.054	0.014
	70804	-0.103	-0.726	-3.437	-0.274	-0.078	-0.167	0.069	0.007
	110748	0.267	0.681	0.555	0.189	0.101	-0.145	-0.026	-0.036
5 Basemat	90306	1.633	-0.406	2.341	0.219	-0.150	2.426	-1.962	0.880
	90310	0.445	-0.957	0.030	0.506	-0.204	-0.171	-0.708	1.380
	90410	0.195	-4.795	-0.653	1.554	0.524	0.164	0.151	-0.109
5 Basemat @ Spent Fuel Pool	90486	0.407	-1.009	-1.091	2.026	1.996	-1.743	-0.995	-0.035
	90490	-0.049	-5.644	0.507	2.336	2.835	-0.175	0.538	-0.900
	90526	2.798	-0.137	-3.221	0.443	0.361	-3.693	-1.172	-0.748
6 Slab EL4.65m	93306	1.355	0.182	-0.860	0.288	-0.056	0.008	-0.077	-0.073
	93310	0.483	0.194	0.424	0.404	-0.225	0.053	-0.306	0.355
	93410	-0.409	0.459	1.304	0.362	0.100	0.081	-0.200	-0.005

**Table 6.2.4-4 Results of NASTRAN Analysis, Seismic Load (Horizontal: East to West Direction)**

Location	Element ID	Nx (MN/m)	Ny (MN/m)	Nxy (MN/m)	Mx (MNm/m)	My (MNm/m)	Mxy (MNm/m)	Qx (MN/m)	Qy (MN/m)
1 Exterior Wall and Pool Wall @ EL-11.50 ~-10.50m	60011	0.127	0.100	1.432	-0.003	0.182	0.017	0.004	0.053
	60219	-0.749	-0.811	0.748	0.095	-0.120	0.002	0.003	-0.021
	70201	-0.041	-0.396	-0.366	-0.035	-0.084	0.006	-0.007	0.029
	70204	-0.066	-1.134	-1.147	-0.038	-0.137	0.027	0.007	0.050
	110718	0.154	-0.450	0.179	-0.057	-0.133	-0.006	0.011	-0.070
2 Exterior Wall @ EL4.65 ~-6.60m	62011	-0.188	0.141	2.379	-0.025	-0.022	0.000	0.009	-0.009
	62019	-0.067	-1.025	1.859	0.004	0.007	0.001	-0.001	0.001
	72001	-0.092	-2.116	-0.080	-0.005	0.032	-0.001	0.033	-0.020
	72004	-0.211	-1.815	-0.919	0.026	0.082	0.012	0.006	-0.011
3 Exterior Wall @ EL22.50 ~-24.60m	64011	-0.040	0.012	1.635	0.000	0.005	-0.001	0.001	-0.001
	64019	0.503	-0.082	1.246	0.000	-0.011	0.006	0.001	0.003
	74001	0.176	-0.213	-0.277	0.054	0.003	0.004	-0.038	-0.022
	74004	0.865	-0.137	-0.920	-0.003	-0.035	-0.001	-0.002	-0.008
4 Spent Fuel Pool Wall @ EL-5.10 ~-3.30m	60819	-0.330	-0.421	0.955	0.078	-0.002	-0.011	0.002	-0.010
	70801	-0.029	-0.942	-0.470	0.031	0.055	0.009	0.010	0.045
	70804	-0.138	-0.873	-1.039	0.005	0.078	0.019	0.005	0.031
	110748	0.152	-0.207	0.175	0.065	0.006	-0.029	-0.014	-0.032
5 Basemat	90306	1.386	0.424	-1.243	-0.964	-0.175	-0.848	1.116	-1.018
	90310	0.146	0.278	-0.141	-0.069	-0.051	0.230	-0.169	-0.269
	90410	0.038	0.191	-1.179	0.159	0.269	-1.639	-0.055	1.018
5 Basemat @ Spent Fuel Pool	90486	-0.256	-0.281	-0.615	2.848	2.976	0.734	-0.251	0.291
	90490	-0.129	-1.702	-0.739	0.644	1.838	-0.546	0.905	0.419
	90526	-0.573	-0.169	-1.355	2.088	0.837	-0.745	-0.977	-1.038
6 Slab EL4.65m	93306	-0.987	-0.072	0.755	-0.210	-0.092	-0.005	-0.050	0.040
	93310	-0.191	-0.199	0.082	-0.011	-0.082	-0.026	-0.067	-0.004
	93410	0.009	-0.598	0.036	-0.030	0.020	-0.015	0.054	0.020



**Table 6.2.4-5 Results of NASTRAN Analysis, Seismic Load (Vertical: Upward Direction)**

Location	Element ID	Nx (MN/m)	Ny (MN/m)	Nxy (MN/m)	Mx (MNm/m)	My (MNm/m)	Mxy (MNm/m)	Qx (MN/m)	Qy (MN/m)
1 Exterior Wall and Pool Wall @ EL-11.50 ~-10.50m	60011	-0.394	-1.290	-0.294	-0.134	-0.824	-0.025	-0.052	-0.250
	60219	-0.106	-1.323	-0.197	-0.253	-0.663	-0.117	0.020	-0.118
	70201	0.031	-0.236	0.012	0.103	-0.108	0.000	-0.076	0.057
	70204	0.089	-0.958	-0.058	-0.078	-0.237	0.031	-0.008	0.062
2 Exterior Wall @ EL4.65 ~6.60m	110718	0.169	-0.999	-0.239	0.000	0.035	0.008	-0.001	0.004
	62011	0.069	-0.913	0.081	0.046	0.204	0.011	0.008	0.068
	62019	0.057	-0.638	-0.092	-0.006	0.097	-0.035	0.001	0.033
	72001	0.038	-0.262	-0.010	0.045	0.006	0.001	-0.001	0.004
3 Exterior Wall @ EL22.50 ~24.60m	72004	0.025	-0.510	0.010	0.004	0.023	0.012	-0.004	-0.004
	64011	0.075	-0.351	-0.041	-0.146	-0.706	-0.004	-0.004	0.097
	64019	-0.055	-0.438	-0.042	-0.084	-0.497	0.064	0.079	0.080
	74001	-0.011	-0.045	0.075	0.066	-0.058	-0.060	-0.029	-0.039
4 Spent Fuel Pool Wall @ EL-5.10 ~-3.30m	74004	-0.063	-0.265	0.023	-0.103	-0.442	-0.078	0.023	-0.089
	60819	0.091	-1.085	-0.333	-0.280	-0.075	-0.164	-0.005	-0.055
	70801	0.090	-0.331	-0.055	0.194	0.026	-0.027	-0.048	-0.005
	70804	0.114	-0.703	-0.012	-0.023	-0.011	0.018	-0.020	0.027
5 Basemat	110748	0.106	-0.671	-0.295	-0.025	0.003	0.003	0.003	0.010
	90306	-0.712	-0.334	0.447	0.682	-0.086	0.181	-0.461	0.901
	90310	-0.084	-0.104	-0.026	-0.102	-0.113	-0.505	0.098	-0.027
5 Basemat @ Spent Fuel Pool	90410	-0.309	-0.785	0.302	-0.474	0.139	1.025	1.008	0.036
	90486	-0.081	-0.369	-0.055	2.628	1.776	0.248	-0.136	0.099
	90490	-0.119	-0.339	0.155	-0.009	0.762	0.334	1.083	0.177
6 Slab EL4.65m	90526	-0.003	-0.102	-0.124	1.279	0.419	0.034	-0.234	-0.829
	93306	0.165	-0.003	0.027	0.048	0.051	0.009	0.026	-0.126
	93310	0.034	0.044	0.206	0.046	0.020	0.041	-0.025	0.006
	93410	0.237	0.287	-0.238	0.075	0.018	-0.068	-0.046	-0.016



**Table 6.3.1-1 Load Combinations and Acceptance Criteria for Safety-related Reinforced Concrete Structures**

Category	Combination <sup>*2</sup> No.	Load <sup>**7</sup>													Acceptance Criteria <sup>*5</sup>
		D	F	L <sup>*6</sup>	H	Pa <sup>*3</sup>	To	Ta <sup>*3</sup>	E'	W	Wt	Ro	Ra	Y <sup>*4</sup>	
Normal	FB-C1	1.4	1.4	1.7	1.7							1.7			U
	FB-C2	1.05	1.05	1.3	1.3		1.3					1.3			U
Severe Environmental	FB-C3	1.4	1.4	1.7	1.7					1.7		1.7			U
	FB-C4	1.05	1.05	1.3	1.3		1.3			1.3		1.3			U
	FB-C5	1.2	1.2							1.7					U
Extreme Environmental	FB-C6	1.0	1.0	1.0	1.0		1.0		1.0			1.0			U
	FB-C7	1.0	1.0	1.0	1.0		1.0				1.0	1.0			U
Abnormal	FB-C8	1.0	1.0	1.0	1.0	1.5		1.0					1.0		U
Abnormal/Extreme Environmental	FB-C9	1.0	1.0	1.0	1.0	1.0		1.0	1.0				1.0	1.0	U

Note :

- \*1: D = Dead loads  
L = Live loads (For the roof, Roof Live loads or Snow loads or Rain loads each acting independently.)  
H = Lateral soil pressure loads  
To = Thermal loads during the normal operation  
E' = Seismic loads (SSE)  
W = Wind loads (basic wind)  
Ro = Pipe reaction loads during the normal operation  
Y = High energy pipe rupture
- F = Hydrostatic pressure loads  
Pa = Pressure loads during LOCA  
Ta = Thermal loads during LOCA  
Wt = Wind loads (tornado wind)  
Ra = Pipe reaction loads during LOCA
- \*2: For any load combination, where any load reduces the effects of other loads, the corresponding coefficient for that load shall be taken as 0.9 if it can be demonstrated that the load is always present or occur simultaneously with the other loads. Otherwise, the coefficient for that load shall be taken as zero.
- \*3: Because Pa and Ta are time-dependent loads, their effects are superimposed accordingly.
- \*4: Y includes Yj, Ym and Yr. The maximum value of Y including an appropriate Dynamic Load Factor (DLF) shall be used, unless an appropriate time history analysis is performed to justify otherwise.
- \*5: U = Section strength required to resist design loads based on the strength design method per ACI 349-01 and in SRP 3.8.4 Section II.3.
- \*6: Check L using LL Building, LL Roof (Lr), LL Roof Snow (S), or LL Roof Rain (R) as defined in Section 6.2. These are independent load cases that are checked independently using the Load Factors for the appropriate categories.
- \*7: The effect of SRV and LOCA dynamic loads originating inside the containment shall be considered as applicable.



**Table 6.3.1-2 Load Combinations and Acceptance Criteria for Safety-Related Steel Structures**

Category	Combination No.	Load <sup>*1</sup>											Acceptance Criteria <sup>*3</sup>
		D	L	Pa	To	Ta	E'	W	Wt	Ro	Ra	Y <sup>*2</sup>	
Normal	FB-S1	1.0	1.0										S
	FB-S2	1.0	1.0		1.0					1.0			S (a)
Severe Environmental	FB-S3	1.0	1.0					1.0					S
	FB-S4	1.0	1.0		1.0			1.0		1.0			S (a)
Extreme Environmental	FB-S5	1.0	1.0		1.0		1.0			1.0			1.6S (b)(c)
	FB-S6	1.0	1.0		1.0				1.0	1.0			1.6S (b)(c)
Abnormal	FB-S7	1.0	1.0	1.0		1.0					1.0		1.6S (b)(c)
Abnormal/Extreme Environmental	FB-S8	1.0	1.0	1.0		1.0	1.0				1.0	1.0	1.7S (b)(c)

Note :

\*1 : D = Dead loads

L = Live loads (For the roof, Roof Live loads or Snow loads or Rain loads each acting independently.)

Pa = Pressure loads during LOCA

To = Temperature loads during the normal operation

Ta = Temperature loads during LOCA

E' = Seismic loads (SSE)

W = Wind loads (basic wind)

Wt = Wind loads (tornado wind)

Ro = Pipe reaction loads during the normal operation

Ra = Pipe reaction loads during LOCA

Y = High energy pipe rupture

\*2: Y includes  $Y_j$ ,  $Y_m$  and  $Y_r$ . The maximum values of Y including an appropriate Dynamic Load Factor (DLF) shall be used, unless an appropriate time history analysis is performed to justify otherwise.

\*3: Allowable elastic working stress (S) is the allowable stress limit specified in Part 1 of AISC N-690-1994-s2 (2004).

(a) For primary plus secondary stress, the allowable limits are increased by a factor of 1.5.

(b) Stress limit coefficient in shear shall not exceed 1.4 in members and bolts.

(c) Stress limit coefficient where axial compression exceeds 20% of nominal allowable, shall be 1.5 for load combination 5, 6, 7, and be 1.6 for load combination 8.



**Table 6.3.1-3 Load Combinations, Load Factors and Acceptance Criteria for Reinforced Concrete Containment**

Description	No. <sup>*2</sup>	Load Conditions <sup>*1</sup>																Acceptance Criteria <sup>*6</sup>
		D	L	Pt	Po	Pa <sup>*3</sup>	Tt	To	Ta <sup>*3</sup>	E <sup>*7</sup>	W	W'	Ro	Ra	Y <sup>*4</sup>	SRV <sup>*7</sup>	LOCA <sup>**7</sup>	
Service Test	CV-1	1.0	1.0	1.0			1.0											S
Construction	CV-2	1.0	1.0					1.0			1.0							S
Normal	CV-3	1.0	1.0		1.0			1.0					1.0			1.0		S
Factored Severe Environmental	CV-4	1.0	1.3		1.0			1.0			1.5		1.0			1.3		U
Extreme Environmental	CV-5	1.0	1.0		1.0			1.0		1.0			1.0			1.0		U
	CV-6	1.0	1.0		1.0			1.0				1.0	1.0			1.0		U
Abnormal	CV-7	1.0	1.0			1.5			1.0					1.0		1.25	Note <sup>*5</sup>	U
	CV-8	1.0	1.0			1.0			1.0					1.25		1.0	Note <sup>*5</sup>	U
	CV-9	1.0	1.0			1.25			1.0					1.0		1.25	Note <sup>*5</sup>	U
Abnormal/Severe Environmental	CV-10	1.0	1.0			1.25			1.0		1.25			1.0		1.0	Note <sup>*5</sup>	U
Abnormal/Extreme Environmental	CV-11	1.0	1.0			1.0			1.0	1.0				1.0	1.0	1.0	Note <sup>*5</sup>	U

Notes:

- \*1: The loads are described in Section 6. The allowable stresses of concrete and reinforcing steel shall be in accordance with ASME Code Section III, Division 2, Subsection CC-3400 (except for tangential shear stress carried by orthogonal reinforcement which shall be limited to 4.41 MPa (639 psi) for factored load combinations). Inclined reinforcement shall not be used to resist tangential shear.
- \*2: For any load combination, if the effect of any load component (other than D) reduces the combined load, then the load component is deleted from the load combination.
- \*3: Because Pa, Ta, SRV and LOCA are time-dependent loads, their effects are superimposed accordingly.
- \*4: Y includes Yj, Ym and Yr.
- \*5: LOCA loads, CO, CHUG and PS are time-dependant loads for which DLF may be used. The sequence of occurrence is shown in Figure 5.2.3-2. The load factor for LOCA loads shall be the same as the corresponding pressure load Pa. LOCA loads shall include hydrostatic pressure (with a load factor of 1.0) due to containment flooding.
- \*6: S = Allowable Stress as in ASME Section III, Div. 2, Subsection CC-3430 for Service Load Combination. U = Allowable Stress as in ASME Section III, Div. 2, Subsection CC-3420 for Factored Load Combination.
- \*7: The peak responses of dynamic loads do not occur at the same instant. SRSS method to combine peak dynamic responses is acceptable for concrete structures.



Table 6.3.2-1 Detail Load Combinations for Reinforced Concrete Structures (Continued)

Combin. No. in DCID	Dead Load	Live Load	Pressure Load																Thermal Load																Seismic Load	Pipe Reac.	Hydrodynamic Load																Wind Load	Tornado Load	Acceptance Criteria																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																											
			LOCA																LOCA (GDCS Condition #1)								LOCA (GDCS Condition #2)										LOCA Flooding				LOCA & LOFCF				Reaction																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																					
			Normal Operation & LOCA		LOCA Flooding		Normal Operation		Soil Pressure (Static)		Test (Max.)		Test (DME)		Normal Operation		After 5 seconds		After 6 minutes		After 10 hours		After 72 hours		Annulus Pressure		HELB in MS Tunnel		HELB in Other Room		Normal Operation		After 5 sec.				After 6 minutes		After 10 hours		After 72 hours		After 5 sec.		After 6 minutes		After 10 hours		After 72 hours		SPF LOFCF (after 72hr.)					SPF LOFCF (after 72hr.)		Normal Operation & LOCA		LOCA Flooding		During AP		SRV		PS		CO		CH		SRV		PS-AP		CO		CH		N to S		S to N		E to W		W to E		N to S		S to N		E to W		W to E		Tornado Differential Load																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																		
			DLO1	DLO2	LLO	LLO	SPO	PTL1	PTL2	POB	PL1	PL2	PL3	PL4	AP	PLMS	HOH	TLW0	TLW1	TLW2	TLW3	TLW4	TLW5	TLW6	TLW7	TLW8	TFS5	TFS6	TFS7	TFS8	TFS9	TFS10	TFS11	TFS12			TFS13	TFS14	TFS15	TFS16	TFS17	TFS18	TFS19	TFS20	TFS21	TFS22	TFS23	TFS24	TFS25	TFS26	TFS27	TFS28				TFS29	TFS30	TFS31	TFS32	TFS33	TFS34	TFS35	TFS36	TFS37	TFS38	TFS39	TFS40	TFS41	TFS42	TFS43	TFS44	TFS45	TFS46	TFS47	TFS48	TFS49	TFS50	TFS51	TFS52	TFS53	TFS54	TFS55	TFS56	TFS57	TFS58	TFS59	TFS60	TFS61	TFS62	TFS63	TFS64	TFS65	TFS66	TFS67	TFS68	TFS69	TFS70	TFS71	TFS72	TFS73	TFS74	TFS75	TFS76	TFS77	TFS78	TFS79	TFS80	TFS81	TFS82	TFS83	TFS84	TFS85	TFS86	TFS87	TFS88	TFS89	TFS90	TFS91	TFS92	TFS93	TFS94	TFS95	TFS96	TFS97	TFS98	TFS99	TFS100	TFS101	TFS102	TFS103	TFS104	TFS105	TFS106	TFS107	TFS108	TFS109	TFS110	TFS111	TFS112	TFS113	TFS114	TFS115	TFS116	TFS117	TFS118	TFS119	TFS120	TFS121	TFS122	TFS123	TFS124	TFS125	TFS126	TFS127	TFS128	TFS129	TFS130	TFS131	TFS132	TFS133	TFS134	TFS135	TFS136	TFS137	TFS138	TFS139	TFS140	TFS141	TFS142	TFS143	TFS144	TFS145	TFS146	TFS147	TFS148	TFS149	TFS150	TFS151	TFS152	TFS153	TFS154	TFS155	TFS156	TFS157	TFS158	TFS159	TFS160	TFS161	TFS162	TFS163	TFS164	TFS165	TFS166	TFS167	TFS168	TFS169	TFS170	TFS171	TFS172	TFS173	TFS174	TFS175	TFS176	TFS177	TFS178	TFS179	TFS180	TFS181	TFS182	TFS183	TFS184	TFS185	TFS186	TFS187	TFS188	TFS189	TFS190	TFS191	TFS192	TFS193	TFS194	TFS195	TFS196	TFS197	TFS198	TFS199	TFS200	TFS201	TFS202	TFS203	TFS204	TFS205	TFS206	TFS207	TFS208	TFS209	TFS210	TFS211	TFS212	TFS213	TFS214	TFS215	TFS216	TFS217	TFS218	TFS219	TFS220	TFS221	TFS222	TFS223	TFS224	TFS225	TFS226	TFS227	TFS228	TFS229	TFS230	TFS231	TFS232	TFS233	TFS234	TFS235	TFS236	TFS237	TFS238	TFS239	TFS240	TFS241	TFS242	TFS243	TFS244	TFS245	TFS246	TFS247	TFS248	TFS249	TFS250	TFS251	TFS252	TFS253	TFS254	TFS255	TFS256	TFS257	TFS258	TFS259	TFS260	TFS261	TFS262	TFS263	TFS264	TFS265	TFS266	TFS267	TFS268	TFS269	TFS270	TFS271	TFS272	TFS273	TFS274	TFS275	TFS276	TFS277	TFS278	TFS279	TFS280	TFS281	TFS282	TFS283	TFS284	TFS285	TFS286	TFS287	TFS288	TFS289	TFS290	TFS291	TFS292	TFS293	TFS294	TFS295	TFS296	TFS297	TFS298	TFS299	TFS300	TFS301	TFS302	TFS303	TFS304	TFS305	TFS306	TFS307	TFS308	TFS309	TFS310	TFS311	TFS312	TFS313	TFS314	TFS315	TFS316	TFS317	TFS318	TFS319	TFS320	TFS321	TFS322	TFS323	TFS324	TFS325	TFS326	TFS327	TFS328	TFS329	TFS330	TFS331	TFS332	TFS333	TFS334	TFS335	TFS336	TFS337	TFS338	TFS339	TFS340	TFS341	TFS342	TFS343	TFS344	TFS345	TFS346	TFS347	TFS348	TFS349	TFS350	TFS351	TFS352	TFS353	TFS354	TFS355	TFS356	TFS357	TFS358	TFS359	TFS360	TFS361	TFS362	TFS363	TFS364	TFS365	TFS366	TFS367	TFS368	TFS369	TFS370	TFS371	TFS372	TFS373	TFS374	TFS375	TFS376	TFS377	TFS378	TFS379	TFS380	TFS381	TFS382	TFS383	TFS384	TFS385	TFS386	TFS387	TFS388	TFS389	TFS390	TFS391	TFS392	TFS393	TFS394	TFS395	TFS396	TFS397	TFS398	TFS399	TFS400	TFS401	TFS402	TFS403	TFS404	TFS405	TFS406	TFS407	TFS408	TFS409	TFS410	TFS411	TFS412	TFS413	TFS414	TFS415	TFS416	TFS417	TFS418	TFS419	TFS420	TFS421	TFS422	TFS423	TFS424	TFS425	TFS426	TFS427	TFS428	TFS429	TFS430	TFS431	TFS432	TFS433	TFS434	TFS435	TFS436	TFS437	TFS438	TFS439	TFS440	TFS441	TFS442	TFS443	TFS444	TFS445	TFS446	TFS447	TFS448	TFS449	TFS450	TFS451	TFS452	TFS453	TFS454	TFS455	TFS456	TFS457	TFS458	TFS459	TFS460	TFS461	TFS462	TFS463	TFS464	TFS465	TFS466	TFS467	TFS468	TFS469	TFS470	TFS471	TFS472	TFS473	TFS474	TFS475	TFS476	TFS477	TFS478	TFS479	TFS480	TFS481	TFS482	TFS483	TFS484	TFS485	TFS486	TFS487	TFS488	TFS489	TFS490	TFS491	TFS492	TFS493	TFS494	TFS495	TFS496	TFS497	TFS498	TFS499	TFS500	TFS501	TFS502	TFS503	TFS504	TFS505	TFS506	TFS507	TFS508	TFS509	TFS510	TFS511	TFS512	TFS513	TFS514	TFS515	TFS516	TFS517	TFS518	TFS519	TFS520	TFS521	TFS522	TFS523	TFS524	TFS525	TFS526	TFS527	TFS528	TFS529	TFS530	TFS531	TFS532	TFS533	TFS534	TFS535	TFS536	TFS537	TFS538	TFS539	TFS540	TFS541	TFS542	TFS543	TFS544	TFS545	TFS546	TFS547	TFS548	TFS549	TFS550	TFS551	TFS552	TFS553	TFS554	TFS555	TFS556	TFS557	TFS558	TFS559	TFS560	TFS561	TFS562	TFS563	TFS564	TFS565	TFS566	TFS567	TFS568	TFS569	TFS570	TFS571	TFS572	TFS573	TFS574	TFS575	TFS576	TFS577	TFS578	TFS579	TFS580	TFS581	TFS582	TFS583	TFS584	TFS585	TFS586	TFS587	TFS588	TFS589	TFS590	TFS591	TFS592	TFS593	TFS594	TFS595	TFS596	TFS597	TFS598	TFS599	TFS600	TFS601	TFS602	TFS603	TFS604	TFS605	TFS606	TFS607	TFS608	TFS609	TFS610	TFS611	TFS612	TFS613	TFS614	TFS615	TFS616	TFS617	TFS618	TFS619	TFS620	TFS621	TFS622	TFS623	TFS624	TFS625	TFS626	TFS627	TFS628	TFS629	TFS630	TFS631	TFS632	TFS633	TFS634	TFS635	TFS636	TFS637	TFS638	TFS639	TFS640	TFS641	TFS642	TFS643	TFS644	TFS645	TFS646	TFS647	TFS648	TFS649	TFS650	TFS651	TFS652	TFS653	TFS654	TFS655	TFS656	TFS657	TFS658	TFS659	TFS660	TFS661	TFS662	TFS663	TFS664	TFS665	TFS666	TFS667	TFS668	TFS669	TFS670	TFS671	TFS672	TFS673	TFS674	TFS675	TFS676	TFS677	TFS678	TFS679	TFS680	TFS681	TFS682	TFS683	TFS684	TFS685	TFS686	TFS687	TFS688	TFS689	TFS690	TFS691	TFS692	TFS693	TFS694	TFS695	TFS696	TFS697	TFS698	TFS699	TFS700	TFS701	TFS702	TFS703	TFS704	TFS705	TFS706	TFS707	TFS708	TFS709	TFS710	TFS711	TFS712	TFS713	TFS714	TFS715	TFS716	TFS717	TFS718	TFS719	TFS720	TFS721	TFS722	TFS723	TFS724	TFS725	TFS726	TFS727	TFS728	TFS729	TFS730	TFS731	TFS732	TFS733	TFS734	TFS735	TFS736	TFS737	TFS738	TFS739	TFS740	TFS741	TFS742	TFS743	TFS744	TFS745	TFS746	TFS747	TFS748	TFS749	TFS750	TFS751	TFS752	TFS753	TFS754	TFS755	TFS756	TFS757	TFS758	TFS759	TFS760	TFS761	TFS762	TFS763	TFS764	TFS765	TFS766	TFS767	TFS768	TFS769	TFS770	TFS771	TFS772	TFS773	TFS774	TFS775	TFS776	TFS777	TFS778	TFS779	TFS780	TFS781	TFS782	TFS783	TFS784	TFS785	TFS786	TFS787	TFS788	TFS789	TFS790	TFS791	TFS792	TFS793	TFS794	TFS795	TFS796	TFS797	TFS798	TFS799	TFS800	TFS801	TFS802	TFS803	TFS804	TFS805	TFS806	TFS807	TFS808	TFS809	TFS810	TFS811	TFS812	TFS813	TFS814	TFS815	TFS816	TFS817	TFS818	TFS819	TFS820	TFS821	TFS822	TFS823	TFS824	TFS825	TFS826	TFS827	TFS828	TFS829	TFS830	TFS831	TFS832	TFS833	TFS834	TFS835	TFS836	TFS837	TFS838	TFS839	TFS840	TFS841	TFS842	TFS843	TFS844	TFS845	TFS846	TFS847	TFS848	TFS849	TFS850	TFS851	TFS852	TFS853	TFS854	TFS855	TFS856	TFS857	TFS858	TFS859	TFS860	TFS861	TFS862	TFS863	TFS864	TFS865	TFS866	TFS867	TFS868	TFS869	TFS870	TFS871	TFS872	TFS873	TFS874	TFS875	TFS876	TFS877	TFS878	TFS879	TFS880	TFS881	TFS882	TFS883	TFS884	TFS885	TFS886	TFS887	TFS888	TFS889	TFS890	TFS891	TFS892	TFS893	TFS894	TFS895	TFS896	TFS897	TFS898	TFS899	TFS900	TFS901	TFS902	TFS903	TFS904	TFS905	TFS906	TFS907	TFS908	TFS909	TFS910	TFS911	TFS912	TFS913	TFS914	TFS915	TFS916	TFS917	TFS918	TFS919	TFS920	TFS921	TFS922	TFS923	TFS924	TFS925	TFS926	TFS927	TFS928	TFS929	TFS930	TFS931	TFS932	TFS933	TFS934	TFS935	TFS936	TFS937	TFS938	TFS939	TFS940	TFS941	TFS942	TFS943	TFS944	TFS945	TFS946	TFS947	TFS948	TFS949	TFS950	TFS951	TFS952	TFS953	TFS954	TFS955	TFS956	TFS957	TFS958	TFS959	TFS960	TFS961	TFS962	TFS963	TFS964	TFS965	TFS966	TFS967	TFS968	TFS969	TFS970	TFS971	TFS972	TFS973	TFS974	TFS975	TFS976	TFS977	TFS978	TFS979	TFS980	TFS981	TFS982	TFS983	TFS984	TFS985	TFS986	TFS987	TFS988	TFS989	TFS990	TFS991	TFS992	TFS993	TFS994	TFS995	TFS996	TFS997	TFS998	TFS999	TFS1000	TFS1001	TFS1002	TFS1003	TFS1004	TFS1005	TFS1006	TFS1007	TFS1008	TFS1009	TFS1010	TFS1011	TFS1012	TFS1013	TFS1014	TFS1015	TFS1016	TFS1017	TFS1018	TFS1019	TFS1020	TFS1021	TFS1022	TFS1023	TFS1024	TFS1025	TFS1026	TFS1027	TFS1028	TFS1029	TFS1030	TFS1031	TFS1032	TFS1033	TFS1034	TFS1035	TFS1036	TFS1037	TFS1038	TFS1039	TFS1040	TFS1041	TFS1042	TFS1043	TFS1044	TFS1045	TFS1046	TFS1047	TFS1048	TFS1049	TFS1050	TFS1051	TFS1052	TFS1053	TFS1054	TFS1055	TFS1056	TFS1057	TFS1058	TFS1059	TFS1060	TFS1061	TFS1062	TFS1063	TFS1064	TFS1065	TFS1066	TFS1067	TFS1068	TFS1069	TFS1070	TFS1071	TFS1072	TFS1073	TFS1074	TFS1075	TFS1076	TFS1077	TFS1078	TFS1079	TFS1080	TFS1081	TFS1082	TFS1083	TFS1084	TFS1085	TFS1086	TFS1087	TFS1088	TFS1089	TFS1090	TFS1091	TFS1092	TFS1093	TFS1094	TFS1095	TFS1096	TFS1097	TFS1098	TFS1099	TFS1100	TFS1101	TFS1102	TFS1103	TFS1104	TFS1105	TFS1106	TFS1107	TFS1108	TFS1109	TFS1110	TFS1111	TFS1112	TFS1113	TFS1114	TFS1115	TFS1116	TFS1117	TFS1118	TFS1119	TFS1120	TFS1121	TFS1122	TFS1123	TFS1124	TFS1125	TFS1126	TFS1127	TFS1128	TFS1129	TFS1130	TFS1131	TFS1132	TFS1133	TFS1134	TFS1135	TFS1136	TFS1137	TFS1138	TFS1139	TFS1140	TFS1141	TFS1142	TFS1143	TFS1144	TFS1145	TFS1146	TFS1147	TFS1148	TFS1149	TFS1150	TFS1151	TFS1152	TFS1153	TFS1154	TFS1155	TFS1156	TFS1157	TFS1158	TFS1159	TFS1160	TFS1161	TFS1162	TFS1163	TFS1164	TFS1165	TFS1166	TFS1167	TFS1168	TFS1169	TFS1170	TFS1171	TFS1172	TFS1173	TFS1174	TFS1175	TFS1176	TFS1177	TFS1178	TFS1179	TFS1180	TFS1181	TFS1182	TFS1183	TFS1184	TFS1185	TFS1186	TFS1187	TFS1188	TFS1189	TFS1190	TFS1191	TFS1192	TFS1193	TFS1194	TFS1195	TFS1196	TFS1197	TFS1198	TFS1199	TFS1200	TFS1201	TFS1202	TFS1203	TFS1204	TFS1205	TFS1206	TFS1207	TFS1208	TFS1209	TFS1210	TFS1211	TFS1212	TFS1213	TFS1214	TFS1215	TFS1216	TFS1217	TFS1218	TFS1219	TFS1220	TFS1221	TFS1222	TFS1223

Table 6.3.2-1 Detail Load Combinations for Reinforced Concrete Structures (Continued)

CV-7	Abnormal LOCA (LSP)	6 min. After	GDCS	w/o Temp	(CO+SRV)Pos	6201	N/A	1.0	1.0	1.0	1.5	Thermal Load																Seismic		Hydrodynamic Load												Wind Load				Tornado Load				Acceptance Criteria																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																												
												LOCA (GDCS Condition 1*)												LOCA (GDCS Condition 2*)				LOCA Flooding				LOCA & LOFCF				SPF LOFCF (after 72hr)	SPF LOFCF (after 72hr)	Normal Operation & LOCA	LOCA Flooding	During AP	Reaction				N to S	S to N	E to W	W to E	N to S		S to N	E to W	W to E																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																									
												Normal Operation				After 5 seconds				After 6 minutes				After 10 hours				After 72 hours				After 5 sec.									After 6 minutes													After 10 hours				After 72 hours				SRV	PS	CO	GH	SRV	PS-AP	CO	GH																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																									
												DL01	DL02	LLO	SP0	PTL1	PTL2	POL	PL1	PL2	PL3	PL4	AP	PLMS	HOTH	TLW0	TLW1	TLW2	TLW3	TLW4	TLW5	TLW6	TLW7	TLW8	TFS5	TFS6	TFS7	TFS8	TFS9	TFS10	TFS11	TFS12	TFS13	TFS14	TFS15	TFS16	TFS17	TFS18	TFS19		TFS20	TFS21	TFS22	TFS23	TFS24	TFS25	TFS26	TFS27	TFS28	TFS29	TFS30									TFS31	TFS32	TFS33	TFS34	TFS35	TFS36	TFS37	TFS38	TFS39	TFS40	TFS41	TFS42	TFS43	TFS44	TFS45	TFS46	TFS47	TFS48	TFS49	TFS50	TFS51	TFS52	TFS53	TFS54	TFS55	TFS56	TFS57	TFS58	TFS59	TFS60	TFS61	TFS62	TFS63	TFS64	TFS65	TFS66	TFS67	TFS68	TFS69	TFS70	TFS71	TFS72	TFS73	TFS74	TFS75	TFS76	TFS77	TFS78	TFS79	TFS80	TFS81	TFS82	TFS83	TFS84	TFS85	TFS86	TFS87	TFS88	TFS89	TFS90	TFS91	TFS92	TFS93	TFS94	TFS95	TFS96	TFS97	TFS98	TFS99	TFS100	TFS101	TFS102	TFS103	TFS104	TFS105	TFS106	TFS107	TFS108	TFS109	TFS110	TFS111	TFS112	TFS113	TFS114	TFS115	TFS116	TFS117	TFS118	TFS119	TFS120	TFS121	TFS122	TFS123	TFS124	TFS125	TFS126	TFS127	TFS128	TFS129	TFS130	TFS131	TFS132	TFS133	TFS134	TFS135	TFS136	TFS137	TFS138	TFS139	TFS140	TFS141	TFS142	TFS143	TFS144	TFS145	TFS146	TFS147	TFS148	TFS149	TFS150	TFS151	TFS152	TFS153	TFS154	TFS155	TFS156	TFS157	TFS158	TFS159	TFS160	TFS161	TFS162	TFS163	TFS164	TFS165	TFS166	TFS167	TFS168	TFS169	TFS170	TFS171	TFS172	TFS173	TFS174	TFS175	TFS176	TFS177	TFS178	TFS179	TFS180	TFS181	TFS182	TFS183	TFS184	TFS185	TFS186	TFS187	TFS188	TFS189	TFS190	TFS191	TFS192	TFS193	TFS194	TFS195	TFS196	TFS197	TFS198	TFS199	TFS200	TFS201	TFS202	TFS203	TFS204	TFS205	TFS206	TFS207	TFS208	TFS209	TFS210	TFS211	TFS212	TFS213	TFS214	TFS215	TFS216	TFS217	TFS218	TFS219	TFS220	TFS221	TFS222	TFS223	TFS224	TFS225	TFS226	TFS227	TFS228	TFS229	TFS230	TFS231	TFS232	TFS233	TFS234	TFS235	TFS236	TFS237	TFS238	TFS239	TFS240	TFS241	TFS242	TFS243	TFS244	TFS245	TFS246	TFS247	TFS248	TFS249	TFS250	TFS251	TFS252	TFS253	TFS254	TFS255	TFS256	TFS257	TFS258	TFS259	TFS260	TFS261	TFS262	TFS263	TFS264	TFS265	TFS266	TFS267	TFS268	TFS269	TFS270	TFS271	TFS272	TFS273	TFS274	TFS275	TFS276	TFS277	TFS278	TFS279	TFS280	TFS281	TFS282	TFS283	TFS284	TFS285	TFS286	TFS287	TFS288	TFS289	TFS290	TFS291	TFS292	TFS293	TFS294	TFS295	TFS296	TFS297	TFS298	TFS299	TFS300	TFS301	TFS302	TFS303	TFS304	TFS305	TFS306	TFS307	TFS308	TFS309	TFS310	TFS311	TFS312	TFS313	TFS314	TFS315	TFS316	TFS317	TFS318	TFS319	TFS320	TFS321	TFS322	TFS323	TFS324	TFS325	TFS326	TFS327	TFS328	TFS329	TFS330	TFS331	TFS332	TFS333	TFS334	TFS335	TFS336	TFS337	TFS338	TFS339	TFS340	TFS341	TFS342	TFS343	TFS344	TFS345	TFS346	TFS347	TFS348	TFS349	TFS350	TFS351	TFS352	TFS353	TFS354	TFS355	TFS356	TFS357	TFS358	TFS359	TFS360	TFS361	TFS362	TFS363	TFS364	TFS365	TFS366	TFS367	TFS368	TFS369	TFS370	TFS371	TFS372	TFS373	TFS374	TFS375	TFS376	TFS377	TFS378	TFS379	TFS380	TFS381	TFS382	TFS383	TFS384	TFS385	TFS386	TFS387	TFS388	TFS389	TFS390	TFS391	TFS392	TFS393	TFS394	TFS395	TFS396	TFS397	TFS398	TFS399	TFS400	TFS401	TFS402	TFS403	TFS404	TFS405	TFS406	TFS407	TFS408	TFS409	TFS410	TFS411	TFS412	TFS413	TFS414	TFS415	TFS416	TFS417	TFS418	TFS419	TFS420	TFS421	TFS422	TFS423	TFS424	TFS425	TFS426	TFS427	TFS428	TFS429	TFS430	TFS431	TFS432	TFS433	TFS434	TFS435	TFS436	TFS437	TFS438	TFS439	TFS440	TFS441	TFS442	TFS443	TFS444	TFS445	TFS446	TFS447	TFS448	TFS449	TFS450	TFS451	TFS452	TFS453	TFS454	TFS455	TFS456	TFS457	TFS458	TFS459	TFS460	TFS461	TFS462	TFS463	TFS464	TFS465	TFS466	TFS467	TFS468	TFS469	TFS470	TFS471	TFS472	TFS473	TFS474	TFS475	TFS476	TFS477	TFS478	TFS479	TFS480	TFS481	TFS482	TFS483	TFS484	TFS485	TFS486	TFS487	TFS488	TFS489	TFS490	TFS491	TFS492	TFS493	TFS494	TFS495	TFS496	TFS497	TFS498	TFS499	TFS500	TFS501	TFS502	TFS503	TFS504	TFS505	TFS506	TFS507	TFS508	TFS509	TFS510	TFS511	TFS512	TFS513	TFS514	TFS515	TFS516	TFS517	TFS518	TFS519	TFS520	TFS521	TFS522	TFS523	TFS524	TFS525	TFS526	TFS527	TFS528	TFS529	TFS530	TFS531	TFS532	TFS533	TFS534	TFS535	TFS536	TFS537	TFS538	TFS539	TFS540	TFS541	TFS542	TFS543	TFS544	TFS545	TFS546	TFS547	TFS548	TFS549	TFS550	TFS551	TFS552	TFS553	TFS554	TFS555	TFS556	TFS557	TFS558	TFS559	TFS560	TFS561	TFS562	TFS563	TFS564	TFS565	TFS566	TFS567	TFS568	TFS569	TFS570	TFS571	TFS572	TFS573	TFS574	TFS575	TFS576	TFS577	TFS578	TFS579	TFS580	TFS581	TFS582	TFS583	TFS584	TFS585	TFS586	TFS587	TFS588	TFS589	TFS590	TFS591	TFS592	TFS593	TFS594	TFS595	TFS596	TFS597	TFS598	TFS599	TFS600	TFS601	TFS602	TFS603	TFS604	TFS605	TFS606	TFS607	TFS608	TFS609	TFS610	TFS611	TFS612	TFS613	TFS614	TFS615	TFS616	TFS617	TFS618	TFS619	TFS620	TFS621	TFS622	TFS623	TFS624	TFS625	TFS626	TFS627	TFS628	TFS629	TFS630	TFS631	TFS632	TFS633	TFS634	TFS635	TFS636	TFS637	TFS638	TFS639	TFS640	TFS641	TFS642	TFS643	TFS644	TFS645	TFS646	TFS647	TFS648	TFS649	TFS650	TFS651	TFS652	TFS653	TFS654	TFS655	TFS656	TFS657	TFS658	TFS659	TFS660	TFS661	TFS662	TFS663	TFS664	TFS665	TFS666	TFS667	TFS668	TFS669	TFS670	TFS671	TFS672	TFS673	TFS674	TFS675	TFS676	TFS677	TFS678	TFS679	TFS680	TFS681	TFS682	TFS683	TFS684	TFS685	TFS686	TFS687	TFS688	TFS689	TFS690	TFS691	TFS692	TFS693	TFS694	TFS695	TFS696	TFS697	TFS698	TFS699	TFS700	TFS701	TFS702	TFS703	TFS704	TFS705	TFS706	TFS707	TFS708	TFS709	TFS710	TFS711	TFS712	TFS713	TFS714	TFS715	TFS716	TFS717	TFS718	TFS719	TFS720	TFS721	TFS722	TFS723	TFS724	TFS725	TFS726	TFS727	TFS728	TFS729	TFS730	TFS731	TFS732	TFS733	TFS734	TFS735	TFS736	TFS737	TFS738	TFS739	TFS740	TFS741	TFS742	TFS743	TFS744	TFS745	TFS746	TFS747	TFS748	TFS749	TFS750	TFS751	TFS752	TFS753	TFS754	TFS755	TFS756	TFS757	TFS758	TFS759	TFS760	TFS761	TFS762	TFS763	TFS764	TFS765	TFS766	TFS767	TFS768	TFS769	TFS770	TFS771	TFS772	TFS773	TFS774	TFS775	TFS776	TFS777	TFS778	TFS779	TFS780	TFS781	TFS782	TFS783	TFS784	TFS785	TFS786	TFS787	TFS788	TFS789	TFS790	TFS791	TFS792	TFS793	TFS794	TFS795	TFS796	TFS797	TFS798	TFS799	TFS800	TFS801	TFS802	TFS803	TFS804	TFS805	TFS806	TFS807	TFS808	TFS809	TFS810	TFS811	TFS812	TFS813	TFS814	TFS815	TFS816	TFS817	TFS818	TFS819	TFS820	TFS821	TFS822	TFS823	TFS824	TFS825	TFS826	TFS827	TFS828	TFS829	TFS830	TFS831	TFS832	TFS833	TFS834	TFS835	TFS836	TFS837	TFS838	TFS839	TFS840	TFS841	TFS842	TFS843	TFS844	TFS845	TFS846	TFS847	TFS848	TFS849	TFS850	TFS851	TFS852	TFS853	TFS854	TFS855	TFS856	TFS857	TFS858	TFS859	TFS860	TFS861	TFS862	TFS863	TFS864	TFS865	TFS866	TFS867	TFS868	TFS869	TFS870	TFS871	TFS872	TFS873	TFS874	TFS875	TFS876	TFS877	TFS878	TFS879	TFS880	TFS881	TFS882	TFS883	TFS884	TFS885	TFS886	TFS887	TFS888	TFS889	TFS890	TFS891	TFS892	TFS893	TFS894	TFS895	TFS896	TFS897	TFS898	TFS899	TFS900	TFS901	TFS902	TFS903	TFS904	TFS905	TFS906	TFS907	TFS908	TFS909	TFS910	TFS911	TFS912	TFS913	TFS914	TFS915	TFS916	TFS917	TFS918	TFS919	TFS920	TFS921	TFS922	TFS923	TFS924	TFS925	TFS926	TFS927	TFS928	TFS929	TFS930	TFS931	TFS932	TFS933	TFS934	TFS935	TFS936	TFS937	TFS938	TFS939	TFS940	TFS941	TFS942	TFS943	TFS944	TFS945	TFS946	TFS947	TFS948	TFS949	TFS950	TFS951	TFS952	TFS953	TFS954	TFS955	TFS956	TFS957	TFS958	TFS959	TFS960	TFS961	TFS962	TFS963	TFS964	TFS965	TFS966	TFS967	TFS968	TFS969	TFS970	TFS971	TFS972	TFS973	TFS974	TFS975	TFS976	TFS977	TFS978	TFS979	TFS980	TFS981	TFS982	TFS983	TFS984	TFS985	TFS986	TFS987	TFS988	TFS989	TFS990	TFS991	TFS992	TFS993	TFS994	TFS995	TFS996	TFS997	TFS998	TFS999	TFS1000	TFS1001	TFS1002	TFS1003	TFS1004	TFS1005	TFS1006	TFS1007	TFS1008	TFS1009	TFS1010	TFS1011	TFS1012	TFS1013	TFS1014	TFS1015	TFS1016	TFS1017	TFS1018	TFS1019	TFS1020	TFS1021	TFS1022	TFS1023	TFS1024	TFS1025	TFS1026	TFS1027	TFS1028	TFS1029	TFS1030	TFS1031	TFS1032	TFS1033	TFS1034	TFS1035	TFS1036	TFS1037	TFS1038	TFS1039	TFS1040	TFS1041	TFS1042	TFS1043	TFS1044	TFS1045	TFS1046	TFS1047	TFS1048	TFS1049	TFS1050	TFS1051	TFS1052	TFS1053	TFS1054	TFS1055	TFS1056	TFS1057	TFS1058	TFS1059	TFS1060	TFS1061	TFS1062	TFS1063	TFS1064	TFS1065	TFS1066	TFS1067	TFS1068	TFS1069	TFS1070	TFS1071	TFS1072	TFS1073	TFS1074	TFS1075	TFS1076	TFS1077	TFS1078	TFS1079	TFS1080	TFS1081	TFS1082	TFS1083	TFS1084	TFS1085	TFS1086	TFS1087	TFS1088	TFS1089	TFS1090	TFS1091	TFS1092	TFS1093	TFS1094	TFS1095	TFS1096	TFS1097	TFS1098	TFS1099	TFS1100	TFS1101	TFS1102	TFS1103	TFS1104	TFS1105	TFS1106	TFS1107	TFS1108	TFS1109	TFS1110	TFS1111	TFS1112	TFS1113	TFS1114	TFS1115	TFS1116	TFS1117	TFS1118	TFS1119	TFS1120	TFS1121	TFS1122	TFS1123	TFS1124	TFS1125	TFS1126	TFS1127	TFS1128	TFS1129	TFS1130	TFS1131	TFS1132	TFS1133	TFS1134	TFS1135	TFS1136	TFS1137	TFS1138	TFS1139	TFS1140	TFS1141	TFS1142	TFS1143	TFS1144	TFS1145	TFS1146	TFS1147	TFS1148	TFS1149	TFS1150	TFS1151	TFS1152	TFS1153	TFS1154	TFS1155	TFS1156	TFS1157	TFS1158	TFS1159	TFS1160	TFS1161	TFS1162	TFS1163	TFS1164	TFS1165	TFS1166	TFS1167	TFS1168	TFS1169	TFS1170	TFS1171	TFS1172	TFS1173	TFS1174	TFS1175	TFS1176	TFS1177	TFS1178	TFS1179	TFS1180	TFS1181	TFS1182	TFS1183	TFS1184	TFS1185	TFS1186	TFS1187	TFS1188	TFS1189	TFS1190	TFS1191	TFS1192	TFS1193	TFS1194	TFS1195	TFS1196	TFS1197	TFS1198	TFS1199	TFS1200	TFS1201	TFS1202	TFS1203	TFS1204	TFS1205	TFS1206	TFS1207	TFS1208	TFS1209	TFS1210	TFS1211	TFS1212	TFS1213	TFS1214	TFS1215	TFS1216	TFS1217	TFS1218	TFS1219	TFS1220	TFS1221	TFS1222	TFS1223









**Table 6.3.3-1 Combined Forces and Moments: 1.05D + 1.3L +1.3To + 1.3W: Winter:  
Load ID = 4021 (Selected Load Combination FB-4)**

Location	Element ID		Nx (MN/m)	Ny (MN/m)	Nxy (MN/m)	Mx (MNm/m)	My (MNm/m)	Mxy (MNm/m)	Qx (MN/m)	Qy (MN/m)	
1 Exterior Wall and Pool Wall @ EL-11.50 ~-10.50m	60011	OTHR	-2.761	-2.158	-0.833	-0.155	-1.183	0.019	-0.066	-0.940	
		TEMP	-1.399	0.244	-0.150	1.389	1.248	0.082	-0.323	-0.124	
	60219	OTHR	-2.521	-1.990	-0.577	0.103	-0.753	0.145	0.027	-0.858	
		TEMP	2.141	-3.473	1.526	-16.532	-22.653	-0.638	-0.009	-2.744	
	70201	OTHR	-0.927	-0.381	0.019	-1.345	-0.894	-0.609	0.588	-0.045	
		TEMP	2.590	3.915	-1.049	-5.504	-5.911	0.402	-0.198	0.757	
	70204	OTHR	-1.294	-1.779	-0.213	0.449	-1.951	-0.415	-0.086	1.941	
		TEMP	1.973	1.474	-0.981	-5.183	-6.088	0.322	0.084	0.078	
	110718	OTHR	-0.743	-1.075	-0.846	-0.079	0.018	0.047	0.072	0.103	
		TEMP	-2.857	-4.097	-1.806	-2.527	-2.904	0.015	0.243	-0.324	
2 Exterior Wall @ EL4.65 ~6.60m	62011	OTHR	-0.206	-1.135	-0.107	0.033	0.189	0.008	0.000	0.075	
		TEMP	7.429	2.426	0.697	-1.402	-1.563	0.008	-0.029	-0.075	
	62019	OTHR	-0.339	-0.714	-0.078	0.018	0.119	-0.030	0.012	0.059	
		TEMP	10.022	0.294	-2.625	-1.562	-1.942	-0.063	0.045	-0.137	
	72001	OTHR	-0.073	-0.261	-0.058	-0.268	-0.039	0.054	0.145	0.026	
		TEMP	5.610	-1.657	3.481	-0.530	-1.166	0.047	-0.963	0.332	
	72004	OTHR	-0.278	-0.666	-0.073	0.390	0.266	0.053	0.061	-0.165	
		TEMP	8.962	1.077	3.662	-1.724	-2.091	0.110	-0.068	0.213	
	3 Exterior Wall @ EL22.50 ~24.60m	64011	OTHR	0.255	-0.308	-0.066	-0.122	-0.585	0.002	-0.002	0.067
			TEMP	5.619	0.223	0.312	-1.261	-0.544	-0.026	-0.006	-0.099
64019		OTHR	0.004	-0.413	-0.085	-0.069	-0.408	0.056	0.067	0.054	
		TEMP	6.640	1.810	1.921	-1.323	-0.590	0.031	-0.009	-0.068	
74001		OTHR	-0.023	-0.056	0.119	0.057	-0.051	-0.042	-0.031	-0.029	
		TEMP	3.770	-0.975	-4.229	-0.993	-0.606	0.162	-0.381	0.129	
74004		OTHR	-0.027	-0.227	0.086	-0.084	-0.383	-0.062	0.018	-0.061	
		TEMP	5.254	0.289	-4.060	-1.230	-0.396	-0.031	0.029	0.115	
4 Spent Fuel Pool Wall @ EL-5.10 ~-3.30m		60819	OTHR	-2.105	-1.488	-0.683	0.638	1.075	0.111	0.184	-0.012
			TEMP	-2.782	-4.484	-0.289	-13.307	-12.914	-1.206	-0.062	-1.487
	70801	OTHR	-1.408	-0.699	-0.089	-3.527	-0.259	-0.424	2.179	-0.351	
		TEMP	0.397	4.656	-0.384	-5.261	-5.277	0.027	0.021	-0.027	
	70804	OTHR	-1.217	-1.098	-0.094	2.790	1.829	-0.341	0.324	0.256	
		TEMP	-0.972	0.944	0.201	-5.140	-5.323	0.365	-0.042	0.181	
	110748	OTHR	-0.545	-0.665	-0.428	-0.053	-0.042	-0.069	0.102	-0.059	
		TEMP	-0.574	-3.683	-1.399	-1.735	-2.298	-0.112	0.476	-0.198	
	5 Basemat	90306	OTHR	-4.302	-3.074	0.797	0.965	-0.801	0.431	-0.612	1.576
			TEMP	-0.551	-0.079	0.609	2.135	1.086	0.301	-0.278	0.264
90310		OTHR	-2.505	-2.555	0.255	-0.649	-0.533	-0.048	0.390	0.184	
		TEMP	0.239	0.313	0.518	1.691	1.777	0.959	0.054	-0.064	
90410		OTHR	-3.285	-5.455	0.721	-2.050	-0.017	1.722	1.710	-0.342	
		TEMP	-0.173	-0.844	0.141	0.811	2.381	-0.132	-0.103	-0.121	
5 Basemat @ Spent Fuel Pool	90486	OTHR	-3.440	-5.735	-0.328	3.065	1.550	-0.126	-0.139	-0.216	
		TEMP	-4.244	-2.720	0.470	-24.557	-25.455	2.673	-0.139	0.534	
	90490	OTHR	-3.543	-4.705	0.200	-1.336	0.798	0.351	1.536	-0.326	
		TEMP	-3.300	3.303	0.448	-29.781	-29.188	0.728	2.617	2.051	
	90526	OTHR	-4.260	-6.628	-0.408	0.655	-5.562	-0.299	-0.211	-1.879	
		TEMP	3.535	0.045	-0.194	-25.792	-9.116	0.463	-1.405	2.015	
6 Slab EL4.65m	93306	OTHR	0.042	-0.229	-0.085	0.100	0.164	0.016	0.034	-0.158	
		TEMP	-1.235	-0.073	-1.154	-0.070	0.029	-0.024	0.086	-0.038	
	93310	OTHR	-0.038	-0.035	0.140	0.092	0.042	0.011	-0.050	0.004	
		TEMP	-2.819	-2.798	-3.576	-0.996	-1.005	-0.291	0.362	0.365	
	93410	OTHR	-0.051	-0.174	0.009	0.220	0.058	-0.047	-0.099	-0.017	
		TEMP	-0.718	-3.379	-0.128	-0.172	-0.035	0.000	-0.089	-0.038	

OTHR: Loads other than thermal loads  
TEMP: Thermal loads



**Table 6.3.3-2 Combined Forces and Moments: LOCA (1.5Pa): Winter: Load ID = 6441  
(Selected Load Combination FB-8)**

Location	Element ID		Nx (MN/m)	Ny (MN/m)	Nxy (MN/m)	Mx (MNm/m)	My (MNm/m)	Mxy (MNm/m)	Qx (MN/m)	Qy (MN/m)	
1 Exterior Wall and Pool Wall @ EL-11.50 ~-10.50m	60011	OTHR	-2.180	-2.014	-0.749	-0.156	-1.172	0.013	-0.079	-0.817	
		TEMP	-0.932	0.104	-0.283	1.040	0.845	0.081	-0.279	-0.151	
		HYDR	0.343	0.293	0.291	0.021	0.118	0.009	0.011	0.040	
	60219	OTHR	-1.837	-1.810	-0.486	-0.058	-0.765	0.068	0.027	-0.605	
		TEMP	1.775	-2.822	0.999	-12.784	-17.538	-0.622	0.026	-2.138	
		HYDR	0.317	0.588	0.207	0.084	0.203	0.013	0.007	0.035	
	70201	OTHR	-0.655	-0.304	0.026	-0.934	-0.689	-0.446	0.399	-0.021	
		TEMP	2.001	2.952	-0.673	-4.155	-4.561	0.310	-0.183	0.610	
		HYDR	0.010	0.175	0.191	0.016	0.053	0.003	0.023	0.017	
	70204	OTHR	-0.909	-1.543	-0.127	0.303	-1.514	-0.294	-0.067	1.423	
		TEMP	1.559	1.017	-0.470	-3.984	-4.709	0.285	0.069	0.073	
		HYDR	0.094	0.569	0.366	0.044	0.100	0.012	0.002	0.023	
	110718	OTHR	-0.527	-1.090	-0.694	-0.070	0.033	0.037	0.062	0.118	
		TEMP	-2.155	-3.145	-1.392	-1.934	-2.203	0.009	0.190	-0.234	
		HYDR	0.159	0.275	0.063	0.016	0.037	0.002	0.004	0.018	
2 Exterior Wall @ EL4.65 ~-6.60m	62011	OTHR	-0.164	-1.130	-0.068	0.029	0.147	0.007	0.002	0.055	
		TEMP	5.880	1.937	0.541	-1.090	-1.228	0.001	-0.030	-0.062	
		HYDR	0.101	0.076	0.187	0.003	0.012	0.001	0.004	0.003	
	62019	OTHR	-0.256	-0.686	-0.078	0.008	0.087	-0.026	0.008	0.040	
		TEMP	7.722	0.133	-2.024	-1.201	-1.492	-0.050	0.033	-0.106	
		HYDR	0.061	0.126	0.193	0.003	0.011	0.001	0.001	0.002	
	72001	OTHR	-0.044	-0.180	-0.014	-0.199	-0.029	0.034	0.117	0.018	
		TEMP	4.333	-1.692	2.655	-0.388	-0.891	0.038	-0.739	0.255	
		HYDR	0.023	0.198	0.270	0.007	0.005	0.001	0.002	0.004	
	72004	OTHR	-0.202	-0.583	-0.015	0.302	0.200	0.036	0.044	-0.113	
		TEMP	7.043	0.683	2.803	-1.318	-1.608	0.083	-0.056	0.166	
		HYDR	0.052	0.190	0.321	0.004	0.006	0.001	0.001	0.001	
	3 Exterior Wall @ EL22.50 ~-24.60m	64011	OTHR	0.002	-0.326	-0.056	-0.121	-0.599	0.001	-0.002	0.083
			TEMP	4.710	0.187	0.313	-0.963	-0.391	-0.017	-0.003	-0.083
			HYDR	0.344	0.002	0.133	0.005	0.015	0.002	0.001	0.002
64019		OTHR	-0.160	-0.426	-0.134	-0.067	-0.419	0.052	0.067	0.067	
		TEMP	5.505	1.413	1.655	-1.023	-0.448	0.026	-0.009	-0.051	
		HYDR	0.254	0.011	0.101	0.005	0.011	0.004	0.002	0.002	
74001		OTHR	-0.036	-0.042	0.158	0.044	-0.056	-0.036	-0.028	-0.028	
		TEMP	2.905	-0.810	-3.488	-0.742	-0.459	0.125	-0.302	0.092	
		HYDR	0.020	0.018	0.092	0.009	0.004	0.004	0.005	0.003	
74004		OTHR	-0.101	-0.239	0.179	-0.084	-0.399	-0.055	0.014	-0.080	
		TEMP	4.031	0.191	-3.611	-0.936	-0.298	-0.021	0.021	0.087	
		HYDR	0.118	0.009	0.173	0.003	0.004	0.004	0.001	0.001	
4 Spent Fuel Pool Wall @ EL-5.10 ~-3.30m		60819	OTHR	-1.496	-1.383	-0.597	0.277	0.634	0.027	0.139	-0.023
			TEMP	-2.067	-3.594	-0.353	-10.280	-9.932	-1.102	-0.058	-1.158
			HYDR	0.057	0.403	0.247	0.083	0.054	0.022	0.009	0.015
	70801	OTHR	-0.949	-0.535	-0.048	-2.507	-0.190	-0.332	1.569	-0.269	
		TEMP	0.377	3.314	-0.183	-3.883	-4.019	0.017	-0.013	-0.017	
		HYDR	0.028	0.219	0.302	0.036	0.010	0.009	0.012	0.005	
	70804	OTHR	-0.813	-0.985	-0.033	2.046	1.302	-0.251	0.231	0.205	
		TEMP	-0.589	0.585	0.363	-3.927	-4.089	0.317	-0.051	0.144	
		HYDR	0.051	0.378	0.366	0.033	0.015	0.017	0.003	0.010	
	110748	OTHR	-0.379	-0.726	-0.447	-0.079	-0.049	-0.053	0.092	-0.050	
		TEMP	-0.434	-2.821	-1.077	-1.340	-1.771	-0.097	0.369	-0.150	
		HYDR	0.060	0.095	0.068	0.010	0.010	0.015	0.002	0.006	

OTHR: Loads other than thermal and hydrodynamic loads  
 TEMP: Thermal loads  
 HYDR: Hydrodynamic loads



**Table 6.3.3-2 Combined Forces and Moments: LOCA (1.5Pa): Winter: Load ID = 6441  
(Selected Load Combination FB-8) (Continued)**

Location	Element ID		Nx (MN/m)	Ny (MN/m)	Nxy (MN/m)	Mx (MNm/m)	My (MNm/m)	Mxy (MNm/m)	Qx (MN/m)	Qy (MN/m)
5 Basemat	90306	OTHR	-3.550	-2.447	0.674	0.918	-0.661	0.322	-0.541	1.431
		TEMP	-0.842	-0.093	0.302	1.812	0.786	0.047	-0.013	0.259
		HYDR	0.379	0.165	0.412	0.357	0.091	0.349	0.331	0.408
	90310	OTHR	-1.958	-1.982	0.184	-0.545	-0.444	-0.171	0.342	0.119
		TEMP	0.134	0.271	0.321	1.221	1.339	0.612	0.152	-0.060
		HYDR	0.052	0.139	0.022	0.062	0.063	0.144	0.111	0.142
	90410	OTHR	-2.640	-4.305	0.681	-1.813	0.002	1.619	1.592	-0.270
		TEMP	-0.192	-0.439	0.257	0.435	1.801	0.052	-0.016	-0.216
		HYDR	0.071	0.650	0.200	0.146	0.116	0.471	0.230	0.146
5 Basemat @ Spent Fuel Pool	90486	OTHR	-2.599	-4.369	-0.202	3.046	1.621	0.005	-0.099	-0.152
		TEMP	-3.327	-2.050	0.616	-18.282	-19.282	2.304	-0.005	0.385
		HYDR	0.158	0.207	0.127	1.680	1.236	0.208	0.129	0.088
	90490	OTHR	-2.642	-3.509	0.202	-0.803	0.812	0.385	1.391	-0.177
		TEMP	-2.565	2.723	0.532	-22.985	-22.408	0.850	2.142	1.611
		HYDR	0.057	0.699	0.167	0.334	0.711	0.173	0.524	0.090
	90526	OTHR	-3.180	-4.999	-0.266	0.879	-3.885	-0.140	-0.187	-1.585
		TEMP	2.586	0.040	0.156	-19.469	-6.941	0.735	-0.998	1.464
		HYDR	0.271	0.062	0.398	0.923	0.352	0.426	0.198	0.477
6 Slab EL4.65m	93306	OTHR	0.053	-0.186	-0.139	0.087	0.128	0.012	0.034	-0.142
		TEMP	-0.789	-0.028	-1.656	-0.051	0.035	-0.014	0.080	-0.030
		HYDR	0.184	0.036	0.234	0.034	0.041	0.003	0.008	0.008
	93310	OTHR	-0.037	-0.027	0.108	0.079	0.035	0.013	-0.045	0.002
		TEMP	-2.219	-2.170	-3.223	-0.752	-0.783	-0.242	0.267	0.288
		HYDR	0.035	0.026	0.060	0.032	0.030	0.004	0.034	0.031
	93410	OTHR	-0.015	-0.083	-0.075	0.165	0.045	-0.049	-0.073	-0.015
		TEMP	-0.686	-2.429	-0.064	-0.055	-0.015	0.020	-0.106	-0.032
		HYDR	0.017	0.128	0.106	0.023	0.007	0.012	0.016	0.001

OTHR: Loads other than thermal and hydrodynamic loads  
 TEMP: Thermal loads  
 HYDR: Hydrodynamic loads



**Table 6.3.3-3 Combined Forces and Moments: LOCA + SSE: Winter: Load ID = 7441  
(Selected Load Combination FB-9)**

Location	Element ID		Nx (MN/m)	Ny (MN/m)	Nxy (MN/m)	Mx (MNm/m)	My (MNm/m)	Mxy (MNm/m)	Qx (MN/m)	Qy (MN/m)
1 Exterior Wall and Pool Wall @ EL-11.50 ~-10.50m	60011	OTHR	-2.179	-2.004	-0.745	-0.154	-1.159	0.012	-0.076	-0.809
		TEMP	-0.932	0.104	-0.283	1.040	0.845	0.081	-0.279	-0.151
		SEIS	3.391	1.389	1.662	0.152	1.097	0.062	0.309	0.411
		HYDR	0.241	0.207	0.204	0.015	0.085	0.007	0.008	0.029
	60219	OTHR	-1.837	-1.809	-0.485	-0.058	-0.765	0.071	0.027	-0.605
		TEMP	1.775	-2.822	0.999	-12.784	-17.538	-0.622	0.026	-2.138
		SEIS	4.507	1.922	1.484	2.874	5.191	1.147	0.405	2.304
		HYDR	0.224	0.415	0.145	0.059	0.141	0.008	0.005	0.024
	70201	OTHR	-0.655	-0.307	0.030	-0.935	-0.688	-0.446	0.399	-0.021
		TEMP	2.001	2.952	-0.673	-4.155	-4.561	0.310	-0.183	0.610
		SEIS	0.602	0.811	2.674	1.445	0.852	0.681	0.452	0.270
		HYDR	0.007	0.122	0.136	0.011	0.038	0.002	0.016	0.012
	70204	OTHR	-0.914	-1.541	-0.123	0.304	-1.512	-0.294	-0.067	1.423
		TEMP	1.559	1.017	-0.470	-3.984	-4.709	0.285	0.069	0.073
		SEIS	2.332	2.155	4.012	0.621	2.107	0.487	0.097	1.544
		HYDR	0.067	0.403	0.260	0.031	0.071	0.008	0.001	0.016
110718	OTHR	-0.526	-1.088	-0.689	-0.070	0.031	0.038	0.062	0.117	
	TEMP	-2.155	-3.145	-1.392	-1.934	-2.203	0.009	0.190	-0.234	
	SEIS	2.496	1.141	2.693	0.133	0.241	0.123	0.108	0.258	
	HYDR	0.114	0.194	0.045	0.011	0.026	0.002	0.003	0.013	
2 Exterior Wall @ EL4.65 ~-6.60m	62011	OTHR	-0.162	-1.120	-0.066	0.029	0.151	0.007	0.002	0.056
		TEMP	5.880	1.937	0.541	-1.090	-1.228	0.001	-0.030	-0.062
		SEIS	1.284	0.962	2.571	0.199	0.891	0.038	0.042	0.348
		HYDR	0.072	0.054	0.130	0.002	0.008	0.000	0.003	0.002
	62019	OTHR	-0.256	-0.685	-0.078	0.008	0.089	-0.026	0.009	0.040
		TEMP	7.722	0.133	-2.024	-1.201	-1.492	-0.050	0.033	-0.106
		SEIS	0.805	1.650	2.732	0.399	0.738	0.166	0.075	0.202
		HYDR	0.043	0.088	0.135	0.002	0.008	0.001	0.000	0.001
	72001	OTHR	-0.044	-0.197	-0.006	-0.199	-0.029	0.034	0.117	0.018
		TEMP	4.333	-1.692	2.655	-0.388	-0.891	0.038	-0.739	0.255
		SEIS	1.556	3.040	4.567	0.663	0.200	0.165	0.301	0.085
		HYDR	0.016	0.138	0.191	0.005	0.004	0.001	0.001	0.003
	72004	OTHR	-0.198	-0.588	-0.002	0.302	0.200	0.036	0.044	-0.113
		TEMP	7.043	0.683	2.803	-1.318	-1.608	0.083	-0.056	0.166
		SEIS	1.884	2.616	5.021	0.622	0.871	0.106	0.117	0.460
		HYDR	0.037	0.133	0.227	0.002	0.004	0.001	0.001	0.001
3 Exterior Wall @ EL22.50 ~-24.60m	64011	OTHR	0.050	-0.326	-0.059	-0.123	-0.604	0.001	-0.002	0.084
		TEMP	4.710	0.187	0.313	-0.963	-0.391	-0.017	-0.003	-0.083
		SEIS	3.265	0.377	1.666	0.160	0.719	0.055	0.028	0.221
		HYDR	0.242	0.001	0.092	0.004	0.011	0.001	0.001	0.001
	64019	OTHR	-0.131	-0.425	-0.116	-0.068	-0.422	0.052	0.067	0.068
		TEMP	5.505	1.413	1.655	-1.023	-0.448	0.026	-0.009	-0.051
		SEIS	2.843	0.448	1.400	0.100	0.545	0.212	0.103	0.088
		HYDR	0.178	0.008	0.070	0.004	0.008	0.002	0.002	0.002
	74001	OTHR	-0.032	-0.046	0.146	0.046	-0.055	-0.037	-0.029	-0.028
		TEMP	2.905	-0.810	-3.488	-0.742	-0.459	0.125	-0.302	0.092
		SEIS	0.221	0.275	1.173	0.154	0.094	0.225	0.073	0.052
		HYDR	0.014	0.013	0.064	0.006	0.003	0.003	0.003	0.002
	74004	OTHR	-0.080	-0.240	0.154	-0.085	-0.400	-0.056	0.014	-0.080
		TEMP	4.031	0.191	-3.611	-0.936	-0.298	-0.021	0.021	0.087
		SEIS	1.773	0.355	2.028	0.120	0.449	0.151	0.071	0.211
		HYDR	0.083	0.006	0.121	0.002	0.003	0.003	0.001	0.001

OTHR: Loads other than thermal, seismic and hydrodynamic loads  
 TEMP: Thermal loads  
 SEIS: Seismic loads  
 HYDR: Hydrodynamic loads



**Table 6.3.3-3 Combined Forces and Moments: LOCA + SSE: Winter: Load ID = 7441  
(Selected Load Combination FB-9) (Continued)**

Location	Element ID		Nx (MN/m)	Ny (MN/m)	Nxy (MN/m)	Mx (MNm/m)	My (MNm/m)	Mxy (MNm/m)	Qx (MN/m)	Qy (MN/m)
4 Spent Fuel Pool Wall @ EL-5.10 ~-3.30m	60819	OTHR	-1.497	-1.381	-0.597	0.277	0.635	0.029	0.139	-0.023
		TEMP	-2.067	-3.594	-0.353	-10.280	-9.932	-1.102	-0.058	-1.158
		SEIS	2.815	1.358	1.990	6.707	2.047	1.474	0.416	1.095
		HYDR	0.039	0.284	0.174	0.058	0.037	0.016	0.006	0.011
	70801	OTHR	-0.950	-0.542	-0.041	-2.508	-0.190	-0.332	1.569	-0.269
		TEMP	0.377	3.314	-0.183	-3.883	-4.019	0.017	-0.013	-0.017
		SEIS	2.446	1.484	3.257	4.046	0.609	0.812	2.099	0.610
		HYDR	0.019	0.153	0.214	0.025	0.007	0.006	0.009	0.003
	70804	OTHR	-0.819	-0.982	-0.023	2.046	1.302	-0.251	0.231	0.205
		TEMP	-0.589	0.585	0.363	-3.927	-4.089	0.317	-0.051	0.144
		SEIS	2.332	1.601	3.755	3.232	1.357	0.538	0.366	0.553
		HYDR	0.036	0.267	0.261	0.023	0.011	0.012	0.002	0.007
110748	OTHR	-0.379	-0.723	-0.443	-0.078	-0.049	-0.053	0.092	-0.050	
	TEMP	-0.434	-2.821	-1.077	-1.340	-1.771	-0.097	0.369	-0.150	
	SEIS	1.618	1.105	2.135	0.421	0.143	0.255	0.101	0.099	
	HYDR	0.043	0.066	0.049	0.007	0.007	0.011	0.001	0.004	
5 Basemat	90306	OTHR	-3.541	-2.445	0.674	0.917	-0.652	0.323	-0.542	1.429
		TEMP	-0.842	-0.093	0.302	1.812	0.786	0.047	-0.013	0.259
		SEIS	2.617	0.678	2.942	1.298	0.418	2.974	2.642	1.674
		HYDR	0.266	0.117	0.292	0.253	0.065	0.246	0.234	0.289
	90310	OTHR	-1.958	-1.979	0.185	-0.542	-0.441	-0.170	0.342	0.115
		TEMP	0.134	0.271	0.321	1.221	1.339	0.612	0.152	-0.060
		SEIS	0.583	1.065	0.300	0.726	0.502	0.939	1.193	2.000
		HYDR	0.036	0.099	0.016	0.044	0.045	0.102	0.078	0.100
	90410	OTHR	-2.630	-4.301	0.674	-1.786	0.003	1.615	1.584	-0.270
		TEMP	-0.192	-0.439	0.257	0.435	1.801	0.052	-0.016	-0.216
		SEIS	0.369	4.923	2.060	1.989	0.824	2.609	1.088	1.731
		HYDR	0.050	0.457	0.140	0.106	0.081	0.332	0.163	0.102
5 Basemat @ Spent Fuel Pool	90486	OTHR	-2.594	-4.374	-0.208	3.019	1.614	-0.002	-0.108	-0.148
		TEMP	-3.327	-2.050	0.616	-18.282	-19.282	2.304	-0.005	0.385
		SEIS	0.450	1.155	1.352	6.105	4.467	2.495	1.324	0.507
		HYDR	0.113	0.145	0.089	1.198	0.875	0.148	0.090	0.061
	90490	OTHR	-2.642	-3.508	0.201	-0.804	0.810	0.377	1.391	-0.182
		TEMP	-2.565	2.723	0.532	-22.985	-22.408	0.850	2.142	1.611
		SEIS	0.329	6.047	1.760	9.878	4.395	1.601	1.904	1.863
		HYDR	0.040	0.495	0.117	0.237	0.504	0.121	0.370	0.063
	90526	OTHR	-3.184	-4.999	-0.266	0.868	-3.882	-0.145	-0.188	-1.583
		TEMP	2.586	0.040	0.156	-19.469	-6.941	0.735	-0.998	1.464
		SEIS	3.195	0.408	3.822	3.345	5.356	4.786	1.856	1.932
		HYDR	0.192	0.044	0.282	0.655	0.248	0.301	0.141	0.339
6 Slab EL4.65m	93306	OTHR	0.051	-0.186	-0.110	0.086	0.127	0.012	0.034	-0.141
		TEMP	-0.789	-0.028	-1.656	-0.051	0.035	-0.014	0.080	-0.030
		SEIS	1.696	0.171	1.135	0.408	0.395	0.029	0.104	0.175
		HYDR	0.129	0.026	0.171	0.024	0.029	0.002	0.005	0.006
	93310	OTHR	-0.034	-0.026	0.124	0.077	0.035	0.014	-0.043	0.002
		TEMP	-2.219	-2.170	-3.223	-0.752	-0.783	-0.242	0.267	0.288
		SEIS	0.577	0.275	0.548	0.580	0.327	0.108	0.431	0.423
		HYDR	0.024	0.018	0.044	0.023	0.022	0.003	0.024	0.022
	93410	OTHR	-0.010	-0.085	-0.080	0.163	0.045	-0.050	-0.072	-0.015
		TEMP	-0.686	-2.429	-0.064	-0.055	-0.015	0.020	-0.106	-0.032
		SEIS	0.606	0.801	1.358	0.813	0.172	0.209	0.392	0.027
		HYDR	0.013	0.091	0.076	0.017	0.005	0.008	0.011	0.001

OTHR: Loads other than thermal, seismic and hydrodynamic loads  
 TEMP: Thermal loads  
 SEIS: Seismic loads  
 HYDR: Hydrodynamic loads

**Table 6.4.1.1-1 Material Constants for Stress Calculations**

Material	Property	Value	
Concrete	Compressive strength, $f_c'$	Basemat	27.6 MPa
		Others	34.5 MPa
	Young's modulus	Basemat	$2.49 \times 10^4$ MPa
		Others	$2.78 \times 10^4$ MPa
	Poisson's ratio	0.17	
Reinforcement	Yield stress, $f_y$	413.6 MPa	
	Young's modulus	$2.00 \times 10^5$ MPa	

**Table 6.4.1.1-2 Allowable Stress of Concrete for Membrane Plus Bending**

Load Condition	Allowable Compressive Stress (MPa)		
Primary	Basemat	20.7	$(0.75 f_c')$
	Others	25.9	
Primary plus secondary	Basemat	23.5	$(0.85 f_c')$
	Others	29.3	

**Table 6.4.1.1-3 Allowable Stress of Reinforcement for Membrane Plus Bending**

	Allowable Stress (MPa)	
Tension	372.2	$(0.90 f_y)$
Compression	372.2	$(0.90 f_y)$

**Table 6.4.1.1-4 Allowable Stress of Concrete for Membrane Compressive Forces**

Load Category	Load Condition	Allowable Compressive Stress (MPa)		
		Basemat		
Factored	Primary	Basemat	16.6	(0.60 $f_c'$ )
		Others	20.7	
	Primary plus secondary	Basemat	20.7	(0.75 $f_c'$ )
		Others	25.9	
Service	Primary	Basemat	8.3	(0.30 $f_c'$ )
		Others	10.4	
	Primary plus secondary	Basemat	12.4	(0.45 $f_c'$ )
		Others	15.5	



**Table 7.3.1.1.1-1 Sectional Thicknesses and Rebar Ratios of FB Used in the Evaluation**

Location	Element ID	Thickness (m)	Primary Reinforcement					Shear Tie		
			Position	Direction 1 <sup>*1</sup>		Direction 2 <sup>*1</sup>		Arrangement	Ratio (%)	
				Arrangement <sup>*2</sup>	Ratio (%)	Arrangement <sup>*2</sup>	Ratio (%)			
1 Exterior Wall and Pool Wall Bottom	60011	2.0	Inside	3-#11@200	0.755	1-#11@100 +3-#11@200	1.258	#6@200x200	0.710	
			Outside	1-#11@100 +3-#11@200	1.258	2-#11@100 +2-#11@200	1.510			
	60219	3.6	Inside	6-#11@200	0.839	6-#11@200	0.839	#6@200x200	0.710	
			Outside	1-#11@100 +7-#11@200	1.258	1-#11@100 +7-#11@200	1.258			
	70201 70204	2.0	Inside	3-#11@100 +1-#11@200	1.761	3-#11@100 +1-#11@200	1.761	#6@200x200	0.710	
			Outside	3-#11@100 +1-#11@200	1.761	5-#11@100	2.516			
	110718	1.5	Inside	2-#11@200	0.671	3-#11@200 (+1-#11@200)	1.342	#6@400x200	0.355	
			Outside	2-#11@200	0.671	3-#11@200 (+1-#11@200)	1.342			
	2 Exterior Wall @ EL4.65 to 6.60m	62011 62019	1.0	Inside	2-#11@200	1.006	2-#11@200	1.006	#5@400x400	0.125
				Outside	3-#11@200	1.510	3-#11@200	1.510		
72001		1.0	Inside	3-#11@200	1.510	3-#11@200	1.510	#5@400x200	0.250	
			Outside	3-#11@200	1.510	3-#11@200	1.510			
72004		1.0	Inside	3-#11@200	1.510	2-#11@200 (+1-#11@200)	1.510	#5@400x200	0.250	
			Outside	3-#11@200	1.510	3-#11@200	1.510			
3 Exterior Wall @ EL22.50 to 24.60m		64011	1.0	Inside	2-#11@200	1.006	2-#11@200	1.006	#5@400x400	0.125
				Outside	2-#11@200 (+1-#11@200)	1.510	2-#11@200 (+1-#11@200)	1.510		
	64019	1.0	Inside	2-#11@200	1.006	2-#11@200	1.006	#5@400x400	0.125	
			Outside	2-#11@200	1.006	2-#11@200	1.006			
	74001 74004	1.0	Inside	2-#11@200	1.006	2-#11@200	1.006	#5@400x400	0.125	
			Outside	3-#11@200	1.510	3-#11@200	1.510			

Note: Updated arrangements of reinforcements and shear ties from standard design are shown in red.

\*1: Exterior Wall, Pool Wall Direction 1: Horizontal Direction 2: Vertical  
Basemat, Slab Direction 1: N-S Direction 2: E-W

\*2: Rebar in parentheses indicates additional bars locally required.



**Table 7.3.1.1.1-1 Sectional Thicknesses and Rebar Ratios of FB Used in the Evaluation (Continued)**

Location	Element ID	Thickness (m)	Primary Reinforcement				Shear Tie		
			Position	Direction 1 <sup>*1</sup>		Direction 2 <sup>*1</sup>		Arrangement	Ratio (%)
				Arrangement <sup>*2</sup>	Ratio (%)	Arrangement <sup>*2</sup>	Ratio (%)		
4 Spent Fuel Pool Wall @ EL-5.10 to -3.30m	60819	3.6	Inside	6-#11@200	0.839	6-#11@200	0.839	#6@200x200	0.710
			Outside	1-#11@100 +7-#11@200	1.258	1-#11@100 +7-#11@200	1.258		
	70801 70804	2.0	Inside	3-#11@100 +1-#11@200	1.761	3-#11@100 +1-#11@200	1.761	#6@200x200	0.710
			Outside	3-#11@100 +1-#11@200	1.761	5-#11@100	2.516		
	110748	1.5	Inside	2-#11@200	0.671	3-#11@200	1.006	#6@400x400	0.177
			Outside	2-#11@200	0.671	3-#11@200	1.006		
5 Basemat	90306 90310 90410	4.0	Top	4-#11@200	0.503	4-#11@200	0.503	#11@400x400	0.629
			Bottom	5-#11@200	0.629	5-#11@200	0.629		
5 Basemat @ Spent Fuel Pool	90486	5.5	Top	4-#11@200 (+2-#11@200)	0.549	4-#11@200 (+2-#11@200)	0.549	#11@600x400	0.419
			Bottom	5-#11@200	0.457	5-#11@200	0.457		
	90490 90526	5.5	Top	4-#11@200 (+2-#11@200)	0.549	4-#11@200 (+2-#11@200)	0.549	#11@400x400	0.629
			Bottom	5-#11@200	0.457	5-#11@200	0.457		
6 Slab EL4.65m	93306 93310 93410	1.3	Top	2-#11@200	0.774	2-#11@200	0.774	#5@200x200	0.500
			Bottom	2-#11@200	0.774	2-#11@200	0.774		

Note: Updated arrangements of reinforcements and shear ties from standard design are shown in red.  
<sup>\*1</sup>: Exterior Wall, Pool Wall Direction 1: Horizontal Direction 2: Vertical  
 Basemat, Slab Direction 1: N-S Direction 2: E-W  
<sup>\*2</sup>: Rebar in parentheses indicates additional bars locally required.



**Table 7.3.1.1.1-2 Rebar and Concrete Stresses of FB: 1.05D+1.3L+1.3To+1.3W: Winter:  
Load ID = 4021 (Selected Load Combination FB-4)**

Location	Element ID	Concrete Stress (MPa)		Primary Reinforcement Stress (MPa)				Allowable
		Calculated	Allowable	Calculated				
				Direction 1		Direction 2		
				In/Top	Out/Bottom	In/Top	Out/Bottom	
1 Exterior Wall and Pool Wall @ EL-11.50 ~-10.50m	60011	-3.4	-29.3	-4.5	-19.2	-4.5	-3.3	372.2
	60219	-7.6	-29.3	-9.6	30.1	-32.4	53.7	372.2
	70201	-9.9	-29.3	-12.0	90.3	-10.1	85.1	372.2
	70204	-9.2	-29.3	-4.6	31.0	-30.5	67.6	372.2
	110718	-11.3	-29.3	-16.3	84.8	-26.3	48.4	372.2
2 Exterior Wall @ EL4.65 ~-6.60m	62011	-6.4	-29.3	33.6	85.5	-12.0	27.9	372.2
	62019	-10.5	-29.3	53.3	116.8	-27.0	79.9	372.2
	72001	-9.5	-29.3	22.5	108.4	-20.1	80.0	372.2
	72004	-11.5	-29.3	56.9	73.6	-23.0	74.1	372.2
3 Exterior Wall @ EL22.50 ~-24.60m	64011	-8.4	-29.3	25.5	101.5	-18.6	66.4	372.2
	64019	-8.4	-29.3	40.6	151.3	-9.4	116.7	372.2
	74001	-4.6	-29.3	23.5	93.7	3.2	80.2	372.2
	74004	-7.5	-29.3	13.7	108.0	1.8	116.4	372.2
4 Spent Fuel Pool Wall @ EL-5.10 ~-3.30m	60819	-5.1	-29.3	-18.1	17.6	-21.1	15.2	372.2
	70801	-11.7	-29.3	-32.2	102.4	1.9	58.6	372.2
	70804	-2.9	-29.3	-12.2	4.0	-5.7	12.8	372.2
	110748	-8.8	-29.3	0.6	57.9	-32.1	33.7	372.2
5 Basemat	90306	-2.1	-23.5	-2.5	-13.7	-5.0	-3.8	372.2
	90310	-0.8	-23.5	-2.6	-4.6	-2.1	-4.9	372.2
	90410	-2.3	-23.5	-7.7	-1.3	-5.7	-15.4	372.2
5 Basemat @ Spent Fuel Pool	90486	-4.0	-23.5	-12.9	8.2	-16.1	8.6	372.2
	90490	-4.2	-23.5	-13.2	23.1	-4.7	11.6	372.2
	90526	-3.1	-23.5	-3.2	12.7	-14.0	4.4	372.2
6 Slab EL4.65m	93306	-1.8	-29.3	18.1	4.0	41.8	5.0	372.2
	93310	-7.5	-29.3	-12.4	53.2	-14.1	56.6	372.2
	93410	-2.6	-29.3	-0.4	-1.8	-16.8	-17.3	372.2

Note: Negative value means compression.

Note \*: Exterior Wall, Pool Wall  
Basemat, Slab

Direction 1: Horizontal,  
Direction 1: N-S,

Direction 2: Vertical  
Direction 2: E-W



**Table 7.3.1.1.1-3 Rebar and Concrete Stresses of FB: LOCA (1.5Pa): Winter:  
Load ID = 6441 (Selected Load Combination FB-8)**

Location	Element ID	Concrete Stress (MPa)		Primary Reinforcement Stress (MPa)				Allowable
		Calculated	Allowable	Calculated				
				Direction 1		Direction 2		
				In/Top	Out/Bottom	In/Top	Out/Bottom	
1 Exterior Wall and Pool Wall @ EL-11.50 ~-10.50m	60011	-2.8	-29.1	-3.8	-15.3	-8.5	-1.8	370.5
	60219	-6.3	-28.5	-7.2	27.8	-26.9	45.0	366.4
	70201	-7.5	-28.3	-7.7	70.1	-7.9	67.5	364.6
	70204	-7.4	-28.3	-2.6	26.3	-27.2	56.0	364.6
	110718	-8.8	-27.5	-12.7	70.7	-23.7	36.0	359.1
2 Exterior Wall @ EL4.65 ~-6.60m	62011	-3.8	-28.3	24.2	64.7	-10.3	22.1	365.0
	62019	-8.6	-28.3	35.5	95.8	-19.8	75.5	365.0
	72001	-8.1	-28.3	24.8	92.9	-19.0	64.9	365.0
	72004	-7.2	-28.3	73.9	56.4	-25.2	59.7	365.0
3 Exterior Wall @ EL22.50 ~-24.60m	64011	-8.5	-28.3	29.4	94.3	-17.7	68.8	365.0
	64019	-6.7	-28.3	32.3	96.9	-8.3	75.4	365.0
	74001	-4.0	-28.3	24.1	76.0	6.3	66.2	365.0
	74004	-6.2	-28.3	13.6	102.0	3.8	101.0	365.0
4 Spent Fuel Pool Wall @ EL-5.10 ~-3.30m	60819	-4.3	-28.5	-13.6	17.1	-18.4	13.1	366.4
	70801	-8.6	-28.3	-23.4	81.7	2.2	47.0	364.6
	70804	-2.1	-28.3	-7.7	7.4	-7.1	13.4	364.6
	110748	-7.2	-27.5	2.1	53.8	-25.9	28.5	359.1
5 Basemat	90306	-2.1	-23.2	-2.3	-14.2	-3.9	-3.2	370.3
	90310	-0.7	-23.2	-2.1	-3.9	-1.4	-4.3	370.3
	90410	-2.0	-23.2	-7.3	-0.9	-5.0	-13.1	370.3
5 Basemat @ Spent Fuel Pool	90486	-3.6	-22.9	-10.9	11.3	-13.0	9.3	367.2
	90490	-3.3	-22.9	-10.1	18.9	-4.9	12.3	367.2
	90526	-2.4	-22.9	-3.0	12.7	-10.6	3.5	367.2
6 Slab EL4.65m	93306	-2.4	-28.5	51.7	29.2	72.1	34.7	366.1
	93310	-6.1	-28.5	-5.3	56.5	-7.2	60.8	366.1
	93410	-2.0	-28.5	0.4	-3.5	-12.3	-12.8	366.1

Note: Negative value means compression.

Note \*: Exterior Wall, Pool Wall  
Basemat, Slab

Direction 1: Horizontal,  
Direction 1: N-S,

Direction 2: Vertical  
Direction 2: E-W



**Table 7.3.1.1.1-4 Rebar and Concrete Stresses of FB: LOCA + SSE: Winter:  
Load ID = 7441 (Selected Load Combination FB-9)**

Location	Element ID	Concrete Stress (MPa)		Primary Reinforcement Stress (MPa)				Allowable
		Calculated	Allowable	Calculated				
				Direction 1		Direction 2		
				In/Top	Out/Bottom	In/Top	Out/Bottom	
1 Exterior Wall and Pool Wall @ EL-11.50 ~-10.50m	60011	-4.6	-29.3	57.3	-25.0	28.0	5.1	372.2
	60219	-10.4	-28.5	35.8	66.5	-39.1	78.8	366.4
	70201	-7.1	-28.3	8.2	127.5	7.5	104.2	364.6
	70204	-11.7	-28.3	72.2	84.6	-40.0	85.8	364.6
	110718	-12.1	-28.1	-10.9	115.7	-18.4	83.9	363.3
2 Exterior Wall @ EL4.65 ~-6.60m	62011	-17.3	-29.3	106.8	202.7	257.3	206.1	372.2
	62019	-20.4	-29.3	179.6	233.7	167.4	199.6	372.2
	72001	-16.2	-29.3	176.8	327.0	99.7	204.5	372.2
	72004	-15.8	-29.3	282.2	333.3	251.7	240.1	372.2
3 Exterior Wall @ EL22.50 ~-24.60m	64011	-22.1	-29.3	130.4	267.0	42.6	235.8	372.2
	64019	-7.1	-29.3	233.0	291.1	30.6	255.5	372.2
	74001	-8.7	-29.3	77.0	98.6	65.0	82.4	372.2
	74004	-9.6	-29.3	148.1	217.0	5.0	220.4	372.2
4 Spent Fuel Pool Wall @ EL-5.10 ~-3.30m	60819	-8.3	-28.5	-32.5	46.4	-20.9	22.2	366.4
	70801	-14.1	-28.3	67.7	146.0	30.0	86.9	364.6
	70804	-8.6	-28.3	126.3	71.5	85.5	45.1	364.6
	110748	-9.8	-28.1	33.0	92.8	-26.6	62.1	363.3
5 Basemat	90306	-5.6	-23.5	59.9	-23.2	55.2	1.0	372.2
	90310	-1.7	-23.5	-2.5	-6.5	1.1	-7.1	372.2
	90410	-4.0	-23.5	16.1	-5.7	44.9	-22.7	372.2
5 Basemat @ Spent Fuel Pool	90486	-6.0	-22.9	-11.7	35.4	-15.6	17.4	367.2
	90490	-7.0	-22.9	15.8	89.6	99.7	60.3	367.2
	90526	-5.0	-22.9	111.5	19.0	48.6	34.4	367.2
6 Slab EL4.65m	93306	-4.3	-29.3	82.9	90.7	133.5	38.8	372.2
	93310	-8.7	-29.3	36.4	96.6	12.7	92.0	372.2
	93410	-6.9	-29.3	83.9	90.3	20.1	-14.7	372.2

Note: Negative value means compression.

Note \*: Exterior Wall, Pool Wall  
Basemat, Slab

Direction 1: Horizontal,  
Direction 1: N-S,

Direction 2: Vertical  
Direction 2: E-W



**Table 7.3.1.1.1-5 Maximum Stress Ratios for Flexure and Membrane Forces**

Location	Element ID	Concrete		Primary Reinforcement							
		$\sigma/\sigma_a$	Load ID	Direction 1				Direction 2			
				In/Top		Out/Bottom		In/Top		Out/Bottom	
				$\sigma/\sigma_a$	Load ID	$\sigma/\sigma_a$	Load ID	$\sigma/\sigma_a$	Load ID	$\sigma/\sigma_a$	Load ID
1 Exterior Wall and Pool Wall @ EL-11.50 ~10.50m	60011	0.246	7461	0.159	7621	0.250	8011	0.112	9013	0.164	7461
	60219	0.481	8511	0.227	7601	0.256	9011	0.168	7701	0.306	8511
	70201	0.448	6981	0.123	7751	0.467	8512	0.111	7751	0.374	8514
	70204	0.551	8511	0.212	7601	0.349	9011	0.217	7701	0.356	8514
	110718	0.719	7492	0.481	7701	0.512	8511	0.111	7751	0.377	7492
2 Exterior Wall @ EL4.65 ~6.60m	62011	0.692	8514	0.383	9013	0.632	7492	0.729	9012	0.801	7492
	62019	0.738	8514	0.531	9014	0.638	7471	0.556	7991	0.540	7482
	72001	0.576	8511	0.766	7653	0.863	8511	0.761	7653	0.710	7491
	72004	1.033	8512	0.839	7221	0.948	8512	0.979	7632	0.946	8071
3 Exterior Wall @ EL22.50 ~24.60m	64011	0.778	8511	0.508	7961	0.726	7521	0.451	8071	0.644	8511
	64019	0.505	7501	0.630	8513	0.798	8513	0.277	8071	0.686	7441
	74001	0.306	8511	0.217	8511	0.276	8511	0.188	7581	0.231	8511
	74004	0.460	8511	0.421	8514	0.584	7471	0.327	8061	0.593	7471
4 Spent Fuel Pool Wall @ EL-5.10 ~-3.30m	60819	0.343	8511	0.277	7711	0.239	7601	0.086	7611	0.120	7491
	70801	0.700	7491	0.300	7601	0.534	7492	0.220	7601	0.336	7492
	70804	0.472	8513	0.434	7861	0.377	7311	0.290	7861	0.253	8513
	110748	0.547	8511	0.517	8001	0.387	8511	0.273	8001	0.278	8511
5 Basemat	90306	0.247	8512	0.181	7121	0.063	8514	0.176	7121	0.017	7911
	90310	0.150	7211	0.042	2011	0.039	7211	0.040	2011	0.044	7961
	90410	0.282	7491	0.061	8021	0.057	7461	0.128	8021	0.199	7711
5 Basemat @ Spent Fuel Pool	90486	0.347	8514	0.158	7251	0.212	7492	0.059	7251	0.165	8514
	90490	0.356	8511	0.230	7601	0.304	7492	0.273	7621	0.212	7992
	90526	0.239	7491	0.300	7921	0.088	7991	0.141	7601	0.145	8512
6 Slab EL4.65m	93306	0.165	7211	0.517	7201	0.245	7301	0.368	8514	0.174	8001
	93310	0.303	8514	0.267	7431	0.268	8514	0.243	7411	0.257	8514
	93410	0.289	7561	0.596	7491	0.395	7701	0.275	7501	0.259	7701

Note \*: Exterior Wall, Pool Wall Direction1 : Horizontal, Direction2 : Vertical  
 Basemat, Slab Direction1 : N-S, Direction2 : E-W  
 $\sigma$  and  $\sigma_a$  are calculated and allowable stress.

Exceedance is highlighted. As shown in Figure 7.3.1.1-1, the exceedance is resolved by considering the moment capacity of wall according to the specifications of ACI 349-01.



**Table 7.3.1.1.2-1 Membrane Compressive Forces of FB**

Location	Element ID	Load ID	Section Forces (MN/m)			Thickness h (m)	Ciculated Concrete Stress (MPa)				Allowable Stress $\sigma_a$ (MPa)	$\sigma_c/\sigma_a$
			Nx	Ny	Nxy		$\sigma_x$	$\sigma_y$	$\tau_{xy}$	$\sigma_c$		
1 Exterior Wall and Pool Wall @ EL-11.50 ~-10.50m	60011	7251	-5.591	-3.421	-2.432	2.0	-2.796	-1.711	-1.216	-3.585	-20.7	0.173
	60219	7251	-6.359	-3.814	-1.988	3.6	-1.766	-1.059	-0.552	-2.068	-20.7	0.100
	70201	7201	-1.257	-1.136	2.712	2.0	-0.629	-0.568	1.356	-1.955	-20.7	0.094
	70204	7251	-3.249	-3.768	-4.153	2.0	-1.624	-1.884	-2.077	-3.835	-20.7	0.185
	110718	8511	-7.621	-7.362	-6.148	1.5	-5.081	-4.908	-4.098	-9.094	-25.9	0.351
2 Exterior Wall @ EL4.65 ~-6.60m	62011	7491	-3.314	-1.939	3.178	1.0	-3.314	-1.939	3.178	-5.878	-25.9	0.227
	62019	7411	-2.386	-2.691	3.254	1.0	-2.386	-2.691	3.254	-5.796	-25.9	0.224
	72001	7501	-1.599	-3.269	4.578	1.0	-1.599	-3.269	4.578	-7.087	-20.7	0.342
	72004	7501	-2.074	-3.215	5.045	1.0	-2.074	-3.215	5.045	-7.722	-20.7	0.373
3 Exterior Wall @ EL22.50 ~-24.60m	64011	7601	-3.251	0.052	1.609	1.0	-3.251	0.052	1.609	-3.905	-20.7	0.189
	64019	7101	-2.993	-0.873	-1.518	1.0	-2.993	-0.873	-1.518	-3.785	-20.7	0.183
	74001	8511	-0.253	-1.193	-2.891	1.0	-0.253	-1.193	-2.891	-3.652	-25.9	0.141
	74004	8511	-1.788	-0.595	-3.522	1.0	-1.788	-0.595	-3.522	-4.763	-25.9	0.184
4 Spent Fuel Pool Wall @ EL-5.10 ~-3.30m	60819	8511	-5.441	-5.636	-3.045	3.6	-1.511	-1.565	-0.846	-2.385	-25.9	0.092
	70801	7251	-3.397	-2.046	-3.314	2.0	-1.698	-1.023	-1.657	-3.052	-20.7	0.147
	70804	7251	-3.152	-2.628	-3.794	2.0	-1.576	-1.314	-1.897	-3.347	-20.7	0.162
	110748	8511	-3.019	-6.596	-4.345	1.5	-2.013	-4.397	-2.897	-6.337	-25.9	0.245
5 Basemat	90306	7251	-6.193	-3.143	3.646	4.0	-1.548	-0.786	0.912	-2.155	-16.6	0.130
	90310	2001	-1.976	-2.034	0.198	4.0	-0.494	-0.509	0.050	-0.551	-8.3	0.067
	90410	7251	-3.005	-9.273	2.743	4.0	-0.751	-2.318	0.686	-2.576	-16.6	0.156
5 Basemat @ Spent Fuel Pool	90486	2001	-2.656	-4.465	-0.269	5.5	-0.483	-0.812	-0.049	-0.819	-8.3	0.099
	90490	7251	-2.977	-9.601	1.971	5.5	-0.541	-1.746	0.358	-1.844	-16.6	0.111
	90526	2001	-3.307	-5.026	-0.442	5.5	-0.601	-0.914	-0.080	-0.933	-8.3	0.113
6 Slab EL4.65m	93306	8514	-2.833	-0.427	-2.614	1.3	-2.180	-0.329	-2.011	-3.468	-25.9	0.134
	93310	2021	-2.208	-2.184	-2.411	1.3	-1.698	-1.680	-1.854	-3.544	-15.5	0.228
	93410	7492	-0.828	-3.805	-1.983	1.3	-0.637	-2.927	-1.525	-3.689	-25.9	0.143

Note: Positive value means tension.

**Table 7.3.1.1.3-1 Transverse Shear of FB**

Location	Element ID	Load ID	d (m)	pv (%)	Shear Force (MN/m)				Vu/φVn
					Vu	Vc	Vs	φVn	
1 Exterior Wall and Pool Wall @ EL-11.50 ~-10.50m	60011	8511	1.70	0.710	1.55	4.02	5.00	7.67	0.202
	60219	8511	3.05	0.710	4.67	3.77	8.96	10.82	0.432
	70201	7481	1.65	0.710	1.19	1.72	4.84	5.58	0.213
	70204	7481	1.59	0.710	3.14	2.16	4.67	5.81	0.540
	110718	7492	1.12	0.355	0.82	1.14	1.64	2.36	0.346
2 Exterior Wall @ EL4.65 ~-6.60m	62011	7571	0.78	0.125	0.49	0.84	0.40	1.06	0.463
	62019	7601	0.72	0.125	0.18	0.13	0.37	0.43	0.407
	72001	7581	0.73	0.250	0.47	0.00	0.76	0.64	0.728
	72004	7612	0.72	0.250	0.46	0.00	0.74	0.63	0.732
3 Exterior Wall @ EL22.50 ~-24.60m	64011	7492	0.72	0.125	0.31	0.71	0.37	0.92	0.336
	64019	8511	0.80	0.125	0.22	0.00	0.41	0.35	0.635
	74001	7492	0.73	0.125	0.15	0.18	0.38	0.47	0.321
	74004	8513	0.72	0.125	0.30	0.40	0.37	0.66	0.462
4 Spent Fuel Pool Wall @ EL-5.10 ~-3.30m	60819	8511	3.05	0.710	2.44	4.35	8.97	11.32	0.216
	70801	8514	1.71	0.710	4.03	2.03	5.02	5.99	0.672
	70804	7571	1.62	0.710	1.11	0.69	4.75	4.62	0.240
	110748	8511	1.22	0.177	1.06	1.32	0.89	1.88	0.563
5 Basemat	90306	8514	3.53	0.629	4.82	6.96	9.18	13.73	0.351
	90310	7511	3.52	0.629	2.82	5.95	9.15	12.84	0.220
	90410	7471	3.53	0.629	3.47	6.91	9.19	13.68	0.254
5 Basemat @ Spent Fuel Pool	90486	7492	5.04	0.419	1.86	4.63	8.74	11.36	0.164
	90490	8514	5.04	0.629	5.65	5.53	13.11	15.85	0.356
	90526	7221	5.03	0.629	4.48	9.27	13.07	18.99	0.236
6 Slab EL4.65m	93306	7482	1.10	0.500	0.41	0.79	2.27	2.60	0.158
	93310	7571	1.10	0.500	0.93	2.47	2.27	4.03	0.231
	93410	7501	1.10	0.500	0.46	0.99	2.27	2.77	0.168



**Table 7.3.1.1.3-2 Transverse Shear of FB for DCD Load Combinations**

Location	Element ID	Load ID	d (m)	pv (%)	Shear Force (MN/m)				Vu/φVn
					Vu	Vc	Vs	φVn	
1 Exterior Wall and Pool Wall @ EL-11.50 ~-10.50m	60011	FB-9	1.70	0.710	1.53	3.97	4.99	7.62	0.200
	60219	FB-9	3.05	0.710	4.04	4.08	8.96	11.08	0.364
	70201	FB-9	1.65	0.710	0.98	1.78	4.85	5.64	0.174
	70204	FB-9	1.59	0.710	3.01	2.56	4.67	6.15	0.490
2 Exterior Wall @ EL4.65 ~-6.60m	110718	FB-9	1.12	0.355	0.50	1.13	1.64	2.36	0.211
	62011	FB-9	0.72	0.125	0.38	0.75	0.37	0.95	0.400
	62019	FB-9	0.78	0.125	0.17	0.24	0.40	0.55	0.314
	72001	FB-9	0.73	0.250	0.47	0.00	0.76	0.64	0.727
3 Exterior Wall @ EL22.50 ~-24.60m	72004	FB-9	0.72	0.250	0.36	0.00	0.74	0.63	0.567
	64011	FB-9	0.72	0.125	0.31	0.71	0.37	0.92	0.334
	64019	FB-9	0.80	0.125	0.22	0.00	0.41	0.35	0.617
	74001	FB-9	0.73	0.125	0.16	0.30	0.38	0.58	0.269
4 Spent Fuel Pool Wall @ EL-5.10 ~-3.30m	74004	FB-9	0.72	0.125	0.30	0.41	0.37	0.66	0.457
	60819	FB-9	3.05	0.710	2.05	6.00	8.97	12.72	0.161
	70801	FB-9	1.71	0.710	3.77	2.16	5.02	6.10	0.617
	70804	FB-9	1.62	0.710	1.02	1.36	4.75	5.19	0.197
5 Basemat	110748	FB-9	1.21	0.177	0.64	1.15	0.88	1.73	0.368
	90306	FB-9	3.53	0.629	4.66	6.92	9.18	13.68	0.341
	90310	FB-9	3.49	0.629	2.66	5.67	9.08	12.54	0.212
	90410	FB-9	3.53	0.629	3.47	6.91	9.19	13.68	0.254
5 Basemat @ Spent Fuel Pool	90486	FB-9	5.04	0.419	1.58	6.56	8.74	13.00	0.122
	90490	FB-9	5.04	0.629	5.35	5.77	13.11	16.05	0.333
	90526	FB-9	5.02	0.629	4.42	9.24	13.07	18.97	0.233
6 Slab EL4.65m	93306	FB-9	1.10	0.500	0.41	0.78	2.27	2.60	0.158
	93310	FB-9	1.10	0.500	0.97	2.85	2.27	4.35	0.223
	93410	FB-9	1.10	0.500	0.57	2.20	2.27	3.80	0.151



Table 7.3.1.2-1 Maximum Stress Ratio of FB Reinforced Concrete Column

ID No.	Sizes (mm)	Column-Row		Checked	Section Forces (MN, MN-m)				Allowable Strength $\phi F_n$	Ratio $F_u/\phi F_n$	
					Design Forces $F_u$						
Location [Direction]	Reinforcing			Items	Load No.	Thermal Load	Other Loads	Total			
610101	1400 x 1400	F2		FD							
FULL [NS SIDE]	Main Bars	12 - #11		(0.62)	P	7461	0.00	-20.14	-20.14	-41.36	0.49
	Other Bars	32 - #11		(1.64)	M	7491	0.00	3.88	3.88	9.46	0.41
	Tie Bars	5 - #6 @200		(0.51)	V	7701	0.00	-0.89	-0.89	-4.48	0.20
	Main Bars	16 - #11		(0.82)	P	7461	0.00	-20.14	-20.14	-45.03	0.45
FULL [EW SIDE]	Other Bars	24 - #11		(1.23)	M	7211	0.00	-3.58	-3.58	-9.91	0.36
	Tie Bars	5 - #6 @200		(0.51)	V	7211	0.00	-1.34	-1.34	-7.31	0.18

ID No.	Sizes (mm)	Column-Row		Checked	Section Forces (MN, MN-m)				Allowable Strength $\phi F_n$	Ratio $F_u/\phi F_n$	
					Design Forces $F_u$						
Location [Direction]	Reinforcing			Items	Load No.	Thermal Load	Other Loads	Total			
610107	1400 x 1400	F2		FD							
FULL [NS SIDE]	Main Bars	7 - #11		(0.36)	P	7261	0.00	-8.73	-8.73	-36.78	0.24
	Other Bars	14 - #11		(0.72)	M	8514	0.00	-4.34	-4.34	-7.56	0.57
	Tie Bars	4 - #5 @200		(0.29)	V	8514	0.00	1.61	1.61	5.41	0.30
	Main Bars	7 - #11		(0.36)	P	7261	0.00	-8.73	-8.73	-36.78	0.24
FULL [EW SIDE]	Other Bars	14 - #11		(0.72)	M	7811	0.00	-1.63	-1.63	-5.97	0.27
	Tie Bars	4 - #5 @200		(0.29)	V	7711	0.00	0.58	0.58	3.12	0.19

ID No.	Sizes (mm)	Column-Row		Checked	Section Forces (MN, MN-m)				Allowable Strength $\phi F_n$	Ratio $F_u/\phi F_n$	
					Design Forces $F_u$						
Location [Direction]	Reinforcing			Items	Load No.	Thermal Load	Other Loads	Total			
611302	1500 x 1500	F1		FC							
FULL [NS SIDE]	Main Bars	17 - #11		(0.76)	P	7971	0.00	9.44	9.44	16.32	0.58
	Other Bars	30 - #11		(1.34)	M	7971	0.00	2.05	2.05	8.69	0.24
	Tie Bars	8 - #5 @200		(0.53)	V	7961	0.00	-1.02	-1.02	-3.78	0.27
	Main Bars	15 - #11		(0.67)	P	9013	0.00	9.59	9.59	20.38	0.47
FULL [EW SIDE]	Other Bars	34 - #11		(1.52)	M	7371	0.00	0.74	0.74	11.09	0.07
	Tie Bars	2 - #5 @200		(0.13)	V	9013	0.00	-0.23	-0.23	-2.57	0.09



Table 7.3.1.2-1 Maximum Stress Ratio of FB Reinforced Concrete Column (Continued)

ID No.	Sizes (mm)		Column-Row		Checked	Section Forces (MN, MN-m)				Allowable Strength $\phi F_n$	Ratio $F_u/\phi F_n$
						Design Forces $F_u$					
Location	Reinforcing				Items	Load No.	Thermal Load	Other Loads	Total	Strength $\phi F_n$	Ratio $F_u/\phi F_n$
[Direction]	(ratio,%)										
611312	1500	x 1500	F1	FC							
FULL	Main Bars	17	- #11	(0.76)	P	8514	0.00	5.63	5.63	17.45	0.32
[NS SIDE]	Other Bars	30	- #11	(1.34)	M	8511	0.00	3.04	3.04	11.21	0.27
	Tie Bars	8	- #5 @200	(0.53)	V	6965	0.00	-0.98	-0.98	-4.77	0.21
FULL	Main Bars	15	- #11	(0.67)	P	8514	0.00	5.63	5.63	20.84	0.27
[EW SIDE]	Other Bars	34	- #11	(1.52)	M	7261	0.00	0.35	0.35	10.51	0.03
	Tie Bars	2	- #5 @200	(0.13)	V	8513	0.00	0.25	0.25	2.99	0.08

ID No.	Sizes (mm)		Column-Row		Checked	Section Forces (MN, MN-m)				Allowable Strength $\phi F_n$	Ratio $F_u/\phi F_n$
						Design Forces $F_u$					
Location	Reinforcing				Items	Load No.	Thermal Load	Other Loads	Total	Strength $\phi F_n$	Ratio $F_u/\phi F_n$
[Direction]	(ratio,%)										
612002	1500	x 1500	F3	FF							
FULL	Main Bars	9	- #11	(0.40)	P	7211	0.00	6.14	6.14	10.73	0.57
[NS SIDE]	Other Bars	14	- #11	(0.63)	M	8511	0.00	-2.41	-2.41	-9.51	0.25
	Tie Bars	4	- #5 @200	(0.27)	V	7211	0.00	-0.41	-0.41	-2.11	0.19
FULL	Main Bars	7	- #11	(0.31)	P	7571	0.00	6.14	6.14	8.85	0.69
[EW SIDE]	Other Bars	18	- #11	(0.81)	M	7571	0.00	0.41	0.41	1.17	0.35
	Tie Bars	2	- #5 @200	(0.13)	V	7571	0.00	0.24	0.24	2.15	0.11

ID No.	Sizes (mm)		Column-Row		Checked	Section Forces (MN, MN-m)				Allowable Strength $\phi F_n$	Ratio $F_u/\phi F_n$
						Design Forces $F_u$					
Location	Reinforcing				Items	Load No.	Thermal Load	Other Loads	Total	Strength $\phi F_n$	Ratio $F_u/\phi F_n$
[Direction]	(ratio,%)										
612012	1500	x 1500	F3	FF							
FULL	Main Bars	9	- #11	(0.40)	P	4023	0.00	-5.83	-5.83	-43.10	0.14
[NS SIDE]	Other Bars	14	- #11	(0.63)	M	4022	0.00	-1.57	-1.57	-9.07	0.17
	Tie Bars	4	- #5 @200	(0.27)	V	4022	0.00	-0.67	-0.67	-5.40	0.12
FULL	Main Bars	7	- #11	(0.31)	P	4023	0.00	-5.83	-5.83	-41.27	0.14
[EW SIDE]	Other Bars	18	- #11	(0.81)	M	8514	0.00	1.56	1.56	8.07	0.19
	Tie Bars	2	- #5 @200	(0.13)	V	8514	0.00	0.80	0.80	5.41	0.15



Table 7.3.1.2-2 Maximum Stress Ratio of FB Reinforced Concrete Girder

ID No.	Sizes (mm)		Column-Row		Checked Items	Section Forces (MN,MN-m)				Allowable Strength fFn	Ratio Fu/fFn
			F1-F2	FE		Design Forces Fu					
Location	Reinforcing			(ratio, %)	Load No.	Thermal Load	Other Loads	Total			
END 1 [F1 SIDE]	Main Bars	Top	10 - #11	(0.84)							P
		Bot.	15 - #11	(1.26)	M	7511	0.00	3.55	3.55	7.39	0.48
	Stirrup			6 - #5 @200	(0.75)	V	7471	0.00	1.33	1.33	3.14
CENTER	Main Bars	Top	10 - #11	(0.84)	P	3011	0.00	-4.78	-4.78	-30.05	0.16
		Bot.	15 - #11	(1.26)	M	7231	0.00	-2.80	-2.80	-6.82	0.41
	Stirrup			6 - #5 @200	(0.75)	V	7461	0.00	1.73	1.73	3.96
END 2 [F2 SIDE]	Main Bars	Top	10 - #11	(0.84)	P	4014	0.00	-2.58	-2.58	-30.05	0.09
		Bot.	15 - #11	(1.26)	M	7101	0.00	1.13	1.13	8.50	0.13
	Stirrup			6 - #5 @200	(0.75)	V	7221	0.00	-0.58	-0.58	-3.16

ID No.	Sizes (mm)		Column-Row		Checked Items	Section Forces (MN,MN-m)				Allowable Strength fFn	Ratio Fu/fFn
			F1-F2	FE		Design Forces Fu					
Location	Reinforcing			(ratio, %)	Load No.	Thermal Load	Other Loads	Total			
END 1 [F1 SIDE]	Main Bars	Top	10 - #11	(0.84)							P
		Bot.	10 - #11	(0.84)	M	8514	0.00	1.54	1.54	6.67	0.23
	Stirrup			4 - #5 @200	(0.50)	V	7561	0.00	-0.41	-0.41	-2.68
CENTER	Main Bars	Top	10 - #11	(0.84)	P	8514	0.00	-4.30	-4.30	-27.75	0.16
		Bot.	10 - #11	(0.84)	M	8514	0.00	0.93	0.93	6.65	0.14
	Stirrup			4 - #5 @200	(0.50)	V	7461	0.00	0.33	0.33	3.60
END 2 [F2 SIDE]	Main Bars	Top	10 - #11	(0.84)	P	8514	0.00	-3.34	-3.34	-27.75	0.12
		Bot.	10 - #11	(0.84)	M	7431	0.00	-2.38	-2.38	-7.36	0.32
	Stirrup			4 - #5 @200	(0.50)	V	7431	0.00	0.98	0.98	2.66

ID No.	Sizes (mm)		Column-Row		Checked Items	Section Forces (MN,MN-m)				Allowable Strength fFn	Ratio Fu/fFn
			F2	FC-FD		Design Forces Fu					
Location	Reinforcing			(ratio, %)	Load No.	Thermal Load	Other Loads	Total			
END 1 [FD SIDE]	Main Bars	Top	10 - #11	(0.84)							P
		Bot.	10 - #11	(0.84)	M	7461	0.00	-2.17	-2.17	-7.20	0.30
	Stirrup			4 - #5 @200	(0.50)	V	7471	0.00	-0.77	-0.77	-2.44
CENTER	Main Bars	Top	10 - #11	(0.84)	P	4012	0.00	-2.49	-2.49	-27.75	0.09
		Bot.	10 - #11	(0.84)	M	7461	0.00	0.67	0.67	7.02	0.09
	Stirrup			4 - #5 @200	(0.50)	V	7471	0.00	-0.78	-0.78	-2.52
END 2 [FC SIDE]	Main Bars	Top	10 - #11	(0.84)	P	4014	0.00	-1.96	-1.96	-27.75	0.07
		Bot.	10 - #11	(0.84)	M	7491	0.00	-1.03	-1.03	-7.54	0.14
	Stirrup			4 - #5 @200	(0.50)	V	7492	0.00	0.30	0.30	2.66




**HITACHI**

WG3-U97-ERD-S-0001 SH NO. 87  
REV. 0 of 151

**Table 7.3.1.2-2 Maximum Stress Ratio of FB Reinforced Concrete Girder (Continued)**

ID No.	Sizes (mm)		Column-Row		Checked Items	Section Forces (MN,MN-m)				Allowable Strength fFn	Ratio Fu/fFn	
			F2	FC-FD		Design Forces Fu						
Location	Reinforcing			(ratio, %)	Load No.	Thermal Load	Other Loads	Total	Allowable Strength fFn	Ratio Fu/fFn		
END 1 [FD SIDE]	Main Bars	Top	10 - #11	(0.84)							P	7461
		Bot.	10 - #11	(0.84)	M	7261	0.00	-1.02	-1.02	-7.79	0.13	
	Stirrup			4 - #5 @200	(0.50)	V	7261	0.00	-0.53	-0.53	-2.50	0.21
					(0.00)							
CENTER	Main Bars	Top	10 - #11	(0.84)	P	7461	0.00	0.39	0.39	13.60	0.03	
		Bot.	10 - #11	(0.84)	M	7492	0.00	0.55	0.55	7.56	0.07	
	Stirrup			4 - #5 @200	(0.50)	V	7461	0.00	-0.56	-0.56	-2.58	0.22
					(0.00)							
END 2 [FC SIDE]	Main Bars	Top	10 - #11	(0.84)	P	7461	0.00	0.28	0.28	14.15	0.02	
		Bot.	10 - #11	(0.84)	M	7492	0.00	-0.48	-0.48	-7.75	0.06	
	Stirrup			4 - #5 @200	(0.50)	V	7441	0.00	0.27	0.27	2.53	0.11
					(0.00)							

ID No.	Sizes (mm)		Column-Row		Checked Items	Section Forces (MN,MN-m)				Allowable Strength fFn	Ratio Fu/fFn	
			F2	FE-FF		Design Forces Fu						
Location	Reinforcing			(ratio, %)	Load No.	Thermal Load	Other Loads	Total	Allowable Strength fFn	Ratio Fu/fFn		
END 1 [FF SIDE]	Main Bars	Top	10 - #11	(0.84)							P	7481
		Bot.	10 - #11	(0.84)	M	8513	0.00	-1.03	-1.03	-7.75	0.13	
	Stirrup			4 - #5 @200	(0.50)	V	7482	0.00	-0.37	-0.37	-2.62	0.14
					(0.00)							
CENTER	Main Bars	Top	10 - #11	(0.84)	P	7481	0.00	0.21	0.21	13.47	0.02	
		Bot.	10 - #11	(0.84)	M	7521	0.00	0.62	0.62	7.63	0.08	
	Stirrup			4 - #5 @200	(0.50)	V	8513	0.00	-0.42	-0.42	-2.97	0.14
					(0.00)							
END 2 [FE SIDE]	Main Bars	Top	10 - #11	(0.84)	P	7481	0.00	0.26	0.26	8.82	0.03	
		Bot.	10 - #11	(0.84)	M	7571	0.00	-1.58	-1.58	-7.78	0.20	
	Stirrup			4 - #5 @200	(0.50)	V	7261	0.00	0.92	0.92	2.54	0.36
					(0.00)							



**Figure 1-1 RB/FB Global FE Analysis Model**

**{{{Security-Related Information - Withheld Under 10 CFR-2.390}}}**



**HITACHI**

WG3-U97-ERD-S-0001 SH NO. 88

REV. 0

of 151

**Table 7.3.2-1 Maximum Stress Ratio of FB Steel Girder**

Member Name : FBroof FB															
Section ID :		100		Section Type :				H				CBAR ID :		630301	
Flange PL :		1000 x 75		Web PL :				1550 x 60						i - edge	
Maximum Ratio		Load ID	Design Load (MN,MNm)			Stress (MPa)			Allowable Stress (MPa)						
			P	M	V	fac,fat	fbf,fbt	fv	Fac,Fat	Fbc,Fbt	Fv				
fac/Fac+fbf/Fbf	0.100	8128	-5.05	0.00		-20.8	0.0		327.6	318.2					
fat/Fat+fbt/Fbt	0.018	5503	1.41	0.00		5.8	0.0		330.9	330.9					
fv/Fv	0.159	8103			3.14			30.8						193.1	

Member Name : FBroof FB															
Section ID :		100		Section Type :				H				CBAR ID :		630305	
Flange PL :		1000 x 75		Web PL :				1550 x 60						j - edge	
Maximum Ratio		Load ID	Design Load (MN,MNm)			Stress (MPa)			Allowable Stress (MPa)						
			P	M	V	fac,fat	fbf,fbt	fv	Fac,Fat	Fbc,Fbt	Fv				
fac/Fac+fbf/Fbf	0.436	5001	-2.10	16.34		-8.6	118.0		307.2	299.5					
fat/Fat+fbt/Fbt	0.164	7520	0.06	7.48		0.2	54.0		330.9	330.9					
fv/Fv	0.072	8103			-1.42			-14.0						193.1	

Member Name : FBroof FC															
Section ID :		100		Section Type :				H				CBAR ID :		630206	
Flange PL :		1000 x 75		Web PL :				1550 x 60						i - edge	
Maximum Ratio		Load ID	Design Load (MN,MNm)			Stress (MPa)			Allowable Stress (MPa)						
			P	M	V	fac,fat	fbf,fbt	fv	Fac,Fat	Fbc,Fbt	Fv				
fac/Fac+fbf/Fbf	0.500	5001	-1.71	19.34		-7.0	139.6		307.2	299.5					
fat/Fat+fbt/Fbt	0.194	7520	0.05	8.85		0.2	63.9		330.9	330.9					
fv/Fv	0.059	5002			1.17			11.4						193.1	

Member Name : FBroof FE															
Section ID :		100		Section Type :				H				CBAR ID :		630006	
Flange PL :		1000 x 75		Web PL :				1550 x 60						i - edge	
Maximum Ratio		Load ID	Design Load (MN,MNm)			Stress (MPa)			Allowable Stress (MPa)						
			P	M	V	fac,fat	fbf,fbt	fv	Fac,Fat	Fbc,Fbt	Fv				
fac/Fac+fbf/Fbf	0.368	5001	-1.97	13.63		-8.1	98.4		307.2	299.5					
fat/Fat+fbt/Fbt	0.137	7520	0.03	6.26		0.1	45.2		330.9	330.9					
fv/Fv	0.050	8126			0.98			9.6						193.1	





Figure 3.1-1 RB and FB Concrete Outline Plan at EL -11500

{{{Security-Related Information - Withheld Under 10 CFR-2.390}}}




**Figure 3.1-2 RB and FB Concrete Outline Plan at EL 4650**  
{{{Security-Related Information - Withheld Under 10 CFR-2.390}}}



**Figure 3.1-3 RB and FB Concrete Outline Plan at EL 17500**

{{{Security-Related Information - Withheld Under 10 CFR-2.390}}}




**Figure 3.1-4 RB and FB Concrete Outline Plan at EL 27000**  
{{{Security-Related Information - Withheld Under 10 CFR-2.390}}}



Figure 3.1-5 RB Concrete Outline Plan at EL 34000

{{{Security-Related Information - Withheld Under 10 CFR-2.390}}}



**Figure 3.1-6 RB and FB Concrete Outline N-S Section**

{{{Security-Related Information - Withheld Under 10 CFR-2.390}}}



**Figure 3.1-7 RB and FB Concrete Outline E-W Section**

{{{Security-Related Information - Withheld Under 10 CFR-2.390}}}




Figure 5.1.2-1 Snow Load Considered Drift Load




Figure 5.2.2-1 Application of Thermal Load on the External Wall (RA)




Figure 5.2.2-2 Application of Thermal Load on the External Wall (RG FF)




Figure 5.2.2-3 Application of Thermal Load on the External Wall (R7/F1)




Figure 5.2.2-4 Application of Thermal Load on the External Wall (F3)



HITACHI

WG3-U97-ERD-S-0001

SH NO. 102

REV. 0

of 151




Figure 5.2.2-5 Application of Thermal Load on the Basemat




Figure 5.2.2-6 Application of Thermal Load on the Spent Fuel Pool Wall-1




Figure 5.2.2-7 Application of Thermal Load on the Spent Fuel Pool Wall-2




Figure 5.2.2-8 Application of Thermal Load on the Spent Fuel Pool Wall-3





HITACHI




Figure 6.2.4-1 Elements Selected for Tabulation (External Wall F3)



HITACHI




Figure 6.2.4-2 Elements Selected for Tabulation (External Wall RA FA)



HITACHI

WG3-U97-ERD-S-0001

SH NO. 109

REV. 0

of 151




Figure 6.2.4-3 Elements Selected for Tabulation (Basemat)




Figure 6.2.4-4 Elements Selected for Tabulation (Slab at EL4,650)



HITACHI

WG3-U97-ERD-S-0001 SH NO. 111  
REV. 0 of 151






Figure 6.2.4-5 Elements Selected for Tabulation (Spent Fuel Pool Wall)



Membrane and Shear Forces



Moments

Definition of Element Coordinate System

Structure	x	y	z
RCCV Wall RPV Pedestal External Wall	horizontal	vertical	outward
Wall in N-S Direction	horizontal	vertical	toward West
Wall in E-W Direction	horizontal	vertical	toward South
Foundation Mat Floor Slab Top Slab	toward South	toward West	downward
Suppression Pool Slab	radial	circumferential	downward

Figure 6.2.4-6 Force and Moment in Shell Element




Figure 6.4.1-1 Design Flow Chart of Reinforced Concrete Structures




Figure 6.4.1.1-1 Calculation of Shear Strength Provided by Concrete




Figure 6.4.1.2-1 Stress-Strain Relationship Assumed for Strength Check




Figure 6.4.1.2-2 Calculation Method of Strength Ratios




Figure 6.4.2-1 Allowable Stress of W-shaped Members (Strong Axis Bending)




Figure 6.4.2-2 Allowable Stress of W-shaped Members (Weak Axis Bending)




Figure 6.4.2-3 Allowable Bending Stress of Box Members




Figure 7.1-1 Reinforcing Steel of Spent Fuel Pool Walls

{

}

**Figure 7.1-2 List of FB Wall and Slab Reinforcement**

{{{Security-Related Information - Withheld Under 10 CFR-2.390}}}




Figure 7.1-3 FB Reinforced Concrete Column Reinforcing Schedule






Figure 7.1-4 FB Reinforced Concrete Girder Reinforcing Schedule



FB ROOF STRUCTURAL STEEL MEMBER SCHEDULE

ID NO.	WELDED PL NUMBER	
	FLG. PL	WEB PL
CH1	1000x75	1550x60



KEY PLAN FOR STRUCTURAL STEEL

Figure 7.1-5 FB Steel Girder Member




Figure 7.3.1.1-1 Moment Capacity Check according to ACI349-01 for Element 72004 with New Arrangement of Reinforcement




Figure 7.3.1.2-1 Elements Selected for Tabulation - FB Frame -



**HITACHI**

---

WG3-U97-ERD-S-0001 SH NO. 127

REV. 0

of 151

## **APPENDIX A**

### **COMPARISON WITH DCD DATA**



**List of Tables**

Table A.1-1 Design Seismic Shear Loads for Horizontal.....129  
Table A.1-2 Design Seismic Moment Loads for Horizontal .....130  
Table A.1-3 Design Seismic Torsion Loads for Horizontal .....131  
Table A.1-4 Vertical Acceleration.....132  
Table A.1-5 Soil Pressure Due to an Earthquake .....135  
Table A.1-6 Sloshing Loads for Spent Fuel Pool .....136  
Table A.2-1 Maximum Stress Ratios for Flexure and Membrane Forces: FB .....137  
Table A.2-2 Maximum Stress Ratios for Membrane Compressive Forces: FB .....139  
Table A.2-3 Calculation Results for Maximum Transverse Shear: FB.....141

**List of Figures**

**None**



Table A.1-1 Design Seismic Shear Loads for Horizontal

Elev. (m)	Elem No.	Node No.	NS-direction			EW-direction		
			NA3 (MN)	DCD (MN)	Ratio (NA3/DCD)	NA3 (MN)	DCD (MN)	Ratio (NA3/DCD)
52.40*	1110	110	192.2	151.9	1.27	140.0	158.2	0.89
		109	192.2	151.9	1.27	140.0	158.2	0.89
34.00	1109	109	173.2	191.7	0.90	113.9	153.0	0.74
		108	173.2	191.7	0.90	113.9	153.0	0.74
27.00	1108	108	396.0	425.4	0.93	259.4	400.7	0.65
		107	396.0	425.4	0.93	259.4	400.7	0.65
22.50	1107	107	436.4	483.7	0.90	291.8	464.0	0.63
		106	436.4	483.7	0.90	291.8	464.0	0.63
17.50	1106	106	438.4	532.9	0.82	343.5	555.4	0.62
		105	438.4	532.9	0.82	343.5	555.4	0.62
13.57	1105	105	450.7	569.2	0.79	363.7	599.9	0.61
		104	450.7	569.2	0.79	363.7	599.9	0.61
9.06	1104	104	454.6	610.1	0.75	383.4	654.3	0.59
		103	454.6	610.1	0.75	383.4	654.3	0.59
4.65	1103	103	454.7	839.8	0.54	360.1	872.2	0.41
		102	454.7	839.8	0.54	360.1	872.2	0.41
-1.00	1102	102	240.0	871.4	0.28	226.6	938.5	0.24
		101	240.0	871.4	0.28	226.6	938.5	0.24
-6.40	1101	101	237.7	933.6	0.25	200.4	1029.7	0.19
-11.50		2	237.7	933.6	0.25	200.4	1029.7	0.19

\*The difference between the modeled elevation 52.4 m and the actual elevation 52.7 m at the RB roof is negligibly small.



Table A.1-2 Design Seismic Moment Loads for Horizontal

Elev. (m)	Elem No.	Node No.	NS-direction			EW-direction		
			NA3 (MN-m)	DCD (MN-m)	Ratio (NA3/DCD)	NA3 (MN-m)	DCD (MN-m)	Ratio (NA3/DCD)
52.4*	1110	110	2724	1642	1.66	2143	1808	1.19
			5838	4303	1.36	4488	4465	1.01
34	1109	109	8196	5585	1.47	5821	5497	1.06
			8719	6477	1.35	6389	6317	1.01
27	1108	108	9400	7685	1.22	7162	7106	1.01
			9599	8964	1.07	7958	8596	0.93
22.5	1107	107	11216	9905	1.13	8328	9193	0.91
			11424	11464	1.00	9227	11297	0.82
17.5	1106	106	12105	12386	0.98	9408	11935	0.79
			12349	13778	0.90	10195	13867	0.74
13.57	1105	105	12839	14298	0.90	10255	14377	0.71
			13651	16593	0.82	11216	16740	0.67
9.06	1104	104	13904	16966	0.82	11338	17191	0.66
			15231	19378	0.79	12506	19672	0.64
4.65	1103	103	9392	19064	0.49	6302	20192	0.31
			10952	23163	0.47	7759	24272	0.32
-1	1102	102	6545	23673	0.28	4819	24948	0.19
			7303	27655	0.26	5358	29263	0.18
-6.4	1101	101	4748	28126	0.17	3351	30038	0.11
			-11.5	2	5053	32235	0.16	3356

\*The difference between the modeled elevation 52.4 m and the actual elevation 52.7 m at the RB roof is negligibly small.

**Table A.1-3 Design Seismic Torsion Loads for Horizontal**

Elev. (m)	Elem No.	Node No.	Calculated Torsion			Accidental Torsion			Design Torsion		
			NA3 (MN-m)	DCD (MN-m)	Ratio (NA3/DCD)	NA3 (MN-m)	DCD (MN-m)	Ratio (NA3/DCD)	NA3 (MN-m)	DCD (MN-m)	Ratio (NA3/DCD)
52.4*	1110	110	1284	1379	0.93	471	388	1.22	1755	1766	0.99
			1284	1379	0.93	471	388	1.22	1755	1766	0.99
34	1109	109	1938	2405	0.81	424	470	0.90	2362	2874	0.82
			1938	2405	0.81	424	470	0.90	2362	2874	0.82
27	1108	108	2799	3329	0.84	1386	1489	0.93	4185	4822	0.87
			2799	3329	0.84	1386	1489	0.93	4185	4822	0.87
22.5	1107	107	4678	6093	0.77	1527	1693	0.90	6205	7786	0.80
			4678	6093	0.77	1527	1693	0.90	6205	7786	0.80
17.5	1106	106	4023	5068	0.79	1535	1944	0.79	5557	7012	0.79
			4023	5068	0.79	1535	1944	0.79	5557	7012	0.79
13.57	1105	105	4211	5245	0.80	1578	2100	0.75	5788	7344	0.79
			4211	5245	0.80	1578	2100	0.75	5788	7344	0.79
9.06	1104	104	4694	5985	0.78	1591	2290	0.69	6285	8275	0.76
			4694	5985	0.78	1591	2290	0.69	6285	8275	0.76
4.65	1103	103	5248	11425	0.46	1591	3053	0.52	6839	14478	0.47
			5248	11425	0.46	1591	3053	0.52	6839	14478	0.47
-1	1102	102	2718	11523	0.24	840	3285	0.26	3558	14808	0.24
			2718	11523	0.24	840	3285	0.26	3558	14808	0.24
-6.4	1101	101	2079	11690	0.18	832	3604	0.23	2910	15294	0.19
-11.5		2	2079	11690	0.18	832	3604	0.23	2910	15294	0.19

\*The difference between the modeled elevation 52.4 m and the actual elevation 52.7 m at the RB roof is negligibly small.



**Table A.1-4 Vertical Acceleration**

**(a) RB/FB**

Elev. (m)	Node No.	Stick Model	NA3 (g)	DCD (g)	Ratio (NA3/DCD)
52.4*	110	RFBF	1.56	1.25	1.25
34	109	RFBF	1.20	0.83	1.45
27	108	RFBF	1.02	0.73	1.40
22.5	107	RFBF	0.92	0.73	1.26
17.5	106	RFBF	0.80	0.73	1.10
13.57	105	RFBF	0.72	0.74	0.97
9.06	104	RFBF	0.62	0.73	0.85
4.65	103	RFBF	0.56	0.78	0.72
-1	102	RFBF	0.57	0.76	0.75
-6.4	101	RFBF	0.53	0.68	0.78
-11.5	2	RFBF	0.51	0.63	0.81
-15.5	1	RFBF	0.52	0.51	1.02

\*The difference between the modeled elevation 52.4 m and the actual elevation 52.7 m at the RB roof is negligibly small.

**Table A.1-4 Vertical Acceleration (Continued)****(b) Slab Oscillator**

Elev. (m)	Node No.	Stick Model	NA3 (g)	DCD (g)	Ratio (NA3/DCD)
52.4*	9101	Oscillator	0.33	1.20	0.28
	9102	Oscillator	1.33	1.82	0.73
	9103	Oscillator	6.27	3.14	2.00
	9104	Oscillator	2.62	2.26	1.16
	9105	Oscillator	2.42	2.32	1.04
	9106	Oscillator	3.74	2.99	1.25
	9107	Oscillator	3.22	2.80	1.15
	9108	Oscillator	2.50	2.61	0.96
	9109	Oscillator	1.53	---	---
34.00	9091	Oscillator	1.61	1.29	1.25
	9092	Oscillator	1.61	1.06	1.52
	9093	Oscillator	1.12	---	---
27.00	9081	Oscillator	1.64	1.16	1.41
	9082	Oscillator	1.52	0.99	1.54
	9083	Oscillator	1.30	1.09	1.19
	9084	Oscillator	1.67	1.31	1.27
	9085	Oscillator	1.46	0.97	1.51
	9086	Oscillator	1.12	---	---
	9087	Oscillator	1.03	---	---
22.50	9071	Oscillator	1.15	1.60	0.72
	9072	Oscillator	1.79	1.31	1.37
	9073	Oscillator	4.47	2.03	2.20
	9074	Oscillator	1.67	1.31	1.27
	9075	Oscillator	1.51	1.16	1.30
	9076	Oscillator	1.65	---	---
17.50	9061	Oscillator	3.65	1.79	2.04
	9062	Oscillator	2.62	1.49	1.76
	9063	Oscillator	1.17	0.82	1.43
	9064	Oscillator	2.56	1.84	1.39
	9065	Oscillator	1.28	1.42	0.90
	99064	Oscillator	0.99	1.07	0.93
	9066	Oscillator	1.09	---	---
	9067	Oscillator	0.91	---	---

\*The difference between the modeled elevation 52.4 m and the actual elevation 52.7 m at the RB roof is negligibly small.

**Table A.1-4 Vertical Acceleration (Continued)****(e) Slab Oscillator**

Elev. (m)	Node No.	Stick Model	NA3 (g)	DCD (g)	Ratio (NA3/DCD)
13.57	9051	Oscillator	1.11	0.81	1.37
	9052	Oscillator	1.25	1.46	0.86
	9053	Oscillator	0.99	---	---
	9054	Oscillator	0.83	---	---
9.06	9041	Oscillator	1.02	0.88	1.16
	9042	Oscillator	1.26	1.42	0.89
	9043	Oscillator	0.93	---	---
	9044	Oscillator	0.80	---	---
4.65	9031	Oscillator	1.62	1.17	1.38
	9032	Oscillator	0.89	0.97	0.92
	9033	Oscillator	1.12	1.02	1.10
	9034	Oscillator	1.81	1.51	1.20
	9035	Oscillator	1.09	1.38	0.79
	9036	Oscillator	0.94	---	---
	9037	Oscillator	0.82	---	---
-1.00	9021	Oscillator	0.97	1.12	0.87
	9022	Oscillator	2.07	1.45	1.43
	9023	Oscillator	0.98	1.01	0.97
	9024	Oscillator	1.12	0.89	1.26
	9025	Oscillator	1.21	1.34	0.90
	9026	Oscillator	1.63	1.57	1.04
	9027	Oscillator	0.93	0.88	1.06
	9028	Oscillator	0.96	---	---
	9029	Oscillator	1.30	---	---
	9030	Oscillator	0.87	---	---
-6.40	9011	Oscillator	0.84	0.92	0.91
	9012	Oscillator	1.17	0.92	1.27
	9013	Oscillator	1.52	1.35	1.13
	9014	Oscillator	1.19	---	---
	9015	Oscillator	1.03	---	---

**Table A.1-5 Soil Pressure Due to an Earthquake**

Elevation (m)	R1 and F3 Wall			RA and RG Wall			Note
	NA3 (MPa)	DCD (MPa)	Ratio (NA3/DCD)	NA3 (MPa)	DCD (MPa)	Ratio (NA3/DCD)	
4.65							Grade
-1	0.56	0.30	1.87	0.45	0.33	1.36	
-6.4	0.28	0.29	0.97	0.29	0.29	1.00	
-11.5	0.24	0.25	0.96	0.22	0.23	0.96	
-15.5	0.94	0.29	3.24	0.76	0.26	2.92	



**Table A.1-6 Sloshing Loads for Spent Fuel Pool**

**(a) NS Motion**

Depth d/H	Wall			Distance x/(L/2)	Floor		
	Pressure				NA3 (kN/m <sup>2</sup> )	DCD (kN/m <sup>2</sup> )	Ratio (NA3/DCD)
	NA3 (kN/m <sup>2</sup> )	DCD (kN/m <sup>2</sup> )	Ratio (NA3/DCD)				
0.0	12.3	12.3	1.00	0.0	0.0	0.0	---
0.2	23.6	22.6	1.04	0.2	7.4	7.1	1.04
0.4	37.8	36.1	1.05	0.4	15.2	14.5	1.05
0.6	44.6	42.6	1.05	0.6	23.7	22.7	1.05
0.8	45.2	43.2	1.05	0.8	33.6	32.1	1.05
1.0	45.2	43.2	1.05	1.0	45.2	43.2	1.05

**(b) EW Motion**

Depth d/H	Wall			Distance x/(L/2)	Floor		
	Pressure				NA3 (kN/m <sup>2</sup> )	DCD (kN/m <sup>2</sup> )	Ratio (NA3/DCD)
	NA3 (kN/m <sup>2</sup> )	DCD (kN/m <sup>2</sup> )	Ratio (NA3/DCD)				
0.0	11.8	11.8	1.00	0.0	0.0	0.0	---
0.2	24.2	23.2	1.04	0.2	8.5	8.2	1.04
0.4	40.0	38.2	1.05	0.4	17.5	16.7	1.05
0.6	49.4	47.2	1.05	0.6	27.4	26.2	1.05
0.8	52.2	49.8	1.05	0.8	38.7	37.0	1.05
1.0	52.2	49.8	1.05	1.0	52.2	49.8	1.05

**(c) Vertical Motion**

Depth d/H	Wall			Floor		
	Pressure			NA3 (kN/m <sup>2</sup> )	DCD (kN/m <sup>2</sup> )	Ratio (NA3/DCD)
	NA3 (kN/m <sup>2</sup> )	DCD (kN/m <sup>2</sup> )	Ratio (NA3/DCD)			
0.0	0.0	0.0	---	98.5  for all floor area	98.5  for all floor area	1.00
0.2	19.7	19.7	1.00			
0.4	39.4	39.4	1.00			
0.6	59.1	59.1	1.00			
0.8	78.8	78.8	1.00			
1.0	98.5	98.5	1.00			



Table A.2-1 Maximum Stress Ratios for Flexure and Membrane Forces: FB

Location	Element ID	Concrete				Ratio (NA3/DCD)
		NA3		DCD		
		$\sigma/\sigma_s$	Load ID	$\sigma/\sigma_s$	Load ID	
1 Exterior Wall and Pool Wall @ EL-11.50 ~-10.50m	60011	0.246	7461	0.392	7301	0.63
	60219	0.481	8511	0.467	7482	1.03
	70201	0.448	6981	0.433	6981	1.03
	70204	0.551	8511	0.654	7482	0.84
	110718	0.719	7492	0.808	7492	0.89
2 Exterior Wall @ EL4.65 ~-6.60m	62011	0.692	8514	0.579	7561	1.20
	62019	0.738	8514	0.449	7482	1.64
	72001	0.576	8511	0.520	7482	1.11
	72004	1.033	8512	0.550	7482	1.88
3 Exterior Wall @ EL22.50 ~-24.60m	64011	0.778	8511	0.918	7561	0.85
	64019	0.505	7501	0.541	7501	0.93
	74001	0.306	8511	0.281	7581	1.09
	74004	0.460	8511	0.493	7201	0.93
4 Spent Fuel Pool Wall @ EL-5.10 ~-3.30m	60819	0.343	8511	0.313	7482	1.10
	70801	0.700	7491	0.800	7492	0.88
	70804	0.472	8513	0.603	7561	0.78
	110748	0.547	8511	0.579	7492	0.94
5 Basemat	90306	0.247	8512	0.451	7241	0.55
	90310	0.150	7211	0.213	7211	0.71
	90410	0.282	7491	0.508	7601	0.55
5 Basemat @ Spent Fuel Pool	90486	0.347	8514	0.715	7201	0.49
	90490	0.356	8511	0.436	7481	0.82
	90526	0.239	7491	0.414	7201	0.58
6 Slab EL4.65m	93306	0.165	7211	0.212	7481	0.78
	93310	0.303	8514	0.314	7421	0.97
	93410	0.289	7561	0.226	7561	1.28

Note : Exceedance is highlighted. As shown in Figure 7.3.1.1-1, the exceedance is resolved by considering the moment capacity of wall according to the specifications of ACI 349-01.



Table A.2-1 Maximum Stress Ratios for Flexure and Membrane Forces: FB (Continued)

Location	Element ID	Primary Reinforcement																			
		Direction 1'									Direction 2'										
		In/Top					Out/Bottom				In/Top					Out/Bottom					
		NA3		DCD		Ratio	NA3		DCD		Ratio	NA3		DCD		Ratio	NA3		DCD		Ratio
$\sigma/\sigma_a$	Load ID	$\sigma/\sigma_a$	Load ID	(NA3/DCD)	$\sigma/\sigma_a$	Load ID	$\sigma/\sigma_a$	Load ID	(NA3/DCD)	$\sigma/\sigma_a$	Load ID	$\sigma/\sigma_a$	Load ID	(NA3/DCD)	$\sigma/\sigma_a$	Load ID	$\sigma/\sigma_a$	Load ID	(NA3/DCD)		
1 Exterior Wall and Pool Wall @ EL-11.50 ~-10.50m	60011	0.159	7621	0.763	7601	0.21	0.250	8011	0.960	8011	0.26	0.112	9013	0.910	7982	0.12	0.164	7461	0.896	7992	0.18
	60219	0.227	7601	0.824	7601	0.27	0.256	9011	0.821	7982	0.31	0.168	7701	0.833	7601	0.20	0.306	8511	0.827	7982	0.37
	70201	0.123	7751	0.254	7701	0.49	0.467	8512	0.666	7491	0.70	0.111	7751	0.394	7701	0.28	0.374	8514	0.816	7482	0.46
	70204	0.212	7601	0.581	7831	0.37	0.349	9011	0.561	7981	0.62	0.217	7701	0.986	7601	0.22	0.356	8514	0.779	7981	0.46
	110718	0.481	7701	0.692	8001	0.70	0.512	8511	0.515	8001	0.99	0.111	7751	0.278	7711	0.40	0.377	7492	0.596	8001	0.63
2 Exterior Wall @ EL4.65 ~-6.60m	62011	0.383	9013	0.593	8081	0.65	0.632	7492	0.742	7492	0.85	0.729	9012	0.879	8021	0.83	0.801	7492	0.952	7492	0.84
	62019	0.531	9014	0.551	7991	0.96	0.638	7471	0.678	7482	0.94	0.556	7991	0.666	8071	0.84	0.540	7482	0.570	7601	0.95
	72001	0.766	7653	0.808	7481	0.95	0.863	8511	0.754	7121	1.14	0.761	7653	0.883	7931	0.86	0.710	7491	0.715	7491	0.99
	72004	0.839	7221	0.833	7491	1.01	0.948	8512	0.851	7482	1.11	0.979	7632	0.774	7811	1.27	0.946	8071	0.989	8071	0.96
3 Exterior Wall @ EL22.50 ~-24.60m	64011	0.508	7961	0.579	7931	0.88	0.726	7521	0.823	7521	0.88	0.451	8071	0.639	8071	0.71	0.644	8511	0.744	7521	0.87
	64019	0.630	8513	0.650	7581	0.97	0.798	8513	0.833	7421	0.96	0.277	8071	0.389	8071	0.71	0.686	7441	0.795	7421	0.86
	74001	0.217	8511	0.298	7331	0.73	0.276	8511	0.278	7482	0.99	0.188	7581	0.210	7331	0.90	0.231	8511	0.241	7482	0.96
	74004	0.421	8514	0.405	8061	1.04	0.584	7471	0.587	7421	0.99	0.327	8061	0.386	8071	0.85	0.593	7471	0.613	7441	0.97
4 Spent Fuel Pool Wall @ EL-5.10 ~-3.30m	60819	0.277	7711	0.773	7711	0.36	0.239	7601	0.783	7601	0.30	0.086	7611	0.860	7612	0.10	0.120	7491	0.958	7601	0.12
	70801	0.300	7601	0.569	7601	0.53	0.534	7492	0.925	7492	0.58	0.220	7601	0.561	7601	0.39	0.336	7492	0.754	7492	0.45
	70804	0.434	7861	0.785	7841	0.55	0.377	7311	0.718	7711	0.53	0.290	7861	0.879	7991	0.33	0.253	8513	0.889	7711	0.28
	110748	0.517	8001	0.490	8001	1.06	0.387	8511	0.399	7981	0.97	0.273	8001	0.376	8001	0.73	0.278	8511	0.260	8001	1.07
5 Basemat	90306	0.181	7121	0.732	8071	0.25	0.063	8514	0.436	7601	0.14	0.176	7121	0.685	7601	0.26	0.017	7911	0.153	7941	0.11
	90310	0.042	2011	0.045	7431	0.92	0.039	7211	0.084	7931	0.46	0.040	2011	0.072	7601	0.55	0.044	7961	0.106	7931	0.42
	90410	0.061	8021	0.746	8021	0.08	0.057	7461	0.169	7411	0.33	0.128	8021	0.681	8021	0.19	0.199	7711	0.414	7911	0.48
5 Basemat @ Spent Fuel Pool	90486	0.158	7251	0.559	7201	0.28	0.212	7492	0.611	7601	0.35	0.059	7251	0.398	7991	0.15	0.165	8514	0.482	7601	0.34
	90490	0.230	7601	0.640	7601	0.36	0.304	7492	0.349	8001	0.87	0.273	7621	0.867	7921	0.31	0.212	7992	0.548	7601	0.39
	90526	0.300	7921	0.907	7982	0.33	0.088	7991	0.433	7601	0.20	0.141	7601	0.548	7921	0.26	0.145	8512	0.291	7492	0.50
6 Slab EL4.65m	93306	0.517	7201	0.641	7201	0.81	0.245	7301	0.425	7941	0.58	0.368	8514	0.351	7301	1.05	0.174	8001	0.242	7991	0.72
	93310	0.267	7431	0.339	7411	0.79	0.268	8514	0.363	7601	0.74	0.243	7411	0.328	7411	0.74	0.257	8514	0.327	7421	0.78
	93410	0.596	7491	0.436	7491	1.37	0.395	7701	0.248	7701	1.59	0.275	7501	0.267	7701	1.03	0.259	7701	0.257	7701	1.01

Note \*: Exterior Wall, Pool Wall Direction1 : Horizontal, Direction2 : Vertical  
 Basemat, Slab Direction1 : N-S, Direction2 : E-W  
 $\sigma$  and  $\sigma_a$  are calculated and allowable stress.



**Table A.2-2 Maximum Stress Ratios for Membrane Compressive Forces: FB**

Location	Element ID	Thickness h (m)	NA3					DCD				Ratio (NA3/DCD)				
			Load ID	Ciculated Concrete Stress (MPa)				Load ID	Ciculated Concrete Stress (MPa)				$\sigma_x$	$\sigma_y$	$\tau_{xy}$	$\sigma_c$
				$\sigma_x$ (MPa)	$\sigma_y$ (MPa)	$\tau_{xy}$ (MPa)	$\sigma_c$ (MPa)		$\sigma_x$ (MPa)	$\sigma_y$ (MPa)	$\tau_{xy}$ (MPa)	$\sigma_c$ (MPa)				
1 Exterior Wall and Pool Wall @ EL-11.50 ~-10.50m	60011	2.0	7251	-2.796	-1.711	-1.216	-3.585	7201	-3.406	-3.527	-3.384	-6.851	0.82	0.49	0.36	0.52
	60219	3.6	7251	-1.766	-1.059	-0.552	-2.068	7201	-1.705	-3.165	-1.440	-4.049	1.04	0.33	0.38	0.51
	70201	2.0	7201	-0.629	-0.568	1.356	-1.955	7501	0.660	-1.724	-1.471	-2.425	-0.95	0.33	-0.92	0.81
	70204	2.0	7251	-1.624	-1.884	-2.077	-3.835	7201	-1.699	-4.839	-2.656	-6.354	0.96	0.39	0.78	0.60
	110718	1.5	8511	-5.081	-4.908	-4.098	-9.094	7482	-5.590	-7.281	-4.164	-10.684	0.91	0.67	0.98	0.85
2 Exterior Wall @ EL4.65 ~-6.60m	62011	1.0	7491	-3.314	-1.939	3.178	-5.878	7301	-1.454	-2.815	-4.170	-6.360	2.28	0.69	-0.76	0.92
	62019	1.0	7411	-2.386	-2.691	3.254	-5.796	7201	-1.365	-2.941	-3.465	-5.706	1.75	0.91	-0.94	1.02
	72001	1.0	7501	-1.599	-3.269	4.578	-7.087	7441	1.224	-4.484	5.783	-8.079	-1.31	0.73	0.79	0.88
	72004	1.0	7501	-2.074	-3.215	5.045	-7.722	7501	-1.229	-3.807	4.709	-7.401	1.69	0.84	1.07	1.04
3 Exterior Wall @ EL22.50 ~-24.60m	64011	1.0	7601	-3.251	0.052	1.609	-3.905	7601	-3.859	0.142	1.995	-4.683	0.84	0.36	0.81	0.83
	64019	1.0	7101	-2.993	-0.873	-1.518	-3.785	7101	-3.098	-0.965	-1.693	-4.032	0.97	0.91	0.90	0.94
	74001	1.0	8511	-0.253	-1.193	-2.891	-3.652	7482	-0.270	-1.159	-2.781	-3.531	0.94	1.03	1.04	1.03
	74004	1.0	8511	-1.788	-0.595	-3.522	-4.763	7101	-1.979	-0.674	1.992	-3.422	0.90	0.88	-1.77	1.39
4 Spent Fuel Pool Wall @ EL-5.10 ~-3.30m	60819	3.6	8511	-1.511	-1.565	-0.846	-2.385	7201	-1.338	-3.405	-1.538	-4.225	1.13	0.46	0.55	0.56
	70801	2.0	7251	-1.698	-1.023	-1.657	-3.052	7201	1.294	-1.749	2.286	-2.974	-1.31	0.58	-0.72	1.03
	70804	2.0	7251	-1.576	-1.314	-1.897	-3.347	7201	1.538	-3.401	2.629	-4.539	-1.02	0.39	-0.72	0.74
	110748	1.5	8511	-2.013	-4.397	-2.897	-6.337	7482	-2.156	-5.184	-2.909	-6.949	0.93	0.85	1.00	0.91
5 Basemat	90306	4.0	7251	-1.548	-0.786	0.912	-2.155	7201	-2.779	-1.199	1.583	-3.758	0.56	0.66	0.58	0.57
	90310	4.0	2001	-0.494	-0.509	0.050	-0.551	2001	-0.494	-0.508	0.049	-0.551	1.00	1.00	1.00	1.00
	90410	4.0	7251	-0.751	-2.318	0.686	-2.576	7201	-0.891	-3.394	1.419	-4.035	0.84	0.68	0.48	0.64
5 Basemat @ Spent Fuel Pool	90486	5.5	2001	-0.483	-0.812	-0.049	-0.819	7561	-0.904	-1.396	-0.465	-1.676	0.53	0.58	0.11	0.49
	90490	5.5	7251	-0.541	-1.746	0.358	-1.844	7201	-0.686	-2.376	0.812	-2.702	0.79	0.73	0.44	0.68
	90526	5.5	2001	-0.601	-0.914	-0.080	-0.933	7201	-1.620	-1.099	-1.131	-2.520	0.37	0.83	0.07	0.37
6 Slab EL4.65m	93306	1.3	8514	-2.180	-0.329	-2.011	-3.468	7211	-3.190	-0.464	-1.635	-3.956	0.68	0.71	1.23	0.88
	93310	1.3	2021	-1.698	-1.680	-1.854	-3.544	2021	-1.698	-1.680	-1.854	-3.544	1.00	1.00	1.00	1.00
	93410	1.3	7492	-0.637	-2.927	-1.525	-3.689	7492	-0.481	-3.287	-1.231	-3.750	1.32	0.89	1.24	0.98

Notes: Compressive forces are negative.



**Table A.2-2 Maximum Stress Ratios for Membrane Compressive Forces: FB (Continued)**

Location	Element ID	Thickness h (m)	NA3			DCD			Ratio (NA3/DCD)
			Load ID	Allowable Stress $\sigma_a$ (MPa)	$\sigma_c/\sigma_a$	Load ID	Allowable Stress $\sigma_a$ (MPa)	$\sigma_c/\sigma_a$	$\sigma_c/\sigma_a$
1 Exterior Wall and Pool Wall @ EL-11.50 ~-10.50m	60011	2.0	7251	-20.7	0.173	7201	-20.7	0.331	0.523
	60219	3.6	7251	-20.7	0.100	7201	-20.7	0.196	0.511
	70201	2.0	7201	-20.7	0.094	7501	-20.7	0.117	0.806
	70204	2.0	7251	-20.7	0.185	7201	-20.7	0.307	0.604
	110718	1.5	8511	-25.9	0.351	7482	-25.9	0.413	0.851
2 Exterior Wall @ EL4.65 ~-6.60m	62011	1.0	7491	-25.9	0.227	7301	-20.7	0.307	0.739
	62019	1.0	7411	-25.9	0.224	7201	-20.7	0.276	0.813
	72001	1.0	7501	-20.7	0.342	7441	-25.9	0.312	1.097
	72004	1.0	7501	-20.7	0.373	7501	-20.7	0.358	1.043
3 Exterior Wall @ EL22.50 ~-24.60m	64011	1.0	7601	-20.7	0.189	7601	-20.7	0.226	0.834
	64019	1.0	7101	-20.7	0.183	7101	-20.7	0.195	0.939
	74001	1.0	8511	-25.9	0.141	7482	-25.9	0.136	1.035
	74004	1.0	8511	-25.9	0.184	7101	-20.7	0.165	1.113
4 Spent Fuel Pool Wall @ EL-5.10 ~-3.30m	60819	3.6	8511	-25.9	0.092	7201	-25.9	0.163	0.564
	70801	2.0	7251	-20.7	0.147	7201	-20.7	0.144	1.026
	70804	2.0	7251	-20.7	0.162	7201	-20.7	0.219	0.737
	110748	1.5	8511	-25.9	0.245	7482	-25.9	0.269	0.912
5 Basemat	90306	4.0	7251	-16.6	0.130	7201	-16.6	0.227	0.573
	90310	4.0	2001	-8.3	0.067	2001	-8.3	0.067	1.000
	90410	4.0	7251	-16.6	0.156	7201	-16.6	0.244	0.638
5 Basemat @ Spent Fuel Pool	90486	5.5	2001	-8.3	0.099	7561	-16.6	0.101	0.977
	90490	5.5	7251	-16.6	0.111	7201	-16.6	0.163	0.682
	90526	5.5	2001	-8.3	0.113	7201	-16.6	0.152	0.741
6 Slab EL4.65m	93306	1.3	8514	-25.9	0.134	7211	-25.9	0.153	0.877
	93310	1.3	2021	-15.5	0.228	2021	-15.5	0.228	1.000
	93410	1.3	7492	-25.9	0.143	7492	-25.9	0.145	0.984

Notes: Compressive forces are negative.



**HITACHI**

WG3-U97-ERD-S-0001

SH NO. 141

REV. 0

of 151

**Table A.2-3 Calculation Results for Maximum Transverse Shear: FB**

Location	Element ID	NA3			DCD			NA3					DCD					Ratio (NA3/DCD)				
		Load ID	d (m)	pv (%)	Load ID	d (m)	pv (%)	Shear Force (MN/m)				Vu/φVn	Shear Force (MN/m)				Vu/φVn	Shear Force (MN/m)				Vu/φVn
								Vu	Vc	Vs	φVn		Vu	Vc	Vs	φVn		Vu	Vc	Vs	φVn	
1 Exterior Wall and Pool Wall @ EL-11.50 ~-10.50m	60011	8511	1.70	0.710	7982	1.74	0.177	1.55	4.02	5.00	7.67	0.202	0.38	0.00	1.28	1.08	0.346	4.14	1.00	3.92	7.07	0.58
	60219	8511	3.05	0.710	7982	3.36	0.177	4.67	3.77	8.96	10.82	0.432	0.26	0.31	2.46	2.35	0.112	17.70	12.08	3.65	4.60	3.85
	70201	7481	1.65	0.710	7982	1.69	0.177	1.19	1.72	4.84	5.58	0.213	0.15	0.18	1.24	1.20	0.125	7.91	9.72	3.92	4.65	1.70
	70204	7481	1.59	0.710	4021	1.69	0.710	3.14	2.16	4.67	5.81	0.540	1.98	2.06	4.97	5.98	0.331	1.59	1.05	0.94	0.97	1.63
2 Exterior Wall @ EL4.65 ~-6.60m	110718	7492	1.12	0.355	7482	1.10	0.355	0.82	1.14	1.64	2.36	0.346	1.02	1.41	1.61	2.56	0.397	0.80	0.81	1.02	0.92	0.87
	62011	7571	0.78	0.125	7982	0.78	0.125	0.49	0.84	0.40	1.06	0.463	0.27	0.23	0.40	0.54	0.499	1.81	3.61	1.00	1.96	0.93
	62019	7601	0.72	0.125	7982	0.72	0.125	0.18	0.13	0.37	0.43	0.407	0.11	0.13	0.37	0.42	0.256	1.62	1.06	1.00	1.02	1.59
	72001	7581	0.73	0.250	7982	0.72	0.250	0.47	0.00	0.76	0.64	0.728	0.45	0.10	0.75	0.72	0.620	1.05	0.00	1.02	0.89	1.17
3 Exterior Wall @ EL22.50 ~-24.60m	72004	7612	0.72	0.250	7982	0.72	0.125	0.46	0.00	0.74	0.63	0.732	0.23	0.00	0.37	0.32	0.734	1.99	1.00	2.00	2.00	1.00
	64011	7492	0.72	0.125	7482	0.72	0.125	0.31	0.71	0.37	0.92	0.336	0.29	0.72	0.37	0.92	0.310	1.08	0.99	1.00	0.99	1.08
	64019	8511	0.80	0.125	7482	0.80	0.125	0.22	0.00	0.41	0.35	0.635	0.24	0.00	0.41	0.35	0.680	0.93	1.00	1.00	1.00	0.93
	74001	7492	0.73	0.125	4021	0.72	0.125	0.15	0.18	0.38	0.47	0.321	0.10	0.12	0.37	0.42	0.249	1.45	1.44	1.02	1.13	1.29
4 Spent Fuel Pool Wall @ EL-5.10 ~-3.30m	74004	8513	0.72	0.125	4021	0.72	0.125	0.30	0.40	0.37	0.66	0.462	0.06	0.08	0.37	0.38	0.168	4.75	5.34	1.00	1.73	2.75
	60819	8511	3.05	0.710	7982	3.33	0.177	2.44	4.35	8.97	11.32	0.216	0.37	0.43	2.44	2.44	0.151	6.63	10.04	3.67	4.63	1.43
	70801	8514	1.71	0.710	7482	1.69	0.710	4.03	2.03	5.02	5.99	0.672	3.99	1.84	4.97	5.79	0.690	1.01	1.10	1.01	1.04	0.97
	70804	7571	1.62	0.710	7982	1.59	0.177	1.11	0.69	4.75	4.62	0.240	0.11	0.13	1.17	1.10	0.098	10.25	5.37	4.07	4.20	2.44
5 Basemat	110748	8511	1.22	0.177	7482	1.22	0.177	1.06	1.32	0.89	1.88	0.563	1.09	1.38	0.89	1.93	0.563	0.97	0.96	1.00	0.97	1.00
	90306	8514	3.53	0.629	7982	3.49	0.629	4.82	6.96	9.18	13.73	0.351	6.11	1.70	9.07	9.15	0.667	0.79	4.10	1.01	1.50	0.53
	90310	7511	3.52	0.629	7482	3.48	0.629	2.82	5.95	9.15	12.84	0.220	3.70	5.75	9.06	12.59	0.294	0.76	1.04	1.01	1.02	0.75
5 Basemat @ Spent Fuel Pool	90410	7471	3.53	0.629	7982	3.50	0.629	3.47	6.91	9.19	13.68	0.254	3.90	1.76	9.09	9.23	0.423	0.89	3.92	1.01	1.48	0.60
	90486	7492	5.04	0.419	7982	3.92	0.419	1.86	4.63	8.74	11.36	0.164	2.91	3.66	6.79	8.89	0.327	0.64	1.26	1.29	1.28	0.50
	90490	8514	5.04	0.629	7482	5.05	0.629	5.65	5.53	13.11	15.85	0.356	11.99	6.04	13.13	16.29	0.736	0.47	0.92	1.00	0.97	0.48
6 Slab EL4.65m	90526	7221	5.03	0.629	7982	3.94	0.629	4.48	9.27	13.07	18.99	0.236	6.45	3.16	10.25	11.40	0.566	0.69	2.93	1.28	1.67	0.42
	93306	7482	1.10	0.500	6483	1.10	0.500	0.41	0.79	2.27	2.60	0.158	0.22	0.26	2.27	2.15	0.101	1.89	3.08	1.00	1.21	1.56
	93310	7571	1.10	0.500	7482	1.10	0.500	0.93	2.47	2.27	4.03	0.231	1.08	2.95	2.27	4.44	0.244	0.86	0.84	1.00	0.91	0.94
	93410	7501	1.10	0.500	7482	1.10	0.500	0.46	0.99	2.27	2.77	0.168	0.46	2.15	2.27	3.75	0.121	1.02	0.46	1.00	0.74	1.38



**HITACHI**

---

WG3-U97-ERD-S-0001

SH NO. 142

REV. 0

of 151

**APPENDIX B**

**IN-PLANE SHEAR CHECK FOR FB ACCORDING TO ACI349-01**



**Table of Contents**

B.1	SCOPE.....	144
B.2	IN-PLANE SHEAR CHECK.....	144
B.3	CONCLUSIONS.....	144

**List of Tables**

Table B-1	Maximum Stress Ratios for In-Plane Shear Check.....	145
Table B-2	In-Plane Shear Check for Entire Wall (FB Exterior Wall at EL 4.65 m to 6.60 m)...	146

**List of Figures**

Figure B-1	Selected Elements for In-plane Shear Check on Entire Wall.....	147
------------	--	-----



## B.1 SCOPE

This appendix describes In-plane Shear Check for FB according to ACI349-01.

## B.2 IN-PLANE SHEAR CHECK

According to ACI 394-01 Section 21.6.5.2, the maximum shear strength of a horizontal wall segment per unit length is calculated as follows.

$$V_n = \left( 2\sqrt{f'_c} + \rho_n f_y \right) h \quad (\text{lb/in})$$

Where,  $h$  is wall thickness.

Shear strength calculated above shall not be taken greater than the following equation specified in ACI 394-01 Section 21.6.5.7.

$$V_{n_{\max}} = 10\sqrt{f'_c} h \quad (\text{lb/in})$$

The reduction of thermal stresses due to the decreased stiffness of a cracked concrete section is considered.

## B.3 CONCLUSIONS

The results of in-plane shear check for the selected elements are shown in Table B-1. For elements at the exterior wall at EL 4,650 to EL 6,600, it is confirmed that the combined forces  $N_{xy}$  are larger than the allowable shear forces evaluated above.

Since ACI 349-01 in-plane shear stress check for walls is developed for the entire wall and not meant for local checks, the stress check by looking at the entire wall at EL 4,650 to EL 6,600 as highlighted in Figure B-1 is performed instead of the stress check on one element.

The results of in-plane shear check on the entire wall at EL 4,650 to EL 6,600 are shown in Table B-2 and in-plane shear stress is confirmed to be lower than the allowable stress.

**Table B-1 Maximum Stress Ratios for In-Plane Shear Check**

Location	Element ID	Load Case	Nxy (MN/m)	Thickness t (m)	Primary Reinforcement Ratio	Allowable Shear Strength $\phi V_n = \phi 10 t f_c^{0.5}$ (MN/m)	Total In-Plane Shear Nxy(MN/m)	$Nxy/\phi V_n$
1 Exterior Wall and Pool Wall @ EL-11.50 ~-10.50m	60011	8514	-2.887	2.0	2.013 %	8.288	2.887	0.348
	60219	7461	-2.172	3.6	2.097 %	14.918	2.172	0.146
	70201	8514	-3.303	2.0	3.522 %	8.288	3.303	0.399
	70204	8514	-4.731	2.0	3.522 %	8.288	4.731	0.571
	110718	8511	-6.148	1.5	1.342 %	6.216	6.148	0.989
2 Exterior Wall @ EL 4.65 ~-6.60m	62011	7481	3.182	1.0	2.516 %	4.144	3.182	0.768
	62019	7482	-3.327	1.0	2.516 %	4.144	3.327	0.803
	72001	8511	6.381	1.0	3.020 %	4.144	6.381	1.540
	72004	8512	5.803	1.0	3.020 %	4.144	5.803	1.400
3 Exterior Wall @ EL22.50 ~-24.60m	64011	7491	1.758	1.0	2.516 %	4.144	1.758	0.424
	64019	8513	1.641	1.0	2.012 %	4.144	1.641	0.396
	74001	8511	-2.891	1.0	2.516 %	4.144	2.891	0.698
	74004	8511	-3.522	1.0	2.516 %	4.144	3.522	0.850
4 Spent Fuel Pool Wall @ EL-5.10 ~-3.30m	60819	8511	-3.045	3.6	2.097 %	14.918	3.045	0.204
	70801	7492	-3.571	2.0	3.522 %	8.288	3.571	0.431
	70804	7441	3.956	2.0	3.522 %	8.288	3.956	0.477
	110748	8511	-4.345	1.5	1.342 %	6.216	4.345	0.699

Note: Exceedance is highlighted.



**HITACHI**

WG3-U97-ERD-S-0001 SH NO. 146

REV. 0

of 151

**Table B-2 In-Plane Shear Check for Entire Wall (FB Exterior Wall at EL 4.65 m to 6.60 m)**

Critical Load Case	Location	Element	Element Length		Element Thickness		Shear Area of Element	Shear Area of Wall	Element Shear Force in Unit Length	Element Shear Force	Total Shear Force	Total Shear Stress	Allowable Shear Stress	$\tau / \tau_a$
			Li (m)	Ti (m)	Ai (m <sup>2</sup> )	As (m <sup>2</sup> )	Qi (MN/m)	Q (MN)	Qt (MN)	$\tau$ (MN/m <sup>2</sup> )	$\tau_a$ (MN/m <sup>2</sup> )			
8514	Exterior Wall @EL 4.65 ~6.60m	72001	2.10	1.00	2.10		6.220	13.06						
		72002	2.10	1.00	2.10		6.233	13.09						
		72003	2.10	1.00	2.10		5.838	12.26						
		72004	1.80	1.00	1.80		5.663	10.19						
		72005	2.40	1.00	2.40		5.504	13.21						
		72006	2.40	1.00	2.40		5.490	13.18						
		72007	1.80	1.00	1.80		5.375	9.68						
		72008	2.10	1.00	2.10		5.318	11.17						
		72009	2.10	1.00	2.10		5.614	11.79						
		72010	2.10	1.00	2.10		5.881	12.35						
		32001	2.50	1.50	3.75		6.272	15.68						
		32002	2.16	1.50	3.24		7.223	15.62						
		32003	2.14	1.50	3.21		6.016	12.86						
		32004	1.85	1.50	2.78		4.839	8.95						
		32005	1.80	1.50	2.70		4.049	7.29						
		32006	2.20	1.50	3.30		3.829	8.42						
		32007	1.85	1.50	2.78		3.563	6.59						
		32008	3.60	1.50	5.40		3.402	12.25						
		32009	2.60	1.50	3.90		3.242	8.43						
		32010	2.80	1.50	4.20		3.095	8.67						
32011	2.80	1.50	4.20		2.972	8.32								
32012	2.60	1.50	3.90		2.865	7.45								
32013	3.60	1.50	5.40		2.764	9.95								
32014	1.85	1.50	2.78		2.781	5.14								
32015	2.20	1.50	3.30		2.858	6.29								
32016	1.80	1.50	2.70		3.086	5.55								
32017	1.85	1.50	2.78		3.514	6.50								
32018	2.14	1.50	3.21		4.093	8.75								
32019	2.16	1.50	3.24		4.287	9.27								
32020	2.50	1.50	3.75		91.5	2.999	7.50	299.46	3.27	4.14	0.79			




**HITACHI**

WG3-U97-ERD-S-0001

SH NO. 147

REV. 0

of 151



**Figure B-1 Selected Elements for In-plane Shear Check on Entire Wall**



**HITACHI**

---

WG3-U97-ERD-S-0001 SH NO. 148

REV. 0

of 151

## APPENDIX C

### COMPRESSION LIMIT CHECK FOR FB ACCORDING TO ACI349-01



**Table of Contents**

C.1	SCOPE .....	150
C.2	MEMBRANE COMPRESSIVE FORCE CHECK .....	150
C.3	CONCLUSION.....	150

**List of Tables**

Table C-1	Membrane Compressive Stress Check According to ACI349-01 .....	151
-----------	--	-----

**List of Figures**

**None**



### C.1 SCOPE

This appendix describes Membrane Compressive Force Check for FB according to ACI349-01.

### C.2 MEMBRANE COMPRESSIVE FORCE CHECK

According to ACI 394-01 Section 10.3.5.2, design axial load strength of compression members shall not be taken greater than the following:

$$\phi P_n(\max) = 0.80\phi \left[ 0.85f'_c (A_g - A_{st}) + f_y A_{st} \right]$$

Where,  $A_g$  and  $A_{st}$  are gross area and total cross-sectional area of reinforcement of section.

### C.3 CONCLUSION

The results of compression force check are shown in Table C-1. It is confirmed that the calculated compression force are less than the allowable compression force evaluated based on the above strength.



**Table C-1 Membrane Compressive Stress Check According to ACI349-01**

Location	Element ID	Load ID	Section Forces (MN/m)			Thickness h (m)	Ciculated Concrete Stress (MPa)				Allowable Stress $\sigma_a$ (MPa)	$\sigma_c/\sigma_a$
			Nx	Ny	Nxy		$\sigma_x$	$\sigma_y$	$\tau_{xy}$	$\sigma_c$		
1 Exterior Wall and Pool Wall @ EL-11.50 ~-10.50m	60011	8511	-7.014	-2.936	-2.745	2.0	-3.507	-1.468	-1.372	-4.197	-20.8	0.202
	60219	7481	-6.893	-4.879	-1.991	3.6	-1.915	-1.355	-0.553	-2.255	-20.9	0.108
	70201	7201	-1.257	-1.136	2.712	2.0	-0.629	-0.568	1.356	-1.955	-24.0	0.081
	70204	8514	-3.260	-2.863	-4.731	2.0	-1.630	-1.432	-2.366	-3.899	-24.0	0.162
	110718	8511	-7.621	-7.362	-6.148	1.5	-5.081	-4.908	-4.098	-9.094	-19.3	0.471
2 Exterior Wall @ EL4.65 ~-6.60m	62011	7491	-3.314	-1.939	3.178	1.0	-3.314	-1.939	3.178	-5.878	-21.8	0.269
	62019	7411	-2.386	-2.691	3.254	1.0	-2.386	-2.691	3.254	-5.796	-21.8	0.265
	72001	7471	2.043	-4.952	6.044	1.0	2.043	-4.952	6.044	-8.438	-22.9	0.368
	72004	7571	-2.933	-2.886	5.044	1.0	-2.933	-2.886	5.044	-7.954	-22.9	0.347
3 Exterior Wall @ EL22.50 ~-24.60m	64011	7491	-3.706	-0.703	1.758	1.0	-3.706	-0.703	1.758	-4.516	-21.8	0.207
	64019	7491	-3.544	-0.976	-1.548	1.0	-3.544	-0.976	-1.548	-4.271	-20.8	0.206
	74001	8511	-0.253	-1.193	-2.891	1.0	-0.253	-1.193	-2.891	-3.652	-21.8	0.167
	74004	8511	-1.788	-0.595	-3.522	1.0	-1.788	-0.595	-3.522	-4.763	-21.8	0.218
4 Spent Fuel Pool Wall @ EL-5.10 ~-3.30m	60819	8511	-5.441	-5.636	-3.045	3.6	-1.511	-1.565	-0.846	-2.385	-20.9	0.114
	70801	7481	-3.440	-2.402	-3.412	2.0	-1.720	-1.201	-1.706	-3.186	-24.0	0.133
	70804	8514	-4.648	-1.903	-3.849	2.0	-2.324	-0.951	-1.924	-3.681	-24.0	0.153
	110748	8511	-3.019	-6.596	-4.345	1.5	-2.013	-4.397	-2.897	-6.337	-19.3	0.328
5 Basemat	90306	7481	-7.988	-2.992	3.858	4.0	-1.997	-0.748	0.965	-2.522	-15.6	0.162
	90310	7491	-3.356	-3.772	0.488	4.0	-0.839	-0.943	0.122	-1.024	-15.6	0.066
	90410	8511	-3.199	-10.517	3.097	4.0	-0.800	-2.629	0.774	-2.913	-15.6	0.187
5 Basemat @ Spent Fuel Pool	90486	7471	-5.741	-7.153	1.489	5.5	-1.044	-1.300	0.271	-1.472	-15.3	0.096
	90490	7491	-4.851	-11.890	2.350	5.5	-0.882	-2.162	0.427	-2.291	-15.3	0.149
	90526	7571	-7.134	-5.515	-4.154	5.5	-1.297	-1.003	-0.755	-1.919	-15.3	0.125
6 Slab EL4.65m	93306	8514	-2.833	-0.427	-2.614	1.3	-2.180	-0.329	-2.011	-3.468	-19.8	0.176
	93310	8514	-2.937	-2.507	-3.390	1.3	-2.259	-1.928	-2.608	-4.707	-19.8	0.238
	93410	7492	-0.828	-3.805	-1.983	1.3	-0.637	-2.927	-1.525	-3.689	-19.8	0.187