

SUSAN PERKINS-GREW

Senior Director, Emergency Preparedness
and Risk Assessment

1201 F Street, NW, Suite 1100
Washington, DC 20004
P: 202.739.8016
spg@nei.org
nei.org



NUCLEAR ENERGY INSTITUTE

December 9, 2015

11/10/2015
@FR 69721

1

RECEIVED

2015 DEC -9 PM 3:17

RULES AND REGULATIONS
GENERAL
INQUIRIES

Ms. Cindy Bladey,
Office of Administration
Mail Stop: O12-H08
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001

Subject: Industry Comment on Proposed Emergency Preparedness Frequently Asked Questions (Docket ID: NRC-2015-0254)

Project Number: 689

Dear Ms. Bladey:

The Nuclear Energy Institute (NEI)¹ and the industry hereby submit the attached comment pursuant to Federal Register notice, "Proposed Emergency Preparedness Frequently Asked Questions," 80 Fed. Reg. 69721 (November 10, 2015).

Please contact David Young at (202) 739-8127 or dly@nei.org if you require information concerning these comments.

Sincerely,

Susan Perkins-Grew

Attachment

c: Mr. Joseph Anderson, NSIR/DPR/ORLOB, NRC
Mr. Don Johnson, NSIR/DPR/ORLOB/ORLT, NRC

¹ The Nuclear Energy Institute (NEI) is the organization responsible for establishing unified industry policy on matters affecting the nuclear energy industry, including the regulatory aspects of generic operational and technical issues. NEI's members include all entities licensed to operate commercial nuclear power plants in the United States, nuclear plant designers, major architect/engineering firms, fuel cycle facilities, nuclear materials licensees, and other organizations and entities involved in the nuclear energy industry.

**NEI and Industry Comment on
Proposed Emergency Preparedness Frequently Asked Questions
(Docket ID: NRC-2015-0254)**

Comment

For clarity, the following editorial change to EP FAQ 2015-004 is recommended (on page 9):

Current wording

Developer Notes: None.

5. Reflecting the above change and rationale, the following additional change should be made to Fuel Clad Barrier LOSS #2, RPV Water Level, "Primary containment flooding required," "SAG entry is required."

Proposed wording

Developer Notes: None.

5. Reflecting the rationale discussed above, the threshold for Fuel Clad Barrier LOSS #2, RPV Water Level, should also be changed from "Primary containment flooding required" to "SAG entry is required."