

## PMLevyCOLPEm Resource

---

**From:** Habib, Donald  
**Sent:** Thursday, December 17, 2015 9:07 AM  
**To:** PMLevyCOLPEm Resource  
**Subject:** FW: Topics for Thursday Levy Teleconference

---

**From:** Habib, Donald  
**Sent:** Tuesday, December 15, 2015 3:47 PM  
**To:** Bob Kitchen (Robert.Kitchen@duke-energy.com) <Robert.Kitchen@duke-energy.com>  
**Subject:** Topics for Thursday Levy Teleconference

Bob –

Below are the topics we would like to discuss on the closed call on Thursday.

### **Clarification Topics of Levy COL Application, Including DCD Revision 19, Incorporated by Reference**

1. Why is the [ ] sealant material being used in the main steam and feedwater penetrations through the containment and shield building? What function(s) does it perform?
2. Is the use of [ ] sealant material intended to be part of the Levy COL application, including DCD Revision 19 that is incorporated by reference?
3. How has the [ ] sealant material been qualified, or been evaluated to be qualified, for the environmental conditions (temperature, compatibility with shield building concrete, etc.) in which it is proposed for use?
4. Are there any penetrations for which departures from the DCD are required (e.g., exemption from ACI 349) related to use of [ ] sealant material?

Don Habib  
Levy COL Review, Lead Project Manager  
NRO/DNRL, Licensing Branch 4  
301-415-1035

**Hearing Identifier:** Levy\_County\_COL\_Public  
**Email Number:** 1310

**Mail Envelope Properties** (f9c70965b26b4e809bb4d996751b744c)

**Subject:** FW: Topics for Thursday Levy Teleconference  
**Sent Date:** 12/17/2015 9:07:16 AM  
**Received Date:** 12/17/2015 9:07:16 AM  
**From:** Habib, Donald

**Created By:** Donald.Habib@nrc.gov

**Recipients:**  
"PMLevyCOLPEm Resource" <PMLevyCOLPEm.Resource@nrc.gov>  
Tracking Status: None

**Post Office:** HQPWMSMRS06.nrc.gov

<b>Files</b>	<b>Size</b>	<b>Date &amp; Time</b>
MESSAGE	1329	12/17/2015 9:07:16 AM

**Options**  
**Priority:** Standard  
**Return Notification:** No  
**Reply Requested:** No  
**Sensitivity:** Normal  
**Expiration Date:**  
**Recipients Received:**