

DETROIT EDISON – FERMI 2
AUTOMATED RECORDS MANAGEMENT
DISTRIBUTION CONTROL LIST

To: 00935
US NRC
DOCUMENT CONTROL DESK
WASHINGTON, DC 20555

Media: 8 ½ x 11

DTC	Doc. Serial Number	Page	Rev	Number Copies	Cnt Lvl	Issue Date	Status
TMTRM	TRM VOL I		110	1	IR	11/20/15	AFC

Please destroy or mark all revised, superseded, or cancelled documents as such.
"CONTROLLED" stamps must be voided by lining through and initialing.

Detroit Edison EF2, C/O Info Mgmt 140 NOC, 6400 North Dixie Highway, Newport MI 48166.
Call (734) 586-4220 OR (734) 586-4554 for questions or concerns.

A001
NRR

LICENSING DOCUMENT TRANSMITTAL
FERMI 2 TECHNICAL REQUIREMENTS MANUAL – VOL I
Revision 110 dated 11/20/15

Immediately, upon receipt of the item(s) below, please insert and/or remove the pages indicated. Destroy the removed pages. Be sure that Revision 109 has been inserted prior to inserting these pages.

<u>SECTION</u>	<u>REMOVE and DESTROY</u>	<u>INSERT</u>
In Front of TRM Manual	<u>Title Page Rev 109 02/09/2015</u>	<u>Title Page Rev 110 11/20/2015</u>
Immediately following Title Page	<u>List of Effective Pages LEP-1 through LEP-4 Rev 109 02/19/15</u>	<u>List of Effective Pages LEP-1 through LEP-4 Rev 110 11/20/15</u>
Core Operating Limits Report	<u>Cycle 17, Revision 0 24 pages</u>	<u>Cycle 18, Revision 1 24 pages</u>

END

Fermi 2

Technical Requirements Manual

Volume I

**DTE
Electric**

<i>ARMS - INFORMATION</i>			
DTC: TMTRM	File: 1754	DSN: TRM VOL I	Rev: 110
Date 11/20/2015	Recipient	935	

FERMI 2 - TECHNICAL REQUIREMENTS MANUAL VOL I

LIST OF EFFECTIVE PAGES

<u>Page</u>	<u>Revision</u>	<u>Page</u>	<u>Revision</u>
TRM i	Revision 106	TRM 3.3-31	Revision 31
TRM ii	Revision 107	TRM 3.3-32	Revision 31
TRM iii	Revision 105	TRM 3.3-33	Revision 31
TRM iv	Revision 106	TRM 3.3-34	Revision 31
TRM v	Revision 107	TRM 3.3-34a	Revision 106
TRM vi	Revision 31	TRM 3.3-35	Revision 60
TRM 1.0-a	Revision 31	TRM 3.3-36	Revision 104
TRM 1.0-1	Revision 31	TRM 3.3-37	Revision 72
TRM 2.0-1	Revision 31	TRM 3.3-38	Revision 31
TRM 3.0-a	Revision 31	TRM 3.3-39	Revision 31
TRM 3.0-1	Revision 63	TRM 3.3-40	Revision 56
TRM 3.0-2	Revision 72	TRM 3.3-41	Revision 56
TRM 3.0-3	Revision 54	TRM 3.3-42	Revision 45
TRM 3.0-4	Revision 72	TRM 3.3-43	Revision 62
TRM 3.1-a	Revision 31	TRM 3.3-44	Revision 72
TRM 3.1-1	Revision 31	TRM 3.3-45	Revision 31
TRM 3.2-1	Revision 31	TRM 3.3-46	Revision 31
TRM 3.3-a	Revision 31	TRM 3.3-47	Revision 31
TRM 3.3-b	Revision 31	TRM 3.3-48	Revision 31
TRM 3.3-c	Revision 106	TRM 3.3-49	Revision 31
TRM 3.3-d	Revision 31	TRM 3.4-a	Revision 31
TRM 3.3-1	Revision 106	TRM 3.4-1	Revision 36
TRM 3.3-2	Revision 106	TRM 3.4-1a	Revision 71
TRM 3.3-3	Revision 31	TRM 3.4-1b	Revision 71
TRM 3.3-4	Revision 31	TRM 3.4-2	Revision 31
TRM 3.3-5	Revision 31	TRM 3.4-3	Revision 31
TRM 3.3-6	Revision 31	TRM 3.4-4	Revision 31
TRM 3.3-7	Revision 31	TRM 3.4-5	Revision 31
TRM 3.3-8	Revision 106	TRM 3.4-6	Revision 31
TRM 3.3-9	Revision 31	TRM 3.4-7	Revision 31
TRM 3.3-10	Revision 106	TRM 3.4-8	Revision 31
TRM 3.3-11	Revision 31	TRM 3.4-9	Revision 31
TRM 3.3-12	Revision 67	TRM 3.4-10	Revision 31
TRM 3.3-13	Revision 74	TRM 3.5-1	Revision 31
TRM 3.3-13a	Revision 67	TRM 3.6-a	Revision 70
TRM 3.3-14	Revision 67	TRM 3.6-1	Revision 60
TRM 3.3-15	Revision 31	TRM 3.6-2	Revision 67
TRM 3.3-16	Revision 31	TRM 3.6-3	Revision 31
TRM 3.3-17	Revision 31	TRM 3.6-4	Revision 109
TRM 3.3-18	Revision 100	TRM 3.6-5	Revision 87
TRM 3.3-19	Revision 31	TRM 3.6-6	Revision 33
TRM 3.3-20	Revision 31	TRM 3.6-7	Revision 31
TRM 3.3-21	Revision 59	TRM 3.6-8	Revision 31
TRM 3.3-22	Revision 31	TRM 3.6-9	Revision 85
TRM 3.3-23	Revision 31	TRM 3.6-10	Revision 31
TRM 3.3-24	Revision 31	TRM 3.6-11	Revision 31
TRM 3.3-25	Revision 31	TRM 3.6-12	Revision 31
TRM 3.3-26	Revision 31	TRM 3.6-13	Revision 71
TRM 3.3-27	Revision 31	TRM 3.6-14	Revision 31
TRM 3.3-28	Revision 76	TRM 3.6-15	Revision 31
TRM 3.3-29	Revision 76	TRM 3.6-16	Revision 31
TRM 3.3-30	Revision 31	TRM 3.6-17	Revision 31

FERMI 2 - TECHNICAL REQUIREMENTS MANUAL VOL I

LIST OF EFFECTIVE PAGES

<u>Page</u>	<u>Revision</u>	<u>Page</u>	<u>Revision</u>
TRM 3.6-18	Revision 31	TRM 3.8-12	Revision 31
TRM 3.6-19	Revision 31	TRM 3.8-13	Revision 61
TRM 3.6-20	Revision 31	TRM 3.8-14	Revision 46
TRM 3.6-21	Revision 31	TRM 3.8-15	Revision 31
TRM 3.6-22	Revision 31	TRM 3.8-16	Revision 31
TRM 3.6-23	Revision 31	TRM 3.8-17	Revision 43
TRM 3.6-24	Revision 58	TRM 3.8-18	Revision 33
TRM 3.6-25	Revision 31	TRM 3.9-a	Revision 31
TRM 3.6-26	Revision 31	TRM 3.9-1	Revision 31
TRM 3.6-27	Revision 31	TRM 3.9-2	Revision 65
TRM 3.6-28	Revision 31	TRM 3.9-3	Revision 80
TRM 3.6-29	Revision 31	TRM 3.9-4	Revision 88
TRM 3.6-30	Revision 31	TRM 3.9-5	Revision 31
TRM 3.6-31	Revision 31	TRM 3.10-1	Revision 31
TRM 3.6-32	Revision 70	TRM 3.11-a	Revision 31
TRM 3.6-33	Revision 31	TRM 3.11-1	Revision 31
TRM 3.6-34	Revision 31	TRM 3.12-a	Revision 31
TRM 3.6-35	Revision 31	TRM 3.12-1	Revision 75
TRM 3.7-a	Revision 107	TRM 3.12-2	Revision 31
TRM 3.7-1	Revision 60	TRM 3.12-3	Revision 31
TRM 3.7-2	Revision 107	TRM 3.12-4	Revision 102
TRM 3.7-3	Revision 70	TRM 3.12-5	Revision 108
TRM 3.7-4	Revision 73	TRM 3.12-6	Revision 53
TRM 3.7-5	Revision 31	TRM 3.12-7	Revision 31
TRM 3.7-6	Revision 31	TRM 3.12-8	Revision 57
TRM 3.7-7	Revision 31	TRM 3.12-9	Revision 40
TRM 3.7-8	Revision 31	TRM 3.12-10	Revision 31
TRM 3.7-9	Revision 31	TRM 3.12-11	Revision 49
TRM 3.7-10	Revision 44	TRM 3.12-12	Revision 31
TRM 3.7-11	Revision 31	TRM 3.12-13	Revision 75
TRM 3.7-12	Revision 72	TRM 3.12-14	Revision 31
TRM 3.7-13	Revision 31	TRM 3.12-15	Revision 31
TRM 3.7-14	Revision 31	TRM 3.12-16	Revision 75
TRM 3.7-15	Revision 98	TRM 3.12-17	Revision 31
TRM 3.7-16	Revision 31	TRM 3.12-18	Revision 75
TRM 3.7-17	Revision 31	TRM 3.12-19	Revision 31
TRM 3.7-18	Revision 77	TRM 3.12-20	Revision 75
TRM 3.7-19	Revision 31	TRM 3.12-21	Revision 31
TRM 3.7-20	Revision 79	TRM 3.12-22	Revision 31
TRM 3.8-a	Revision 31	TRM 3.12-23	Revision 31
TRM 3.8-1	Revision 31	TRM 3.12-24	Revision 31
TRM 3.8-2	Revision 31	TRM 3.12-25	Revision 31
TRM 3.8-3	Revision 96	TRM 3.12-26	Revision 75
TRM 3.8-4	Revision 96	TRM 3.12-27	Revision 31
TRM 3.8-5	Revision 31	TRM 3.12-28	Revision 31
TRM 3.8-6	Revision 50	TRM 3.12-29	Revision 78
TRM 3.8-7	Revision 50	TRM 3.12-30	Revision 31
TRM 3.8-8	Revision 50	TRM 4.0-1	Revision 31
TRM 3.8-9	Revision 50	TRM 5.0-a	Revision 105
TRM 3.8-10	Revision 50	TRM 5.0-1	Revision 105
TRM 3.8-11	Revision 50	TRM 5.0-2	Revision 105

FERMI 2 - TECHNICAL REQUIREMENTS MANUAL VOL I

LIST OF EFFECTIVE PAGES

<u>Page</u>	<u>Revision</u>	<u>Page</u>	<u>Revision</u>
TRM B1.0-1	Revision 31	TRM B3.6.2-1	Revision 67
TRM B2.0-1	Revision 31	TRM B3.6.3-1	Revision 87
TRM B3.0-1	Revision 63	TRM B3.6.4-1	Revision 31
TRM B3.0-2	Revision 63	TRM B3.6.5-1	Revision 31
TRM B3.0-2a	Revision 72	TRM B3.6.6-1	Revision 70
TRM B3.0-2b	Revision 72	TRM B3.6.7-1	Revision 31
TRM B3.0-2c	Revision 72	TRM B3.6.8-1	Revision 31
TRM B3.0-3	Revision 31	TRM B3.7.1-1	Revision 31
TRM B3.0-4	Revision 31	TRM B3.7.2-1	Revision 107
TRM B3.0-5	Revision 54	TRM B3.7.3-1	Revision 73
TRM B3.0-6	Revision 72	TRM B3.7.4-1	Revision 31
TRM B3.0-7	Revision 72	TRM B3.7.4-2	Revision 31
TRM B3.1-1	Revision 31	TRM B3.7.5-1	Revision 31
TRM B3.2-1	Revision 31	TRM B3.7.6-1	Revision 31
TRM B3.3.1-1	Revision 31	TRM B3.7.7-1	Revision 99
TRM B3.3.1-2	Revision 31	TRM B3.7.8-1	Revision 31
TRM B3.3.2-1	Revision 31	TRM B3.7.9-1	Revision 79
TRM B3.3.2-2	Revision 31	TRM B3.8.1-1	Revision 31
TRM B3.3.3-1	Revision 67	TRM B3.8.2-1	Revision 31
TRM B3.3.4-1	Revision 31	TRM B3.8.3-1	Revision 96
TRM B3.3.4-2	Revision 84	TRM B3.8.4-1	Revision 31
TRM B3.3.5-1	Revision 31	TRM B3.8.5-1	Revision 31
TRM B3.3.5-2	Revision 31	TRM B3.8.6-1	Revision 43
TRM B3.3.6-1	Revision 31	TRM B3.9.1-1	Revision 31
TRM B3.3.6-2	Revision 31	TRM B3.9.2-1	Revision 65
TRM B3.3.6-3	Revision 31	TRM B3.9.3-1	Revision 31
TRM B3.3.6-4	Revision 31	TRM B3.9.4-1	Revision 31
TRM B3.3.6-5	Revision 76	TRM B3.10-1	Revision 31
TRM B3.3.6-6	Revision 76	TRM B3.11.1-1	Revision 31
TRM B3.3.7-1	Revision 31	TRM B3.12.1-1	Revision 31
TRM B3.3.7-2	Revision 31	TRM B3.12.2-1	Revision 44
TRM B3.3.7-3	Revision 106	TRM B3.12.3-1	Revision 31
TRM B3.3.8-1	Revision 31	TRM B3.12.4-1	Revision 31
TRM B3.3.9-1	Revision 31	TRM B3.12.5-1	Revision 31
TRM B3.3.10-1	Revision 56	TRM B3.12.6-1	Revision 31
TRM B3.3.11-1	Revision 45	TRM B3.12.7-1	Revision 31
TRM B3.3.12-1	Revision 62	TRM B3.12.8-1	Revision 31
TRM B3.3.13-1	Revision 31		
TRM B3.3.14-1	Revision 31		
TRM B3.4.1-1	Revision 31		
TRM B3.4.1-2	Revision 71		
TRM B3.4.1-3	Revision 71		
TRM B3.4.1-4	Revision 71		
TRM B3.4.1-5	Revision 71		
TRM B3.4.2-1	Revision 31		
TRM B3.4.3-1	Revision 31		
TRM B3.4.4-1	Revision 31		
TRM B3.4.5-1	Revision 31		
TRM B3.4.6-1	Revision 31		
TRM B3.4.7-1	Revision 31		
TRM B3.5-1	Revision 31		
TRM B3.6.1-1	Revision 31		

FERMI 2 - TECHNICAL REQUIREMENTS MANUAL VOL I

LIST OF EFFECTIVE PAGES

CORE OPERATING LIMITS REPORT

COLR 18, Revision 1

<u>Page</u>	<u>Revision</u>
Notation Page	
1	1
2	1
3	1
4	1
5	1
6	1
7	1
8	1
9	1
10	1
11	1
12	1
13	1
14	1
15	1
16	1
17	1
18	1
19	1
20	1
21	1
22	1
23	1
24	1


FERMI 2

CORE OPERATING LIMITS REPORT

CYCLE 18

REVISION 1


Prepared by:



Paul R. Kiel
Principal Technical Expert, Reactor Engineering

10/23/15
Date


Reviewed by:



Richard Beck Jr.
Senior Engineer, Reactor Engineering

10/27/15
Date

Approved by:



Michael A. Lake
Supervisor, Reactor Engineering

10/27/15
Date

October 2015

TABLE OF CONTENTS

1.0 INTRODUCTION AND SUMMARY	4
2.0 AVERAGE PLANAR LINEAR HEAT GENERATION RATE	5
2.1 Definition	5
2.2 Determination of MAPLHGR Limit	5
2.2.1 Calculation of MAPFAC(P)	7
2.2.2 Calculation of MAPFAC(F)	8
3.0 MINIMUM CRITICAL POWER RATIO	9
3.1 Definition	9
3.2 Determination of Operating Limit MCPR	9
3.3 Calculation of MCPR(P)	11
3.3.1 Calculation of K_p	11
3.3.2 Calculation of τ	13
3.4 Calculation of MCPR(F)	14
4.0 LINEAR HEAT GENERATION RATE	15
4.1 Definition	15
4.2 Determination of LHGR Limit	15
4.2.1 Calculation of LHGRFAC(P)	17
4.2.2 Calculation of LHGRFAC(F)	18
5.0 CONTROL ROD BLOCK INSTRUMENTATION	19
5.1 Definition	19
6.0 BACKUP STABILITY PROTECTION REGIONS	20
6.1 Definition	20
7.0 REFERENCES	23

LIST OF TABLES

TABLE 1	FUEL TYPE-DEPENDENT STANDARD MAPLHGR LIMITS	6
TABLE 2	FLOW-DEPENDENT MAPLHGR LIMIT COEFFICIENTS	8
TABLE 3	OLMCPR _{100/105} AS A FUNCTION OF EXPOSURE AND τ	10
TABLE 4	FLOW-DEPENDENT MCPR LIMIT COEFFICIENTS	14
TABLE 5	STANDARD LHGR LIMITS FOR VARIOUS FUEL TYPES.....	16
TABLE 6	FLOW-DEPENDENT LHGR LIMIT COEFFICIENTS.....	18
TABLE 7	CONTROL ROD BLOCK INSTRUMENTATION SETPOINTS WITH FILTER	19

LIST OF FIGURES

FIGURE 1	BSP REGIONS FOR NOMINAL FEEDWATER TEMPERATURE	21
FIGURE 2	BSP REGIONS FOR REDUCED FEEDWATER TEMPERATURE	22

1.0 INTRODUCTION AND SUMMARY

This report provides the cycle specific plant operating limits, which are listed below, for Fermi 2, Cycle 18, as required by Technical Specification 5.6.5. The analytical methods used to determine these core operating limits are those previously reviewed and approved by the Nuclear Regulatory Commission in GESTAR II (Reference 7).

The cycle specific limits contained within this report are valid for the full range of the licensed operating domain.

<u>OPERATING LIMIT</u>	<u>TECHNICAL SPECIFICATION</u>
APLHGR	3.2.1
MCPR	3.2.2
LHGR	3.2.3
RBM	3.3.2.1
BSP REGIONS	3.3.1.1

APLHGR	=	AVERAGE PLANAR LINEAR HEAT GENERATION RATE
MCPR	=	MINIMUM CRITICAL POWER RATIO
LHGR	=	LINEAR HEAT GENERATION RATE
RBM	=	ROD BLOCK MONITOR
BSP	=	BACKUP STABILITY PROTECTION

2.0 AVERAGE PLANAR LINEAR HEAT GENERATION RATE

2.1 Definition

TECH SPEC IDENT	OPERATING LIMIT
3.2.1	APLHGR

The AVERAGE PLANAR LINEAR HEAT GENERATION RATE (APLHGR) shall be applicable to a specific planar height and is equal to the sum of the LINEAR HEAT GENERATION RATES (LHGRs) for all the fuel rods in the specified bundle at the specified height divided by the number of fuel rods in the fuel bundle at the height.

2.2 Determination of MAPLHGR Limit

The maximum APLHGR (MAPLHGR) limit is a function of reactor power, core flow, fuel type, and average planar exposure. The limit is developed, using NRC approved methodology described in References 7 and 8, to ensure gross cladding failure will not occur following a loss of coolant accident (LOCA). The MAPLHGR limit ensures that the peak clad temperature during a LOCA will not exceed the limits as specified in 10CFR50.46(b)(1) and that the fuel design analysis criteria defined in References 7 and 8 will be met.

The MAPLHGR limit during dual loop operation is calculated by the following equation:

$$MAPLHGR_{LIMIT} = \text{MIN} (MAPLHGR (P), MAPLHGR (F))$$

where:

$$MAPLHGR (P) = MAPFAC (P) \times MAPLHGR_{STD}$$

$$MAPLHGR (F) = MAPFAC (F) \times MAPLHGR_{STD}$$

Within four hours after entering single loop operation, the MAPLHGR limit is calculated by the following equation:

$$MAPLHGR_{LIMIT} = \text{MIN} (MAPLHGR (P), MAPLHGR (F))$$

where:

$$MAPLHGR (P) = MAPFAC (P) \times MAPLHGR_{STD}$$

$$MAPLHGR (F) = MAPFAC (F) \times MAPLHGR_{STD}$$

MAPFAC (P) and MAPFAC (F) are limited to 0.80

The Single Loop multiplier limit is 0.80 (Reference 2) based on assuring a Loss of Coolant Accident (LOCA) while in single loop will be bounded by the two loop LOCA (Reference 12).

MAPLHGR_{STD}, the standard MAPLHGR limit, is defined at a power of 3486 MWth and flow of 105 Mlbs/hr for each fuel type as a function of average planar exposure and is presented in Table 1. (Reference 2) When hand calculations are required, MAPLHGR_{STD} shall be determined by interpolation from Table 1. MAPFAC(P), the core power-dependent MAPLHGR limit adjustment factor, shall be calculated by using Section 2.2.1. MAPFAC(F), the core flow-dependent MAPLHGR limit adjustment factor, shall be calculated by using Section 2.2.2.

TABLE 1
FUEL TYPE-DEPENDENT
STANDARD MAPLHGR LIMITS

GE14 Exposure <u>GWD/ST</u>	GE14 MAPLHGR <u>kW/ft</u>
0.0	12.82
19.13	12.82
57.61	8.00
63.50	5.00

Fuel Types

- | | |
|---|---|
| 2 = GE14-P10CNAB381-4G6/11G5-100T-150-T6-4372 | 14 = GE14-P10CNAB376-4G6/9G5/2G2-100T-150-T6-4061 |
| 3 = GE14-P10CNAB381-4G6/9G5-100T-150-T6-4371 | 15 = GE14-P10CNAB373-7G5/6G4-100T-150-T6-4064 |
| 4 = GE14-P10CNAB381-15G5-100T-150-T6-4373 | 16 = GE14-P10CNAB376-15GZ-100T-150-T6-4063 |
| 5 = GE14-P10CNAB381-6G6/9G5-100T-150-T6-4374 | 17 = GE14-P10CNAB379-14GZ-100T-150-T6-4259 |
| 9 = GE14-P10CNAB380-7G5/8G4-100T-150-T6-3152 | 18 = GE14-P10CNAB381-4G6/11G5-100T-150-T6-4260 |
| 11 = GE14-P10CNAB375-13G5-100T-150-T6-3339 | 19 = GE14-P10CNAB381-4G6/12G5-100T-150-T6-4261 |
| 12 = GE14-P10CNAB376-15G5-100T-150-T6-3340 | 20 = GE14-P10CNAB379-15GZ-100T-150-T6-4262 |
| 13 = GE14-P10CNAB375-14G5-100T-150-T6-3338 | |

2.2.1 Calculation of MAPFAC(P)

The core power-dependent MAPLHGR limit adjustment factor, MAPFAC(P) (Reference 2, 3, 11 & 15), shall be calculated by one of the following equations:

For $0 \leq P < 25$:

No thermal limits monitoring is required.

For $25 \leq P < 29.5$:

With turbine bypass OPERABLE,

For core flow ≤ 50 Mlbs/hr,

$$MAPFAC(P) = 0.604 + 0.0038(P - 29.5)$$

For core flow > 50 Mlbs/hr,

$$MAPFAC(P) = 0.584 + 0.0038(P - 29.5)$$

With turbine bypass INOPERABLE,

For core flow ≤ 50 Mlbs/hr,

$$MAPFAC(P) = 0.488 + 0.0050(P - 29.5)$$

For core flow > 50 Mlbs/hr,

$$MAPFAC(P) = 0.436 + 0.0050(P - 29.5)$$

For $29.5 \leq P \leq 100$:

$$MAPFAC(P) = 1.0 + 0.005234(P - 100)$$

where: P = Core power (fraction of rated power times 100).

Note: This range applies with pressure regulator in service and, for power $>85\%$, it also applies with the pressure regulator out of service

MAPFAC(P) for Pressure Regulator Out of Service Limits

With one Turbine Pressure Regulator Out of Service and Reactor Power Greater Than or Equal to 29.5% and Less Than or Equal to 85% and both Turbine Bypass and Moisture Separator Reheater Operable:

For $29.5 \leq P < 45$:

$$MAPFAC(P) = 0.680 + 0.00627(P - 45)$$

For $45 \leq P < 60$:

$$MAPFAC(P) = 0.758 + 0.0052(P - 60)$$

For $60 \leq P \leq 85$:

$$MAPFAC(P) = 0.831 + 0.00292(P - 85)$$

where: P = Core power (fraction of rated power times 100).

2.2.2 Calculation of MAPFAC(F)

The core flow-dependent MAPLHGR limit adjustment factor, MAPFAC(F) (Reference 2 & 3), shall be calculated by the following equation:

$$MAPFAC(F) = \text{MIN}(C, A_F \times \frac{WT}{100} + B_F)$$

where:

- WT = Core flow (Mlbs/hr).
- A_F = Given in Table 2.
- B_F = Given in Table 2.
- C = 1.0 in Dual Loop and 0.80 in Single Loop.

TABLE 2 FLOW-DEPENDENT MAPLHGR LIMIT COEFFICIENTS

Maximum Core Flow* (Mlbs/hr)	A _F	B _F
110	0.6787	0.4358

* As limited by the Recirculation System MG Set mechanical scoop tube stop setting.

3.0 MINIMUM CRITICAL POWER RATIO

TECH SPEC IDENT	OPERATING LIMIT
3.2.2	MCPR

3.1 Definition

The MINIMUM CRITICAL POWER RATIO (MCPR) shall be the smallest Critical Power Ratio (CPR) that exists in the core for each type of fuel. The CPR is that power in the assembly that is calculated by application of the appropriate correlation(s) to cause some point in the assembly to experience boiling transition, divided by the actual assembly operating power.

3.2 Determination of Operating Limit MCPR

The required Operating Limit MCPR (OLMCPR) (Reference 2) at steady-state rated power and flow operating conditions is derived from the established fuel cladding integrity Safety Limit MCPR and an analysis of abnormal operational transients. To ensure that the Safety Limit MCPR is not exceeded during any anticipated abnormal operational transient, the most limiting transients have been analyzed to determine which event will cause the largest reduction in CPR. Three different core average exposure conditions are evaluated. The result is an Operating Limit MCPR which is a function of exposure and τ . τ is a measure of scram speed, and is defined in Section 3.3.2. Cycle 18 operating limits are based on the Dual Loop SLMCPR of 1.08.

The OLMCPR shall be calculated by the following equation:

$$OLMCPR = \text{MAX}(MCPR(P), MCPR(F))$$

MCPR(P), the core power-dependent MCPR operating limit, shall be calculated using Section 3.3.

MCPR(F), the core flow-dependent MCPR operating limit, shall be calculated using Section 3.4.

In case of **Single Loop Operation**, the Safety Limit MCPR (Reference 2) is increased to account for increased uncertainties in core flow measurement and TIP measurement. However, OLMCPR is not increased when operating in single loop due to inherent conservatism.

In case of operation with one Turbine Pressure Regulator out of service, OLMCPR limits are bounding when reactor power is less than 29.5% or greater than 85%. When reactor power is greater than or equal to 29.5% and less than or equal to 85%, then operation with one Turbine Pressure Regulator out of service is permitted if both Turbine Bypass Valves and the Moisture Separator Reheater are operable. (Reference 2 and 11)

TABLE 3 OLMCPR_{100/105} AS A FUNCTION OF EXPOSURE AND τ
(Reference 2 and 11)

<u>CONDITION</u>	<u>EXPOSURE</u> <u>(MWD/ST)</u>		OLMCPR_{100/105}		
			Two Loop	Single Loop	
BOTH Turbine Bypass Valves AND Moisture Separator Reheater OPERABLE	BOC to 8000	$\tau = 0$	1.30	1.30	
		$\tau = 1$	1.44	1.44	
	8000 to EOC	$\tau = 0$	1.33	1.33	
		$\tau = 1$	1.50	1.50	
	ONE Turbine Pressure Regulator Out of Service AND Reactor Power between 29.5% and 85% AND BOTH Turbine Bypass Valves and Moisture Separator Reheater Operable	BOC to EOC	$\tau = 0$	1.33	1.33
			$\tau = 1$	1.50	1.50
Moisture Separator Reheater INOPERABLE		BOC to EOC	$\tau = 0$	1.41	1.41
			$\tau = 1$	1.58	1.58
Turbine Bypass Valve INOPERABLE	BOC to EOC	$\tau = 0$	1.39	1.39	
		$\tau = 1$	1.56	1.56	
BOTH Turbine Bypass Valve AND Moisture Separator Reheater INOPERABLE	BOC to EOC	$\tau = 0$	1.45	1.45	
		$\tau = 1$	1.62	1.62	

3.3 Calculation of MCPR(P)

MCPR(P), the core power-dependent MCPR operating limit (Reference 2, 3, 11, & 15), shall be calculated by the following equation:

$$MCPR(P) = K_P \times OLMCPR_{100/105}$$

K_P , the core power-dependent MCPR Operating Limit adjustment factor, shall be calculated by using Section 3.3.1.

$OLMCPR_{100/105}$ shall be determined by interpolation on τ from Table 3 (Reference 2), and τ shall be calculated by using Section 3.3.2.

3.3.1 Calculation of K_P

The core power-dependent MCPR operating limit adjustment factor, K_P (Reference 2, 3, 11, & 15), shall be calculated by using one of the following equations:

Note: P = Core power (fraction of rated power times 100) for all calculation of K_P

For $0 \leq P < 25$:

No thermal limits monitoring is required.

For $25 \leq P < 29.5$:

When turbine bypass is OPERABLE,

$$K_P = \frac{(K_{BYP} + (0.032 \times (29.5 - P)))}{OLMCPR_{100/105}}$$

where: $K_{BYP} = 2.18$ for core flow ≤ 50 Milbs/hr
 $= 2.46$ for core flow > 50 Milbs/hr

When turbine bypass is INOPERABLE,

$$K_P = \frac{(K_{BYP} + (0.076 \times (29.5 - P)))}{OLMCPR_{100/105}}$$

where: $K_{BYP} = 2.65$ for core flow ≤ 50 Milbs/hr
 $= 3.38$ for core flow > 50 Milbs/hr

For $29.5 \leq P < 45$:

$$K_p = 1.28 + (0.0134 \times (45 - P))$$

For $45 \leq P < 60$:

$$K_p = 1.15 + (0.00867 \times (60 - P))$$

K_p for Moisture Separator Reheater Operable and Turbine Bypass Valves Operable or Inoperable

For $60 \leq P < 85$:

$$K_p = 1.065 + (0.0034 \times (85 - P))$$

For $85 \leq P \leq 100$:

$$K_p = 1.0 + (0.004333 \times (100 - P))$$

K_p for Moisture Separator Reheater Inoperable and Turbine Bypass Valves Operable or Inoperable

For $60 \leq P < 85$:

$$K_p = 1.076 + (0.00296 \times (85 - P))$$

For $85 \leq P \leq 100$:

$$K_p = 1.0 + (0.00507 \times (100 - P))$$

K_p for Pressure Regulator Out of Service Limits

With one Turbine Pressure Regulator Out of Service, Reactor Power greater than 29.5%, and both Turbine Bypass and Moisture Separator Reheater Operable:

For $29.5 \leq P < 45$:

$$K_p = 1.52 + (0.01193 \times (45 - P))$$

For $45 \leq P < 60$:

$$K_p = 1.362 + (0.01053 \times (60 - P))$$

For $60 \leq P \leq 85$:

$$K_p = 1.217 + (0.0058 \times (85 - P))$$

For $85 \leq P \leq 100$:

For Reactor Power $> 85\%$, the Pressure Regulator Out of Service condition is not limiting (Reference 11). Calculate K_p using the applicable equations above based on Moisture Separator Reheater and Turbine Bypass Valve operability.

3.3.2 Calculation of τ

The value of τ , which is a measure of the conformance of the actual control rod scram times to the assumed average control rod scram time in the reload licensing analysis (References 4 & 24), shall be calculated by using the following equation:

$$\tau = \frac{(\tau_{ave} - \tau_B)}{\tau_A - \tau_B}$$

where: $\tau_A = 1.096$ seconds

$$\tau_B = 0.830 + 0.019 \times 1.65 \sqrt{\frac{N_1}{\sum_{i=1}^n N_i}} \text{ seconds}$$

$$\tau_{ave} = \frac{\sum_{i=1}^n N_i \tau_i}{\sum_{i=1}^n N_i}$$

n = number of surveillance tests performed to date in cycle,

N_i = number of active control rods measured in the i^{th} surveillance test,

τ_i = average scram time to notch 36 of all rods measured in the i^{th} surveillance test, and

N_1 = total number of active rods measured in the initial control rod scram time test for the cycle (Technical Specification Surveillance Requirement 3.1.4.4).

The value of τ shall be calculated and used to determine the applicable OLMCPR_{100/105} value from Table 3 within 72 hours of the conclusion of each control rod scram time surveillance test required by Technical Specification Surveillance Requirements 3.1.4.1, 3.1.4.2, and 3.1.4.4.

3.4 Calculation of MCPR(F)

MCPR(F), the core flow-dependent MCPR operating limit (Reference 2 & 3), shall be calculated by using the following equation:

$$MCPR(F) = \text{MAX}(1.21, (A_F \times \frac{WT}{100} + B_F))$$

where:

- WT = Core flow (Mlbs/hr).
- A_F = Given in Table 4.
- B_F = Given in Table 4.

TABLE 4 FLOW-DEPENDENT MCPR LIMIT COEFFICIENTS

	Maximum Core Flow* (Mlbs/hr)	A _F	B _F
Single or Two Loop	110	-0.601	1.743

* As limited by the Recirculation System MG Set mechanical scoop tube stop setting.

4.0 LINEAR HEAT GENERATION RATE

TECH SPEC IDENT	OPERATING LIMIT
3.2.3	LHGR

4.1 Definition

The LINEAR HEAT GENERATION RATE (LHGR) shall be the heat generation rate per unit length of fuel rod. It is the integral of the heat flux over the heat transfer area associated with the unit length. By maintaining the operating LHGR below the applicable LHGR limit, it is assured that all thermal-mechanical design bases and licensing limits for the fuel will be satisfied.

4.2 Determination of LHGR Limit

The maximum LHGR limit is a function of reactor power, core flow, fuel and rod type, and fuel rod nodal exposure. The limit is developed, using NRC approved methodology described in References 7 and 8, to ensure the cladding will not exceed its yield stress and that fuel thermal-mechanical design criteria will not be violated during any postulated transient events. The LHGR limit ensures the fuel mechanical design requirements as defined in References 1 & 21 will be met.

The LHGR limit during dual loop operation is calculated by the following equation:

$$LHGR_{LIMIT} = \text{MIN} (LHGR (P), LHGR (F))$$

where:

$$LHGR (P) = LHGRFAC (P) \times LHGR_{STD}$$

$$LHGR (F) = LHGRFAC (F) \times LHGR_{STD}$$

Within four hours after entering single loop operation, the LHGR limit is calculated by the following equation:

$$LHGR_{LIMIT} = \text{MIN} (LHGR (P), LHGR (F))$$

where:

$$LHGR (P) = LHGRFAC (P) \times LHGR_{STD}$$

$$LHGR (F) = LHGRFAC (F) \times LHGR_{STD}$$

LHGRFAC (P) and LHGRFAC (F) are limited to 0.80

The Single Loop multiplier limit is 0.80 (Reference 2) based on assuring a LOCA in single loop will be bounded by the two loop LOCA (Reference 12).

LHGR_{STD}, the standard LHGR limit, is defined at a power of 3486 MWth and flow of 105 Mlbs/hr for each fuel and rod type as a function of fuel rod nodal exposure and found in the Table 5 reference. When hand calculations are required, LHGR_{STD} shall be determined by interpolation from the Table 5 reference. LHGRFAC(P), the core power-dependent LHGR limit adjustment factor, shall be calculated by using Section 4.2.1. LHGRFAC(F), the core flow-dependent LHGR limit adjustment factor, shall be calculated by using Section 4.2.2.

TABLE 5
STANDARD LHGR LIMITS FOR VARIOUS FUEL TYPES

For GE14 fuel listed below, the most limiting LHGR for Uranium Only fuel rod is found in NEDC-32868P Revision 5 Table D-2 (References 1 & 21).

For GE14 fuel listed below, the most limiting LHGR for Gadolinia Bearing fuel rods is found in NEDC-32868P Revision 5 Table D-4 (References 1 & 21). Utilize the row for 6% Rod/Section wt-% Gd₂O₃

Fuel Types	
2 = GE14-P10CNAB381-4G6/11G5-100T-150-T6-4372	14 = GE14-P10CNAB376-4G6/9G5/2G2-100T-150-T6-4061
3 = GE14-P10CNAB381-4G6/9G5-100T-150-T6-4371	15 = GE14-P10CNAB373-7G5/6G4-100T-150-T6-4064
4 = GE14-P10CNAB381-15G5-100T-150-T6-4373	16 = GE14-P10CNAB376-15GZ-100T-150-T6-4063
5 = GE14-P10CNAB381-6G6/9G5-100T-150-T6-4374	17 = GE14-P10CNAB379-14GZ-100T-150-T6-4259
9 = GE14-P10CNAB380-7G5/8G4-100T-150-T6-3152	18 = GE14-P10CNAB381-4G6/11G5-100T-150-T6-4260
11 = GE14-P10CNAB375-13G5-100T-150-T6-3339	19 = GE14-P10CNAB381-4G6/12G5-100T-150-T6-4261
12 = GE14-P10CNAB376-15G5-100T-150-T6-3340	20 = GE14-P10CNAB379-15GZ-100T-150-T6-4262
13 = GE14-P10CNAB375-14G5-100T-150-T6-3338	

4.2.1 Calculation of LHGRFAC(P)

The core power-dependent LHGR limit adjustment factor, LHGRFAC(P) (Reference 2, 3, 11, & 15), shall be calculated by one of the following equations:

For $0 \leq P < 25$:

No thermal limits monitoring is required.

For $25 \leq P < 29.5$:

With turbine bypass OPERABLE,

For core flow ≤ 50 Mlbs/hr,

$$LHGRFAC(P) = 0.604 + 0.0038(P - 29.5)$$

For core flow > 50 Mlbs/hr,

$$LHGRFAC(P) = 0.584 + 0.0038(P - 29.5)$$

With turbine bypass INOPERABLE,

For core flow ≤ 50 Mlbs/hr,

$$LHGRFAC(P) = 0.488 + 0.0050(P - 29.5)$$

For core flow > 50 Mlbs/hr,

$$LHGRFAC(P) = 0.436 + 0.0050(P - 29.5)$$

For $29.5 \leq P \leq 100$:

$$LHGRFAC(P) = 1.0 + 0.005234(P - 100)$$

where: P = Core power (fraction of rated power times 100).

Note: This range applies with pressure regulator in service and, for power $>85\%$, it also applies with the pressure regulator out of service

LHGRFAC(P) for Pressure Regulator Out of Service Limits

With one Turbine Pressure Regulator Out of Service and Reactor Power Greater Than or Equal to 29.5% and Less Than or Equal to 85% and both Turbine Bypass and Moisture Separator Reheater Operable:

For $29.5 \leq P < 45$:

$$LHGRFAC(P) = 0.680 + 0.00627(P - 45)$$

For $45 \leq P < 60$:

$$LHGRFAC(P) = 0.758 + 0.0052(P - 60)$$

For $60 \leq P \leq 85$:

$$LHGRFAC(P) = 0.831 + 0.00292(P - 85)$$

where: P = Core power (fraction of rated power times 100).

4.2.2 Calculation of LHGRFAC(F)

The core flow-dependent LHGR limit adjustment factor, LHGRFAC(F) (Reference 2 & 3), shall be calculated by the following equation:

$$LHGRFAC(F) = \text{MIN}(C, A_F \times \frac{WT}{100} + B_F)$$

where:

- WT = Core flow (Mlbs/hr).
- A_F = Given in Table 6.
- B_F = Given in Table 6.
- C = 1.0 in Dual Loop and 0.80 in Single Loop.

TABLE 6 FLOW-DEPENDENT LHGR LIMIT COEFFICIENTS

Maximum Core Flow* (Mlbs/hr)	A _F	B _F
110	0.6787	0.4358

* As limited by the Recirculation System MG Set mechanical scoop tube stop setting.

5.0 CONTROL ROD BLOCK INSTRUMENTATION

TECH SPEC IDENT	SETPOINT
3.3.2.1	RBM

5.1 Definition

The nominal trip setpoints and allowable values of the control rod withdrawal block instrumentation are shown in Table 7. These values are consistent with the bases of the APRM Rod Block Technical Specification Improvement Program (ARTS) and the MCPR operating limits. (References 2, 5, & 10).

TABLE 7 CONTROL ROD BLOCK INSTRUMENTATION SETPOINTS WITH FILTER

Setpoint	Trip Setpoint	Allowable Value
LPSP	27.0	28.4
IPSP	62.0	63.4
HPSP	82.0	83.4
LTSP	117.0	118.9
ITSP	112.2	114.1
HTSP	107.2	109.1
DTSP	94.0	92.3

Where:

LPSP	Low power setpoint; Rod Block Monitor (RBM) System trip automatically bypassed below this level
IPSP	Intermediate power setpoint
HPSP	High power setpoint
LTSP	Low trip setpoint
ITSP	Intermediate trip setpoint
HTSP	High trip setpoint
DTSP	Downscale trip setpoint

6.0 BACKUP STABILITY PROTECTION REGIONS


TECH SPEC REFERENCE 3.3.1.1 Action Condition J	OPERATING LIMIT Alternate method to detect and suppress thermal hydraulic instability oscillations
TRM REFERENCE 3.4.1.1	OPERATING LIMIT Scram, Exit, and Stability Awareness Regions

6.1 Definition


The Backup Stability Protection (BSP) Regions are an integral part of the Tech Spec required alternative method to detect and suppress thermal hydraulic instability oscillations in that they identify areas of the power/flow map where there is an increased probability that the reactor core could experience a thermal hydraulic instability. The BSP Regions are required if the Oscillation Power Range Monitors are inoperable. Regions are identified (refer to Figures 1 and 2) that are either excluded from planned entry (Scram Region), or where specific actions are required to be taken to immediately leave the region (Exit Region). A region is also identified where operation is allowed provided that additional monitoring is performed to verify that the reactor core is not exhibiting signs of core thermal hydraulic instability (Stability Awareness Region). (Reference 2)

The boundaries of these regions are established on a cycle specific basis based upon core decay ratio calculations performed using NRC approved methodology. The Cycle 18 regions are valid to a cycle exposure of 11,127 MWD/ST (Reference 22).

The Cycle 18 BSP boundaries defined in Figure 1 are applicable when final feedwater temperature is near the optimum range as illustrated in 20.107.02, Loss of Feedwater Heating Abnormal Operating Instruction. Figure 2 is applicable to operation with Feedwater Heaters Out-Of-Service (FWHOOS) or with Final Feedwater Temperature Reduction (FFWTR) or when final feedwater temperature is below the optimum range.



Nominal feedwater heating exists with all feedwater heaters in service, the moisture separator reheaters in service, and reactor water cleanup in or out of service. Nominal Feedwater temperature is determined with the Loss of Feedwater Heating Abnormal Operating Procedure, 20.107.02. If feedwater temperature is less than 15 degrees Fahrenheit below the Optimum Line of the Feedwater Inlet Temperature vs. Reactor Power graph of Enclosure A of 20.107.02, Loss of Feedwater Heating, then Figure 1 can be used.



Reduced feedwater temperature is analyzed for a 50 degree Fahrenheit reduction in feedwater temperature. If feedwater temperature is more than 15 degrees Fahrenheit below the Optimum Line of the Feedwater Inlet Temperature vs. Reactor Power graph of Enclosure A of 20.107.02, Loss of Feedwater Heating, then Figure 2 can be used.

7.0 REFERENCES

Core Operating Limits Report references are cited for two purposes. Many references are used as the basis for information, numbers, and equations found in COLR. These references tend to be fuel type or cycle specific. Other references are listed as basis information for the content and structure of COLR but are not Cycle specific.

1. "Fuel Bundle Information Report for Enrico Fermi 2 Reload 17 Cycle 18," DRF: 001N4128, Revision 0, July 2015 (LHGR Limits), DTC:TRVEND, DSN: Cycle 18 FBIR
2. "Supplemental Reload Licensing Report for Enrico Fermi 2 Reload 17 Cycle 18," Global Nuclear Fuel, DRF: 001N4127, Revision 0, July 2015 (MAPLHGR Limits, SLO Multiplier, MCPR Limits, SLMCPR, Off-Rated Limits, Backup Stability Regions, OPRM setpoints, RBM setpoint), DTC:TRVEND, DSN: Cycle 18 SRLR
3. "GE14 Fuel Cycle-Independent Analyses for Fermi Unit 2", GE-NE-0000-0025-3282-00 dated November 2004 (ARTS Limits equations, RR Pump Seizure)
4. Letter from Greg Porter to B. L. Myers, "Scram Times for Improved Tech Specs." GP-99014, October 22, 1999 containing DRF A12-00038-3, Vol. 4 information from G. A. Watford, GE, to Distribution, Subject: Scram Times versus Notch Position (TAU Calculation), Edison File No. R1-7242
5. NUMAC Power Range Neutron Monitoring System (PRNM) Surveillance Validation, Design Calculation DC-4608 Volume 1, Revision G (RBM A and B Setpoints), DTC: TDPINC, DSN: DC-4608 VOL I
6. Detroit Edison Fermi-2 Thermal Power Optimization Task T0201: Operating Power/Flow Map, Edison File No. T13-050, (P-F Map for BSP figures)
7. "General Electric Standard Application for Reactor Fuel (GESTAR II)," NEDE-24011-P-A, Revision 21 with amendments
8. "The GESTR-LOCA and SAFER Models for the Evaluation of the Loss-of-Coolant Accident - SAFER/GESTR Application Methodology," NEDE 23785-1-PA, Revision 1, October 1984
9. "Fermi-2 SAFER/GESTR-LOCA, Loss-of-Coolant Accident Analysis," NEDC-31982P, July 1991, and Errata and Addenda No. 1, April 1992
10. "Maximum Extended Operating Domain Analysis for Detroit Edison Company Enrico Fermi Energy Center Unit 2," GE Nuclear Energy, NEDC-31843P, July 1990

11. Fermi 2 Pressure Regulator Out of Service Evaluation – Verified Final Report, Letter 1-2LHRMS-4 dated February 10, 2011. DTC:TRVEND, DSN: 1-2LHRMS-4 Edison File Number: R1-8100 (PROOS Limits)
12. “DTE Energy Enrico Fermi 2 SAFER/PRIME-LOCA Loss of Coolant Accident Analysis” DRF: 000N1319-R0 dated March 2015
13. Letter from T. G. Colburn to W. S. Orser, “Fermi-2 - Amendment No. 87 to Facility Operating License No. NPF-43 (TAC NO. M82102),” September 9, 1992
14. Letter from J. F. Stang to W. S. Orser, “Amendment No. 53 to Facility Operating License No. NPF-43: (TAC No. 69074),” July 27, 1990
15. “Fermi 2 TRACG Implementation for Reload Licensing Transient Analysis”, Revision 1, 0000-0128-8831-R1, June 2014, Edison File No. R1-8124.
16. Methodology and Uncertainties for Safety Limit MCPR Evaluations, NEDC-32601P-A, August 1999
17. Power Distribution Uncertainties for Safety Limit MCPR Evaluation, NEDC-32694P-A, August 1999
18. R-Factor Calculation Method for GE11, GE12, and GE13 Fuel, NEDC-32505P-A, Revision 1, July 1999
19. “Turbine Control Valve Out-Of-Service for Enrico Fermi Unit-2,” GE – Nuclear Energy, GE-NE-J11-03920-07-01, October 2001
20. Letter from David P. Beaulieu (USNRC) to William T. O’Connor, Jr. (Detroit Edison), “Fermi-2 - Issuance of Amendment RE: Changes to the Safety Limit Minimum Critical Power Ratio (TAC NO. MC4748),” dated November 30, 2004 (SLMCPR Limit)
21. “GE14 Compliance with Amendment 22 of NEDE-24011-P-A (GESTAR II)”, NEDC-32868P, Revision 5, May 2013 (LHGR Limits), Edison File No: R1-7307
22. Cycle 18 Stability Information, DTC: TRVEND DSN: Cycle 18 Stability, Edison File No: R1-8355 (Stability Limiting Exposure)
23. “Fermi 2 – Issuance of Amendment Re: Measurement Uncertainty Recapture Power Uprate (TAC No. MF0650)” Letter from Thomas Wengert, NRC, to Joseph Plona, DTE Electric dated February 10, 2014.
24. Qualification of the One-Dimensional Core Transient Model for Boiling Water Reactors – Volume 1, NEDO-24154-A, August 1986, Edison File No. R1-7389.