NRCDISTRIBUTION FOR PART 50 DOCKET MATERIAL (TEMPORARY FORM) 4298 CONTROL NO:___ FILE: FROM: Duke Power Company DATE OF DOC DATE REC'D TWX RPT. OTHER LTR Charlotte, N.C. 28201 4-16-75 4-19-75 XX A.C. Thies XX OTHER ORIG SENT AEC PDR_ CC TO: ΧХ SENT LOCAL PDR 1 signed Mr. R.A. Purple INPUT NO CYS REC'D DOCKET NO: CLASS UNCLASS **PROP INFO** 50-269 2707287 XXX 1 ENCLOSURES: DESCRIPTION: Ltr re our 4-3-75 ltr.... Surveillance Items Required furnishing addl info re definition of refueling During Refueling Outage period for Oconee Tech Specs...trans the following: (1 cy encl rec'd) at with a set year in PLANT NAME: Oconee Units 1-2-3 FOR ACTION/INFORMATION DHL 4-23-75 ZIEMANN (L) REGAN (E) SCHWENCER (L) BUTLER (L) W/ Copies W/ Copies W/ Copies W/ Copies DICKER (E) LEAR (L) STOLZ (L) CLARK (L) W/ Copies W/ Copies W/ Copies W/ Copies KNIGHTON (E) eurie -MASSALLO (L) PARRIEL W/ Copies W/ Copies W/ Copies W/ Copies MPURPLE (L) YOUNGBLOOD (E) LPM KNIEL (L) W/ Copies W/Copies W/ Copies W/ Copies INTERNAL DISTRIBUTION. A/T IND DENTON LIC ASST TECH REVIEW

REG FILE BRAITMAN SCHROEDER **GRIMES** R. DIGGS (L) SALTZMAN ♦ OGC, ROOM P-506A GAMMILL MACCARY H. GEARIN (L) GOSSICK/STAFF E, GOULBOURNE (L) MELTZ KASTNER KNIGHT CASE PAWLICKI BALLARD P. KREUTZER (E) PLANS SPANGLER J. LEE (L) **GIAMBUSSO** SHAO MCDONALD STELLO M. MAIGRET (L) BOYD CHAPMAN. **ENVIRO** HOUSTON S. REED (E) MOORE (L) DUBE (Ltr) MULLER DÉYOUNG (L) NOVAK M. SERVICE (L) ✓E. COUPE SKOVHOLT (L) ROSS DICKER **US. SHEPPARD (L)** PETERSON **IPPOLITO KNIGHTON** GOLLER (L) (Ltr) M. SLATER (E) HARTFIELD (2) YOUNGBLOOD P. COLLINS TEDESCO H. SMITH (L) KLECKER. DENISE REGAN S. TEETS (L) J. COLLINS PROJECT LDR EISENHUT REG OPR LAINAS G. WILLIAMS (E) WIGGINTON FILE & REGION (2) V. WILSON (L) BENAROYA HARLESS VOLLMER R. INGRAM (L) STEELE EXTERNAL DISTRIBUTION ♥1 - LOCAL PDR Walhalla, S.C. 1 - PDR-SAN/LA/NY✓1 - TIC (ABERNATHY) (1)(2)(10) - NATIONAL LABS ____ 1 – BROOKHAVEN NAT LAB M – NSIC (BUCHANAN) 1 - W. PENNINGTON, Rm E-201 GT 1 - G. ULRIKSON, OBNE 1 - ASLB1 - CONSULTANTS 1 - AGMED (RUTH GUSSMAN) 1- Newton Anderson NEWMARK/BLUME/AGB. 14- ACRS HELBING/SENT TO LA SHEPPARD 4.23-25 NEWMARK/BLUME/AGBABIAN Rm B-127 GT

- 1 J. D. RUNKLES, Rm E-201
- and Som GT

DUKE POWER COMPANY

POWER BUILDING

422 SOUTH CHURCH STREET, CHARLOTTE, N. C. 28201

A. C. THIES SENIOR VICE PRESIDENT PRODUCTION AND TRANSMISSION

April 16, 1975

Regulatory Docket File

Mr. R. A. Purple, ChiefOperating Reactors Branch 1Division of Reactor LicensingU. S. Nuclear Regulatory CommissionWashington, D. C. 20555

Re: Oconee Nuclear Station Docket Nos. 50-269, -270-287

P. O. Box 2178

4200

Dear Mr. Purple:

Your letter of April 3, 1975 requested additional information necessary to complete your review of my March 12, 1975 request to delete the definition of refueling period (Section 1.2.8) for Oconee Nuclear Station Technical Specifications. Attached is the listing of all Oconee Nuclear Station surveillance requirements which are specified for performance prior to, during, or after a refueling shutdown with an explanation of why they can only be/or should be performed at this time.

The one-hour discharge test of the 125 volt DC batteries required by Technical Specification 4.6.6.c, currently required during a refueling outage, does not require a refueling outage for its completion. A change to Oconee Nuclear Station Technical Specifications is hereby requested which will make this an annual surveillance item.

Very truly yours,

A. C. Thies

ACT:vr

Attachment



SILLE FILE

SURVEILLANCE ITEMS REQUIRED DURING REFUELING OUTAGE

Technical Specification 4.1.2

1. Functional Tests and Refueling System Interlocks

2. Functional Test of Spent Fuel Cooling System

RESPONSE

These two items are scheduled prior to refueling. The intention is to test these systems immediately prior to their use.

Technical Specification 4.6.3

During each refueling outage for the affected unit, a simulated emergency transfer from the 4160 volt main feeder buses to the startup transformer (i.e., CT1, CT2, or CT3) to the 4160 volt standby buses shall be made to verify proper operation.

RESPONSE

The performance of this test requires a complete unit blackout for approximately four hours. Therefore, in order to ensure adequate decay heat removal, the test must be performed at the end of a refueling interval when decay heat generation is a minimum. During the test, the reactor vessel head is removed and the fuel transfer canal is filled to provide heat transfer. It is concluded that this test is not feasible at times other than a refueling outage.

Technical Specification 4.7.1

The control rod trip insertion time shall be measured for each control rod at either full flow or no flow conditions following each refueling outage prior to return to power.

RESPONSE

This test is performed following refueling to assure the proper installation of control rods after the installation of the reactor vessel head.