

**AEC DISTRIBUTION FOR PART 50 DOCKET MATERIAL
(TEMPORARY FORM)**

CONTROL NO: 8145

FILE:

FROM: Duke Power Company Charlotte, NC A. C. Thies		DATE OF DOC 8-5-74	DATE REC'D 8-7-74	LTR X	TWX	RPT	OTHER
TO: L. Manning Muntzing		ORIG	CC 40	OTHER	SENT AEC PDR XXXX SENT LOCAL PDR XXXX		
CLASS	UNCLASS XXXX	PROP INFO	INPUT XXX	NO CYS REC'D 40	DOCKET NO: 50-260/270/287		

DESCRIPTION:

Ltr notarized 8-5-74 submitting Appendix "K" Calculations & proposed Change to Tech Specs re 10CFR50, Appendix "K".....

** Denotes Letter Only

PLANT NAME: OCONEE UNITS 1, 2 & 3

ENCLOSURES: **ACKNOWLEDGED**

Amendment to the OL consisting of:

- 1) Loss of Coolant Accident Analysis conformance with 10CFR50.46, Appendix "K"
- 2) Proposed Change to tech specs...

DO NOT REMOVE

(40 cys encl rec'd)

FOR ACTION/INFORMATION 8-7-74 GMC

BUTLER (L) W/ CYS	SCHWENCER (L) W/ CYS	ZIEMANN (L) W/ CYS	REGAN (E) W/ CYS
CLARK (L) W/ CYS	STOLZ (L) W/ CYS	DICKER (E) W/ CYS	W/ CYS
PARR (L) W/ CYS	VASSALLO (L) W/ CYS	KNECHTON (E) W/ CYS	W/ CYS
KNIEL (L) W/ CYS	PURPLE (L) W/9 CYS	YOUNGBLOOD (E) W/ CYS	W/ CYS

INTERNAL DISTRIBUTION

REG FILE + 2 Ltrs	TECH REVIEW	DENTON	LIC ASST	A/T IND
AEC PDR + 2 Ltrs	HENDRIE	GRIMES	DIGGS (L)	BRAITMAN
OGC	SCHROEDER	GAMMILL	GEARIN (L)	SALTZMAN
MUNTZING/STAFF	MACCARY	KASTNER	GOULBOURNE (L)	B. HURT
CASE	KNIGHT	BALLARD	KREUTZER (E)	
GIAMBUSO	PAWLICKI	SPANGLER	LEE (L)	PLANS
BOYD	SHAO		MAIGRET (L)	MCDONALD
MOORE (L)(LWR-2)	STELLO(2)	ENVIRO	REED (E)	CHAPMAN
DEYOUNG (L)(LWR-1)	HOUSTON	MULLER	SERVICE (L)	**DUBE w/input
SKOVHOLT (L)	NOVAK	DICKER	**SHEPPARD (L)	**E. COUPE
GOLLER (L)	ROSS	KNIGHTON	SLATER (E)	
P. COLLINS	IPPOLITO	YOUNGBLOOD	SMITH (L)	D. THOMPSON (2)
DENISE	TEDESCO	REGAN	TEETS (L)	KLECKER
REG OPR	LONG	PROJECT MGR	WILLIAMS (E)	EISENHUT
FILE & REGION (2)	LAINAS	SCALETTI	WILSON (L)	
MORRIS	BENAROYA	HARLESS		VARGA
STEELE	VOLLMER			

EXTERNAL DISTRIBUTION

1 - LOCAL PDR WALHALLA, SC	(1)(2)(10) - NATIONAL LABS	1 - PDR-SAN/LA/NY
1 - TIC (ABERNATHY)	1-ASLBP(E/W Bldg, Rm 529)	1-BROOKHAVEN NAT LAB
1 - NSIC (BUCHANAN)	1-W. PENNINGTON, Rm E-201 GT	1-G. ULRIKSON, ORNL
1 - ASLB	1-B&M SWINEBROAD, Rm E-201 GT	1-AGMED (RUTH GUSMAN)
1 - P. R. DAVIS	1-CONSULTANTS	Rm B-127 GT
16 - ACRS HOLDING	NEWARK/BLUME/AGBABIAN	1-RD..MUELLER, Rm F-309
SENT TO LIC ASST SHEPPARD 8-7-74		GT

DUKE POWER COMPANY
POWER BUILDING
422 SOUTH CHURCH STREET, CHARLOTTE, N. C. 28201

A. C. THIES
SENIOR VICE PRESIDENT
PRODUCTION AND TRANSMISSION

REGULATORY DOCKET FILE COPY P. O. Box 2178

August 5, 1974

Mr. L. Manning Muntzing
Director of Regulation
U. S. Atomic Energy Commission
Washington, D. C. 20545


Re: Oconee Nuclear Station
Docket Nos. 50-269, -270, -287

Dear Mr. Muntzing:

On January 4, 1974 the AEC issued the Final Acceptance Criteria (FAC) for Emergency Core Cooling System (ECCS) evaluation as revisions to 10 CFR 50. In Compliance with these revisions, Babcock & Wilcox has developed an evaluation model which meets the requirements of Appendix K of 10 CFR 50. The description of this model is contained within their non-proprietary topical report BAW-10091, "B&W's ECCS Evaluation Model Report with Specific Application to 177 FA Class Plants with Lowered Loop Arrangement," which has been submitted to the Directorate of Licensing on August 5, 1974. In addition, B&W has provided supporting documentation for the computer codes utilized in this model in the following non-proprietary topical reports:

1. BAW-10092, "CRAFT 2- Fortran Program for Digital Simulation of a Multinode Reactor Plant During Loss of Coolant."
2. BAW-10093, "REFLOOD - Description of Model for Multinode Core Reflood Analysis."
3. BAW-10094, Babcock & Wilcox Revisions to THETAL-B, a Computer Code for Nuclear Reactor Core Thermal Analysis - IN-1445.
4. BAW-10095, Babcock & Wilcox Revisions to CONTEMPT - Computer Program for Predicting Containment Pressure - Temperature Response to a Loss-of-Coolant Accident.

The analysis presented in BAW-10091 for the B&W 177 FA plants with lowered loop is generic in nature, since the plant parameters utilized in the analysis (such as the rated power level, fuel densification and containment building volume) are taken to be the most conservative values for all the plants of this type. Thus, the results contained in BAW-10091 provide an overly conservative analysis for all plants of this type and can be applied to Oconee Units 1, 2, & 3. As



August 5, 1974

such we adopt the results contained in BAW-10091. These results demonstrate conformance to the criteria of 10 CFR 50.46 under the following operating conditions:

1. The peak linear heat rate is less than or equal to 17.2kW/ft at the six foot elevation.
2. The Oconee Units 2 & 3 are operated within the attached revised Technical Specifications for the loss-of-coolant limits. These revisions were established on the basis of the LOCA limits as established from the FAC ECCS analysis (BAW-10091).
3. Oconee Unit 1 which has achieved in excess of 200 effective full power days of operation, can meet the final acceptance criteria as published in 10 CFR 50.46 without any changes to the existing technical specifications. Figure 1 shows the LOCA limit curve and the maximum operating peaks which are allowed under present technical specifications. Since in all cases the operating peaks, using existing technical specification limits, are below the LOCA limit the Final Acceptance Criteria are met.

Revisions to the rod withdrawal limits contained in the Oconee Nuclear Station Technical Specifications will be implemented on August 5, 1974. Continued operation of Oconee Units 1, 2, and 3 at rated power will be in compliance with 10 CFR 50.46. Technical specifications will be developed specifically for Oconee Units 2 and 3 using the methods developed in BAW-10091, and submitted to the AEC for review at a later date.

Very truly yours,

s/A. C. Thies
A. C. Thies

ACT:ch