

KHNPDCDRAIsPEm Resource

From: Ciocco, Jeff
Sent: Thursday, January 28, 2016 8:18 AM
To: apr1400rai@khnp.co.kr; KHNPDCDRAIsPEm Resource; Harry (Hyun Seung) Chang; Andy Jiyong Oh; Christopher Tyree
Cc: Williams, Stephen; Burkhart, Lawrence; Vera, John; Lee, Samuel
Subject: APR1400 Design Certification Application RAI 377-8487 (11.02 - Liquid Waste Management System)
Attachments: APR1400 DC RAI 377 RPAC 8487.pdf

KHNP,

The attachment contains the subject request for additional information (RAI). This RAI was sent to you in draft form. Your licensing review schedule assumes technically correct and complete responses within 30 days of receipt of RAIs.

Please submit your RAI response to the NRC Document Control Desk.

Thank you,

Jeff Ciocco
New Nuclear Reactor Licensing
301.415.6391
jeff.ciocco@nrc.gov



Hearing Identifier: KHNP_APR1400_DCD_RAI_Public
Email Number: 425

Mail Envelope Properties (2ee9754fc47a422181c364cfee4aa94d)

Subject: APR1400 Design Certification Application RAI 377-8487 (11.02 - Liquid Waste Management System)
Sent Date: 1/28/2016 8:18:12 AM
Received Date: 1/28/2016 8:18:14 AM
From: Ciocco, Jeff
Created By: Jeff.Ciocco@nrc.gov

Recipients:

"Williams, Stephen" <Stephen.Williams@nrc.gov>
Tracking Status: None
"Burkhart, Lawrence" <Lawrence.Burkhart@nrc.gov>
Tracking Status: None
"Vera, John" <John.Vera@nrc.gov>
Tracking Status: None
"Lee, Samuel" <Samuel.Lee@nrc.gov>
Tracking Status: None
"apr1400rai@khnp.co.kr" <apr1400rai@khnp.co.kr>
Tracking Status: None
"KHNPDCDRAIsPEM Resource" <KHNPDCDRAIsPEM.Resource@nrc.gov>
Tracking Status: None
"Harry (Hyun Seung) Chang" <hyunseung.chang@gmail.com>
Tracking Status: None
"Andy Jiyong Oh" <jiyong.oh5@gmail.com>
Tracking Status: None
"Christopher Tyree" <Christopher.tyree@aecom.com>
Tracking Status: None

Post Office: HQPWMSMRS08.nrc.gov

Files	Size	Date & Time
MESSAGE	498	1/28/2016 8:18:14 AM
APR1400 DC RAI 377 RPAC 8487.pdf		84741
image001.jpg	5040	

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

REQUEST FOR ADDITIONAL INFORMATION 377-8487

Issue Date: 01/28/2016
Application Title: APR1400 Design Certification Review – 52-046
Operating Company: Korea Hydro & Nuclear Power Co. Ltd.
Docket No. 52-046
Review Section: 11.02 - Liquid Waste Management System
Application Section: 11.2

QUESTIONS

11.02-10

REQUIREMENT: 10 CFR 50, APPENDIX I

GUIDANCE: RG 1.109

ISSUE: NRC staff reviewed the information provided in RAI 123-7920 response (9/14/2015, ML15278A149), to verify 10 CFR 50 Appendix I compliance. NRC staff confirmatory calculations are unable to verify the data provided for the irrigated food pathways. When performing the confirmatory analysis the staff originally observed values 100 times greater than those reported in the LADTAP output files provided by the applicant and the values provided in DCD Table 11.2-5. In the RAI 7920 response the applicant confirmed that there was indeed an error with consumption values and acknowledged that the consumption values in the input deck were not positioned correctly. The applicant has specified that they have corrected these values to the intended values of 520 kg for adults, 630 kg for teens, and 520 kg for children. However, staff notes that in the newly provided LADTAP input file the applicant uses the values found in in RG 1.109, Table E-5 for the “Fruits, vegetables & grain” pathway for all of the irrigated food pathways (vegetables, leafy vegetables, milk, and meat pathways).

1) NRC staff requests the applicant to confirm the values being reported in the LADTAP input and output files and results being reported in DCD Table 11.2-5. The staff also asks the applicant to provide a justification for the use of RG 1.109 Table E-5 values for “Fruits, vegetables & grain” for the Leafy vegetables, milk, and meat pathways and to provide a DCD table within DCD 11.2 to provide further clarification on the consumption values to be used by the applicant.

Additionally, the applicant’s response to RAI 7920 stated:

“The irrigation rate of 16.67 L/m²-month (0.5 m/yr) used in the LADTAP II calculation is based on a document titled “Data collection handbook to support modeling impacts of radioactive material in soil”, Argonne National Laboratory, 1993. This document provides the definitions and values that can be used in RESRAD code analysis. In Section 11.3 of the document, the default value for the irrigation rate is 0.2 m/yr, which represents the conditions of a relatively humid region. For LADTAP II code calculation, a conservative value of 0.5 m/yr was selected.”

2) NRC staff notes that Table 11.2-4 in the DCD states the irrigation rate was 41.68 L/m²-month. Please provide which is the correct value, either 16.67 or 41.68, and explain why it is the correct value.

Please address these items and provide a markup for the proposed DCD changes.



U.S.NRC

United States Nuclear Regulatory Commission

Protecting People and the Environment