

NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL
(TEMPORARY FORM)

CONTROL NO: 6525

FILE: _____

FROM: Duke Power Company Charlotte, N.C. A C Thies		DATE OF DOC 6-10-75	DATE REC'D 6-17-75	LTR XX	TWX	RPT	OTHER
TO: Mr. A Giambusso		ORIG 3 signed	CC	OTHER	SENT NRC PDR <u>XXX</u> SENT LOCAL PDR <u>XXX</u>		
CLASS	UNCLASS XXXX	PROP INFO	INPUT	NO CYS REC'D 40	DOCKET NO: <u>50-269,270,287</u>		

DESCRIPTION: Ltr notarized 6-10-75 trans the following:

ENCLOSURES: Proposed revisions to Tech Specs which would provide added flexibility to the measurement of quadrant power tilt,...

ACKNOWLEDGED

40 copies encl rec'd

DO NOT REMOVE
PLANT NAME: Oconee I-2-3

FOR ACTION/INFORMATION

wtm 6-18-75

BUTLER (L) W/ Copies	SCHWENCER (L) W/ Copies	ZIEMANN (L) W/ Copies	REGAN (E) W/ Copies
CLARK (L) W/ Copies	STOLZ (L) W/ Copies	DICKER (E) W/ Copies	LEAR (L) W/ Copies
PARR (L) W/ Copies	VASSALLO (L) W/ Copies	KNIGHTON (E) W/ Copies	SPIES W/ Copies
KNIEL (L) W/ Copies	PURPLE (L) W/ Copies	YOUNGBLOOD (E) W/ Copies	LPM W/ Copies

INTERNAL DISTRIBUTION

<u>REG FILE</u> NRC PDR OGC, ROOM P-506A GOSSICK/STAFF CASE GIAMBUSSO BOYD MOORE (L) DEYOUNG (L) SKOVHOLT (L) GOLLER (L) (Ltr) P. COLLINS DENISE <u>REG OPR(2)</u> FILE & REGION (2) MIPC	TECH REVIEW SCHROEDER MACCARY KNIGHT PAWLICKI SHAO STELLO HOUSTON NOVAK ROSS IPPOLITO TEDESCO LONG LAINAS BENAROYA VOLLMER	DENTON GRIMES GAMMILL KASTNER BALLARD SPANGLER <u>ENVIRO</u> MULLER DICKER KNIGHTON YOUNGBLOOD REGAN PROJECT LDR <u>M.AY</u> HARLESS	<u>LIC ASST</u> R. DIGGS (L) H. GEARIN (L) E. GOULBOURNE (L) P. KREUTZER (E) J. LEE (L) M. MAIGRET (L) S. REED (E) M. SERVICE (L) S. SHEPPARD (L) M. SLATER (E) H. SMITH (L) S. TEETS (L) G. WILLIAMS (E) V. WILSON (L) R. INGRAM (L) M. DUNCAN	A/T IND. BRAITMAN SALTZMAN MELTZ <u>PLANS</u> MCDONALD CHAPMAN DUBE (Ltr) E. COUPE PETERSON HARTFIELD (2) KLECKER EISENHUT WIGGINTON <u>E. HUGHES</u>
--	---	--	---	---

EXTERNAL DISTRIBUTION

1 - LOCAL PDR <u>Walhalla, SC</u>	1 - NATIONAL LABS _____	1 - PDR-SAN/LA/NY
1 - TIC (ABERNATHY) (1)(2)(10)	1 - W. PENNINGTON, Rm E-201 GT	1 - BROOKHAVEN NAT LAB
1 - NSIC (BUCHANAN)	1 - CONSULTANTS	1 - G. ULRIKSON ORNL
1 - ASLB	NEWMARK/BLUME/AGBABIAN	
1 - Newton Anderson		
1 - ACRS HOLDING/SENT		

DUKE POWER COMPANY

POWER BUILDING

422 SOUTH CHURCH STREET, CHARLOTTE, N. C. 28201


A. C. THIES
SENIOR VICE PRESIDENT
PRODUCTION AND TRANSMISSION

P. O. Box 2178

June 10, 1975

Mr. Angelo Giambusso, Director
Division of Reactor Licensing
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Re: Oconee Nuclear Station
Docket Nos. 50-269, -270, -287



Dear Mr. Giambusso:

Oconee Nuclear Station Technical Specification 1.6.1, "Quadrant Power Tilt," currently requires the use of the out-of-core power range detectors to determine the core power tilt. As you are aware, the Oconee reactors have both an out-of-core and an in-core system for measurement of core power. The requirement to preferentially use only one system to measure quadrant power tilt can unnecessarily restrict station operation. Therefore, pursuant to 10 CFR 50.90, a revision to Oconee Technical Specifications 1.6 and 3.5.4 which will provide added flexibility to the measurement of quadrant power tilt, is requested. The proposed revisions are indicated on the attached replacement pages.


Very truly yours,

A. C. Thies

A. C. Thies

ACT:vr

Attachment



Mr. Angelo Giambusso
Page 2
June 10, 1975

A. C. THIES, being duly sworn, states that he is Senior Vice President of Duke Power Company; that he is authorized on the part of said Company to sign and file with the Nuclear Regulatory Commission this request for amendment of the Oconee Nuclear Station Technical Specifications, Appendix A to Facility Operating Licenses DPR-38, DPR-47 and DPR-55; and that all statements and matters set forth therein are true and correct to the best of his knowledge.

A. C. Thies
A. C. Thies, Senior Vice President

ATTEST:

John C. Goodman, Jr.
John C. Goodman, Jr.
Assistant Secretary

Subscribed and sworn to before me this 10th day of June, 1975.

Edna B. Turner
Notary Public

My Commission Expires:

October 24, 1977

1.5.5 Heat Balance Check

A heat balance check is a comparison of the indicated neutron power and core thermal power.

1.5.6 Heat Balance Calibration

An adjustment of the power range channel amplifiers output to agree with the core thermal power as determined by a heat balance on the secondary side of the steam generator considering all heat losses and additions.

1.6 POWER DISTRIBUTION

1.6.1 Quadrant Power Tilt

Quadrant power tilt is defined by the following equation and is expressed in percent.

$$100 \left(\frac{\text{Power in any core quadrant}}{\text{Average power of all quadrants}} - 1 \right)$$

1.6.2 Reactor Power Imbalance

Reactor power imbalance is the power in the top half of the core minus the power in the bottom half of the core expressed as a percentage of rated power. Imbalance is monitored continuously by the RPS using input from the power range channels. Imbalance limits are defined in Specification 2.1 and imbalance setpoints are defined in Specification 2.3.

1.7 CONTAINMENT INTEGRITY

Containment integrity exists when the following conditions are satisfied:

- a. The equipment hatch is closed and sealed and both doors of the personnel hatch and emergency hatch are closed and sealed except as in b below.
- b. At least one door of the personnel hatch and the emergency hatch is closed and sealed during refueling or during personnel passage through these hatches.
- c. All non-automatic containment isolation valves and blind flanges are closed as required.
- d. All automatic containment isolation valves are operable or locked closed.
- e. The containment leakage determined at the last testing interval satisfies Specification 4.4.1.

3.5.4 Incore Instrumentation

Applicability

Applies to the operability of the incore instrumentation system

Objective

To specify the functional and operational requirements of the incore instrumentation system.

Specification

3.5.4.1 At or above 80 percent of the power allowable for the existing reactor coolant pump operating combination, incore detectors shall be operable as necessary to meet the following:

a. For axial imbalance measurements:

At least three detectors in each of at least three strings shall lie in the same axial plane, with one plane in each axial core half. The axial planes in each core half shall be symmetrical about the core mid-plane. The detector strings shall not have radial symmetry.

b. For quadrant power tilt measurements:

At least two sets of at least four detectors shall lie in each axial core half. Each set of detectors shall lie in the same axial plane. The two sets in the same core half may lie in the same axial plane. Detectors in the same plane shall have quarter core radial symmetry.

3.5.4.2 If requirements of 3.5.4.1 are not met, power shall be reduced below 80 percent of the power allowable for the existing reactor coolant pump combination within eight hours and incore detector measurements shall not be used to determine axial imbalance or quadrant power tilt.

Bases

The operability of the incore detectors with the specified minimum complement of equipment ensures that the measurements obtained from use of this system accurately represent the spatial neutron flux distribution of the reactor core. See Figures 3.5.4-1, 3.5.4-2, and 3.5.4-3 for satisfactory incore detector arrangements.

The safety of reactor operation at or below 80 percent of the power allowable for the reactor coolant pump combination⁽¹⁾ without the axial imbalance trip system has been determined by extensive 3-D calculations, and was verified during the physics startup testing program.

(1) FSAR, Section 4.1.1.3