

DISTRIBUTION AFTER ISSUANCE OF OPERATING LICENSE

U.S. NUCLEAR REGULATORY COMMISSION

DOCKET NUMBER

NRC FORM 195
(2-73)

ML **50-269/1070/287**
FILE NUMBER

NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL

TO: Mr. Edson G. Case	FROM: Duke Power Company Cahrlotte, North Carolina William O. Parker, Jr.	DATE OF DOCUMENT 10/31/77
		DATE RECEIVED 11/7/77
<input checked="" type="checkbox"/> LETTER <input checked="" type="checkbox"/> ORIGINAL <input type="checkbox"/> COPY	<input checked="" type="checkbox"/> NOTORIZED <input checked="" type="checkbox"/> UNCLASSIFIED	NUMBER OF COPIES RECEIVED 3516200

DESCRIPTION	ENCLOSURE
PLANT NAME: Oconee Units 1-2-3 RJL 11/7/77 (1-P)	License No. DPR-39, DPR-47 and DPR-55 Appl for Amend: tech specs proposed change concerning the deletion of redundant info. which is presently being reported in the Annual Operating Report.....notorized 10/31/77 (1-P)+(4-P) 40 ENCL.

SAFETY		FOR ACTION/INFORMATION	
BRANCH CHIEF: (7)	<i>SCHWENGER</i>		

INTERNAL DISTRIBUTION			
<input checked="" type="checkbox"/> REG FILE			
<input type="checkbox"/> NRC PDR			
<input type="checkbox"/> I & E (2)			
<input type="checkbox"/> OELD			
<input type="checkbox"/> HANAUER			
<input type="checkbox"/> CHECK			
<input type="checkbox"/> EISENHUT			
<input type="checkbox"/> SHAO			
<input type="checkbox"/> BAER			
<input type="checkbox"/> BUTLER			
<input type="checkbox"/> GRIMES			
<input type="checkbox"/> J. COLLINS			
<input type="checkbox"/> J. McGOUGH			

EXTERNAL DISTRIBUTION		CONTROL NUMBER
LPDR: <i>WALHALLA S.C.</i>		<i>773110150</i>
TIC		
NSIC		
16 CYS ACRS SENT CATEGORY <i>B</i>		

DUKE POWER COMPANY

POWER BUILDING

422 SOUTH CHURCH STREET, CHARLOTTE, N. C. 28242

WILLIAM O. PARKER, JR.
VICE PRESIDENT
STEAM PRODUCTION


October 31, 1977

TELEPHONE: AREA 704
373-4083

Mr. Edson G. Case, Acting Director
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Attention: Mr. A. Schwencer, Chief
Operating Reactors Branch #1

Reference: Oconee Nuclear Station
Docket Nos. 50-269, -270, -287



Dear Mr. Case:

As requested by your letter of September 16, 1977 and pursuant to 10CFR50.90, the attached proposed amendment to the Oconee Nuclear Station Technical Specifications is requested which will delete redundant information which is presently being reported in the Annual Operating Report. The requirements for annual reports of occupational exposure data and facility changes, tests or experiments conducted pursuant to 10CFR50.59 have been retained in the proposed amendment.

Your request for modifications to the Monthly Operating Report is under review. A letter supplying commitment dates for implementation of the revisions will be supplied by November 30, 1977 pending resolution of the definitions of certain requirements with your staff.

Very truly yours,

A handwritten signature in dark ink, appearing to read "William O. Parker, Jr." with a stylized flourish at the end.

William O. Parker, Jr.


LJB:ge

Attachment

773110150

Mr. Edson G. Case
October 31, 1977
Page 2

WILLIAM O. PARKER, JR., being duly sworn, states that he is Vice President of Duke Power Company; that he is authorized on the part of said Company to sign and file with the Nuclear Regulatory Commission this request for amendment of the Oconee Nuclear Station Facility Operating Licenses DPR-38, DPR-47, and DPR-55; and that all statements and matters set forth therein are true and correct to the best of his knowledge.



William O. Parker, Jr., Vice President

Subscribed and sworn to before me this 31st day of October, 1977.



Vivian B. Robinson
Notary Public
(Notarial Seal)

My Commission Expires:

Feb. 15, 1982

6.6 STATION REPORTING REQUIREMENTS

6.6.1 Routine Reports

The following reports shall be submitted to the Director, Office of Inspection and Enforcement Region II, Atlanta, Georgia.

6.6.1.1 Startup Report

A summary report of unit startup and power escalation testing shall be submitted following (1) receipt of an operating license, (2) amendment to the facility license involving a planned increase in power level, (3) installation of fuel that has a different design or has been manufactured by a different fuel supplier, and (4) modifications that may have significantly altered the nuclear, thermal or hydraulic performance of the unit. Startup reports shall be submitted (1) within 90 days following completion of the startup test program, (2) 90 days following resumption or commencement of commercial power operation, or (3) nine months following initial criticality, whichever occurs first. If a startup report does not cover all three events, i.e., initial criticality, completion of the startup test program and resumption or commencement of commercial power operation, supplementary reports shall be submitted at least every three months until all three events are completed.

6.6.1.2 Report of Changes, Tests and Experiments

A brief description and the summary of the safety evaluation for those changes, tests, and experiments carried out without prior Commission approval pursuant to the provisions of 10CFR50.59 shall be submitted prior to April 1 of each year.

6.6.1.3 Personnel Exposure and Monitoring Report

A tabulation (supplementing the requirements of 10CFR20.407) of the number of personnel receiving exposures greater than 100 mrem in the reporting period and their associated man-rem exposure, according to duty function, e.g., routine plant surveillance and inspection (regular duty), routine plant maintenance, special plant maintenance (describe maintenance), routine fueling operation, special refueling operation (describe operation), and other job-related exposures shall be submitted prior to April 1 of each year.

6.6.1.4 Reporting of Radioactive Effluent Releases

Data shall be reported to the Commission semi-annually in a form similar to that shown in Table 6.6-1 and shall include the following:

(1) Gaseous Releases

- (a) Total radioactivity (in curies) releases of noble and activation gases.
- (b) Maximum noble gas release rate during any one-hour period.
- (c) Total radioactivity (in curies) released, by nuclide, based on representative isotopic analyses performed.

(d) Percentage applicable limits released.

(2) Iodine Releases

- (a) Total I-131, I-133, I-135 radioactivity (in curies) released.
- (b) Total radioactivity (in curies) released, by nuclide, based on representative isotopic analyses performed.
- (c) Percentage of limit.

(3) Particulate Releases

- (a) Gross radioactivity (β - γ) released (in curies) excluding background radioactivity.
- (b) Gross alpha radioactivity released (in curies) excluding background radioactivity.
- (c) Total radioactivity released (in curies) of nuclides with half-lives greater than eight days.
- (d) Percentage of limit.

(4) Liquid Releases

- (a) Gross radioactivity (β - γ) released (in curies) excluding tritium and average concentration released to the unrestricted area at the Keowee Hydro unit.
- (b) The maximum concentration of gross radioactivity (β - γ) released to the unrestricted area (averaged over the period of release).
- (c) Total tritium and alpha radioactivity (in curies) released and average concentration released to the unrestricted area at the Keowee Hydro unit.
- (d) Total dissolved gas radioactivity (in curies) and average concentration released to the unrestricted area at the Keowee Hydro unit.
- (e) Total volume (in liters) of Keowee Hydro liquid waste released.
- (f) Total volume (in liters) of dilution water used prior to release from the restricted area.
- (g) Total radioactivity (in curies) released, by nuclide, based on representative isotopic analyses performed.
- (h) Percentage of limit for total activity released.

(5) Solid Waste

- (a) The total amount of solid waste packaged (in cubic feet).
- (b) Estimated total radioactivity (in curies):
- (c) Disposition including date and destination if shipped off site.

+

DELETE ENTIRE
PAGE