

50-269

NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL

FILE NUMBER

INCIDENT REPORT

TO:

Mr. Norman C. Moseley

FROM:
Duke Power Company
Charlotte, NC
William O. Parker, Jr.

DATE OF DOCUMENT

7/15/77

DATE RECEIVED

8/1/77

LETTER
 ORIGINAL
 COPY

NOTORIZED
 UNCLASSIFIED

PROP

INPUT FORM

NUMBER OF COPIES RECEIVED

1 signed

DESCRIPTION

ACKNOWLEDGED

PLANT NAME:

Oconee Nuclear Station
VT 8/2/77

(1-P)

ENCLOSURE

Licensee Event Report #RO 50-269/77-19 on
6/15/77 concerning Feedwater containment
isolation valve 1FDW-108 inoperable

(1-P)

NOTE: IF PERSONNEL EXPOSURE IS INVOLVED
SEND DIRECTLY TO KREGER/J. COLLINS

1 CY ENCL Rec'd

FOR ACTION/INFORMATION

BRANCH CHIEF:	Schwenger
W/ 3 CYS FOR ACTION	
LIC ASST.:	Sheppard

INTERNAL DISTRIBUTION

<u>REG FILE</u>				
NRC PDR				
I & E (2)				
MIPC				
SCHROEDER/IPPOLITO				
HOUSTON				
NOVAK/CHECK				
GRIMES				
KNIGHT				
BUTLER				
HANAHER				
TEDESCO				
EISENHIT				
BAER				
SHAO				
VOLLMER/BUNCH				
KREGER/ J. COLLINS				
ROSA				

EXTERNAL DISTRIBUTION

L.PDR: WALHAIN, S.C.			
TIC:			
NSIC:			
ACRS (16) SENT AS CAT. B			

CONTROL NUMBER

772140277

DUKE POWER COMPANY

POWER BUILDING

422 SOUTH CHURCH STREET, CHARLOTTE, N. C. 28242

WILLIAM O. PARKER, JR.
VICE PRESIDENT
STEAM PRODUCTION

July 15, 1977

TELEPHONE: AREA 704
373-4083

Mr. Norman C. Moseley, Director
U. S. Nuclear Regulatory Commission
Suite 818
230 Peachtree Street, Northwest
Atlanta, Georgia 30303

Re: Oconee Unit 1
Docket No. 50-269

Dear Mr. Moseley:

Pursuant to Sections 6.2 and 6.6.2 of the Oconee Nuclear Station Technical Specifications, please find attached Reportable Occurrence Report R0-269/77-19.

Very truly yours,

William O. Parker, Jr.

William O. Parker, Jr. *by PHS*

LJB:ge
Attachment

cc: Director, Office of Management Information
and Program Control

Regulatory

File Copy



772140277

DUKE POWER COMPANY
OCONEE UNIT 1

Report No.: RO-269/77-19

Report Date: July 15, 1977

Occurrence Date: June 15, 1977

Facility: Oconee Unit 1, Seneca, South Carolina

Identification of Occurrence: Feedwater containment isolation valve
1FDW-108 inoperable

Conditions Prior to Occurrence: Unit at 100 percent full power

Description of Occurrence:

On June 15, 1977, feedwater containment isolation valve 1FDW-108 failed to close under system pressure. This valve, located outside the reactor building, is part of the chemical sampling system and provides containment isolation following a ES actuation. The redundant valve, 1FDW-107, located inside the reactor building, was closed and locked as required by Oconee Technical Specification 3.6.4.b.2. The valve was repaired and returned to service within the time period allowed by Oconee Technical Specification 3.6.4.b.1.

Apparent Cause of Occurrence:

Examination of the valve indicated no definite reason for the inability of the valve to cycle properly.

Analysis of Occurrence:

Valve 1FDW-108 was properly isolated in compliance with Technical Specification 3.6.4.b.2 by securing redundant valve 1FDW-107 in the closed position. Valve 1FDW-108 was returned to service within the 4 hour period allowed by Technical Specification 3.6.4.b.1. In the event that containment isolation had been required prior to securing valve 1FDW-107, valve 1FDW-107 would have closed upon an ES actuation. Containment integrity was not affected by this incident, and it is thus concluded that the health and safety of the public were not affected.

Corrective Action:

The stem of valve 1FDW-108 was lubricated and its operability verified. To prevent recurrence of this incidence, the following action will be taken.

Valves 1FDW-108 and 1FDW-106 will be replaced on Oconee Unit 1 during the upcoming refueling outage. The FDW-108 and FDW-106 valves on Oconee Units 2 and 3 will also be replaced as delivery of the replacement valves and unit operation permit. Until that time, a program to periodically examine and adjust or replace packing on the FDW-106 and FDW-108 valves will be utilized to assure proper valve operation. This program will be initiated by July 15, 1977.

CENTRO REGION II
ATLANTA, GEORGIA

77 JUL 18 AIO: 14