

A04/28/78

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)
DISTRIBUTION FOR INCOMING MATERIAL

50-262/270/287

REC:
NRC

ORG: PARKER W O
DUKE PWR

DOCDATE: 06/19/78
DATE RCVD: 06/27/78

DOCTYPE: LETTER NOTARIZED: NO
SUBJECT:

COPIES RECEIVED
LTR 1 ENCL 1

FORWARDING REPT ON RADIOACTIVE WASTE RELEASES WHICH WAS INADVERTENTLY OMITTED FROM APPLICANT'S MONTHLY OPERATING REPT FOR THE MONTH OF MAY, 1978, SUBMITTED BY LTR DTD 06/15/78.

PLANT NAME: OCONEE - UNIT 1
OCONEE - UNIT 2
OCONEE - UNIT 3

REVIEWER INITIAL: XJM
DISTRIBUTER INITIAL: *W*

***** DISTRIBUTION OF THIS MATERIAL IS AS FOLLOWS *****

NOTES:
1. M. CUNNINGHAM - ALL AMENDMENTS TO FSAR AND CHANGES TO TECH SPECS ANNUAL & SEMI-ANNUAL OPERATING REPORTS (OL STAGE). (DISTRIBUTION CODE A008)

FOR ACTION: BR CHIEF ORB#4 BC**W/6 ENCL

INTERNAL: REG FILE**W/ENCL
I & E**W/2 ENCL
HANAUER**W/ENCL
AD FOR SYS & PROJ**W/ENCL
REACTOR SAFETY BR**W/ENCL
EEB**W/ENCL
EFFLUENT TREAT SYS**W/ENCL

NRC PDR**W/ENCL
MIFC**W/2 ENCL
DIRECTOR DOR**W/ENCL
ENGINEERING BR**W/ENCL
PLANT SYSTEMS BR**W/ENCL
P. CHECK**W/ENCL

EXTERNAL: LPDR'S
WALHALLA, SC**W/ENCL
NATL LAB ORNL**W/ENCL
TIC**W/ENCL
NSIC**W/ENCL
ACRS CAT B**W/15 ENCL

DISTRIBUTION: LTR 41 ENCL 41
SIZE: 1P+1P

CONTROL NBR: 781780113

***** THE END *****

DUKE POWER COMPANY

POWER BUILDING

422 SOUTH CHURCH STREET, CHARLOTTE, N. C. 28242

WILLIAM O. PARKER, JR.
VICE PRESIDENT
STEAM PRODUCTION

June 19, 1978

TELEPHONE: AREA 704
373-4083

Director
Office of Management Information
and Program Control
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Re: Oconee Nuclear Station
Docket Nos. 50-269, -270, -287

Dear Sir:

On June 15, 1978, we distributed the operating status report for the Oconee Nuclear Station for the month of May, 1978. Inadvertently, the report on radioactive waste releases and personnel exposure was omitted from the report. Please find attached this report for your information.

Very truly yours,

William O. Parker, Jr.

William O. Parker, Jr. *By [Signature]*

JAR:scs
Attachment

cc: Mr. J. P. O'Reilly
Mr. Ted Cintula

REGULATORY DOCKET FILE COPY

751730119

A008
5/11

OCONEE NUCLEAR STATION
MONTHLY OPERATING REPORT
MAY, 1978

1. Personnel Exposure

For the month of April three (3) individuals exceeded 10 percent of their allowable annual radiation dose limit with the highest dose being 1.600 REM, which represents approximately 13.3% of that person's allowable annual limit.

2. Radioactive Waste Releases

The total station liquid waste release for April has been compared with the Technical Specifications annual value of 15 curies and was less than 10 percent of this limit.

The total station gaseous release for April has been compared with the Technical Specification derived annual value of 51,000 curies and was 17.7 percent of this limit. However, the total gaseous release for the first four months of 1978 (year to date) was 23.7 percent of the annual objective. Although April is the first month of the quarter, it is not anticipated that the quarterly objective for the second quarter will be exceeded.