

NRC FORM 195
(2-76)

U.S. NUCLEAR REGULATORY COMMISSION

DOCKET NUMBER

50-269/220/287

NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL

TO: USNRC

FROM: DUKE POWER CO.
CHARLOTTE, N.C.
W.O. PARKER, JR.

FILE NUMBER

MONTHLY REPORT

DATE OF DOCUMENT

6/10/77

DATE RECEIVED

6/13/77

NUMBER OF COPIES RECEIVED

1 SIGNED

☒ LETTER

☐ NOTORIZED

PROP

INPUT FORM

☒ ORIGINAL

☒ UNCLASSIFIED

☐ COPY

DESCRIPTION

Letter trans the following:

DO NOT REMOVE

ACKNOWLEDGED

(1P)

ENCLOSURE

Monthly Report for MAY 1977

Plant & Component Operability & Availability.
This Report to be used in preparing Gray Book
by Plans & Operations.

(12P)

PLANT NAME: OCONEE # 1, 2 & 3
SAB

FOR ACTION/INFORMATION

MIPC W/2 CYS FOR ACTION

INTERNAL DISTRIBUTION

☒ Reg Files

☒ NRC PDR

Branch Chief (L)

Lic Asst

Schwenger
Sheppard

EXTERNAL DISTRIBUTION

LPDR: Walther, SC

TIC

NSIC

CONTROL NUMBER

771650250

R
MAD
Rpt

DUKE POWER COMPANY
POWER BUILDING
422 SOUTH CHURCH STREET, CHARLOTTE, N. C. 28242


WILLIAM O. PARKER, JR.
VICE PRESIDENT
STEAM PRODUCTION

June 10, 1977

TELEPHONE: AREA 704
373-4083

Director
Office of Management Information
and Program Control
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Re: Oconee Nuclear Station
Docket Nos. 50-269, -270, -287



Dear Sir:


REGULATORY DOCKET FILE COPY

Please find attached information concerning the performance and operating status of the Oconee Nuclear Station for the month of May, 1977.

The following correction is submitted to the operating data for March, 1977, previously provided by my letter of April 13, 1977. The reported value for the cumulative unit availability factor is incorrect. The value reported was 65.17; the correct value is 65.26.

Additionally, the following corrections are submitted to the operating data for April, 1977, previously provided by my letter of May 10, 1977. The reported value for the cumulative unit availability factor was 65.68; the correct value is 65.77. The unit shutdown numbers reported were 7, 8, and 9; the correct numbers are 6, 7, and 8.

Very truly yours,


William O. Parker, Jr.

JAR:ge
Attachment

cc: Mr. Norman C. Moseley

771650250

UNIT Oconee Unit 1
 DATE 6-10-77
 DOCKET NO. 50-269
 PREPARED BY J. A. Reavis

OPERATING STATUS

1. REPORTING PERIOD: May 1 THROUGH May 31, 1977
 GROSS HOURS IN REPORTING PERIOD: 744.00
2. CURRENTLY AUTHORIZED POWER LEVEL (MWt): 2568 NET CAPABILITY
 (MWe-Net): 860
3. POWER LEVEL TO WHICH RESTRICTED (IF ANY): (MWe-Net) _____
4. REASONS FOR RESTRICTION (IF ANY) _____
5. NUMBER OF HOURS THE REACTOR WAS CRITICAL

	<u>This Month</u>	<u>Year to Date</u>	<u>Cumulative</u>
6. REACTOR RESERVE SHUTDOWN HOURS	<u>-</u>	<u>-</u>	<u>-</u>
7. HOURS GENERATOR ON-LINE	<u>357.74</u>	<u>2226.67</u>	<u>22190.66</u>
8. UNIT RESERVE SHUTDOWN HOURS	<u>-</u>	<u>-</u>	<u>-</u>
9. GROSS THERMAL ENERGY GENERATED (MWH)	<u>761462</u>	<u>5368247</u>	<u>51753958</u>
10. GROSS ELECTRICAL ENERGY GENERATED (MWH)	<u>260790</u>	<u>1852060</u>	<u>17975490</u>
11. NET ELECTRICAL ENERGY GENERATED (MWH)	<u>243423</u>	<u>1753439</u>	<u>16985972</u>
12. REACTOR SERVICE FACTOR	<u>49.10</u>	<u>62.43</u>	<u>71.73</u>
13. REACTOR AVAILABILITY FACTOR	<u>96.31</u>	<u>54.72</u>	<u>66.81</u>
14. UNIT SERVICE FACTOR	<u>48.08</u>	<u>61.46</u>	<u>65.30</u>
15. UNIT AVAILABILITY FACTOR	<u>48.08</u>	<u>61.46</u>	<u>65.38</u>
16. UNIT CAPACITY FACTOR (Using Net Capability)	<u>38.04</u>	<u>56.28</u>	<u>58.12</u>
17. UNIT CAPACITY FACTOR (Using Design Mwe)	<u>36.89</u>	<u>54.56</u>	<u>56.35</u>
18. UNIT FORCED OUTAGE RATE	<u>51.92</u>	<u>38.54</u>	<u>20.42</u>
19. SHUTDOWNS SCHEDULED OVER NEXT 6 MONTHS (TYPE, DATE & DURATION OF EACH:)
Refueling - July 17, 1977 - 6 weeks
20. IF SHUTDOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP: _____

$$\text{REACTOR SERVICE FACTOR} = \frac{\text{HOURS REACTOR WAS CRITICAL}}{\text{HOURS IN REPORTING PERIOD}} \times 100$$

$$\text{REACTOR AVAILABILITY FACTOR} = \frac{\text{HOURS REACTOR WAS AVAILABLE TO OPERATE}}{\text{HOURS IN REPORTING PERIOD}} \times 100$$

$$\text{UNIT SERVICE FACTOR} = \frac{\text{HOURS GENERATOR ON LINE}}{\text{HOURS IN REPORTING PERIOD}} \times 100$$

$$\text{UNIT AVAILABILITY FACTOR} = \frac{\text{HOURS UNIT WAS AVAILABLE TO GENERATE}}{\text{HOURS IN REPORTING PERIOD}} \times 100$$

$$\text{UNIT CAPACITY FACTOR} = \frac{\text{NET ELECTRICAL POWER GENERATED}}{[\text{Net Capability or Design (Mwe-Net)}] \times \text{HOURS IN REPORTING PERIOD}} \times 100$$

$$\text{UNIT FORCED OUTAGE RATE} = \frac{\text{FORCED OUTAGE HOURS}}{\text{HOURS GENERATOR ON LINE} + \text{FORCED OUTAGE HOURS}} \times 100$$

DOCKET NO. 50-269UNIT Oconee Unit 1DATE 6-10-77**AVERAGE DAILY UNIT POWER LEVEL**MONTH May, 1977

AVERAGE DAILY POWER LEVEL (MWe-net)		AVERAGE DAILY POWER LEVEL (MWe-net)	
DAY		DAY	
1	<u>846</u>	17	<u>-</u>
2	<u>857</u>	18	<u>-</u>
3	<u>858</u>	19	<u>-</u>
4	<u>856</u>	20	<u>-</u>
5	<u>853</u>	21	<u>-</u>
6	<u>856</u>	22	<u>-</u>
7	<u>349</u>	23	<u>173</u>
8	<u>-</u>	24	<u>339</u>
9	<u>-</u>	25	<u>496</u>
10	<u>-</u>	26	<u>604</u>
11	<u>-</u>	27	<u>603</u>
12	<u>-</u>	28	<u>601</u>
13	<u>-</u>	29	<u>592</u>
14	<u>-</u>	30	<u>631</u>
15	<u>-</u>	31	<u>762</u>
16	<u>-</u>		

DAILY UNIT POWER LEVEL FORM INSTRUCTIONS

On this form, list the average daily unit power level in MWe-net for each day in the reporting month. Compute to the nearest whole megawatt.

These figures will be used to plot a graph for each reporting month. Note that by using maximum dependable capacity for the net electrical rating of the unit, there may be occasions when the daily average power level exceeds the 100% line (or the restricted power level line). In such cases, the average daily unit power output sheet should be footnoted to explain the apparent anomaly.

UNIT SHUTDOWNS

DOCKET NO. 50-269

UNIT NAME Oconee Unit 1

DATE 6-10-77

REPORT MONTH May, 1977

NO.	DATE	TYPE F-FORCED S-SCHEDULED	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR (2)	CORRECTIVE ACTIONS/COMMENTS
9	77-05-07	F	382.00	A	1	Tube leak repair in "B" OTSG.
10	77-05-24	F	4.26	A	3	During emergency feedwater pump test lost condenser vacuum due to failed valve.
<p>(1) REASON</p> <p>A-EQUIPMENT FAILURE (EXPLAIN)</p> <p>B-MAINT. OR TEST.</p> <p>C-REFUELING</p> <p>D-REGULATORY RESTRICTION</p> <p>E-OPERATOR TRAINING AND LICENSE EXAMINATION</p> <p>F-ADMINISTRATIVE</p> <p>G-OPERATIONAL ERROR (EXPLAIN)</p> <p>H-OTHER (EXPLAIN)</p>						<p>(2) METHOD</p> <p>1-MANUAL</p> <p>2-MANUAL SCRAM</p> <p>3-AUTOMATIC SCRAM</p> <p>4-Other</p>

SUMMARY:

One major outage this month.

UNIT Oconee Unit 2
 DATE 6-10-77
 DOCKET NO. 50-270
 PREPARED BY J. A. Reavis

OPERATING STATUS

1. REPORTING PERIOD: May 1 THROUGH May 31, 1977
 GROSS HOURS IN REPORTING PERIOD: 744.00
2. CURRENTLY AUTHORIZED POWER LEVEL (MWt): 2568 NET CAPABILITY
 (MWe-Net): 860
3. POWER LEVEL TO WHICH RESTRICTED (IF ANY): (MWe-Net) _____
4. REASONS FOR RESTRICTION (IF ANY) _____
5. NUMBER OF HOURS THE REACTOR WAS CRITICAL
6. REACTOR RESERVE SHUTDOWN HOURS
7. HOURS GENERATOR ON-LINE
8. UNIT RESERVE SHUTDOWN HOURS
9. GROSS THERMAL ENERGY GENERATED (MWH)
10. GROSS ELECTRICAL ENERGY GENERATED (MWH)
11. NET ELECTRICAL ENERGY GENERATED (MWH)
12. REACTOR SERVICE FACTOR
13. REACTOR AVAILABILITY FACTOR
14. UNIT SERVICE FACTOR
15. UNIT AVAILABILITY FACTOR
16. UNIT CAPACITY FACTOR (Using Net Capability)
17. UNIT CAPACITY FACTOR (Using Design Mwe)
18. UNIT FORCED OUTAGE RATE
19. SHUTDOWNS SCHEDULED OVER NEXT 6 MONTHS (TYPE, DATE & DURATION OF EACH:)

	This Month	Year to Date	Cumulative
5. NUMBER OF HOURS THE REACTOR WAS CRITICAL	671.91	3548.67	17775.70
6. REACTOR RESERVE SHUTDOWN HOURS	-	-	-
7. HOURS GENERATOR ON-LINE	667.74	3539.47	17305.01
8. UNIT RESERVE SHUTDOWN HOURS	-	-	-
9. GROSS THERMAL ENERGY GENERATED (MWH)	1686648	8864517	41625779
10. GROSS ELECTRICAL ENERGY GENERATED (MWH)	569520	3007570	14163176
11. NET ELECTRICAL ENERGY GENERATED (MWH)	543551	2879108	13463231
12. REACTOR SERVICE FACTOR	90.31	97.95	74.36
13. REACTOR AVAILABILITY FACTOR	89.75	97.90	72.87
14. UNIT SERVICE FACTOR	89.75	97.69	72.39
15. UNIT AVAILABILITY FACTOR	89.75	97.69	72.39
16. UNIT CAPACITY FACTOR (Using Net Capability)	84.95	92.40	65.49
17. UNIT CAPACITY FACTOR (Using Design Mwe)	82.37	89.59	63.50
18. UNIT FORCED OUTAGE RATE	10.25	2.31	21.59

20. IF SHUTDOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP:
July 10, 1977

$$\text{REACTOR SERVICE FACTOR} = \frac{\text{HOURS REACTOR WAS CRITICAL}}{\text{HOURS IN REPORTING PERIOD}} \times 100$$

$$\text{REACTOR AVAILABILITY FACTOR} = \frac{\text{HOURS REACTOR WAS AVAILABLE TO OPERATE}}{\text{HOURS IN REPORTING PERIOD}} \times 100$$

$$\text{UNIT SERVICE FACTOR} = \frac{\text{HOURS GENERATOR ON LINE}}{\text{HOURS IN REPORTING PERIOD}} \times 100$$

$$\text{UNIT AVAILABILITY FACTOR} = \frac{\text{HOURS UNIT WAS AVAILABLE TO GENERATE}}{\text{HOURS IN REPORTING PERIOD}} \times 100$$

$$\text{UNIT CAPACITY FACTOR} = \frac{\text{NET ELECTRICAL POWER GENERATED}}{[\text{Net Capability or Design (Mwe-Net)}] \times \text{HOURS IN REPORTING PERIOD}} \times 100$$

$$\text{UNIT FORCED OUTAGE RATE} = \frac{\text{FORCED OUTAGE HOURS}}{\text{HOURS GENERATOR ON LINE} + \text{FORCED OUTAGE HOURS}} \times 100$$

DOCKET NO. 50-270UNIT Oconee Unit 2DATE 6-10-77**AVERAGE DAILY UNIT POWER LEVEL**MONTH May, 1977

AVERAGE DAILY POWER LEVEL (MWe-net)		AVERAGE DAILY POWER LEVEL (MWe-net)	
DAY		DAY	
1	<u>827</u>	17	<u>816</u>
2	<u>827</u>	18	<u>816</u>
3	<u>828</u>	19	<u>816</u>
4	<u>832</u>	20	<u>814</u>
5	<u>829</u>	21	<u>812</u>
6	<u>788</u>	22	<u>811</u>
7	<u>819</u>	23	<u>812</u>
8	<u>821</u>	24	<u>814</u>
9	<u>823</u>	25	<u>809</u>
10	<u>821</u>	26	<u>813</u>
11	<u>819</u>	27	<u>810</u>
12	<u>819</u>	28	<u>609</u>
13	<u>819</u>	29	<u>-</u>
14	<u>818</u>	30	<u>-</u>
15	<u>817</u>	31	<u>-</u>
16	<u>817</u>		

DAILY UNIT POWER LEVEL FORM INSTRUCTIONS

On this form, list the average daily unit power level in MWe-net for each day in the reporting month. Compute to the nearest whole megawatt.

These figures will be used to plot a graph for each reporting month. Note that by using maximum dependable capacity for the net electrical rating of the unit, there may be occasions when the daily average power level exceeds the 100% line (or the restricted power level line). In such cases, the average daily unit power output sheet should be footnoted to explain the apparent anomaly.

UNIT SHUTDOWNS

DOCKET NO. 50-270

UNIT NAME Oconee Unit 2

DATE 6-10-77

REPORT MONTH May, 1977

NO.	DATE	TYPE F-FORCED S-SCHEDULED	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR (2)	CORRECTIVE ACTIONS/COMMENTS
2	77-05-28	S	76.26	C	1	Refueling

- (1) REASON

 - A-EQUIPMENT FAILURE (EXPLAIN)
 - B-MAINT. OR TEST.
 - C-REFUELING
 - D-REGULATORY RESTRICTION
 - E-OPERATOR TRAINING AND
LICENSE EXAMINATION
 - F-ADMINISTRATIVE
 - G-OPERATIONAL ERROR
(EXPLAIN)
 - H-OTHER (EXPLAIN)
- (2) METHOD

 - 1-MANUAL
 - 2-MANUAL
SCRAM
 - 3-AUTOMATIC
SCRAM
 - 4-Other

SUMMARY:

Reactor shutdown for refueling.

UNIT Oconee Unit 3
DATE 6-10-77
DOCKET NO. 50-287
PREPARED BY J. A. Reavis

OPERATING STATUS

1. REPORTING PERIOD: May 1 THROUGH May 31, 1977
GROSS HOURS IN REPORTING PERIOD: 744.00
2. CURRENTLY AUTHORIZED POWER LEVEL (MWt): 2568 NET CAPABILITY (MWe-Net): 860
3. POWER LEVEL TO WHICH RESTRICTED (IF ANY): (MWe-Net) _____
4. REASONS FOR RESTRICTION (IF ANY) _____
5. NUMBER OF HOURS THE REACTOR WAS CRITICAL
- | | <u>This Month</u> | <u>Year to Date</u> | <u>Cumulative</u> |
|-----------------------------------------------------------------------------|-------------------|---------------------|-------------------|
| 6. REACTOR RESERVE SHUTDOWN HOURS | <u>744.00</u> | <u>3368.77</u> | <u>16771.47</u> |
| 7. HOURS GENERATOR ON-LINE | <u>-</u> | <u>-</u> | <u>-</u> |
| 8. UNIT RESERVE SHUTDOWN HOURS | <u>744.00</u> | <u>3346.84</u> | <u>16370.34</u> |
| 9. GROSS THERMAL ENERGY GENERATED (MWH) | <u>-</u> | <u>-</u> | <u>-</u> |
| 10. GROSS ELECTRICAL ENERGY GENERATED (MWH) | <u>1924115</u> | <u>8483044</u> | <u>38851261</u> |
| 11. NET ELECTRICAL ENERGY GENERATED (MWH) | <u>662510</u> | <u>2958700</u> | <u>13398144</u> |
| 12. REACTOR SERVICE FACTOR | <u>633604</u> | <u>2830589</u> | <u>12764231</u> |
| 13. REACTOR AVAILABILITY FACTOR | <u>100.00</u> | <u>92.98</u> | <u>77.82</u> |
| 14. UNIT SERVICE FACTOR | <u>100.00</u> | <u>92.52</u> | <u>78.26</u> |
| 15. UNIT AVAILABILITY FACTOR | <u>100.00</u> | <u>92.38</u> | <u>75.96</u> |
| 16. UNIT CAPACITY FACTOR (Using Net Capability) | <u>100.00</u> | <u>92.38</u> | <u>75.96</u> |
| 17. UNIT CAPACITY FACTOR (Using Design Mwe) | <u>99.03</u> | <u>90.85</u> | <u>68.87</u> |
| 18. UNIT FORCED OUTAGE RATE | <u>96.01</u> | <u>88.08</u> | <u>66.77</u> |
| 19. SHUTDOWNS SCHEDULED OVER NEXT 6 MONTHS (TYPE, DATE & DURATION OF EACH:) | <u>-</u> | <u>7.62</u> | <u>12.74</u> |
- Refueling - September 4, 1977 - 6 weeks
20. IF SHUTDOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP: _____

$$\text{REACTOR SERVICE FACTOR} = \frac{\text{HOURS REACTOR WAS CRITICAL}}{\text{HOURS IN REPORTING PERIOD}} \times 100$$

$$\text{REACTOR AVAILABILITY FACTOR} = \frac{\text{HOURS REACTOR WAS AVAILABLE TO OPERATE}}{\text{HOURS IN REPORTING PERIOD}} \times 100$$

$$\text{UNIT SERVICE FACTOR} = \frac{\text{HOURS GENERATOR ON LINE}}{\text{HOURS IN REPORTING PERIOD}} \times 100$$

$$\text{UNIT AVAILABILITY FACTOR} = \frac{\text{HOURS UNIT WAS AVAILABLE TO GENERATE}}{\text{HOURS IN REPORTING PERIOD}} \times 100$$

$$\text{UNIT CAPACITY FACTOR} = \frac{\text{NET ELECTRICAL POWER GENERATED}}{[\text{Net Capability or Design (Mwe-Net)}] \times \text{HOURS IN REPORTING PERIOD}} \times 100$$

$$\text{UNIT FORCED OUTAGE RATE} = \frac{\text{FORCED OUTAGE HOURS}}{\text{HOURS GENERATOR ON LINE} + \text{FORCED OUTAGE HOURS}} \times 100$$

DOCKET NO. 50-287
 UNIT Oconee Unit 3
 DATE 6-10-77

AVERAGE DAILY UNIT POWER LEVEL

MONTH May, 1977

DAY	AVERAGE DAILY POWER LEVEL (MWe-net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-net)
1	<u>825</u>	17	<u>859</u>
2	<u>838</u>	18	<u>855</u>
3	<u>829</u>	19	<u>855</u>
4	<u>818</u>	20	<u>854</u>
5	<u>867</u>	21	<u>854</u>
6	<u>864</u>	22	<u>854</u>
7	<u>863</u>	23	<u>854</u>
8	<u>864</u>	24	<u>852</u>
9	<u>864</u>	25	<u>853</u>
10	<u>851</u>	26	<u>814</u>
11	<u>848</u>	27	<u>854</u>
12	<u>859</u>	28	<u>859</u>
13	<u>859</u>	29	<u>857</u>
14	<u>854</u>	30	<u>855</u>
15	<u>856</u>	31	<u>854</u>
16	<u>860</u>		

DAILY UNIT POWER LEVEL FORM INSTRUCTIONS

On this form, list the average daily unit power level in MWe-net for each day in the reporting month. Compute to the nearest whole megawatt.

These figures will be used to plot a graph for each reporting month. Note that by using maximum dependable capacity for the net electrical rating of the unit, there may be occasions when the daily average power level exceeds the 100% line (or the restricted power level line). In such cases, the average daily unit power output sheet should be footnoted to explain the apparent anomaly.

UNIT SHUTDOWNS

DOCKET NO. 50-287

UNIT NAME Oconee Unit 3

DATE 6-10-77

REPORT MONTH May, 1977

NO.	DATE	TYPE F-FORCED S-SCHEDULED	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR (2)	CORRECTIVE ACTIONS/COMMENTS
						<div> <div> (1) REASON A-EQUIPMENT FAILURE (EXPLAIN) B- MAINT. OR TEST. C- REFUELING D-REGULATORY RESTRICTION E-OPERATOR TRAINING AND LICENSE EXAMINATION F-ADMINISTRATIVE G-OPERATIONAL ERROR (EXPLAIN) H-OTHER (EXPLAIN) </div> <div> (2) METHOD 1-MANUAL 2-MANUAL SCRAM 3-AUTOMATIC SCRAM 4-Other </div> </div>

SUMMARY:

No outages this month.

UNIT Oconee Unit 1
 DATE 6-10-77
 DOCKET NO. 50-269
 PREPARED BY J. A. Reavis

OPERATING STATUS

1. REPORTING PERIOD: March 1 THROUGH March 31, 1977
 GROSS HOURS IN REPORTING PERIOD: 744
2. CURRENTLY AUTHORIZED POWER LEVEL (MWt): 2568 NET CAPABILITY
 (MWe-Net): 860
3. POWER LEVEL TO WHICH RESTRICTED (IF ANY): (MWe-Net) _____
4. REASONS FOR RESTRICTION (IF ANY) _____
- | | <u>This Month</u> | <u>Year to Date</u> | <u>Cumulative</u> |
|-------------------------------------------------|-------------------|---------------------|-------------------|
| 5. NUMBER OF HOURS THE REACTOR WAS CRITICAL | <u>236.45</u> | <u>1251.13</u> | <u>23366.93</u> |
| 6. REACTOR RESERVE SHUTDOWN HOURS | <u>-</u> | <u>-</u> | <u>-</u> |
| 7. HOURS GENERATOR ON-LINE | <u>230.21</u> | <u>1230.57</u> | <u>21194.56</u> |
| 8. UNIT RESERVE SHUTDOWN HOURS | <u>-</u> | <u>-</u> | <u>-</u> |
| 9. GROSS THERMAL ENERGY GENERATED (MWH) | <u>521612</u> | <u>3065709</u> | <u>49451420</u> |
| 10. GROSS ELECTRICAL ENERGY GENERATED (MWH) | <u>181570</u> | <u>1057780</u> | <u>17181210</u> |
| 11. NET ELECTRICAL ENERGY GENERATED (MWH) | <u>168820</u> | <u>1002696</u> | <u>16235229</u> |
| 12. REACTOR SERVICE FACTOR | <u>31.78</u> | <u>57.92</u> | <u>71.85</u> |
| 13. REACTOR AVAILABILITY FACTOR | <u>35.72</u> | <u>58.62</u> | <u>67.61</u> |
| 14. UNIT SERVICE FACTOR | <u>30.94</u> | <u>56.97</u> | <u>65.17</u> |
| 15. UNIT AVAILABILITY FACTOR | <u>30.94</u> | <u>56.97</u> | <u>65.26</u> |
| 16. UNIT CAPACITY FACTOR (Using Net Capability) | <u>26.38</u> | <u>53.98</u> | <u>58.05</u> |
| 17. UNIT CAPACITY FACTOR (Using Design Mwe) | <u>25.58</u> | <u>52.33</u> | <u>56.28</u> |
| 18. UNIT FORCED OUTAGE RATE | <u>69.06</u> | <u>43.03</u> | <u>19.78</u> |
19. SHUTDOWNS SCHEDULED OVER NEXT 6 MONTHS (TYPE, DATE & DURATION OF EACH:)
 Refueling - June 5, 1977 - 6 weeks
20. IF SHUTDOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP:
April 2, 1977

$$\text{REACTOR SERVICE FACTOR} = \frac{\text{HOURS REACTOR WAS CRITICAL}}{\text{HOURS IN REPORTING PERIOD}} \times 100$$

$$\text{REACTOR AVAILABILITY FACTOR} = \frac{\text{HOURS REACTOR WAS AVAILABLE TO OPERATE}}{\text{HOURS IN REPORTING PERIOD}} \times 100$$

$$\text{UNIT SERVICE FACTOR} = \frac{\text{HOURS GENERATOR ON LINE}}{\text{HOURS IN REPORTING PERIOD}} \times 100$$

$$\text{UNIT AVAILABILITY FACTOR} = \frac{\text{HOURS UNIT WAS AVAILABLE TO GENERATE}}{\text{HOURS IN REPORTING PERIOD}} \times 100$$

$$\text{UNIT CAPACITY FACTOR} = \frac{\text{NET ELECTRICAL POWER GENERATED}}{[\text{Net Capability or Design (Mwe-Net)}] \times \text{HOURS IN REPORTING PERIOD}} \times 100$$

$$\text{UNIT FORCED OUTAGE RATE} = \frac{\text{FORCED OUTAGE HOURS}}{\text{HOURS GENERATOR ON LINE} + \text{FORCED OUTAGE HOURS}} \times 100$$

UNIT Oconee Unit 1
 DATE 6-10-77
 DOCKET NO. 50-269
 PREPARED BY J. A. Reavis

OPERATING STATUS

1. REPORTING PERIOD: April 1 THROUGH April 30, 1977
 GROSS HOURS IN REPORTING PERIOD: 719.00
2. CURRENTLY AUTHORIZED POWER LEVEL (MWt): 2568 NET CAPABILITY
 (MWe-Net): 860
3. POWER LEVEL TO WHICH RESTRICTED (IF ANY): (MWe-Net) _____
4. REASONS FOR RESTRICTION (IF ANY) _____
5. NUMBER OF HOURS THE REACTOR WAS CRITICAL

	This Month	Year to Date	Cumulative
6. REACTOR RESERVE SHUTDOWN HOURS	-	-	-
7. HOURS GENERATOR ON-LINE	638.36	1868.93	21832.92
8. UNIT RESERVE SHUTDOWN HOURS	-	-	-
9. GROSS THERMAL ENERGY GENERATED (MWH)	1541075	4606784	50992495
10. GROSS ELECTRICAL ENERGY GENERATED (MWH)	533450	1591270	17714700
11. NET ELECTRICAL ENERGY GENERATED (MWH)	507320	1510016	16742549
12. REACTOR SERVICE FACTOR	89.78	65.88	72.24
13. REACTOR AVAILABILITY FACTOR	99.66	68.87	68.30
14. UNIT SERVICE FACTOR	88.78	64.92	65.68
15. UNIT AVAILABILITY FACTOR	88.78	64.92	65.77
16. UNIT CAPACITY FACTOR (Using Net Capability)	82.05	60.99	58.57
17. UNIT CAPACITY FACTOR (Using Design Mwe)	79.55	59.13	56.79
18. UNIT FORCED OUTAGE RATE	11.22	35.08	19.56
19. SHUTDOWNS SCHEDULED OVER NEXT 6 MONTHS (TYPE, DATE & DURATION OF EACH:)
 Refueling - June 25, 1977 - 6 weeks
20. IF SHUTDOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP:

$$\text{REACTOR SERVICE FACTOR} = \frac{\text{HOURS REACTOR WAS CRITICAL}}{\text{HOURS IN REPORTING PERIOD}} \times 100$$

$$\text{REACTOR AVAILABILITY FACTOR} = \frac{\text{HOURS REACTOR WAS AVAILABLE TO OPERATE}}{\text{HOURS IN REPORTING PERIOD}} \times 100$$

$$\text{UNIT SERVICE FACTOR} = \frac{\text{HOURS GENERATOR ON LINE}}{\text{HOURS IN REPORTING PERIOD}} \times 100$$

$$\text{UNIT AVAILABILITY FACTOR} = \frac{\text{HOURS UNIT WAS AVAILABLE TO GENERATE}}{\text{HOURS IN REPORTING PERIOD}} \times 100$$

$$\text{UNIT CAPACITY FACTOR} = \frac{\text{NET ELECTRICAL POWER GENERATED}}{[\text{Net Capability or Design (Mwe-Net)}] \times \text{HOURS IN REPORTING PERIOD}} \times 100$$

$$\text{UNIT FORCED OUTAGE RATE} = \frac{\text{FORCED OUTAGE HOURS}}{\text{HOURS GENERATOR ON LINE} + \text{FORCED OUTAGE HOURS}} \times 100$$

UNIT SHUTDOWNS

DOCKET NO. 50-269

UNIT NAME Oconee Unit 1

DATE June 10, 1977

REPORT MONTH April, 1977

NO.	DATE	TYPE F-FORCED S-SCHEDULED	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR (2)	CORRECTIVE ACTIONS/COMMENTS
6	77-04-01	F	66.94	A	1	Continuation of previous outage for repair of turning gear oil pump bearing for damage.
7	77-04-08	F	2.46	A	3	Failure in ICS feedwater control module circuitry.
8	77-04-24	F	11.24	A	3	Reheater drain valve failed to open resulting in reheater high level trip.
						<div> <div> (1) REASON A-EQUIPMENT FAILURE (EXPLAIN) B-MAINT. OR TEST C-REFUELING D-REGULATORY RESTRICTION E-OPERATOR TRAINING AND LICENSE EXAMINATION F-ADMINISTRATIVE G-OPERATIONAL ERROR (EXPLAIN) H-OTHER (EXPLAIN) </div> <div> (2) METHOD 1-MANUAL 2-MANUAL SCRAM 3-AUTOMATIC SCRAM 4-Other </div> </div>

SUMMARY: