

AEC DISTRIBUTION FOR PART 50 DOCKET MATERIAL
(TEMPORARY FORM)

CONTROL NO: 12641

FILE: _____

FROM: Duke Power Co. Charlotte, N.C. A.C. Thies		DATE OF DOC 12-13-74	DATE REC'D 12-16-74	LTR xxx	TWX	RPT	OTHER
TO: Mr. Angelo Giambusso		ORIG I-signed	CC	OTHER	SENT AEC PDR <u>XXXXX</u> SENT LOCAL PDR <u>XXXXX</u>		
CLASS	UNCLASS XXXXX	PROP INFO	INPUT	NO CYS REC'D 1	DOCKET NO: 50-269, 270, <u>287</u>		
DESCRIPTION: Ltr reporting Environmental Abnormal Occurrence 12-5-74 concerning six of the 24 condenser cooling water (CCW) intake screens at the Oconee Nuclear Station..... Trans the following:				ENCLOSURES: Enclosure 1 Oconee Nuclear Station Summary of Fish Impingement Data From Intake Screen Dec, 5, 1974			
PLANT NAME: Dconee 1-2-3							

ACKNOWLEDGED
DO NOT REMOVE

FOR ACTION/INFORMATION 12-16-74 JGB

BUTLER (L) W/ Copies	SCHWENCER (L) W/ Copies	ZIEMANN (L) W/ Copies	REGAN (E) W/ Copies
CLARK (L) W/ Copies	STOLZ (L) W/ Copies	DICKER (E) W/ Copies	LEAR (L) W/ Copies
PARR (L) W/ Copies	VASSALLO (L) W/ Copies	KNIGHTON (E) W/ Copies	W/ Copies
KNIEL (L) W/ Copies	PURPLE (L) W/ Copies	YOUNGBLOOD (E) W/ Copies	W/ Copies

INTERNAL DISTRIBUTION

<u>REG FILE</u> AEC PDR OSC, ROOM P-506A MUNTZING/STAFF CASE GIAMBUSO BOYD MOORE (L) (BWR) DEYOUNG (L) (PWR) SKOVHOLT (L) GOLLER (L) P. COLLINS DENISE REG OPR FILE & REGION (2) MORRIS STEELE	TECH REVIEW SCHROEDER MACCARY KNIGHT PAWLICKI SHAO STELLO HOUSTON NOVAK ROSS IPPOLITO TEDESCO LONG LAINAS BENAROYA VOLIMER	<u>ENVIRO</u> DENTON GRIMES GAMMILL KASTNER BALLARD SPANGLER MULLER DICKER KNIGHTON YOUNGBLOOD REGAN PROJECT LDR (2) Sc Abetti HARLESS	LIC ASST DIGGS (L) GEARIN (L) GOULBOURNE (L) KREUTZER (E) LEE (L) MAIGRET (L) REED (E) SERVICE (L) SHEPPARD (L) SLATER (E) SMITH (L) TEETS (L) WILLIAMS (E) WILSON (L)	A/T IND BRAITHAN SALTZMAN B. HURT PLANS MCDONALD CHAPMAN DUBE w/input E. COUPE D. THOMPSON (2) KLECKER EISENHUT
--	---	--	--	--

EXTERNAL DISTRIBUTION

Waihalla, S.C. LOCAL PDR TIC (ABERNATHY) (1) (2) (3) 1 - NSIC (BUCHANAN) 1 - ASLB 1 - Newton Anderson 1 - ACRS SENT to Lic Asst	NATIONAL LABS 1 - ASLB (IE W Bldg, Rm 529) 1 - W. PENNINGTON, Rm E-201 GT 1 - B&M SHINEDROAD, Rm E-201 GT 1 - CONSULTANTS NEWMARK, BLUMETAGBABIAN	1 - PDR SAN/LA/NY 1 - BROOKHAVEN NAT LAB 1 - G. ULRIKSON, OAKL 1 - AGMED (RUTH GUSMAN) Rm B-127 GT 1 - R. D. WUELLER, Rm E-201 GT
--	--	--

DUKE POWER COMPANY
POWER BUILDING
422 SOUTH CHURCH STREET, CHARLOTTE, N. C. 28201


A. C. THIES
SENIOR VICE PRESIDENT
PRODUCTION AND TRANSMISSION

Regulatory

File Cy. P. O. Box 2178

December 13, 1974

Mr. Angelo Giambusso
Deputy Director for Reactor Projects
Directorate of Licensing
Office of Regulation
U. S. Atomic Energy Commission
Washington, D. C. 20545



Re: Oconee Nuclear Station
Docket Nos. 50-269, -270, -287


Dear Mr. Giambusso:

On December 5, 1974, six of the 24 condenser cooling water (CCW) intake screens at the Oconee Nuclear Station were inspected. A total of 695 small fingerling fish, weighing 1,500 grams, had collected on the screens. The fish, averaging 2.15 grams per fish, were removed from the screens and categorized, where possible, as to screen location, type, size, degree of decomposition, and weight. This information is tabulated in Enclosure 1. It is concluded that the mortality of these 1,500 grams of fish had an insignificant effect on fisheries resources in Lake Keowee.

Very truly yours,

A. C. Thies

ACT:vr
Enclosure



cc: Mr. H. J. Logan
S. C. Wildlife & Marine Resources Dept.

12641

Enclosure 1

Oconee Nuclear Station

Summary of Fish Impingement Data Per Intake Screen

December 5, 1974

Screen 2A1

Total Fish Impinged - 207

<u>Species Composition</u>	<u>Size Groups</u>	<u>Decomposition*</u>	<u>Weight</u>
Bluegill - 36	2-4 cm - 30	Class 1 - 0	
Yellow Perch - 11	4-6 cm - 154	Class 2 - 40	~ 450 gms
Largemouth Bass - 2	6-8 cm - 19	Class 3 - 69	
Crappie - 1	8-10cm - 3	Class 4 - 98	
Threadfin Shad - 59	10-12cm - 1		
Unidentifiable - 98			

Screen 2A2

Total Fish Impinged - 419

<u>Species Composition</u>	<u>Size Groups</u>	<u>Decomposition*</u>	<u>Weight</u>
Bluegill - 61	2-4 cm - 67	Class 1 - 1	
Yellow Perch - 22	4-6 cm - 291	Class 2 - 12	~ 900 gms
Crappie - 3	6-8 cm - 52	Class 3 - 158	
Threadfin Shad - 85	8-10cm - 7	Class 4 - 248	
Unidentifiable - 248	10-12cm - 1		
	12-14cm - 1		

Screen 3A1

Total Fish Impinged - 30

<u>Species Composition</u>	<u>Size Groups</u>	<u>Decomposition*</u>	<u>Weight</u>
Bluegill - 2	2-4 cm - 6	Class 1 - 0	
Yellow Perch - 4	4-6 cm - 14	Class 2 - 5	~ 75 gms
Largemouth Bass - 1	6-8 cm - 9	Class 3 - 7	
Threadfin Shad - 5	10-12cm - 1	Class 4 - 18	
Unidentifiable - 18			

Screen 3A2

Total Fish Impinged - 39

<u>Species Composition</u>	<u>Size Groups</u>	<u>Decomposition*</u>	<u>Weight</u>
Bluegill - 2	2-4 cm - 14	Class 1 - 0	
Yellow Perch - 1	4-6 cm - 16	Class 2 - 5	~ 75 gms
Threadfin Shad - 5	6-8 cm - 9	Class 3 - 3	
Unidentifiable - 31		Class 4 - 31	

Screen 3B1

No fish impinged

Screen 3B2

No fish impinged

- * Class 1 - No noticeable decomposition
- Class 2 - Slightly decomposed
- Class 3 - Badly decomposed, identifiable
- Class 4 - Badly decomposed, unidentifiable