

**AEC DISTRIBUTION FOR PART 50 DOCKET MATERIAL**  
(TEMPORARY FORM)

CONTROL NO: 10254

FILE: \_\_\_\_\_

FROM: Duke Power Company Charlotte, N. C. 28201 A. C. Thies			DATE OF DOC 9-30-74	DATE REC'D 10-3-74	LTR X	TWX	RPT	OTHER
TO: N. C. Moseley			ORIG 1 cy	CC	OTHER	SENT AEC PDR <u>XX</u> SENT LOCAL PDR <u>XX</u>		
CLASS	UNCLASS XX	PROP INFO	INPUT	NO CYS REC'D 1		DOCKET NO: 50-287		

**DESCRIPTION:**

Ltr trans the following:

**Do Not Remove**  
**ACKNOWLEDGED**

PLANT NAME: Oconee #3

**ENCLOSURES:**

REPORT: Unusual Event No. UE-287/74-1 on  
8-18-74 re reactor coolant pump 3B2 reverse  
rotation

(1 cy encl)

**FOR ACTION/INFORMATION**

LMB 10-12-74

BUTLER (L)	SCHWENCER (L)	ZIEMANN (L)	REGAN (E)
W/ Copies	W/ Copies	W/ Copies	W/ Copies
CLARK (L)	STOLZ (L)	DICKER (E)	LEAR (L)
W/ Copies	W/ Copies	W/ Copies	W/ Copies
PARR (L)	VASSALLO (L)	KNIGHTON (E)	
W/ Copies	W/ Copies	W/ Copies	W/ Copies
KNIEL (L)	<del>PURPLE (L)</del>	YOUNGBLOOD (E)	
W/ Copies	W/ Copies	W/ Copies	W/ Copies

**INTERNAL DISTRIBUTION**

<u>REG FILE</u>	<u>TECH REVIEW</u>	<u>DENTON</u>	<u>LIC ASST</u>	<u>A/T IND</u>
<del>AEC PDR</del>	<del>SCHROEDER</del>	GRIMES	DIGGS (L)	BRAITMAN
<del>OGC, ROOM P-506A</del>	<del>MACCARY</del>	GAMMILL	GEARIN (L)	SALTZMAN
<del>MUNTZING/STAFF</del>	<del>KNIGHT</del>	KASTNER	GOULBOURNE (L)	B. HURT
<del>CASE</del>	<del>PAWLICKI</del>	BALLARD	KREUTZER (E)	<u>PLANS</u>
GIAMBUSSO	<del>SHAO</del>	SPANGLER	LEE (L)	MCDONALD
BOYD	<del>STELLO</del>	<u>ENVIRO</u>	MAIGRET (L)	CHAPMAN
MOORE (L) (BWR)	<del>HOUSTON</del>	MULLER	REED (E)	DUBE w/input
DEYOUNG (L) (PWR)	<del>NOVAK</del>	DICKER	SERVICE (L)	E. COUPE
SKOVHOLT (L)	<del>ROSS</del>	KNIGHTON	<del>SHEPPARD (L)</del>	
GOLLER (L)	<del>IPPOLITO</del>	YOUNGBLOOD	SLATER (E)	<del>D. THOMPSON (2)</del>
P. COLLINS	<del>TEDESCO</del>	REGAN	SMITH (L)	<del>KLECKER</del>
DENISE	<del>LONG</del>	PROJECT LDR	TEETS (L)	<del>EISENHUT</del>
<u>REG OPR</u>	<del>LAINAS</del>	<u>HARLESS</u>	WILLIAMS (E)	
<del>FILE &amp; REGION (3)</del>	<del>BENAROYA</del>		WILSON (L)	
<del>MORRIS</del>	<del>VOLIMER</del>			
<del>STEELE</del>				

**EXTERNAL DISTRIBUTION**

1 - LOCAL PDR Walhalla, S. C.	1 - NATIONAL LABS	1 - PDR-SAN/LA/NY
1 - TIC (ABERNATHY) (1)(2)(10)	1 - ASLBP (E/W Bldg, Rm 529)	1 - BROOKHAVEN NAT LAB
1 - NSIC (BUCHANAN)	1 - W. PENNINGTON, Rm E-201 GT	1 - G. ULRIKSON, ORNL
1 - ASLB	1 - B&M SWINEBROAD, Rm E-201 GT	1 - AGMED (RUTH GUSSMAN)
1 - Newton Anderson	1 - CONSULTANTS	Rm B-127 GT
5 - ACRS	NEWMARK/BLUME/AGBABIAN	1 - R. D. MUELLER, Rm E-201
SENT TO L/A SHEPPARD		GT

BN

4  
DUKE POWER COMPANY

POWER BUILDING

422 SOUTH CHURCH STREET, CHARLOTTE, N. C. 28201

Regulatory


File Cy.

A. C. THIES  
SENIOR VICE PRESIDENT  
PRODUCTION AND TRANSMISSION

P. O. Box 2178

September 30, 1974

Mr. Norman C. Moseley, Director  
Directorate of Regulatory Operations  
U. S. Atomic Energy Commission  
Region II - Suite 818  
230 Peachtree Street, Northwest  
Atlanta, Georgia 30303



Re: Oconee Unit 3  
Docket No. 50-287

Dear Mr. Moseley:


Pursuant to Sections 6.2 and 6.6.2 of the Oconee Nuclear Station  
Technical Specifications, please find attached Unusual Event  
Report UE-287/74-1.

Very truly yours,

A. C. Thies

ACT:vr  
Attachment

cc: Mr. Angelo Giambusso



10254

DUKE POWER COMPANY  
OCONEE UNIT 3

Report No.: UE-287/74-1

Report Date: September 30, 1974

Event Date: August 18, 1974

Facility: Oconee Unit 3, Seneca, South Carolina

Identification of Event: Reactor Coolant Pump 3B2 Reverse Rotation

Conditions Prior to Event: Reactor Shut Down, Coolant Temperature 220°F,  
Pressure 480 psi

Description of Event:

On August 17, 1974, the 3B2 Reactor Coolant Pump for Oconee Unit 3 was stopped after completion of venting the Reactor Coolant System. A short time later, it was noted that the zero motor speed indicator showed the pump was not at zero speed and the AC oil lift pump had been energized. Since the reactor coolant pumps have devices which prevent reverse rotation, it was assumed that a malfunction of the zero motor speed switch had occurred, and hence, the AC oil lift pump had been energized.

At 0930 on August 18, 1974, it was determined by vibration and observation of the motor shaft that 3B2 Reactor Coolant Pump was rotating in the reverse direction at approximately 680 revolutions per minute. The AC oil lift pump was started and low pressure service water was supplied to the oil cooler. All other reactor coolant pumps were stopped in order to stop 3B2 Reactor Coolant Pump. Tests performed by running various pump combinations could not reproduce the reverse rotation in 3B2 Reactor Coolant Pump.

Designation of Apparent Cause of Event:

The reverse rotation device for this particular reactor coolant pump consists of eleven pawls mounted in the flywheel of the pump. One of the pawls is shown in Figure 1. The pawls are supported by cutouts in the flywheel and retainer plates along the periphery of the flywheel. When the flywheel is rotating in the correct direction, the pawls become horizontal due to centrifugal action. As the flywheel slows, the pawls become vertical and drop into a ratchet plate to prevent reverse rotation. In RCP 3B2, the pawls contacted the retainer plate after the pump was started. The friction between the pawls and the retainer plates prevented the pawls from becoming vertical and preventing reverse rotation when the pump slowed.

Corrective Action:

Maintenance testing performed by using Prussian bluing determined that the pawls on 3B2 Reactor Coolant Pump were contacting the retainer plate on the

periphery of the flywheel. The retainer plates were modified by milling the area of contact, as shown in Figure 1, to ensure freedom of motion of the pawls. Subsequent testing has demonstrated that the pawls drop at 50 to 60 rpm, as designed.

There are 12 reactor coolant pump motors of two different designs at the Oconee Nuclear Station. Only two motors, 3B1 and 3B2, are of the earlier design and both have been modified to prevent interference by the retainer plate. The remainder of the pumps at Oconee are of the later design. The Unit 2 and 3 pumps have been satisfactorily tested. The Unit 1 pumps will be tested during the pending refueling outage.

A written standing order has been issued to Control Room operators to check for reverse rotation each time a reactor coolant pump is stopped. Indications which will be monitored are: pump speed, zero speed indication, and pump vibration.

FIGURE 1

