

NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL

FILE NUMBER
INCIDENT REPORT

TO:

N. R. C.

FROM:
Duke Power Company
Charlotte, North Carolina
William O. Parker, Jr.

DATE OF DOCUMENT
5/17/77

DATE RECEIVED
5/23/77

LETTER
 ORIGINAL
 COPY

NOTORIZED
 UNCLASSIFIED

PROP

INPUT FORM

NUMBER OF COPIES RECEIVED
1 cc -

DESCRIPTION

PLANT NAME: (1-P)
Ocone Units 1-2-3

RJL

ENCLOSURE

Consists of corrections to previously submitted reports concerning radioactive effluents released for the first six months of 1976 & the last six months of 1976.....

ACKNOWLEDGED

DO NOT REMOVE

(2-P)

NOTE: IF PERSONNEL EXPOSURE IS INVOLVED SEND DIRECTLY TO KREGER/J. COLLINS

FOR ACTION/INFORMATION

BRANCH CHIEF:	<i>SCHWENCER</i>
W/3 CYS FOR ACTION	
LIC. ASST.:	<i>SHEPPARD</i>
W/1 CYS	
ACRS 16 CYS HOLDING/SENT AS CAT B	

INTERNAL DISTRIBUTION

<input checked="" type="checkbox"/> REG FILE					
NRC PDR					
I & E (2)					
MIPC					
SCHROEDER/IPPOLITO					
HOUSTON					
NOVAK/CHECK					
GRIMES					
BUTLER					
HANAUER					
TEDESCO/MACCARY					
EISENHUT					
BAER					
SHAO					
VOLLMER/BUNCH					
KREGER/J. COLLINS					

EXTERNAL DISTRIBUTION

LPDR: <i>WABHALLA SC.</i>	
TIC:	
NSIC:	

CONTROL NUMBER

771450091

DUKE POWER COMPANY

POWER BUILDING


422 SOUTH CHURCH STREET, CHARLOTTE, N. C. 28242

WILLIAM O. PARKER, JR.
VICE PRESIDENT
STEAM PRODUCTION

May 17, 1977

TELEPHONE: AREA 704
373-4083

Director
U. S. Nuclear Regulatory Commission
Suite 818
230 Peachtree Street, Northwest
Atlanta, Georgia 30303



Re: Oconee Nuclear Station
Docket Nos. 50-269, -270, -287


Regulatory Docket File

Dear Sir:

Pursuant to 10CFR50.36a and Oconee Technical Specifications 6.6.1.2(c), reports were submitted on August 19, 1976 and February 23, 1977 concerning radioactive effluents released from Oconee Nuclear Station for the first six months of 1976 and the last six months of 1976, respectively. During review of this data, certain errors in isotope identification have been discovered. Please find attached copies of the following sheets which correct these errors.

1. Summary of liquid radioactive effluent releases for the first six month period transmitted by our letter of August 19, 1976. Under item 7, the isotope designated as Ag198m is corrected to read Ag108m.
2. Summary of liquid radioactive effluent releases for the first and second six month period transmitted by our letter of February 23, 1977. Under item 7, the isotope designated as Kr87 is corrected to read Ag108m.

Very truly yours,


William O. Parker, Jr.

LJB:ge
Attachment

cc: Mr. Ernst Volgenau

771450091

Radioactive Effluent Releases

Year 1976

I. Liquid Releases

	Units	January	February	March	April	May	June	Sub-Total
1. Gross radioactivity (Bq)								
a. total release	Curies	1.89	1.64	1.34	1.40×10^{-1}	1.23×10^{-1}	1.03×10^{-1}	5.24
b. average concentration released	$\mu\text{Ci/ml}$	1.67×10^{-8}	1.59×10^{-8}	1.09×10^{-8}	1.29×10^{-9}	8.55×10^{-10}	6.71×10^{-10}	7.72×10^{-9}
c. maximum concentration released	$\mu\text{Ci/ml}$	2.94×10^{-6}	3.79×10^{-6}	2.07×10^{-6}	2.50×10^{-7}	2.80×10^{-7}	3.22×10^{-6}	2.09×10^{-5}
2. Tritium								
a. total release	Curies	3.60×10^2	3.00×10^2	3.30×10^2	1.49×10^2	8.25 x 10	5.12×10	1.27×10^3
b. average concentration released	$\mu\text{Ci/ml}$	3.17×10^{-6}	2.89×10^{-6}	2.69×10^{-6}	1.38×10^{-6}	5.73×10^{-7}	3.35×10^{-7}	1.84×10^{-6}
3. Dissolved noble gases								
a. total release	Curies	5.01×10^{-2}	4.64×10^{-1}	4.26×10^{-1}	1.31×10^{-1}	2.32×10^{-3}	5.43×10^{-3}	1.08
b. average concentration released	$\mu\text{Ci/ml}$	4.41×10^{-10}	4.47×10^{-9}	3.47×10^{-9}	1.21×10^{-9}	1.61×10^{-11}	3.56×10^{-11}	1.61×10^{-9}
4. Gross alpha radioactivity								
a. total release	Curies	0	0	0	0	0	0	0
b. average concentration released	$\mu\text{Ci/ml}$	0	0	0	0	0	0	0
5. Volume of liquid waste to discharge canal	Liters	1.79×10^6	1.20×10^6	1.79×10^6	1.55×10^6	1.22×10^6	1.83×10^6	9.38×10^6
6. Volume of dilution water	Liters	1.14×10^{11}	1.04×10^{11}	1.23×10^{11}	1.08×10^{11}	1.44×10^{11}	1.53×10^{11}	7.46×10^{11}
7. Isotopes released	Curies							
Ba-La-140			1.49×10^{-2}	6.70×10^{-5}	8.86×10^{-6}	4.52×10^{-5}	7.50×10^{-5}	1.51×10^{-2}
Sr-89		2.26×10^{-3}	3.13×10^{-3}	1.96×10^{-3}	0	1.17×10^{-4}	2.93×10^{-5}	7.76×10^{-3}
I-131		6.35×10^{-1}	5.14×10^{-1}	1.44×10^{-1}	2.05×10^{-2}	1.48×10^{-2}	5.00×10^{-3}	1.33
I-133		3.52×10^{-2}	2.21×10^{-2}	8.25×10^{-4}	1.59×10^{-3}	0	4.90×10^{-4}	6.02×10^{-2}
Ye-133		5.01×10^{-2}	4.62×10^{-1}	4.23×10^{-1}	1.03×10^{-1}	2.32×10^{-3}	5.11×10^{-3}	1.05
Xe-135		0	1.16×10^{-3}	1.50×10^{-3}	2.65×10^{-2}	0	2.81×10^{-4}	2.94×10^{-2}
Ce-137		4.71×10^{-1}	3.39×10^{-1}	7.56×10^{-2}	5.50×10^{-3}	9.48×10^{-3}	3.86×10^{-3}	9.04×10^{-1}
Cs-134		2.94×10^{-1}	2.29×10^{-1}	5.96×10^{-2}	4.37×10^{-3}	6.35×10^{-3}	3.28×10^{-3}	5.97×10^{-1}
Co-60		7.48×10^{-2}	5.78×10^{-2}	1.25×10^{-1}	1.41×10^{-2}	1.34×10^{-2}	1.93×10^{-2}	3.04×10^{-1}
Co-58		3.15×10^{-1}	3.89×10^{-1}	8.71×10^{-1}	7.37×10^{-2}	6.17×10^{-2}	4.75×10^{-2}	1.74
Cr-51		1.75×10^{-2}	1.50×10^{-3}	1.40×10^{-2}	7.30×10^{-3}	1.47×10^{-3}	1.31×10^{-2}	5.46×10^{-2}
Mn-54		1.61×10^{-2}	2.57×10^{-2}	1.68×10^{-2}	3.43×10^{-3}	1.28×10^{-2}	5.42×10^{-3}	9.73×10^{-2}
Ag-109m			2.48×10^{-5}					2.48×10^{-5}
Ni-65					1.84×10^{-5}			1.84×10^{-5}
Nb-97				4.69×10^{-3}	6.63×10^{-3}	3.81×10^{-4}	3.18×10^{-4}	1.20×10^{-2}
Na-24		3.68×10^{-3}	2.08×10^{-3}	1.60×10^{-5}	2.52×10^{-5}		6.19×10^{-6}	5.86×10^{-3}
Xe-133m			1.31×10^{-3}	1.12×10^{-3}	6.56×10^{-4}		3.82×10^{-5}	3.12×10^{-3}
I-132		1.45×10^{-4}	9.63×10^{-5}		8.24×10^{-5}			3.24×10^{-4}
Cs-136		1.34×10^{-2}	1.38×10^{-2}	8.57×10^{-3}	1.45×10^{-4}	1.35×10^{-4}	2.61×10^{-5}	3.61×10^{-2}
Kr-85m				3.31×10^{-6}				3.31×10^{-6}
Kr-88				2.10×10^{-3}				2.10×10^{-3}
Np-239					1.95×10^{-5}			1.95×10^{-5}
Sr-90		1.41×10^{-4}	1.44×10^{-4}	8.94×10^{-5}	4.41×10^{-5}	1.22×10^{-5}	5.67×10^{-5}	4.86×10^{-4}
Sr-92								1.29×10^{-4}
Ce-144				1.29×10^{-4}				2.80×10^{-4}
Mn-56				2.80×10^{-4}				2.16×10^{-3}
Mo-99		2.16×10^{-3}						3.81×10^{-5}
Zr-97						3.81×10^{-6}		3.81×10^{-5}
Ag-110m		3.76×10^{-3}	4.71×10^{-4}	8.24×10^{-3}	2.50×10^{-3}	2.39×10^{-3}	2.54×10^{-3}	1.99×10^{-1}
Ba-139				3.42×10^{-4}				3.42×10^{-4}
Nb-95		3.69×10^{-4}		2.52×10^{-4}	9.33×10^{-5}	5.76×10^{-5}	4.53×10^{-4}	1.22×10^{-3}
Fe-59			6.43×10^{-4}	1.06×10^{-3}	3.33×10^{-4}	9.11×10^{-5}	5.15×10^{-5}	2.18×10^{-3}
Sr-124								1.95×10^{-5}
Co-57				5.54×10^{-4}	7.16×10^{-5}	2.56×10^{-5}	1.31×10^{-4}	7.82×10^{-4}
W-187								1.95×10^{-5}
Cs-135m								1.95×10^{-5}
Xe-131m					3.97×10^{-4}			3.97×10^{-4}
Zr-95		8.69×10^{-6}		4.15×10^{-5}		2.38×10^{-5}	1.49×10^{-4}	2.23×10^{-5}
I-134				2.44×10^{-5}				2.44×10^{-5}
In-115m		1.94×10^{-4}	2.73×10^{-4}		2.15×10^{-6}			4.69×10^{-4}
Ic-99m		1.11×10^{-2}	3.24×10^{-2}	2.93×10^{-3}	7.31×10^{-5}		2.74×10^{-5}	4.65×10^{-2}
Cd-115		1.31×10^{-3}		3.74×10^{-4}			6.68×10^{-4}	2.35×10^{-3}
Sn-125		2.98×10^{-3}						2.98×10^{-3}
Ru-103			4.09×10^{-5}		6.95×10^{-6}			4.79×10^{-5}
8. Percent of Technical Specifications limit (15 Ci) for total activity released		12.65	10.93	8.93	0.93	0.82	0.68	34.94

Radioactive Effluent Releases

1. Liquid Releases

	Units	Jan.-June	July-Dec.	1976
		1st 6 months	2nd 6 months	TOTAL
1. Gross radioactivity (E,y)	Curies			
a. total release		5.24	1.43	6.67
b. average concentration released	µCi/ml	7.72×10^{-9}	9.34×10^{-9}	8.53×10^{-9}
c. maximum concentration released	µCi/ml	2.09×10^{-6}	1.27×10^{-3}	1.28×10^{-3}
2. Tritium	Curies			
a. total release		1.27×10^3	9.20×10^2	2.19×10^3
b. average concentration released	µCi/ml	1.84×10^{-6}	8.03×10^{-6}	4.94×10^{-6}
3. Dissolved noble gases	Curies			
a. total release		1.08	1.88×10^{-1}	1.27
b. average concentration released	µCi/ml	1.61×10^{-9}	1.39×10^{-9}	1.50×10^{-9}
4. Gross alpha radioactivity	Curies			
a. total release		0	0	0
b. average concentration released	µCi/ml	0	0	0
5. Volume of liquid waste to discharge canal	Liters	9.38×10^6	1.01×10^7	1.95×10^7
6. Volume of dilution water	Liters	7.46×10^{11}	4.62×10^{11}	1.21×10^{12}
7. Isotopes released	Curies			
Ba-La-140		1.51×10^{-2}	3.10×10^{-3}	1.82×10^{-2}
Sr-89		7.76×10^{-3}	2.64×10^{-3}	1.04×10^{-2}
I-131		1.33	5.75×10^{-1}	1.91
I-133		6.02×10^{-2}	2.05×10^{-2}	8.07×10^{-2}
Xe-133		1.05	1.76×10^{-2}	1.07
Xe-135		2.94×10^{-2}	1.02×10^{-2}	3.96×10^{-2}
Cs-137		9.04×10^{-1}	1.40×10^{-1}	1.04
Cs-134		5.97×10^{-1}	3.85×10^{-2}	6.36×10^{-1}
Co-60		3.04×10^{-1}	6.38×10^{-2}	3.68×10^{-1}
Co-58		1.76	2.51×10^{-1}	2.01
Cr-51		5.46×10^{-2}	2.18×10^{-2}	7.64×10^{-2}
Mn-54		8.03×10^{-2}	1.51×10^{-1}	2.31×10^{-1}
Ag-108m		2.48×10^{-5}	0	2.48×10^{-5}
Zr-97		2.22×10^{-5}	1.18×10^{-4}	1.40×10^{-4}
Nb-97		1.20×10^{-2}	9.03×10^{-3}	2.10×10^{-2}
Na-24		5.86×10^{-3}	1.42×10^{-3}	7.28×10^{-3}
Xe-133m		3.12×10^{-3}	4.71×10^{-4}	3.59×10^{-3}
I-132		3.24×10^{-4}	0	3.24×10^{-4}
Cs-136		3.61×10^{-2}	1.06×10^{-2}	4.67×10^{-2}
Kr-85m		3.31×10^{-6}	3.45×10^{-4}	3.48×10^{-4}
Kr-88		2.10×10^{-3}	8.63×10^{-4}	2.96×10^{-3}
Zn-65		1.95×10^{-5}	0	1.95×10^{-5}
Sr-90		4.85×10^{-4}	1.65×10^{-4}	6.50×10^{-4}
Sr-92		-	3.28×10^{-4}	3.28×10^{-4}
Ce-144		1.29×10^{-4}	0	1.29×10^{-4}
Mn-56		2.80×10^{-4}	1.91×10^{-5}	2.99×10^{-4}
Mo-99		2.16×10^{-3}	3.77×10^{-3}	5.93×10^{-3}
Y-92		-	1.18×10^{-6}	1.18×10^{-6}
Ag-110m		1.99×10^{-2}	1.31×10^{-2}	3.30×10^{-2}
Ba-139		3.42×10^{-4}	0	3.42×10^{-4}
Pb-95		1.22×10^{-3}	1.02×10^{-3}	2.24×10^{-3}
Fe-59		2.18×10^{-3}	3.94×10^{-3}	6.12×10^{-3}
Co-57		7.82×10^{-4}	4.01×10^{-4}	1.18×10^{-3}
Xe-131m		3.97×10^{-4}	0	3.97×10^{-4}
Zr-95		2.23×10^{-4}	1.52×10^{-3}	1.74×10^{-3}
I-134		2.44×10^{-5}	1.42×10^{-4}	1.66×10^{-4}
In-115m		4.69×10^{-4}	2.79×10^{-5}	5.00×10^{-4}
Tc-99m		4.65×10^{-2}	5.87×10^{-3}	5.24×10^{-2}
Cd-115		2.35×10^{-3}	1.80×10^{-3}	4.15×10^{-3}
Sn-125m		2.98×10^{-3}	1.21×10^{-2}	1.51×10^{-2}
Ru-103		4.79×10^{-5}	0	4.79×10^{-5}
I-135		-	5.45×10^{-4}	5.45×10^{-4}
W-187		-	1.08×10^{-4}	1.08×10^{-4}
Cd-115m		-	5.01×10^{-4}	5.01×10^{-4}
Ce-134		-	3.17×10^{-3}	3.17×10^{-3}
Ar-41		-	2.06×10^{-5}	2.06×10^{-5}
Rb-88		-	2.95×10^{-2}	2.95×10^{-2}
8. Percent of Technical Specifications limit (15 Ci) for total activity released.		34.94	9.43	44.37