

DISTRIBUTION AFTER ISSUANCE OF OPERATING LICENSE

NRC FORM 195
(2-76)

U.S. NUCLEAR REGULATORY COMMISSION

DOCKET NUMBER

50-287

NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL

FILE NUMBER

TO:

Mr. Edson G. Case

FROM:

Duke Power Company
Charlotte, North Carolina
William O. Parker, Jr.

DATE OF DOCUMENT

12/12/77

DATE RECEIVED

12/19/77

☒ LETTER☐ NOTORIZED

PROP

INPUT FORM

NUMBER OF COPIES RECEIVED

☒ ORIGINAL☒ UNCLASSIFIED☐ COPY

1 signed

DESCRIPTION

Advising that no tubes in the Oconee Unit 3 steam generators were removed from service due to inspection results re inservice inspection of steam generator tubes.....

ENCLOSURE

PLANT NAME: Oconee Unit No. 3

RJL 12/20/77

(1-P)

SAFETY

FOR ACTION/INFORMATION

BRANCH CHIEF: (7)

Schwencer

INTERNAL DISTRIBUTION

☒ REG FILE☐ NRC-PDR

I & E (2)

OELD

HANAUER

CHECK

EISENHUT

SHAO

BAER

BUTLER

BRIMES

J. COLLINS

J. MCGOUGH

EXTERNAL DISTRIBUTION

LPDR: WALHALLA, S.C.

TIC

NSIC

ACRS 16 CYS SENT CATEGORY

CONTROL NUMBER

773540060

DUKE POWER COMPANY
POWER BUILDING
422 SOUTH CHURCH STREET, CHARLOTTE, N. C. 28242


REGULATORY DOCKET FILE COPY

WILLIAM O. PARKER, JR.
VICE PRESIDENT
STEAM PRODUCTION

December 12, 1977

TELEPHONE: AREA 704
373-4083

Mr. Edson G. Case, Acting Director
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555




RE: Oconee Unit 3
Docket No. 287

Dear Sir:

In accordance with our letter of June 21, 1977 which proposed revisions to the Oconee Nuclear Station Technical Specifications concerning steam generator tubing surveillance, a report is to be submitted within 30 days following each inservice inspection of steam generator tubes. The report is to provide the number of tubes plugged in each steam generator as a result of that inspection.

The purpose of this letter is to advise you that no tubes in the Oconee Unit 3 steam generators were removed from service due to inspection results.

Very truly yours,


William O. Parker, Jr.

MST:ge

773540060