

DISTRIBUTION AFTER ISSUANCE OF OPERATING LICENSE

NRC FORM 195
(2-76)

U.S. NUCLEAR REGULATORY COMMISSION

DOCKET NUMBER

50-287

NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL

FILE NUMBER

TO:

Mr. Edson G. Case

FROM:
Duke Power Company
Charlotte, North Carolina
William O. Parker, Jr.

DATE OF DOCUMENT
12/12/77

DATE RECEIVED
12/19/77

LETTER
 ORIGINAL
 COPY

NOTORIZED
 UNCLASSIFIED

PROP

INPUT FORM

NUMBER OF COPIES RECEIVED

1 signed

DESCRIPTION

Advising that no tubes in the Oconee Unit 3 steam generators were removed from service due to inspection results re inservice inspection of steam generator tubes.....

PLANT NAME: Oconee Unit No. 3
RJL 12/20/77 (1-P)

ENCLOSURE

SAFETY FOR ACTION/INFORMATION

BRANCH CHIEF: (7)	Schwencer		

INTERNAL DISTRIBUTION

<input checked="" type="checkbox"/> REG FILE			
<input type="checkbox"/> NRC-PDR			
T & E (2)			
OELD			
HANAUER			
CHECK			
EISENHUT			
SHAO			
BAER			
BUTLER			
BRIMES			
J. COLLINS			
J. MCGOUGH			

EXTERNAL DISTRIBUTION

LPDR: WALHALLA, S.C.		
TIC		
NSIC		
ACRS 16 CYS SENT CATEGORY		

CONTROL NUMBER

nmh4
773540060

DUKE POWER COMPANY

POWER BUILDING

422 SOUTH CHURCH STREET, CHARLOTTE, N. C. 28242


REGULATORY DOCKET FILE COPY

WILLIAM O. PARKER, JR.
VICE PRESIDENT
STEAM PRODUCTION

December 12, 1977

TELEPHONE: AREA 704
373-4083

Mr. Edson G. Case, Acting Director
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555




RE: Oconee Unit 3
Docket No. 287

Dear Sir:

In accordance with our letter of June 21, 1977 which proposed revisions to the Oconee Nuclear Station Technical Specifications concerning steam generator tubing surveillance, a report is to be submitted within 30 days following each inservice inspection of steam generator tubes. The report is to provide the number of tubes plugged in each steam generator as a result of that inspection.

The purpose of this letter is to advise you that no tubes in the Oconee Unit 3 steam generators were removed from service due to inspection results.

Very truly yours,


William O. Parker, Jr.

MST:ge

773540060