

B 03/15/78

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)
DISTRIBUTION FOR INCOMING MATERIAL 50-287

REC: OREILLY J P
NRC

ORG: PARKER W O
DUKE PWR

DOC DATE: 03/09/78
DATE RCVD: 03/14/78

DOCTYPE: LETTER NOTARIZED: NO COPIES RECEIVED
SUBJECT: LTR 1 ENCL 1
LICENSEE EVENT REPT (RO 50-287/78-005) ON 02/07/78 CONCERNING DURING VALVE
OPERABILITY TEST, BS-2 FAILED IN AN INTERMEDIATE POSITION CAUSING ONE OF TWO
BLDG SPRAY TRAINS TO BE INOPERABLE.

PLANT NAME: OGDNEE - UNIT 3

REVIEWER INITIAL: XJM
DISTRIBUTOR INITIAL: DL

***** DISTRIBUTION OF THIS MATERIAL IS AS FOLLOWS *****

NOTES:

- 1. M. CUNNINGHAM - ALL AMENDMENTS TO FSAR AND CHANGES TO TECH SPECS

INCIDENT REPORTS
(DISTRIBUTION CODE A002)

FOR ACTION: ~~GR CHIEF REID**W/4 ENCL~~

INTERNAL:	REG FILE**W/ENCL	NRC PDR**W/ENCL
	I & E**W/2 ENCL	MIPC**W/3 ENCL
	SCHROEDER/IPPOLITO**W/ENCL	HOUSTON**W/ENCL
	NOVAK/CHECK**W/ENCL	GRIMES**W/ENCL
	KNIGHT**W/ENCL	BUTLER**W/ENCL
	HANAUER**W/ENCL	TEDESCO**W/ENCL
	EISENHUT**W/ENCL	BAER**W/ENCL
	SHAO**W/ENCL	VOLLMER/BUNCH**W/ENCL
	KREGER/J. COLLINS**W/ENCL	ROSA**W/ENCL
	K SEYFRIT/IE**W/ENCL	

EXTERNAL: LPDR'S
WALHALLA, SC**W/ENCL
TIC**W/ENCL
NSIC**W/ENCL
ACRS CAT B**W/16 ENCL

DISTRIBUTION: LTR 45 ENCL 45
SIZE: 1P+1P+1P

CONTROL NBR: 780740017

***** THE END *****

DUKE POWER COMPANY

POWER BUILDING

422 SOUTH CHURCH STREET, CHARLOTTE, N. C. 28242


REGULATORY DOCKET FILE COPY

WILLIAM O. PARKER, JR.
VICE PRESIDENT
STEAM PRODUCTION

TELEPHONE: AREA 704
373-4083

March 9, 1978

Mr. James P. O'Reilly, Director
U. S. Nuclear Regulatory Commission
Suite 1217
230 Peachtree Street, Northwest
Atlanta, GA 30303



RE: Oconee Unit 3
Docket No. 50-287

Dear Mr. O'Reilly:

Pursuant to Sections 6.2 and 6.6.2 of the Oconee Nuclear Station Technical Specifications, please find attached Reportable Occurrence Report RO-287/78-5.

Very truly yours,

William O. Parker Jr.
William O. Parker, Jr. *by WAH*

KRW/rpc

Attachment

cc: Director, Office of Management Information
and Program Control

780740017

A002
S
111

DUKE POWER COMPANY
OCONEE UNIT 3

Report Number: RO-287/78-5

Report Date: March 9, 1978

Occurrence Date: February 7, 1978

Facility: Oconee Unit 3, Seneca, South Carolina

Identification of Occurrence: 3BS-2 ES Discharge Valve Failure

Conditions Prior to Occurrence: 100 Percent Full Power

Description of Occurrence:

On February 7 at 0950 during the performance of PT/3/A/0150/15A (valve operability), valve 3BS-2 Reactor Building Spray System Discharge Valve, failed in an intermediate position. It was determined that the valve stem was damaged and would have to be replaced. A replacement valve stem was fabricated on-site but failed when it was operated. A reactor shutdown was commenced at 1849 as required by Technical Specification 3.3.5. The shutdown was halted when the station was notified that a Technical Specification change had been approved extending the time allowed for repair to 72 hours. At 0345 on February 10, the stem was replaced and the valve functioned properly.

Apparent Cause of Occurrence:

The apparent cause of the valve failure was the faulty stem which was either caused or aggravated by a faulty torque switch.

Analysis of Occurrence:

The failure of 3BS-2 caused the B train of the Reactor Building Spray System to be inoperable. However, the A train was available at all times to mitigate the consequences of any potential accidents. The analysis of the potential hazard associated with one spray train being inoperable is presented in FSAR Supplement 13 and indicates that the system is fully capable of handling any postulated incident. The Technical Specifications for the Oconee Nuclear Station allow for a 24 hour repair time but Standard Technical Specifications allow a 72 hour period. Upon request by Duke, the NRC extended the allowed repair time to 72 hours. The health and safety of the public were not affected by this incident.

Corrective Action:

The corrective action taken was the replacement of the valve stem, stem key and torque switch. The valve functioned properly after the repair parts were installed.

