

FROM: Duke Power Company Charlotte, N.C. 28201 Mr. A. C. Thies			DATE OF DOC 4-10-74	DATE REC'D 4-12-74	LTR X	MEMO	RPT	OTHER
TO: AEC			ORIG 1 signed	CC	OTHER	SENT AEC PDR SENT LOCAL PDR		XXX XXX
CLASS	UNCLASS XXX	PROP INFO	INPUT	NO CYS REC'D 1	DOCKET NO: 50-269/270			

DESCRIPTION:
Ltr trans the following....

PLANT NAME: Oconee 1 & 2

ENCLOSURES:
March monthly operating report "Plant operability and availability" for preparing the Grey Book

ACKNOWLEDGED
(1 cy encl rec'd)
DO NOT REMOVE

FOR ACTION/INFORMATION

4-12-74

JB

- | | | | |
|------------------------|---------------------------|----------------------------|-----------------------|
| BUTLER(L)
W/ Copies | SCHWENCER(L)
W/ Copies | ZIEMANN(L)
W/ Copies | REGAN(E)
W/ Copies |
| CLARK(L)
W/ Copies | STOLZ(L)
W/ Copies | DICKER(E)
W/ Copies | ✓ W. Magee |
| GOLLER(L)
W/ Copies | VASSALLO(L)
W/ Copies | KNIGHTON(E)
W/ Copies | W/ 2 Copies |
| KNIEL(L)
W/ Copies | SCHEMEL(L)
W/ Copies | YOUNGBLOOD(E)
W/ Copies | W/ Copies |

INTERNAL DISTRIBUTION

- | | | | | |
|---------------------------|--------------------|----------------|----------------|--------------|
| ✓ <u>REG FILE (L-270)</u> | <u>TECH REVIEW</u> | DENTON | LIC ASST | A/T IND |
| ✓ AEC PDR (L-270) | HENDRIE | GRIMES | DIGGS (L) | BRAITMAN |
| OGC, ROOM P-506A | SCHROEDER | GAMMILL | GEARIN (L) | SALTZMAN |
| MUNTZING/STAFF | MACCARY | KASTNER | GOULBOURNE (L) | B. HURT |
| CASE | KNIGHT | BALLARD | LEE (L) | <u>PLANS</u> |
| GIAMBUSSO | PAWLICKI | SPANGLER | MAIGRET (L) | ✓ MCDONALD |
| BOYD | SHAO | <u>ENVIRO</u> | REED (E) | DUBE w/Input |
| MOORE (L)(BWR) | STELLO | <u>MULLER</u> | SERVICE (L) | <u>INFO</u> |
| DEYOUNG(L)(PWR) | HOUSTON | DICKER | SHEPPARD (L) | C. MILES |
| SKOVHOLT (L) | NOVAK | KNIGHTON | SLATER (E) | B. KING |
| P. COLLINS | ROSS | YOUNGBLOOD | SMITH (L) | ✓ Chapman |
| DENISE | IPPOLITO | REGAN | TEETS (L) | ✓ Schwencer |
| <u>REG OPR</u> | TEDESCO | PROJECT LDR | WADE (E) | |
| FILE & REGION(3) | LONG | <u>HARLESS</u> | WILLIAMS (E) | |
| MORRIS | LAINAS | | WILSON (L) | |
| STEELE | BENAROYA | | | |
| | VOLLMER | | | |

EXTERNAL DISTRIBUTION

- | | | |
|---------------------------------------|------------------------------|------------------------|
| ✓ 1 - LOCAL PDR <u>Walhalla, S.C.</u> | (1)(2)(10)-NATIONAL LAB'S | 1-PDR-SAN/LA/NY |
| ✓ 1 - DTIE(ABERNATHY) | 1-ASLBP(E/W Bldg, Rm 529) | 1-GERALD LELLOUCHE |
| ✓ 1 - NSIC(BUCHANAN) | 1-W. PENNINGTON, Rm E-201 GT | BROOKHAVEN NAT. LAB |
| 1 - ASLB(YORE) | 1-CONSULTANT'S | 1-AGMED(Ruth Gussman) |
| | NEWMARK/BLUME/AGBABIAN | RM-B-127, GT. |
| 16 - CYS ACRS HOLDING | 1-GERALD ULRIKSON...ORNL | 1-RD..MULLER..F-309 GT |

Rg.

13

1954

10588
10589
10590

1-13-54

105

1-13-54

105

10588-10590

1

105

Handwritten notes and stamps at the bottom of the page, including a date and some illegible text.

October 1 1954

10588-10590

10588-10590

10588-10590

10588-10590

DUKE POWER COMPANY

POWER BUILDING

422 SOUTH CHURCH STREET, CHARLOTTE, N. C. 28201

A. C. THIES
SENIOR VICE PRESIDENT
PRODUCTION AND TRANSMISSION

P. O. Box 2178

April 10, 1974

Director
Office of Plans and Schedules
Directorate of Licensing
Office of Regulation
U. S. Atomic Energy Commission
Washington, D. C. 20545

Re: Oconee Nuclear Station
Units 1 and 2
Docket Nos. 50-269 and 50-270

Dear Sir:



Please find attached information requested in Mr. L. Manning Muntzing's letter of February 19, 1974. This information is submitted on the forms provided and covers the performance and operating status of Oconee Units 1 and 2 for the month of March, 1974.

Very truly yours,

A. C. Thies for
A. C. Thies

ACT:vr
Attachment

cc: Mr. Norman C. Moseley



UNIT Oconee Unit 1

DATE April 10, 1974

OPERATING STATUS

1. REPORTING PERIOD: March 1 TO March 31, 1974

GROSS HOURS IN REPORTING PERIOD: 744

2. CURRENTLY AUTHORIZED POWER LEVEL Mwt 2568 MWe-NET 871

3. POWER LEVEL TO WHICH RESTRICTED (IF ANY): None

4. REASONS FOR RESTRICTIONS (IF ANY):

	THIS MONTH	YR-TO-DATE	CUMULATIVE TO DATE
5. HOURS REACTOR WAS CRITICAL	<u>739.9</u>	<u>1684.9</u>	<u>6038.8</u>
6. HOURS GENERATOR ON-LINE	<u>732.3</u>	<u>1629.6</u>	<u>4618.7</u>
7. GROSS THERMAL POWER GENERATED (MWH)	<u>1,666,746</u>	<u>3,768,909</u>	<u>9,779,789</u>
8. GROSS ELECTRICAL POWER GENERATED (MWH)	<u>590,628</u>	<u>1,327,280</u>	<u>3,415,868</u>
9. NET ELECTRICAL POWER GENERATED (MWH)	<u>562,144</u>	<u>1,257,495</u>	<u>3,216,573</u>
10. REACTOR AVAILABILITY FACTOR (1)	<u>99.5</u>	<u>78.0</u>	<u>97.2</u>
11. PLANT AVAILABILITY FACTOR (2)	<u>98.4</u>	<u>75.5</u>	<u>74.3</u>
12. PLANT CAPACITY FACTOR (3)	<u>86.8</u>	<u>66.9</u>	<u>59.4</u>
13. FORCED OUTAGE RATE (4)	<u>1.6</u>	<u>6.7</u>	<u>8.15</u>

14. SHUTDOWNS SCHEDULED TO BEGIN IN NEXT 6 MONTHS (STATE TYPE, DATE AND DURATION OF EACH): Two week shutdown for modifications to high energy lines outside containment to commence April 24, 1974.

15. IF SHUTDOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP: _____

16. PLANTS IN TEST STATUS (PRIOR TO COMMERCIAL OPERATION) REPORT THE FOLLOWING:

	DATE LAST FORECAST	DATE ACHIEVED	REASON FOR DIFFERENCE
INITIAL CRITICALITY	_____	_____	_____
INITIAL ELECTRICAL POWER GENERATION	_____	_____	_____
COMMERCIAL OPERATION	_____	_____	_____

(1) REACTOR AVAILABILITY FACTOR = $\frac{\text{HOURS REACTOR WAS CRITICAL}}{\text{GROSS HOURS IN REPORTING PERIOD}} * 100$

(2) PLANT AVAILABILITY FACTOR = $\frac{\text{HOURS GENERATOR ON-LINE}}{\text{GROSS HOURS IN REPORTING PERIOD}} * 100$

(3) PLANT CAPACITY FACTOR = $\frac{\text{NET ELECTRICAL POWER GENERATED}}{\text{CURRENTLY LICENSED POWER LEVEL * GROSS HOURS IN REPORTING PERIOD}}$

(4) FORCED OUTAGE RATE = $\frac{\text{FORCED OUTAGE HOURS}}{\text{HOURS GENERATOR ON-LINE + FORCED OUTAGE HOURS}} * 100$

SUMMARY:

UNIT NAME Oconee Unit 1
DATE April 10, 1974

REPORT MONTH March, 1974

PLANT SHUTDOWNS

NO.	DATE	TYPE F-FORCED S-SCHEDULED	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR (2)	COMMENTS
4	740311	F	11.7	A*	C	*External Cause

(1) REASON:
A-EQUIPMENT FAILURE (EXPLAIN)
B-MAINT. OR TEST
C-REFUELING
D-REGULATORY RESTRICTION
E-OPERATOR TRAINING AND
LICENSE EXAMINATION
F-ADMINISTRATIVE
G-OPERATIONAL ERROR
(EXPLAIN)

(2) METHOD:
A- MANUAL
B- MANUAL SCRAM
C- AUTOMATIC SCRAM

UNIT Oconee Unit 1

DATE 4/8/74

DAILY PLANT POWER OUTPUT

MONTH March, 1974

<u>DAY</u>	<u>AVERAGE DAILY MWe-net</u>	<u>DAY</u>	<u>AVERAGE DAILY MWe-net</u>
1	<u>20962</u>	22	<u>20822</u>
2	<u>20006</u>	23	<u>20696</u>
3	<u>16253</u>	24	<u>20669</u>
4	<u>20912</u>	25	<u>20899</u>
5	<u>16563</u>	26	<u>20772</u>
6	<u>20899</u>	27	<u>20694</u>
7	<u>20942</u>	28	<u>20773</u>
8	<u>20502</u>	29	<u>20838</u>
9	<u>20114</u>	30	<u>20815</u>
10	<u>20759</u>	31	<u>20703</u>
11	<u>7614</u>		
12	<u>13091</u>		
13	<u>14672</u>		
14	<u>14606</u>		
15	<u>14538</u>		
16	<u>14329</u>		
17	<u>14176</u>		
18	<u>14010</u>		
19	<u>14361</u>		
20	<u>15026</u>		
21	<u>20128</u>		

UNIT Oconee Unit

DATE April 10, 1974

OPERATING STATUS

1. REPORTING PERIOD: March 1 TO March 31, 1974

GROSS HOURS IN REPORTING PERIOD: 744

2. CURRENTLY AUTHORIZED POWER LEVEL MWe 2568 MWe-NET _____

3. POWER LEVEL TO WHICH RESTRICTED (IF ANY): None

4. REASONS FOR RESTRICTIONS (IF ANY):
Oconee Unit 2 is currently in power escalation testing and is not commercially operable. Items 10-13 are not applicable.

	THIS MONTH	YR-TO-DATE	CUMULATIVE TO DATE
5. HOURS REACTOR WAS CRITICAL	0	85.6	743.0
6. HOURS GENERATOR ON-LINE	0	64.0	577.2
7. GROSS THERMAL POWER GENERATED (MWH)	0	104099	709271
8. GROSS ELECTRICAL POWER GENERATED (MWH)	0	33000	209310
9. NET ELECTRICAL POWER GENERATED (MWH)	-2165	21447	173734
10. REACTOR AVAILABILITY FACTOR (1)	_____	_____	_____
11. PLANT AVAILABILITY FACTOR (2)	_____	_____	_____
12. PLANT CAPACITY FACTOR (3)	_____	_____	_____
13. FORCED OUTAGE RATE (4)	_____	_____	_____

14. SHUTDOWNS SCHEDULED TO BEGIN IN NEXT 6 MONTHS (STATE TYPE, DATE AND DURATION OF EACH):

15. IF SHUTDOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP: _____

16. PLANTS IN TEST STATUS (PRIOR TO COMMERCIAL OPERATION) REPORT THE FOLLOWING:

	DATE LAST FORECAST	DATE ACHIEVED	REASON FOR DIFFERENCE
INITIAL CRITICALITY	_____	11/11/73	_____
INITIAL ELECTRICAL POWER GENERATION	_____	12/5/73	_____
COMMERCIAL OPERATION	5/15/74	_____	_____

(1) REACTOR AVAILABILITY FACTOR = $\frac{\text{HOURS REACTOR WAS CRITICAL}}{\text{GROSS HOURS IN REPORTING PERIOD}} * 100$

(2) PLANT AVAILABILITY FACTOR = $\frac{\text{HOURS GENERATOR ON-LINE}}{\text{GROSS HOURS IN REPORTING PERIOD}} * 100$

(3) PLANT CAPACITY FACTOR = $\frac{\text{NET ELECTRICAL POWER GENERATED}}{\text{CURRENTLY LICENSED POWER LEVEL * GROSS HOURS IN REPORTING PERIOD}}$

(4) FORCED OUTAGE RATE = $\frac{\text{FORCED OUTAGE HOURS}}{\text{HOURS GENERATOR ON-LINE + FORCED OUTAGE HOURS}} * 100$

SUMMARY:

UNIT NAME Oconee Unit 2

DATE April 10, 1974

REPORT MONTH March, 1974

PLANT SHUTDOWNS

NO.	DATE	TYPE F-FORCED S-SCHEDULED	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR (2)	COMMENTS
3	740122	F	744	A	B	

(1) REASON:
A-EQUIPMENT FAILURE (EXPLAIN)
B-MAINT. OR TEST
C-REFUELING
D-REGULATORY RESTRICTION
E-OPERATOR TRAINING AND
LICENSE EXAMINATION
F-ADMINISTRATIVE
G-OPERATIONAL ERROR
(EXPLAIN)

(2) METHOD:
A- MANUAL
B- MANUAL SCRAM
C- AUTOMATIC SCRAM



26x18