



United States Department of the Interior

FISH AND WILDLIFE SERVICE

BUREAU OF SPORT FISHERIES AND WILDLIFE

WASHINGTON, D.C. 20240

ADDRESS ONLY THE DIRECTOR
BUREAU OF SPORT FISHERIES
AND WILDLIFE

50-269

50-270

50-287

OCT 4 1971

Mr. Harold L. Price
Director of Regulation
U.S. Atomic Energy Commission
Washington, D.C. 20545



Dear Mr. Price:

This is in response to Mr. DeYoung's letter of July 12, 1971, transmitting copies of the Pre-Operational Environmental Radioactivity Monitoring Program Report for the Duke Power Company's Oconee Nuclear Station, South Carolina, AEC Docket Nos. 50-269, 270, and 287.

The environmental monitoring program for this station for the most part is adequate, but data for benthic organisms are omitted in some tables. The list of criteria for the selection of sampling locations as mentioned on pages 6 and 7 of the report appears adequate. However, in subsequent tables, listing samples and locations (summary, 2-1 and 2-1a) no data are shown for benthic organisms. Also, the distance from the radioactive waste discharge point to the nearest downstream sampling station is not clearly indicated.

Sincerely yours,

Willis King
Assistant
Director

4313

DEC 8 1971

Docket Nos. 50-269
50-270
and 50-287

Dr. Spencer H. Bush
Chairman, Advisory Committee
on Reactor Safeguards
U. S. Atomic Energy Commission
Washington, D. C. 20545

Dear Dr. Bush:

Three (3) copies of the following are transmitted
for the information of the Committee:

DUKE POWER COMPANY
(Oconee Nuclear Station, Units 1, 2, and 3)

Comments by the Fish and Wildlife Service dated October 4, 1971
on the applicant's Pre-Operational Environmental Radioactivity
Monitoring Program Report for the Duke Power Station. (DRL Control
No. 4313)

DISTRIBUTION

Docket File (3)
PWR-4 Reading
F. W. Karas (2)
A. Schwencer

Sincerely,

Peter A. Morris

Peter A. Morris, Director
Division of Reactor Licensing

Enclosures:
As stated

OFFICE ▶	DRL:AD/PWRs	DRL:PWR-4				
SURNAME ▶	<i>FWK</i> FWKaras:emp	<i>AS</i> ASchwencer				<i>LB</i>
DATE ▶	12/7/71	12/8/71				

Docket No. 50-269

DEC 8 1971

Dr. Spencer H. Bush
Chairman, Advisory Committee
on Reactor Safeguards
U. S. Atomic Energy Commission
Washington, D. C. 20545

Dear Dr. Bush:

Three (3) copies of the following are transmitted
for the information of the Committee:

DUKE POWER COMPANY
(Oconee Nuclear Station Unit 1)

Duke Power Company's letter dated November 15, 1971 requesting
AEC approval of a deviation from Technical Specification 3.1.2.1
for zero power physics testing. (DRL Control No. 5044)

DISTRIBUTION

Docket
PWR-4 Reading
FWKaras (2)
ASchwencer

Sincerely,

Peter A. Morris

Peter A. Morris, Director
Division of Reactor Licensing

Enclosures:
As stated

OFFICE ▶	DRL:AD/PWRs	DRL:PWR-4				
SURNAME ▶	<i>FWK</i> FWKaras:emp	<i>AS</i> ASchwencer				
DATE ▶	12/7/71	12/8/71				