

NRR-PMDAPEm Resource

From: Schaaf, Robert
Sent: Monday, February 01, 2016 2:26 PM
To: Gordon Arent; Casey, Kevin E (kecasey@tva.gov)
Cc: Daniels, Desiree L
Subject: Watts Bar 2 Request for Additional Information on Relief Request ISPT-02 (CAC No. MF7038)
Attachments: Watts Bar Unit 2 Request for Additional Information on Relief Request ISPT-02.pdf

Gentlemen,

By letter dated October 30, 2015 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML15303A546), Tennessee Valley Authority requested approval of alternative testing associated with the inservice inspection program first 10-year interval for Watts Bar Nuclear Plant, Unit 2.

The U.S. Nuclear Regulatory Commission staff is reviewing your submittal and has determined that additional information is required to complete the review. The specific information requested is attached to this e-mail. The proposed question was provided to your staff on February 1, 2016, for clarification, if needed. TVA indicated by e-mail on February 1, 2016, that no clarification was needed. TVA agreed to provide a response to this request by March 2, 2016.

Regards,
Robert G. Schaaf
Senior Project Manager, Watts Bar/Bellefonte
Plant Licensing Branch II-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Mail Stop O-8G9A
Washington, DC 20555
301-415-6020 (o)
Robert.Schaaf@nrc.gov

Hearing Identifier: NRR_PMDA
Email Number: 2629

Mail Envelope Properties (Robert.Schaaf@nrc.gov20160201142600)

Subject: Watts Bar 2 Request for Additional Information on Relief Request ISPT-02 (CAC No. MF7038)
Sent Date: 2/1/2016 2:26:21 PM
Received Date: 2/1/2016 2:26:00 PM
From: Schaaf, Robert

Created By: Robert.Schaaf@nrc.gov

Recipients:
"Daniels, Desiree L" <dlboyd@tva.gov>
Tracking Status: None
"Gordon Arent" <garent@tva.gov>
Tracking Status: None
"Casey, Kevin E (kecasey@tva.gov)" <kecasey@tva.gov>
Tracking Status: None

Post Office:

Files	Size	Date & Time
MESSAGE	1095	2/1/2016 2:26:00 PM
Watts Bar Unit 2 Request for Additional Information on Relief Request ISPT-02.pdf	15267	

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received: ZZZ

REQUEST FOR ADDITIONAL INFORMATION
REGARDING REQUEST NUMBER ISPT-02
FOR THE INSERVICE INSPECTION PROGRAM FIRST 10-YEAR INTERVAL
TENNESSEE VALLEY AUTHORITY
WATTS BAR NUCLEAR PLANT UNIT 2
DOCKET NO. 50-391

By letter dated October 30, 2015, Agencywide Documents Access and Management System (ADAMS) Accession No. ML15303A546 Cost Activity Code (CAC) Number MF7038, Tennessee Valley Authority (TVA), the licensee, requested approval of alternative testing associated with the inservice inspection (ISI) program first 10-year interval for Watts Bar Nuclear Plant (WBN) Unit 2. The Nuclear Regulatory Commission (NRC) staff is reviewing the submittal and has the following question:

Request ISPT-02:

- 1) What is the proposed test pressure (i.e., the numerical value of the static head pressure developed from the water level above the reactor pressure vessel flange when the reactor cavity is flooded) for the proposed system leakage testing of the subject leak-off piping?

ENCLOSURE