

## **NRR-PMDAPem Resource**

---

**From:** Schaaf, Robert  
**Sent:** Monday, February 01, 2016 2:26 PM  
**To:** Gordon Arent; Casey, Kevin E (kecasey@tva.gov)  
**Cc:** Daniels, Desiree L  
**Subject:** Watts Bar 2 Request for Additional Information on Relief Request ISPT-02 (CAC No. MF7038)  
**Attachments:** Watts Bar Unit 2 Request for Additional Information on Relief Request ISPT-02.pdf

Gentlemen,

By letter dated October 30, 2015 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML15303A546), Tennessee Valley Authority requested approval of alternative testing associated with the inservice inspection program first 10-year interval for Watts Bar Nuclear Plant, Unit 2.

The U.S. Nuclear Regulatory Commission staff is reviewing your submittal and has determined that additional information is required to complete the review. The specific information requested is attached to this e-mail. The proposed question was provided to your staff on February 1, 2016, for clarification, if needed. TVA indicated by e-mail on February 1, 2016, that no clarification was needed. TVA agreed to provide a response to this request by March 2, 2016.

Regards,

Robert G. Schaaf  
Senior Project Manager, Watts Bar/Bellefonte  
Plant Licensing Branch II-2  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
Mail Stop O-8G9A  
Washington, DC 20555  
301-415-6020 (o)  
Robert.Schaaf@nrc.gov

**Hearing Identifier:** NRR\_PMDA  
**Email Number:** 2629

**Mail Envelope Properties** (Robert.Schaaf@nrc.gov20160201142600)

**Subject:** Watts Bar 2 Request for Additional Information on Relief Request ISPT-02 (CAC No. MF7038)  
**Sent Date:** 2/1/2016 2:26:21 PM  
**Received Date:** 2/1/2016 2:26:00 PM  
**From:** Schaaf, Robert

**Created By:** Robert.Schaaf@nrc.gov

**Recipients:**  
"Daniels, Desiree L" <dlboyd@tva.gov>  
Tracking Status: None  
"Gordon Arent" <garent@tva.gov>  
Tracking Status: None  
"Casey, Kevin E (kecasey@tva.gov)" <kecasey@tva.gov>  
Tracking Status: None

**Post Office:**

<b>Files</b>	<b>Size</b>	<b>Date &amp; Time</b>
MESSAGE	1095	2/1/2016 2:26:00 PM
Watts Bar Unit 2 Request for Additional Information on Relief Request ISPT-02.pdf	15267	

**Options**  
**Priority:** Standard  
**Return Notification:** No  
**Reply Requested:** No  
**Sensitivity:** Normal  
**Expiration Date:**  
**Recipients Received:** ZZZ

REQUEST FOR ADDITIONAL INFORMATION  
REGARDING REQUEST NUMBER ISPT-02  
FOR THE INSERVICE INSPECTION PROGRAM FIRST 10-YEAR INTERVAL  
TENNESSEE VALLEY AUTHORITY  
WATTS BAR NUCLEAR PLANT UNIT 2  
DOCKET NO. 50-391

By letter dated October 30, 2015, Agencywide Documents Access and Management System (ADAMS) Accession No. ML15303A546 Cost Activity Code (CAC) Number MF7038, Tennessee Valley Authority (TVA), the licensee, requested approval of alternative testing associated with the inservice inspection (ISI) program first 10-year interval for Watts Bar Nuclear Plant (WBN) Unit 2. The Nuclear Regulatory Commission (NRC) staff is reviewing the submittal and has the following question:

Request ISPT-02:

- 1) What is the proposed test pressure (i.e., the numerical value of the static head pressure developed from the water level above the reactor pressure vessel flange when the reactor cavity is flooded) for the proposed system leakage testing of the subject leak-off piping?

ENCLOSURE