

Vogle PEmails

From: Hoellman, Jordan
Sent: Tuesday, February 02, 2016 8:20 AM
To: Vogtle PEmails
Subject: 2/4/2016 Public Meeting Talking Points - LAR 15-020
Attachments: LAR-15-020 Public Meeting Talking Points.docx

Jordan Hoellman
Project Manager
NRO / DNRL / LB4
U.S. Nuclear Regulatory Commission
office: TWFN 6-F33
phone: (301) 415-5481
email: Jordan.Hoellman2@nrc.gov

Hearing Identifier: Vogtle_COL_Docs_Public
Email Number: 15

Mail Envelope Properties (2af1a98fa50f4d1eba4589935965e752)

Subject: 2/4/2016 Public Meeting Talking Points - LAR 15-020
Sent Date: 2/2/2016 8:19:59 AM
Received Date: 2/2/2016 8:20:00 AM
From: Hoellman, Jordan

Created By: Jordan.Hoellman2@nrc.gov

Recipients:
"Vogtle PEmails" <Vogtle.PEmails@nrc.gov>
Tracking Status: None

Post Office: HQPWMSMRS03.nrc.gov

Files	Size	Date & Time
MESSAGE	229	2/2/2016 8:20:00 AM
LAR-15-020 Public Meeting Talking Points.docx		19634

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

Talking Points
Handout for 2/4/2016 Public Meeting

Vogle LAR 15-020
“Use of Localized Shoring for Composite Floors and Roof in the Auxiliary Building”

The applicant request the use of shoring to provide temporary support for openings in unshored construction addressed in Appendix 3H.5.2. Two specific conditions are presented in the LAR - 15-020.

1. Shoring around openings where the steel deck has penetrations and the span of the steel deck is interrupted by the penetration/opening
2. Shoring under steel beams supporting the steel deck until the wall to support the beams is completed.

The staff request more details on the extent of use of the second(2) type of shoring and clarification on how the load transfer will be made from the shoring to the support wall to be constructed.