

**From:** [MONTGOMERY, Bruce](#)  
**To:** [Morris, Scott](#); [Chernoff, Harold](#); [Thompson, John](#)  
**Subject:** [External\_Sender] CCNPP 2B EDG Failure - 2010  
**Date:** Thursday, January 21, 2016 8:14:30 AM

---

Gents, I owe you an apology.

Last night I was able to link up with my former colleagues at Calvert and review the root cause analysis as revised following the more detailed investigation. As it turns out we added the fouled sensing line as the cause of the failure of the EDG to run, but we did not remove the original cause regarding the service life of the Agastat relay. We kept it in the report as a contributing cause. I am not sure why we did that, since we could not find any evidence of a problem with the relay, but it is still in the report. So in that sense the draft RIS is accurate. Sorry for the confusion, that was just the engineer in me talking yesterday!

I would still like us to look at a clearer example for the RIS, though, since there are several good ones out there where not following an established replacement interval led directly to a failure. Power supplies with electrolytic capacitors come to mind. Just a thought.

Our team thought the meeting yesterday added significant value to the overall dialog on the issue.

Thank you,

bsm  


Bruce S. Montgomery  
Senior Project Manager

Nuclear Energy Institute  
1201 F Street, N.W.  
Washington, D.C. 20004  
[www.nei.org](http://www.nei.org)

P: 202-739-8128  
M: 202-406-0054  
F: 202-533-0147  
E: [bsm@nei.org](mailto:bsm@nei.org)



**TAKE THE NEI FUTURE OF ENERGY QUIZ, [www.NEI.org/futureofenergy](http://www.NEI.org/futureofenergy)**

FOLLOW US ON



*This electronic message transmission contains information from the Nuclear Energy Institute, Inc. The information is intended solely for the use of the*

*addressee and its use by any other person is not authorized. If you are not the intended recipient, you have received this communication in error, and any review, use, disclosure, copying or distribution of the contents of this communication is strictly prohibited. If you have received this electronic transmission in error, please notify the sender immediately by telephone or by electronic mail and permanently delete the original message. IRS Circular 230 disclosure: To ensure compliance with requirements imposed by the IRS and other taxing authorities, we inform you that any tax advice contained in this communication (including any attachments) is not intended or written to be used, and cannot be used, for the purpose of (i) avoiding penalties that may be imposed on any taxpayer or (ii) promoting, marketing or recommending to another party any transaction or matter addressed herein.*

---

Sent through [www.intermedia.com](http://www.intermedia.com)