



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

February 23, 2016

LICENSEE: Omaha Public Power District

FACILITY: Fort Calhoun Station, Unit No. 1

SUBJECT: SUMMARY OF PUBLIC PRE-APPLICATION AUDIOCONFERENCE HELD ON FEBRUARY 3, 2016, WITH OMAHA PUBLIC POWER DISTRICT TO DISCUSS LICENSE AMENDMENT REQUEST REGARDING NFPA 805 CHANGES AT FORT CALHOUN STATION, UNIT NO. 1 (CAC NO. MF7222)

On February 3, 2016, a public audioconference was held between the U.S. Nuclear Regulatory Commission (NRC) and representatives of Omaha Public Power District (OPPD). The purpose of the meeting was to discuss OPPD's proposed application to revise Table S-2, "Plant Modifications Committed," Recommendations 111, 119, 120, and 137 of License Amendment No. 275, Transition to [National Fire Protection Association (NFPA) 805], dated June 16, 2014 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML14098A092), for Fort Calhoun Station, Unit No. 1. A list of attendees is provided in the Enclosure. The meeting notice and agenda, dated January 15, 2016, is available at ADAMS Accession No. ML16032A355. The licensee's presentation slides are available at ADAMS Accession No. ML16027A079. No regulatory decisions were made at the meeting.


OPPD described the proposed changes and anticipated schedule for submitting the application and answered clarifying questions from the NRC staff. The licensee anticipates making the changes during the fall 2016 refueling outage. In accordance with Table S-2 of Amendment No. 275, changes to Recommendation (REC)-111 (High Energy Arc Fault Shields above 4160V and 480V Switchgear) and REC-137 (Alternate Water Supply from the Main Condenser to Auxiliary Feedwater Pump FW-54) require formal notification to the NRC. OPPD anticipates submitting its notification letter to the NRC by mid-February 2016. The licensee proposes to eliminate REC-119 and REC-120 (Addition of Isolation Fuses between Battery No. 1(2) and Associated DC Bus), which requires NRC approval through the license amendment process. OPPD anticipates submitting its license amendment request (LAR) in mid-March 2016.

The NRC staff discussed what the licensee should consider in its application if, as the licensee stated, it uses only the methods and approaches accepted by the staff in the safety evaluation for Amendment No. 275. To support a streamlined review, the LAR should include (1) a summary of all changes made to the modifications approved in Amendment No. 275, (2) a summary of all of the changes made to PRA models and an explanation of each change, (3) updated versions of Tables M, S, and W for each fire area, and (4) a statement that the licensee performed an evaluation of changes to defense-in-depth and safety margins and the results of the evaluation.

The public was invited to listen to the meeting and was given an opportunity to communicate with the NRC after the business portion, but before the meeting was adjourned. Members of the public listened in on the telephone, but had no questions or comments. No public meeting feedback forms were received.

If you have any questions, please contact me at 301-415-2296 or via e-mail at Fred.Lyon@nrc.gov.

Sincerely,



Carl F. Lyon, Project Manager
Plant Licensing Branch IV-1
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-285

Enclosure:
List of Attendees

cc w/encl: Distribution via Listserv

LIST OF ATTENDEES

U.S. NUCLEAR REGULATORY COMMISSION

FEBRUARY 3, 2016, MEETING WITH OMAHA PUBLIC POWER DISTRICT

LICENSE AMENDMENT REQUEST PRE-APPLICATION

FORT CALHOUN STATION, UNIT NO. 1

DOCKET NO. 50-285

Name	Organization
Brad Blome	OPPD
Mike Edwards	OPPD
Erick Matzke	OPPD
Jeff Wilson	OPPD
Tim Leibel	OPPD
Alan Hackerott	OPPD
Steve Kensicki	OPPD
Rob Swerczek	OPPD
Francesco Pellizzari	EPM, Inc.
Clarence Worrell	Westinghouse
Steve Odell	Westinghouse
Chris Rochon	Westinghouse
John Victor	Westinghouse
Jeff Stone	Exelon
Don Ferraro	Exelon
Ken Nicely	Exelon
Andrew Ratchford	Jenson Hughes
Elizabeth Kleinsorg	Jenson Hughes
Amy Hazelhoff	Enercon
Harold Barrett	NRC/NRR/DRA
Stephen Dinsmore	NRC/NRR/DRA
JS Hyslop	NRC/NRR/DRA
Fred Lyon	NRC/NRR/DORL
Chuck Moulton	NRC/NRR/DRA

Enclosure

If you have any questions, please contact me at 301-415-2296 or via e-mail at Fred.Lyon@nrc.gov.

Sincerely,

/RA/

Carl F. Lyon, Project Manager
Plant Licensing Branch IV-1
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-285

Enclosure:
List of Attendees

cc w/encl: Distribution via Listserv

DISTRIBUTION:

PUBLIC
LPL4-1 Reading
RidsACRS_MailCTR Resource
RidsNrrDorl Resource
RidsNrrDorlLpl4-1 Resource
RidsNrrDra Resource
RidsNrrDraApfb Resource
RidsNrrDraApla Resource
RidsNrrLAJBurkhardt Resource
RidsNrrPMFortCalhoun Resource

RidsRgn4MailCenter Resource
Rlyengae, EDO RIV
TWertz, NRR
JSowa, RIV
HBarrett, NRR
SDinsmore, NRR
JHyslop, NRR
CMoulton, NRR
MSchneider, RIV

ADAMS Accession Nos.: Meeting Notice ML16032A355; Meeting Summary ML16036A350;
Slides ML16027A079

OFFICE	NRR/DORL/LPL4-1/PM	NRR/DORL/LPL4-1/LA	NRR/DORL/LPL4-1/BC	NRR/DORL/LPL4-1/PM
NAME	FLyon	JBurkhardt	RPascarelli	FLyon
DATE	02/22/16	02/18/16	02/23/16	02/23/16

OFFICIAL RECORD COPY