



**Entergy Nuclear Northeast**  
Indian Point Energy Center  
450 Broadway, GSB  
P.O. Box 249  
Buchanan, NY 10511-0249  
Tel (914) 254-6700

**Lawrence Coyle**  
Site Vice President

NL-16-017

February 4, 2016

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, DC 20555-0001

**SUBJECT:** Mid-cycle Revision to the Core Operating Limits Report for Cycle 19  
Indian Point Nuclear Generating Unit No. 3  
Docket No. 50-286  
License No. DPR-64

**REFERENCE** 1) Entergy Letter dated April 21, 2015, L. Coyle to USNRC, "Revised Core Operating Limits Report for Cycle 19" (NL-15-052)

Dear Sir or Madam:

In Reference 1, Entergy Nuclear Operations, Inc. (Entergy) submitted its revised Core Operating Limits Report (COLR) for Indian Point Nuclear Generating Unit No. 3 Cycle 19 changes.

The purpose of this letter is to provide a mid-cycle revision to the COLR report for Cycle 19 changes. A cautionary statement was added on page 6 of 12 to clarify section Technical Specification (TS) 3.4.1 RCS Pressure, Temperature, and Flow Departure from Nucleate Boiling (DNB) Limits. This report is submitted in accordance with Technical Specification 5.6.5.d.

There are no new commitments being made in this submittal. If you have any questions or require additional information, please contact Mr. Robert W. Walpole, Regulatory Assurance Manager at (914) 254-6710.

Sincerely,

LC/rl

Enclosure: 3-GRAPH-RPC-16, Revision: 8 Core Operating Limits Report

ADD  
NRR

cc: Mr. Daniel H. Dorman, Regional Administrator, NRC Region I  
Mr. Douglas Pickett, NRC, Sr. Project Manager, Division of Reactor Licensing  
NRC Resident Inspector's Office  
Ms. Bridget Frymire, New York State Department of Public Service  
Mr. John B. Rhodes, President and CEO, NYSERDA (w/o enclosure)

ENCLOSURE TO NL-16-017

3-GRAPH-RPC-16, Revision: 8

Core Operating Limits Report

ENTERGY NUCLEAR OPERATIONS, INC.  
INDIAN POINT NUCLEAR GENERATING UNIT NO. 3  
DOCKET NO. 50-286



**Entergy**

Nuclear Northeast



Procedure Use Is:

- Continuous
- Reference
- Information

Control Copy: \_\_\_\_\_

Effective Date: 12/30/2015

Page 1 of 12

### 3-GRAPH-RPC-16 , Revision: 8

## CORE OPERATING LIMITS REPORT

Approved By:

*Tom Casma*

Procedure Sponsor, DM/Designee

1 3 <sup>12/29</sup> 12/29/15  
Date

Team 3B

Procedure Owner



**PARTIAL REVISION**

**REVISION SUMMARY**

(Page 1 of 1)

**1.0 REASON FOR REVISION**

1.1 Incorporate LBDCR# U3-COLR-2015-001 markup.

**2.0 SUMMARY OF CHANGES**

2.1 Added Caution to section TS 3.4.1 on page 6.

**TABLE OF CONTENTS**

<u><b>SECTION</b></u>	<u><b>PAGE</b></u>
TS 2.1.1 Reactor Core SLs.....	4
TS 3.1.1 Shutdown Margin (SDM) .....	4
TS 3.1.3 Moderator Temperature Coefficient (MTC) .....	4
TS 3.1.5 Shutdown Bank Insertion Limits .....	5
TS 3.1.6 Control Bank Insertion Limits.....	5
TS 3.2.1 Heat Flux Hot Channel Factor ( $F_Q(Z)$ ).....	5
TS 3.2.2 Nuclear Enthalpy Rise Hot Channel Factor $F_{\Delta H}^N$ .....	5
TS 3.2.3 Axial Flux Difference (AFD) (Constant Axial Offset Control (CAOC) Methodology).....	6
TS 3.3.1 RPS Instrumentation .....	6
TS 3.4.1 RCS Pressure, Temperature, and Flow Departure from Nucleate Boiling (DNB) Limits.....	6
TS 3.9.1 Refueling Boron Concentration.....	6

**ATTACHMENTS**

Attachment 1 OVERTEMPERATURE $\Delta T$ ALLOWABLE VALUE.....	7
Attachment 2 OVERPOWER $\Delta T$ ALLOWABLE VALUE .....	8

**FIGURES**

Figure 1 Reactor Core Safety Limit – Four Loops in Operation .....	9
Figure 2 Rod Bank Insertion Limits .....	10
Figure 3 Hot Channel Factor Normalized Operating Envelope .....	11
Figure 4 Axial Flux Difference Envelope Limits.....	12

**NOTE**

The data presented in this report applies to Cycle 19 ONLY and may NOT be used for other cycles of operation. Also, it applies only to operation at a maximum power level of 3188.4 MWt. Any technical change to this document may require a Safety Evaluation to be performed in accordance with 10 CFR 50.59.

**TS 2.1.1 Reactor Core SLs**

In MODE 1 and 2, the combination of thermal power level, pressurizer pressure, and Reactor Vessel inlet temperature SHALL not exceed the limits shown in Figure 1. The safety limit is exceeded if the point defined by the combination of Reactor Vessel inlet temperature and power level is at any time above the appropriate pressure line.

**TS 3.1.1 Shutdown Margin (SDM)**

The shutdown margin SHALL be greater than or equal to 1.3%  $\Delta k/k$ .

**TS 3.1.3 Moderator Temperature Coefficient (MTC)**

The MTC upper limit SHALL be  $\leq 0.0 \Delta k/k/^\circ F$  at hot zero power.

The MTC lower limit SHALL be less negative than or equal to:

-38.0 pcm/ $^\circ F$  @ 300 ppm  
-44.5 pcm/ $^\circ F$  @ 60 ppm  
-47.0 pcm/ $^\circ F$  @ 0 ppm

### **TS 3.1.5 Shutdown Bank Insertion Limits**

The Shutdown Banks SHALL be fully withdrawn when the reactor is in MODE 1 and MODE 2. Shutdown Banks with a group step counter demand position  $\geq 225$  steps are considered fully withdrawn because the bank demand position is above the top of the active fuel.

### **TS 3.1.6 Control Bank Insertion Limits**

The Control Bank Insertion Limits for MODE 1 and MODE 2 with  $k_{\text{eff}} \geq 1.0$  are as indicated in Figure 2. Control Bank Insertion Limits apply to the step counter demand position.

Each control bank shall be considered fully withdrawn at  $\geq 225$  steps.

### **TS 3.2.1 Heat Flux Hot Channel Factor ( $F_Q(Z)$ )**

#### **NOTE**

- P is the fraction of Rated Thermal Power (RTP) at which the core is operating.
- $K(Z)$  is the fraction given in Figure 3 and Z is the core height location of  $F_Q$ .

$$\text{IF } P > .5, F_Q(Z) \leq (2.30 / P) \times K(Z)$$

$$\text{IF } P \leq .5, F_Q(Z) \leq (4.60) \times K(Z)$$

### **TS 3.2.2 Nuclear Enthalpy Rise Hot Channel Factor $F_{\Delta H}^N$**

#### **NOTE**

P is the fraction of Rated Thermal Power (RTP) at which the core is operating.

$$F_{\Delta H}^N \leq 1.65 \{ 1 + 0.3 ( 1 - P ) \}$$



**TS 3.2.3 Axial Flux Difference (AFD) (Constant Axial Offset Control (CAOC) Methodology)**

The Indicated limit is the Target Band; i.e., the Target  $\pm$  5%

The AFD shall be maintained within the ACCEPTABLE OPERATION portion of Figure 4, as required by TS 3.2.3.

**TS 3.3.1 RPS Instrumentation**

1. Overtemperature  $\Delta T$  Allowable Value as referenced in Technical Specifications Table 3.3.1-1, Function 5, Note 1  
Refer to Attachment 1
2. Overpower  $\Delta T$  Allowable Value as referenced in Technical Specifications Table 3.3.1-1, Function 6, Note 2  
Refer to Attachment 2

**TS 3.4.1 RCS Pressure, Temperature, and Flow Departure from Nucleate Boiling (DNB) Limits**

The following DNB related parameters are applicable in MODE 1:

**CAUTION**

The RCS loop  $T_{avg}$  limit should be decreased one degree for each degree that the full power  $T_{avg}$  is less than 572°F. For example, if the cycle full power  $T_{avg}$  is equal to 570°F, then the RCS loop  $T_{avg}$  limit is  $\leq$  574.7°F.

- a. Reactor Coolant System loop  $T_{avg} \leq 576.7^\circ\text{F}$  for full-power  $T_{avg} = 572.0^\circ\text{F}$
- b. Pressurizer Pressure  $\geq 2204$  psig
- c. Reactor Coolant System Total Flow Rate  $\geq 364,700$  gpm

**TS 3.9.1 Refueling Boron Concentration**

When required by Technical Specification 3.9.1, the minimum boron concentration in the RCS, Refuel Canal, and Reactor Cavity SHALL be the more restrictive of either  $\geq 2050$  ppm or that which is sufficient to provide a shutdown margin  $\geq 5\% \Delta k/k$ .

**Attachment 1**

(Page 1 of 1)

**OVERTEMPERATURE  $\Delta T$  ALLOWABLE VALUE**

The Overtemperature  $\Delta T$  Function Allowable Value SHALL NOT exceed the Technical Specification Table 3.3.1-1, Note 1 value.

The following provides the computed value:

$$\Delta T \leq \Delta T_o [K_1 - K_2 [(1 + \tau_1 s)/(1 + \tau_2 s)] (T - T') + K_3 (P - P') - f_1(\Delta I)]$$

Where:  $\Delta T$  is measured RCS  $\Delta T$ , °F (measured by hot leg and cold leg RTDs).

$\Delta T_o$  is the loop specific indicated  $\Delta T$  at RTP, °F.

$s$  is the Laplace transform operator,  $\text{sec}^{-1}$ .

$T$  is the measured RCS average temperature, °F.

$T'$  is the loop specific indicated  $T_{\text{avg}}$  at RTP, °F  $\leq 572.0^\circ\text{F}$ .

$P$  is the measured pressurizer pressure, psig.

$P'$  is the nominal RCS operating pressure,  $\geq 2235$  psig.

$$K_1 \leq 1.26$$

$$K_2 \geq 0.022/^\circ\text{F}$$

$$K_3 \geq 0.00070/\text{psi}$$

$$\tau_1 \geq 25.0 \text{ sec}$$

$$\tau_2 \leq 3.0 \text{ sec}$$

$$f_1(\Delta I) = \begin{array}{ll} 4.00[-15.75 - (qt - qb)] & \text{when } qt - qb \leq -15.75\% \text{ RTP} \\ 0\% \text{ of RTP} & \text{when } -15.75\% \text{ RTP} < qt - qb \leq 6.9\% \text{ RTP} \\ +3.33[(qt - qb) - 6.9] & \text{when } qt - qb > 6.9\% \text{ RTP} \end{array}$$

Where  $qt$  and  $qb$  are percent RTP in the upper and lower halves of the core, respectively, and  $qt + qb$  is the total THERMAL POWER in percent RTP.

**Attachment 2**  
(Page 1 of 1)

**OVERPOWER ΔT ALLOWABLE VALUE**

The Overpower ΔT Function Allowable Value SHALL NOT exceed the Technical Specification Table 3.3.1-1, Note 2 value.

The following provides the computed value:

$$\Delta T \leq \Delta T_o [K_4 - K_5 [(\tau_3 s)/(1 + \tau_3 s)](T) - K_6(T - T'') - f_2(\Delta I)]$$

Where: ΔT is measured RCS ΔT, °F (measured by hot leg and cold leg RTDs).

ΔT<sub>o</sub> is the loop specific indicated ΔT at RTP, °F.

s is the Laplace transform operator, sec<sup>-1</sup>.

T is the measured RCS average temperature, °F.

T'' is the loop specific indicated T<sub>avg</sub> at RTP, °F ≤ 572.0°F.


$$K_4 \leq 1.10 \quad K_5 \geq 0.0175/^\circ\text{F for increasing T} \quad K_6 \geq 0.0015/^\circ\text{F when T > T''}$$

$$0/^\circ\text{F for decreasing T} \quad 0/^\circ\text{F when T} \leq T''$$


$$\tau_3 \geq 10 \text{ sec}$$

$$f_2(\Delta I) = 0$$


Figure 1  
Reactor Core Safety Limit – Four Loops in Operation  
(Page 1 of 1)



**Figure 2**  
**Rod Bank Insertion Limits**  
(Page 1 of 1)  
(Four Loop Operation)  
104 Step Overlap



**Figure 3**  
**Hot Channel Factor Normalized Operating Envelope**  
 (For S. G. Tube Plugging up to 10%)  
 (Page 1 of 1)



**Figure 4**  
**Axial Flux Difference Envelope Limits**  
 (Page 1 of 1)

