

Dominion Resources Services, Inc.  
Innsbrook Technical Center  
5000 Dominion Boulevard, 2SE, Glen Allen, VA 23060



February 4, 2016

United States Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, D.C. 20555

Serial No. 15-564A  
NL&OS/GDM: R0  
Docket No. 50-281  
License No. DPR-37

**VIRGINIA ELECTRIC AND POWER COMPANY (DOMINION)**  
**SURRY POWER STATION UNIT 2**  
**CORE OPERATING LIMITS REPORT**  
**SURRY 2 CYCLE 27 PATTERN HGG REVISION 2**

Pursuant to Surry Power Station (Surry) Technical Specification (TS) 6.2.C, attached is a copy of Dominion's Core Operating Limits Report (COLR) for Surry Unit 2 Cycle 27, Pattern HGG, Revision 2. The revision was prepared to provide Surry Unit 2 with additional operational flexibility. Specifically, Dominion implemented an increased statistical/deterministic FΔH limit of 1.635/1.70. To implement the increased FΔH limit, Dominion also implemented the use of the ABB-NV and WLOP CHF correlations in place of the W-3 CHF correlation at Surry. The DNB statepoint and reload analyses for Surry Unit 2 were reanalyzed using the increased FΔH and the ABB-NV and WLOP CHF correlations, and the reanalysis confirmed the applicable limits were met. The other licensing basis accident analyses continue to support the increased FΔH limit and therefore were not required to be reevaluated. The use of the ABB-NV and WLOP CHF correlations were previously approved by the NRC in a letter dated August 12, 2014 (ADAMS Accession No. ML14169A359).

If you have any questions or require additional information, please contact Mr. Gary Miller at (804) 273-2771.

Sincerely,

T. R. Huber, Director  
Nuclear Licensing and Operations Support  
Dominion Resources Services, Inc. for  
Virginia Electric and Power Company

Attachment:

Core Operating Limits Report, Surry Unit 2 Cycle 27, Pattern HGG, Revision 2,  
January 2016

Commitment Summary: There are no new commitments contained in this letter.

ADD  
NRR

cc: U.S. Nuclear Regulatory Commission  
Region II  
Marquis One Tower  
245 Peachtree Center Avenue, NE  
Suite 1200  
Atlanta, Georgia 30303-1257

Ms. K. Cotton Gross  
NRC Project Manager  
U. S. Nuclear Regulatory Commission  
One White Flint North  
Mail Stop 08 G-9A  
11555 Rockville Pike  
Rockville, Maryland 20852-2738

Dr. V. Sreenivas  
NRC Project Manager  
U. S. Nuclear Regulatory Commission  
One White Flint North  
Mail Stop 08 G-9A  
11555 Rockville Pike  
Rockville, Maryland 20852-2738

NRC Senior Resident Inspector  
Surry Power Station

# **CORE OPERATING LIMITS REPORT**

**Surry Unit 2 Cycle 27**

**Pattern HGG**

**Revision 2**

**January 2016**

## 1.0 INTRODUCTION

This Core Operating Limits Report (COLR) for Surry Unit 2 Cycle 27 has been prepared in accordance with the requirements of Surry Technical Specification 6.2.C.

The Technical Specifications affected by this report are:

TS 2.1 – Safety Limit, Reactor Core

TS 2.3.A.2.d – Overtemperature  $\Delta T$

TS 2.3.A.2.e – Overpower  $\Delta T$

TS 3.1.E - Moderator Temperature Coefficient

TS 3.12.A.1, TS 3.12.A.2, TS 3.12.A.3 and TS 3.12.C.3.b.1(b) - Control Bank Insertion Limits

TS 3.12.A.1.a, TS 3.12.A.2.a, TS 3.12.A.3.c and TS 3.12.G – Shutdown Margin

TS 3.12.B.1 and TS 3.12.B.2 - Power Distribution Limits (Heat Flux Hot Channel Factor and Nuclear Enthalpy Rise Hot Channel Factor)

TS 3.12.F – DNB Parameters

TS Table 4.1-2A – Minimum Frequency for Equipment Tests: Item 22 – RCS Flow

## 2.0 REFERENCES

1. VEP-FRD-42, Rev. 2.1-A, “Reload Nuclear Design Methodology,” August 2003.

Methodology for:

TS 2.1 - Safety Limit, Reactor Core

TS 3.1.E - Moderator Temperature Coefficient

TS 3.12.A.1, TS 3.12.A.2, TS 3.12.A.3 and TS 3.12.C.3.b.1(b) - Control Bank Insertion Limit

TS 3.12.A.1.a, TS 3.12.A.2.a, TS 3.12.A.3.c and TS 3.12.G – Shutdown Margin

TS 3.12.B.1 and TS 3.12.B.2 - Heat Flux Hot Channel Factor and Nuclear Enthalpy Rise Hot Channel Factor

TS 3.12.F – DNB Parameters

TS Table 4.1-2A – Minimum Frequency for Equipment Tests: Item 22 – RCS Flow

2. WCAP-16009-P-A, “Realistic Large Break LOCA Evaluation Methodology Using the Automated Statistical Treatment of Uncertainty Method (ASTRUM),” (Westinghouse Proprietary), January 2005.

Methodology for:

TS 3.12.B.1 and TS 3.12.B.2 - Heat Flux Hot Channel Factor

3. WCAP-10054-P-A, “Westinghouse Small Break ECCS Evaluation Model Using the NOTRUMP Code,” (Westinghouse Proprietary), August 1985.

Methodology for:

TS 3.12.B.1 and TS 3.12.B.2 - Heat Flux Hot Channel Factor

4. WCAP-10079-P-A, "NOTRUMP, A Nodal Transient Small Break and General Network Code," (Westinghouse Proprietary), August 1985.

Methodology for:

TS 3.12.B.1 and TS 3.12.B.2 - Heat Flux Hot Channel Factor

5. WCAP-12610-P-A, "VANTAGE+ Fuel Assembly Report," (Westinghouse Proprietary), April 1995.

Methodology for:

TS 3.12.B.1 and TS 3.12.B.2 - Heat Flux Hot Channel Factor

6. WCAP-12610-P-A and CENPD-404-P-A, Addendum 1-A, "Optimized ZIRLO," (Westinghouse Proprietary), July 2006.

Methodology for:

TS 3.12.B.1 and TS 3.12.B.2 - Heat Flux Hot Channel Factor

7. VEP-NE-2-A, Rev. 0, "Statistical DNBR Evaluation Methodology," June 1987.

Methodology for:

TS 3.12.B.1 and TS 3.12.B.2 - Nuclear Enthalpy Rise Hot Channel Factor

8. DOM-NAF-2-P-A, Rev. 0.3, "Reactor Core Thermal-Hydraulics Using the VIPRE-D Computer Code," including Appendix B, "Qualification of the Westinghouse WRB-1 CHF Correlation in the Dominion VIPRE-D Computer Code," and Appendix D, "Qualification of the ABB-NV and WLOP CHF Correlations in the Dominion VIPRE-D Computer Code," September 2014.

Methodology for:

TS 3.12.B.1 and TS 3.12.B.2 - Nuclear Enthalpy Rise Hot Channel Factor

9. WCAP-8745-P-A, "Design Bases for Thermal Overpower Delta-T and Thermal Overtemperature Delta-T Trip Function," September 1986.

Methodology for:

TS 2.3.A.2.d - Overtemperature  $\Delta T$

TS 2.3.A.2.e - Overpower  $\Delta T$

### 3.0 OPERATING LIMITS

The cycle-specific parameter limits for the specifications listed in Section 1.0 are presented in the following subsections. These limits have been developed using the NRC-approved methodologies specified in Technical Specification 6.2.C and repeated in Section 2.0.

#### 3.1 Safety Limit, Reactor Core (TS 2.1)

The Reactor Core Safety Limits are presented in **Figure A-1**.

#### 3.2 Overtemperature $\Delta T$ (TS 2.3.A.2.d)

$$\Delta T \leq \Delta T_0 \left[ K_1 - K_2 \left( \frac{1 + t_1 s}{1 + t_2 s} \right) (T - T') + K_3 (P - P') - f(\Delta T) \right]$$

Where:

$\Delta T$  is measured RCS  $\Delta T$ , °F.

$\Delta T_0$  is the indicated  $\Delta T$  at RATED POWER, °F.

$s$  is the Laplace transform operator,  $\text{sec}^{-1}$ .

$T$  is the measured RCS average temperature ( $T_{avg}$ ), °F.

$T'$  is the nominal  $T_{avg}$  at RATED POWER,  $\leq 573.0^\circ\text{F}$ .

$P$  is the measured pressurizer pressure, psig.

$P'$  is the nominal RCS operating pressure  $\geq 2235$  psig.

$$K_1 \leq 1.1425$$

$$K_2 \geq 0.01059 / ^\circ\text{F}$$

$$K_3 \geq 0.000765 / \text{psig}$$

$$t_1 \geq 29.7 \text{ seconds}$$

$$t_2 \leq 4.4 \text{ seconds}$$

$$f(\Delta T) \geq 0.0268 \{-24 - (q_t - q_b)\}, \text{ when } (q_t - q_b) < -24.0\% \text{ RATED POWER}$$

$$0, \text{ when } -24.0\% \text{ RATED POWER} \leq (q_t - q_b) \leq 8.0\% \text{ RATED POWER}$$

$$0.0188 \{(q_t - q_b) - 8.0\}, \text{ when } (q_t - q_b) > +8.0\% \text{ RATED POWER}$$

Where  $q_t$  and  $q_b$  are percent RATED POWER in the upper and lower halves of the core, respectively, and  $q_t + q_b$  is the total THERMAL POWER in percent RATED POWER.

**3.3 Overpower  $\Delta T$  (TS 2.3.A.2.e)**

$$\Delta T \leq \Delta T_0 \left[ K_4 - K_5 \left( \frac{t_3 s}{1 + t_3 s} \right) T - K_6 (T - T') - f(\Delta I) \right]$$

Where:

$\Delta T$  is measured RCS  $\Delta T$ , °F.

$\Delta T_0$  is the indicated  $\Delta T$  at RATED POWER, °F.

$s$  is the Laplace transform operator,  $\text{sec}^{-1}$ .

$T$  is the measured RCS average temperature ( $T_{\text{avg}}$ ), °F.

$T'$  is the nominal  $T_{\text{avg}}$  at RATED POWER,  $\leq 573.0^\circ\text{F}$ .

$$K_4 \leq 1.0965 \quad K_5 \geq 0.0198 / ^\circ\text{F} \text{ for increasing } T_{\text{avg}} \quad K_6 \geq 0.001074 / ^\circ\text{F} \text{ for } T > T'$$

$$\geq 0 / ^\circ\text{F} \text{ for decreasing } T_{\text{avg}} \quad \geq 0 \text{ for } T \leq T'$$

$$t_3 \geq 9.0 \text{ seconds}$$

$f(\Delta I)$  = as defined above for OT $\Delta T$

**3.4 Moderator Temperature Coefficient (TS 3.1.E)**

The Moderator Temperature Coefficient (MTC) limits are:

+6.0 pcm/°F at less than 50 percent of RATED POWER, and

+6.0 pcm/°F at 50 percent of RATED POWER and linearly decreasing to 0 pcm/°F at RATED POWER

**3.5 Control Bank Insertion Limits (TS 3.12.A.1, TS 3.12.A.2, TS 3.12.A.3, and TS 3.12.C.3.b.1(b))**

3.5.1 The control rod banks shall be limited in physical insertion as shown in **Figure A-2**.

3.5.2 The rod insertion limit for the A and B control banks is the fully withdrawn position as shown on **Figure A-2**.

3.5.3 The rod insertion limit for the A and B shutdown banks is the fully withdrawn position as shown on **Figure A-2**.

**3.6 Shutdown Margin (TS 3.12.A.1.a, TS 3.12.A.2.a, TS 3.12.A.3.c and TS 3.12.G)**

Shutdown margin (SDM) shall be  $\geq 1.77 \% \Delta k/k$ .

**3.7 Power Distribution Limits** (TS 3.12.B.1 and TS 3.12.B.2)

3.7.1 Heat Flux Hot Channel Factor - FQ(z)

$$FQ(z) \leq \frac{CFQ}{P} K(z) \text{ for } P > 0.5$$

$$FQ(z) \leq \frac{CFQ}{0.5} K(z) \text{ for } P \leq 0.5$$

$$\text{where: } P = \frac{\text{THERMAL POWER}}{\text{RATED POWER}}$$

$$CFQ = 2.5$$

$$K(z) = 1.0 \text{ for all core heights, } z$$

3.7.2 Nuclear Enthalpy Rise Hot Channel Factor - FΔH(N)

$$F\Delta H(N) \leq CFDH * \{1 + PFDH(1 - P)\}$$

$$\text{where: } P = \frac{\text{THERMAL POWER}}{\text{RATED POWER}}$$

$$CFDH = 1.635$$

$$PFDH = 0.3$$

**3.8 DNB Parameters** (TS 3.12.F and TS Table 4.1-2A)

Departure from Nucleate Boiling (DNB) Parameters shall be maintained within their limits during POWER OPERATION:

- Reactor Coolant System  $T_{avg} \leq 577.0 \text{ }^\circ\text{F}$
- Pressurizer Pressure  $\geq 2205 \text{ psig}$
- Reactor Coolant System Total Flow Rate  $\geq 273,000 \text{ gpm}$  (Tech Spec Limit) and  $\geq 274,000 \text{ gpm}$  (COLR Limit)



Figure A-1

### REACTOR CORE SAFETY LIMITS THREE LOOP OPERATION, 100% FLOW




Figure A-2

