

## **Enclosure 2**

### **MFN 16-001, Revision 1**

### **ABWR COPS Redesign - ABWR DCD Revision 5 Markups**

#### **IMPORTANT NOTICE REGARDING CONTENTS OF THIS DOCUMENT Please Read Carefully**

The information contained in this document is furnished solely for the purpose(s) stated in the transmittal letter. The only undertakings of GEH with respect to information in this document are contained in the contracts between GEH and its customers or participating utilities, and nothing contained in this document shall be construed as changing that contract. The use of this information by anyone for any purpose other than that for which it is intended is not authorized; and with respect to any unauthorized use, GEH makes no representation or warranty, and assumes no liability as to the completeness, accuracy, or usefulness of the information contained in this document.

**Table 6.2-7 Containment Isolation Valve Information  
Atmospheric Control System**

Valve No.	T31-F001	T31-F002	T31-F003	T31-F004	T31-F005	T31-F006	T31-F007
Tier 2 Figure	6.2-39 (Sheet 1)	6.2-39 (Sheet 1)	6.2-39 (Sheet 1)	6.2-39 (Sheet 1)	6.2-39 (Sheet 1)	6.2-39 (Sheet 1)	6.2-39 (Sheet 1)
Applicable Basis	GDC 56	GDC 56	GDC 56	GDC 56	GDC 56	GDC 56	GDC 56
Fluid	Air	Air or N <sub>2</sub>	Air or N <sub>2</sub>	Air or N <sub>2</sub>	Air or N <sub>2</sub>	Air or N <sub>2</sub>	Air or N <sub>2</sub>
Line Size	550A	550A	550A	550A	50A	550A	<del>250A</del> 350A
ESF	Yes	Yes	Yes	Yes	Yes	Yes	Yes
Leakage Class	(b)	(b)	(b)	(b)	(b)	(b)	(b)
Location	O	O	O	O	O	O	O
Type C Leak Test	Yes	Yes(e)	Yes(e)	Yes(e)	Yes(e)	Yes(e)	Yes(e)
Valve Type	Butterfly	Butterfly	Butterfly	Butterfly	Globe	Butterfly	Butterfly
Operator	Pneumatic	Pneumatic	Pneumatic	Pneumatic	Pneumatic	Pneumatic	Pneumatic
Primary Actuation	Electric	Electric	Electric	Electric	Electric	Electric	Electric
Secondary Actuation	Manual	Manual	Manual	Manual	Manual	Manual	Manual
Normal Position	Close	Close	Close	Close	Close	Close	Open
Shutdown Position	Close	Close	Close	Close	Close	Close	Open
Post-Accident Position	Close	Close	Close	Close	Close	Close	Open
Power Fail Position	Close	Close	Close	Close	Close	Close	Open
Containment Isolation Signal <sup>(c)</sup>	A, K, XX, YY	A, K, XX, YY	A, K, XX, YY	A, K, XX, YY	A, K, XX, YY	A, K, XX, YY	RM
Closure Time (s)	<20	<20	<20	<20	<15	<20	<20
Power Source (Div)	I	II	II	II	II	II	II
See page 6.2-167 for notes							

**Table 6.2-7 Containment Isolation Valve Information  
Atmospheric Control System**

Valve No.	T31-F731	T31-F033A/B	T31-F035A-D	T31-F010	T31-F011
Tier 2 Figure	6.2-39 (Sheet 3)	6.2-39 (Sheet 3)	6.2-39 (Sheet 3)	6.2-39 (Sheet 1)	6.2-39 (Sheet 1)
Applicable Basis	RG 1.11	RG 1.11	RG 1.11	GDC 56	GDC 56
Fluid	DW Atmosphere	DW Atmosphere	DW Atmosphere	Air or N <sub>2</sub>	Air or N <sub>2</sub>
Line Size	20A	20A	20A	<del>250A</del> 350A	550A
ESF	No	No	No	Yes	Yes
Leakage Class	(a)	(a)	(a)	(a)	(a)
Location	O	O	O	O	O
Type C Leak Test	No(m)	No(m)	No(m)	Yes(e)	Yes(e)
Valve Type	Gate	Gate	Gate	Butterfly	Butterfly
Operator	Solenoid	Solenoid	Solenoid	Pneumatic	Pneumatic
Primary Actuation	Electric	Electric	Electric	Electric	Electric
Secondary Actuation	N/A	N/A	N/A	Manual	Manual
Normal Position	Open	Open	Open	Open	Close
Shutdown Position	Open	Open	Open	Open	Close
Post-Accident Position	Open	Open	Open	Open	Close
Power Fail Position	Open	Open	Open	Open	Close
Containment Isolation Signal <sup>(c)</sup>	RM	RM	RM	RM	A, K XX, YY
Closure Time (s)	N/A	N/A	N/A	<20	<20
Power Source (Div)	N/A	N/A	N/A	I	III
See page 6.2-167 for notes					

**Table 6.2-7 Containment Isolation Valve Information  
Atmospheric Control System**

Valve No.	T31-F805A/B	T31-D001	T31-D002
Tier 2 Figure	6.2-39 (Sheet 3)	6.2-39 (Sheet 1)	6.2-39 (Sheet 1)
Applicable Basis	RG 1.11	GDC 56	GDC 56
Fluid	WW Atmosphere	WW Atmosphere	WW Atmosphere
Line Size	20A	<del>250A</del> 350A	<del>250A</del> 350A
ESF	No	Yes	Yes
Leakage Class	(a)	N/A	N/A
Location	O	O	O
Type C Leak Test	No(m)	No(P)	No (P)
Valve Type	Gate	Rupture Disk	Rupture Disk
Operator	Solenoid	Self	Self
Primary Actuation	Electric	N/A	N/A
Secondary Actuation	N/A	N/A	N/A
Normal Position	Open	Close	Close
Shutdown Position	Open	Close	Close
Post-Accident Position	Open	Open	Open
Power Fail Position	Open	N/A	N/A
Containment Isolation Signal <sup>(c)</sup>	RM	N/A	N/A
Closure Time (s)	N/A	N/A	N/A
Power Source (Div)	N/A	N/A	N/A
See page 6.2-167 for notes			

Table 19.8-7 Key Severe Accident Parameters (Continued)

Parameter Description	Value	Relates to What Feature?	Cross Reference
Lower Drywell Flooder			
Elevation	-10.5 m	Lower Drywell Flooder	
Area per valve	0.0081 m <sup>2</sup>	Lower Drywell Flooder	
Plug Melting Temperature	533 K	Lower Drywell Flooder	
Suppression Pool Mass	3.6 x 10 <sup>6</sup> kg	Containment Performance	ITAAC 2.14.1
COPS			
Equivalent Flow Diameter of Disk	<del>0.2 m (8 in.)</del> 0.25 m (10 in.)	COPS	
Diameter of Piping	<del>0.25 m (10 in.)</del> 0.35 m (14 in.)	COPS	
Setpoint	0.72 MPa		ITAAC 2.14.6
Tolerance at nom. temp.	5%		ITAAC 2.14.6
Effect of temp. on setpoint	2% per 55.6°C		
Firewater Addition System			
Injection Locations	<del>Vessel and Drywell</del> Vessel, Wetwell, Drywell, and SFP	ACIWA	ITAAC 2.4.1, 2.15.6
Maximum Flow Rate	0.06 m <sup>3</sup> /s	ACIWA	
Minimum Flow rate at COPS Setpoint	0.04 m <sup>3</sup> /s	ACIWA	
Oxygen Concentration	<3.5% By Volume	Containment Inerting	Technical Specification LCO 3.6.3.2

Editorial Note: This part of Table 19.8-7 was revised as a result of MFN 15-069 addressing NRC Item #26.



pool surface and carried into the COPS piping. Calculation of entrainment at the surface of the suppression pool is considered using the work of Rozen, et. al. (Reference 19E.2-17) and is found to have an insignificant impact on fission product release.

### 19E.2.3.5.1 Response of Suppression Pool Surface to Decompression Wave

#### 19E.2.3.5.1.1 Summary

Sudden opening of the containment overpressure protection system (COPS) rupture disk causes a gas discharge from the ABWR pool airspace. The associated decompression wave which enters the airspace spreads to the pool surface. It is necessary to determine how the pool surface responds to the arriving decompression. If the decompression wave causes pool pressure to fall below the saturation pressure, rapid vapor formation would cause the pool to swell as a flashing steam/water mixture. However, if the arriving decompression does not cause the pool pressure to fall below its saturation value, flashing would not occur, and the pool would respond as a compressed liquid.

The theoretical modeling used to determine pool response from operation of the COPS includes prediction of:

- The gas discharge rate
- The velocity and decompression disturbances originating where the COPS enters the airspace
- Expansion of the decompression into the airspace, and its attenuation with distance
- Decompression transmission from the airspace into the pool at the water surface
- The pool water dynamic and thermodynamic response

It was found that the originating decompression wave entering the containment airspace was ~~38.861.4~~ kPa, dropping below the initial 721 kPa air pressure. The decompression wave leaving the COPS pipe of 0.275 m (0.9 ft) radius would reach the pool surface a distance of 4 m (13.12 ft) away, attenuating from ~~38.861.4~~ kPa to ~~2.674.2~~ kPa. Since sound speed and density of water are much higher than corresponding values in air, a decompression wave entering the water is nearly twice that arriving in the air, or about ~~5.348.4~~ kPa. The decompression is not large enough to cause pool pressure to drop below its saturation pressure of 330 kPa at its initial temperature of 410 K, or 137°C (738 R or 278°F). The pool surface would move upward at only ~~0.0044 m/s (0.014 fps)~~ 0.0069 m/s (0.022 fps) for the transmitted decompression.

#### 19E.2.3.5.1.2 The Gas Discharge Rate

The COPS pipe has a radius  $R$  and area  $A$ . The open COPS rupture disk has a flow area  $a$ . Since the airspace pressure  $P_0$  is 721 kPa and discharge is into the atmosphere at 101 kPa, the initial

air flow is expected to be choked in the valve throat at a choked mass flux of (Reference 19E.2-37)

$$G_{gc} = \left(\frac{2}{k+1}\right)^{(k+1)/2(k-1)} \sqrt{k g_0 P_0 \rho_{g0}} \quad (19E.2-41a)$$

The quasi-steady mass flow rate through the pipe and valve is expressed as

$$m = G_{gc} a \quad (19E.2-41b)$$

Assuming isentropic flow from the airspace to the throat, and expressing the airspace sound speed as:

$$C_{g0} = \sqrt{(k g_0 P_0) / \rho_{g0}} \quad (19E.2-41c)$$

the discharging mass flow rate is obtained in the form,

$$\frac{m}{A C_{g0} \rho_{g0}} = \left(\frac{2}{k+1}\right)^{(k+1)/2(k-1)} \frac{a}{A} \quad (19E.2-41d)$$

### 19E.2.3.5.1.3 Disturbance Entering the Airspace

It is assumed that the COPS valve opens instantly, causing an instantaneous quasi-steady flow in the attachment pipe. This assumption gives the maximum pipe velocity, which corresponds to a maximum initial decompression wave.

Acoustic theory can be applied if pressure disturbances do not create Mach numbers much greater than 0.2. An area ratio of  $a/A = 0.1320.207$  (diameter ratio of  $d/D = 0.3640.455$ ) with an airspace state described by

$$P_0 = 721 \text{ kPa}$$

$$T_0 = 410 \text{ K (278°F)}$$

$$\rho_{g0} = 6.16 \text{ kg/m}^3 \text{ (0.384 lbm/ft}^3\text{)}$$

$$C_{g0} = 406 \text{ m/s (1332 fps)}$$

yields a gas velocity in the pipe of ~~31 m/s (102 fps)~~ 49 m/s (161 fps). The corresponding mach number is ~~31/406 = 0.076~~ 49/406 = 0.121, which justifies treating the decompression as an acoustic wave.

It is further assumed that the discharge begins suddenly, imposing the pipe flow velocity of ~~31~~ 49 m/s at its entrance. In order to employ spherical propagation of the acoustic wave, an

imaginary hemisphere of pipe radius  $R = D/2 = 0.55/2 \text{ m} = 0.275 \text{ m}$  (0.902 ft) has twice the pipe flow area, reducing the entrance velocity on the hemisphere to  ~~$31/2 = 15.5 \text{ m/s}$  (50.8 fps)~~ $49/2 = 24.5 \text{ m/s}$  (81 fps). The acoustic equation,

$$\delta P_0 = \frac{\rho C \delta V}{g_0} \quad (19E.2-41e)$$

can be employed to show that the corresponding decompression disturbance is  $\delta P_0 = \del{38.8 \text{ kPa}} $61.4 \text{ kPa}$  (~~5.6 psid~~) $8.9 \text{ psid}$ ).$

#### 19E.2.3.5.1.4 Expansion Into Airspace

The acoustic decompression wave propagation is governed by the spherical wave Equation 19E.2-41b,

$$\frac{\partial^2 P}{\partial t^2} - \frac{C^2}{r^2} \frac{\partial}{\partial r} \left( r^2 \frac{\partial P}{\partial r} \right) = 0 \quad (19E.2-41f)$$

with the boundary and initial conditions at  $r = R$  of

$$P = P_0 - \delta P_0 \quad (19E.2-41g)$$

a boundary condition as  $r$  approaches infinity of

$$P = P_0 \quad (19E.2-41h)$$

and initial conditions at  $t = 0$  of

$$P = P_0 \quad (19E.2-41i)$$

$$\frac{\partial P}{\partial r} = 0 \quad (19E.2-41j)$$

A solution for the outgoing decompression wave is given by

$$\frac{\delta P}{\delta P_0} = \frac{R}{r} e^{-(Ct/r - r/R + 1)} H_s \left( t - \frac{r-R}{C} \right) \quad (19E.2-41k)$$

where  $H_s$  is the Heaviside step function, which is zero for negative arguments, and 1.0 for positive arguments. A pressure disturbance in the airspace will travel from  $r = R$  to another  $r$  at the acoustic speed  $C$ , which requires a time  $(r - R)/C$ . When it does arrive,  $H_s$  is 1.0, and the arriving magnitude is



$$\delta P = \frac{R}{r} \delta P_0$$

It is seen from Equation (~~00.1-41k~~19E.2-41k) that even after the decompression arrives at  $r$ , its amplitude decays exponentially with time. This feature is excluded from the analysis for conservatism.

If the water surface is a distance  $r = 4$  m away from the COPS pipe, the arriving decompression wave will have an amplitude of only ~~2.67~~4.2 kPa.

#### 19E.2.3.5.1.5 Transmission into the Pool

The arriving decompression wave undergoes both simultaneous transmission and reflection at the pool surface interface. Acoustic theory for a plane wave arriving at a flat surface discontinuity of density and sound speed gives the ratio of transmitted to oncoming pressure disturbances as

$$\frac{\delta P_{\text{transmitted}}}{\delta P_{\text{oncoming}}} = \frac{2}{1 + \rho_1 C_1 / \rho_2 C_2} \quad (19E.2-41)$$

where subscripts 1 and 2 refer to the airspace and water in this case. A water density and sound speed of 1000 kg/m<sup>3</sup> and 1220 m/s yields a transmitted/oncoming pressure of

$$\frac{\delta P_{\text{transmitted}}}{\delta P_{\text{oncoming}}} = 1.99$$

That is, the decompression wave arriving at the pool surface nearly doubles from the oncoming value to ~~5.34~~8.4 kPa. The plane wave analysis employed here is based on left and right traveling waves which add to satisfy continuity and energy conservation at the interface (Reference 19E.2-38). A similar analysis for spherical waves is obtained from the method of images to provide a plane surface of symmetry. The local pressure transmission and reflection amplitudes are the same as those obtained from the plane wave analysis (Reference 19E.2-38).

#### 19E.2.3.5.1.6 Water Dynamic and Thermodynamic Response

The ~~5.34~~8.4 kPa decompression wave transmitted into the water pool does not lower the initial 721 kPa pressure anywhere near the 330 kPa saturation pressure. Therefore, the arriving decompression cannot cause rapid pool flashing and swelling. Steam formation will occur in the pool later when continued decompression of the airspace lowers the pressure below saturation.

The water is expected to respond acoustically to the arriving decompression, taking on a velocity obtained from Equation ~~00.1-41e~~19E.2-41e, written for the liquid as

$$\delta V_L = \frac{g_0 \delta P}{\rho_L C_L} \quad (19E.2-41m)$$

where subscript L refers to the water, and  $\delta P$  is the transmitted pressure disturbance. The resulting pool velocity is only ~~0.0044 m/s (0.014 fps)~~, 0.0069 m/s (0.022 fps).

### 19E.2.3.5.2 Critical Time Constants for Blowdown Response

The time constant for the depressurization of the wetwell airspace is calculated from critical flow considerations. Comparing this value to the time constant for propagation of a pressure wave around the wetwell annulus allows one to determine if non-uniform effects in the suppression need to be considered in calculating the suppression pool response.

The depressurization time constant for the wetwell airspace is estimated based on the critical flow through the rupture disk opening and the ideal gas law. There are two sources of steam to the wetwell airspace: the blowdown through the vent system of steam and non-condensable gas from the drywell, and the boiling or steaming of the suppression pool which results from the pressure decrease. If both of these sources are neglected, the time constant for the depressurization of the wetwell will conservatively be underestimated. If one further neglects the effects of any temperature change which results from the blowdown (a second order effect), the rate of depressurization is:

$$\frac{dP}{dt} = \frac{0.665 ART \sqrt{P \rho_g}}{V_w M_{a,w}} \quad (19E.2-42)$$

where:

P	=	pressure
A	=	rupture disk flow area
R	=	universal gas constant
$\rho_g$	=	density of gas
$V_w$	=	volume of wetwell airspace
$M_{a,w}$	=	molecular weight of gas species in wetwell.

Conservatively assuming the wetwell vapor space has only steam, for a blowdown from 0.65 MPa to atmospheric conditions, the assumptions above yield a time constant on the order of 95.7 minutes. A typical time constant for a pressure wave going around the torus which comprises the wetwell is about 0.5 seconds. Comparison of these two numbers indicates clearly that the entire suppression pool will participate in the blowdown. Thus, two dimensional effects may be neglected.

to perform detailed uncertainty analysis for the dual issues of debris coolability and core concrete interaction.

#### 19E.2.6.9 Fission Product Release Location

The adoption of the rupture disk in the ABWR containment design serves to significantly reduce the uncertainties in the timing, location and area of any fission product release. As discussed in Subsection 19E.2.8.1, the Containment Overpressure Protection System (COPS) is highly reliable. The setpoint of the rupture disk, 0.72 MPa, was selected such that there is a very small probability that the containment structure fails. As shown in Subsection 19F.3.1.2, the weakest portion of the ABWR containment is the drywell head. The median failure pressure of the drywell head is estimated to be 1.03 MPa abs. The other portions of the containment have an estimated failure pressure of 1.34 MPa. Thus, it is expected that most fission product releases will be via the rupture disk.

A fragility curve for the drywell head, Figure 19FA-1, shows the uncertainty in the failure pressure for the drywell head. The uncertainty of the rupture pressure for the COPS is very small as discussed in Subsections 19E.2.8.1.1 and 19E.2.8.1.2. Integrating over these two distributions, one can determine the probability that the drywell head fails before the COPS actuates. Because of the pressure difference between the wetwell and the drywell, three cases must be considered. For sequences in which the firewater system is used and water is added to the containment, as described in Subsection 19E.2.2, there is a small chance that the drywell head will fail. For sequences without water addition to the containment, the drywell head failure probability is even smaller. These probabilities are used in the quantification of the containment event trees in Subsection 19D.5. The third case applies to sequences with no pressure difference between wetwell and drywell. In these cases the drywell head failure probability is smaller yet.

#### 19E.2.6.10 Fission Product Release Flow Area

The presence of the COPS serves to substantially reduce the uncertainties associated with the flow area for release of fission products from the containment. In the unlikely event that fission products are released from the containment, the release will almost always be via the COPS. Since this is an engineered feature of the plant, the uncertainties associated with the available flow area are very small. The COPS is designed to allow steam flow equivalent to ~~2.4%~~ 2.3% rated power. Since the decay heat level will be less than 1% at the time COPS operation is required, it is judged that the containment response is not sensitive to any small variation in the COPS effective flow area.

However, for the few cases discussed in Subsection 19E.2.6.9, the pressurization of the containment leads to failure of the drywell head. For these cases there is substantial uncertainty in the failure area. Therefore, two sensitivity cases were analyzed. In the first case the nominal failure area of 0.0129 m<sup>2</sup> (20 sq in) was increased by a factor of two. In the second case the failure area was divided by two. This broad range should bound any possible variations in the failure flow area.

of a severe accident which results in the release of fission products and to limit the effects of uncertainties in severe accident phenomena, ABWR is equipped with a Containment Overpressure Protection System (COPS). This system is intended to provide protection against the rare sequences in which structural integrity of the containment is challenged by overpressurization. It has been determined that these rare sequences comprise a small percentage of the hypothesized severe accident sequences.

The COPS is part of the atmospheric control system and consists of two ~~200A (8-inch)~~ 250A (10-inch) diameter overpressure relief rupture disks mounted in series on a ~~250A (10-inch)~~ 350A (14-inch) line which connects the wetwell airspace to the stack. The second rupture disk, located at the inlet to the plant stack, has a very low setpoint, less than 0.03 MPa differential pressure. The setpoint of the inner rupture disk, located near the containment boundary, will be selected such that the COPS opens when the wetwell pressure is 0.72 MPa. The COPS provides a fission product release point at a time prior to containment structural failure. Thus, the containment structure will not fail. By engineering the release point in the wetwell airspace, the escaping fission products are forced through the suppression pool. In a core damage event initiated by a transient in which the vessel does not fail, fission products are directed to the suppression pool via the SRVs, scrubbing any potential release. In a severe accident with core damage and vessel failure or in a LOCA which leads to core damage, the fission products will be directed from the vessel and drywell through the drywell connecting vents and into the suppression pool again ensuring any release is scrubbed. Eventually, if the containment pressure cannot be controlled, the rupture disk opens. Any fission product release to the environment is greatly reduced by the scrubbing provided by the suppression pool.

In the absence of the COPS, unmitigated overpressurization of the containment will result in failure of the drywell head for most severe accident scenarios (Some high-pressure core melt sequences result in fission product leakage through the moveable penetrations in the drywell rather than drywell head failure.). To compare the consequences of severe accidents resulting in fission product releases via drywell head failure to those with releases through the COPS, MAAP-ABWR was used to simulate a series of severe accident sequences for both release mechanisms. These severe accident sequences are described in Subsection 19E.2.2. Failure pressure of the drywell head was assumed to be equal to its median ultimate strength, 1.025 MPaG. The results of these runs show releases of volatile fission products, after 72 hours, for the COPS cases to be several orders of magnitude less than for the corresponding drywell head failure cases. The CsI release fractions are compared in Table 19E.2-25. Most accident sequences show this large difference in releases between drywell head failure and COPS cases.

#### 19E.2.8.1.1 Pressure Setpoint Determination

Several factors were considered in determining the optimum pressure setpoint for the rupture disk. The results of the previous analysis show that it is desirable to avoid drywell head failure. This can be assured by providing a rupture disk pressure setpoint below the pressure that would begin to challenge the structural integrity of the containment. However, as the pressure setpoint

of the ABWR rupture disk, a sensitivity study was performed in which the pressure setpoint of the rupture disk was varied.

The nominal pressure setpoint of the rupture disk is 0.72 MPa at 366 K (200°F). Two cases were examined using MAAP-ABWR in this sensitivity study. For both cases the LCLP-PF-R sequence was used as the base case. First, the rupture disk pressure setpoint was reduced to 0.708 MPa which corresponds to a rupture disk temperature of 422 K (300°F); and, second, the pressure setpoint was increased to 0.735 MPa which corresponds to a temperature of 311 K (100°F). This temperature range, from 311 to 422 K (100 to 300°F), bounds all anticipated rupture disk temperatures.

The elapsed time to rupture disk opening was within 0.8 hours of the base case value of 20.2 hours for both cases tested. Higher rupture disk temperatures (i.e. lower pressure setpoints) reduce the time to rupture disk opening and lower rupture disk temperatures (i.e. higher pressure setpoints) increase the time to rupture disk opening. There were no significant changes in fission product release. For both cases the CsI release fraction at 72 hours remained less than 1E-7.

Another parameter affected by the variation in the rupture disk temperature is the probability of drywell head failure prior to rupture disk opening in a severe accident. Using the rupture disk and drywell head failure distributions, it was determined that the probability of drywell head failure prior to rupture disk opening increased slightly for the case with the rupture disk temperature of 311 K (100°F). With a rupture disk temperature of 422 K (300°F), the probability decreased slightly. The rupture disk temperature variation has a similar effect on the severe accident sequences in which the firewater spray system is activated. The probability of drywell head failure prior to rupture disk opening increases slightly for the case with the rupture disk temperature of 311 K (100°F) and decreases slightly for the case with the rupture disk temperature of 422 K (300°F).

The results of this sensitivity study show that variations in rupture disk temperature, which cause small variations in rupture disk opening pressure, have a minor effect on the performance of the ABWR Containment Overpressure Protection System.

### 19E.2.8.1.3 Sizing of Rupture Disk

The size of the rupture disk has also been optimized. If the rupture disk is too small, it could be incapable of venting enough steam to prevent further containment pressurization. On the other hand, if the rupture disk is too large, level swell in the suppression pool could introduce water into the COPS piping. If this were to occur, the piping could be damaged or there could be carryover of waterborne fission products from the containment.

A ~~200~~250A (8~~10~~-inch) rupture disk was selected. This is sufficient to allow ~~35~~33.7 kg/s of steam flow at the opening pressure of 0.72 MPaA and corresponds to a energy flow of about ~~2.4~~2.3% rated power. The minimum acceptable flow rate is 28 kg/s of steam flow at the same





Figure 19E.2-25 Limiting Configuration for COPS Blowdown Study



NOTES:

1. QUALITY CONTROL GROUP AND QUALITY GROUP CLASSIFICATION ARE PROVIDED IN FOLLOWING TABLE:

ITEM	CLASSIFICATION	QUALITY	DESIGN
AC SYS EXCEPT FOR FOLLOWING ITEMS	F	7	4
PCV BOUNDARY	B	7	3
HYAC SYS	7	7	3
UPSTREAM OF VALVE	SAME AS PROCESS LINE	G	7
DOWNSTREAM OF VALVE	SAME AS PROCESS LINE	G	7
DRAIN	SAME AS PROCESS LINE	G	7
INSTRUMENT PIPING	SAME AS PROCESS LINE	G	7
TEST TAP FROM VALVE TO CAPI	G	6	7

2. THE FLANGE TO THE WAK SHALL BE LOCATED AWAY FROM NORMALLY OCCUPIED AREAS. THE EXHAUST SHALL HAVE A SHROUD THAT PREVENTS ENTRY OF RAIN.
3. HMT OVERRIDE THE PCV ISolation SIGNAL MANUALLY BY SWITCHES.
4. THIS VALVE IS MANUALLY OPENED AFTER EACH PURGE.
5. PURGE TEMPERATURES SHALL BE MONITORED AS THE LEAK RATE TEST.
6. LEAK RATE TEST SHALL BE ANNULAR-TYPE.
7. DESIGN CONDITIONS OF PIPING ARE AS FOLLOWS UNLESS OTHERWISE SPECIFIED:
- A. CARBON STEEL
  - B. SCHEDULE 40 AND OVER - SCH 40
  - C. 50A AND LESS - SCH 80
  - D. SCHEDULE 40 AND OVER - SCH 40
  - E. PCV BOUNDARY AND EXHAUST LINE - SCH 40
  - F. INSTRUMENTATION - SCH 40
  - G. INSTRUMENTATION - SCH 40
  - H. INSTRUMENTATION - SCH 40
  - I. INSTRUMENTATION - SCH 40
  - J. INSTRUMENTATION - SCH 40
  - K. INSTRUMENTATION - SCH 40
  - L. INSTRUMENTATION - SCH 40
  - M. INSTRUMENTATION - SCH 40
  - N. INSTRUMENTATION - SCH 40
  - O. INSTRUMENTATION - SCH 40
  - P. INSTRUMENTATION - SCH 40
  - Q. INSTRUMENTATION - SCH 40
  - R. INSTRUMENTATION - SCH 40
  - S. INSTRUMENTATION - SCH 40
  - T. INSTRUMENTATION - SCH 40
  - U. INSTRUMENTATION - SCH 40
  - V. INSTRUMENTATION - SCH 40
  - W. INSTRUMENTATION - SCH 40
  - X. INSTRUMENTATION - SCH 40
  - Y. INSTRUMENTATION - SCH 40
  - Z. INSTRUMENTATION - SCH 40

8. DESIGN CONDITIONS OF TEST, DRAIN AND INSTRUMENT PIPING ARE AS FOLLOWS:

ITEM	MAX OPERATING PRESSURE	MAX OPERATING TEMPERATURE	MATERIAL
TAP	SAME AS PROCESS LINE	68°C	CS
UPSTREAM OF VALVE	SAME AS PROCESS LINE	68°C	CS
DOWNSTREAM OF VALVE	SAME AS PROCESS LINE	68°C	CS
DRAIN	AMBIENT PRESSURE	68°C	CS
INSTRUMENT PIPING	SAME AS PROCESS LINE	171°C	SS
CONNECTED TO DRYWELL	0.310 MPa G	171°C	SS
TO SUPPRESSION POOL	0.310 MPa G	171°C	SS
TEST	0.310 MPa G	171°C	CS
TAP	0.310 MPa G	68°C	CS

9. SUPPRESSION POOL WATER TEMPERATURE MONITORING IS PROVIDED.
10. THESE VALVES ARE NOT PROVIDED WITH AN ISOLATION SIGNAL CONTROL. SWITCHES SHOULD BE LOCKED OPEN.
11. MEANS SHALL BE PROVIDED FOR MAINTAINING WATER TEMPERATURE MONITORING. THE REFERENCE POINT IS LOCATED AS CLOSE AS PRACTICAL TO THE CONTAINER AND OPEN TO THE WATER.

- REFERENCE DOCUMENTS:
1. PIPING AND INSTRUMENT SYMBOLS DIAGRAM AFD-3030
  2. HYAC SYSTEM PAD U41-1009
  3. STANDBY GAS TREATMENT SYSTEM PAD T22-1009
  4. HIGH PRESS. NITROGEN GAS SUPPLY SYS P&ID P54-1009
  5. NUCLEAR BOLLER SYSTEM PAD B81-1009
  6. SUPPLY POOL WATER TEMP MONITORING SYS IED T52-1009
  7. DRYWELL COOLING SYSTEM T14-1009
  8. REMOTE SHUTDOWN SYSTEM IED C01-1009
  9. HIGH PRESSURE CORE FLOUNDER SYS PAD E22-1009
  10. SUPPRESSION POOL CLEANUP SYS PAD P05-1009
  11. SUPPRESSION POOL CLEANUP SYSTEM PAD P05-1009
  12. HOUSE BOLLER SYS PAD P02-1009

FIGURE 6.2-39 ATMOSPHERIC CONTROL SYSTEM P&ID (Sheet 1 of 31)  
 ABWR DCD/Tier 2 Rev. 5 25A5675BC  
 21-220